

**Combined Instrument Transformer**

Insulation level	145/215/650 KV	Standard	IEC 61869-4	Type	PVA 145a
Oil type	Nytro Libra	Weight/Oil weight	540 / 150 kg	Temp. range	-50°C → +40°C
S/N	2GKPO13K1486145	Voltage factor	1,9Um/8h	Ue	0,2 mV/kA

**CURRENT PART**

$K_n$	150-300 / 5-1-5-1	A/A	A-N	132-13	KV
$I_{br}/I_S$	20-20	KA	$I_{dyn}$	50-50	KA
$I_{ctn}$	180-360	A			


1S1-1S2 2S1-2S2 3S1-3S2 4S1-4S2 5S1-5S2 6S1-6S2

A	5	1	5	1						
VA	30	40	60	80						
KL	0,2	5P	5P	5P						
F5/ALF	5	20	20	20						
Ext. %	120									

Transportation: Vertical / Horizontal

**VOLTAGE PART**

1a-1a	2a-2a	3a-3a	4a-4a	dk-dk
110-13	110-13	110-13	110-13	110-3
V	100	100	100	200
VA	1,0	1,0	1/3P	3/3P
KL	1,0	1,0	1000	1000
VA <sub>nom</sub>	1000	1000	1000	1000
Ext. %	450			



301

A. Remond

J. B. J.

C

C



INSTITUTE OF POWER ENGINEERING  
Certification Department

INSTITUTE OF POWER ENGINEERING  
Certification Department  
No DZC/36c/E/2013/2014  
Author: mgr inż. Grażyna Wieczorek

Report

2 / 12

**Contents:**

1. Introduction	3
2. List of applied documents	4
3. Testing laboratory competences	5
4. Test result list	5
4.1. Type tests	5
4.2. Routine tests	6
5. Summary	9

**APPENDIX – Type test reports and special test reports (pages not numbered)**

**PRODUCT EVALUATION REPORT**

No DZC/36c/E/2013/2014

Product name and symbol: HV combined instrument transformer, single-phase, outdoor, type: PVA 123a and PVA 145a

Supplier: ABB Sp. z o.o., Oddział w Przasnyszu, ul. Leszno 59, 06-300 Przasnysz

Non-conformities observed:

None found

General evaluation result:

**Positive**  
Based on the analysis made, herewith I conclude for granting of compliance certificates to the HV combined instrument transformers, types: PVA 123a and PVA 145a, with composite or ceramic insulator, manufactured by ABB Sp. z o.o., Oddział w Przasnyszu

Warsaw, February 2014

Grażyna Wieczorek

Full name

signature

5 February 2014

date

## 1. Introduction

Report from evaluation of HV overhead, single-phase, current transformer series, types: PVA 123a and PVA 145a, manufactured by ABB Sp. z o.o., Oddział w Przasnyszu, developed during the certification process carried out by Zespół ds. Certyfikacji (Certification Team) upon manufacturer's application (contract No DZC/36c/E/2013 of the 23 October 2013). This document concerns the new series of combined instrument transformers featuring design modifications and marked: PVA ...a.

The PVA 123a and PVA 145a combined instrument transformers are used for feeding measurement and protection systems in electric power grids with the highest system voltage of 126 kV or 145 kV and frequency of 50 Hz. Combined transformers consist of a current element and a voltage element located inside a common enclosure with a composite insulator (cover configuration: straight and spiral) or with a ceramic insulator filled with transformer oil.

The PVA transformer tests were carried out on selected representatives at the laboratories of Instytut Energetyki (Institute of Power Engineering) in Warszawa and Instytut Elektrotechniki Oddział w Gdańsku (Electrotechnical Institute, Gdańsk Branch) as well as (for product tests and deviation measurements) at the manufacturer's laboratory. The selection procedure included the most severe conditions resulting from the combined transformer design and occurring during the temperature-rise tests, short-circuit withstand, voltage and mechanical tests such as: values of continuous and short-circuit currents, winding wire size, different main circuits, winding power for measurement and protection, housing types, accuracy classes, etc. Tests were carried out on seven selected combined transformer prototypes. The results are valid for the entire transformer series acc. to the list as suggested for certification. Test results confirming the combined transformers features are listed in the reports in cl. 2 of this document. The test results were compared against requirements in the following standards:

- PN-EN 61869-1:2009  
Instrument transformers – Part 1: General requirements
- PN-EN 61869-2:2013-06  
Instrument transformers – Part 2: Detailed requirements for current transformers
- PN-EN 61869-3:2011  
Instrument transformers – Part 3: Detailed requirements for voltage transformers
- IEC 61869-4 Ed. 1.0  
Instrument transformers – Part 4: Additional requirements for combined transformers
- PN-EN 60529:2005  
Protection class provided by the housing (IP)

- PN-EN 62262:2003

Degrees of protection against external mechanical impacts as provided by electric device enclosures (IK coding)

Customer/manufacturer: ABB Sp. z o.o., Przasnysz holds the complex certificate for the following standards: ISO 9001:2008, ISO 14001:2004 and PN-N-18001:2004 – certificate No 0198 150 01525 issued by TÜV Rheinland Polska Sp. z o.o.

## 2. List of applied documents

The combined transformers design and the test results were evaluated and analysed based on the following documents delivered by the Manufacturer and included in the reports:

- D1. Report No EWP/10/E/2014-1e, Temperature-rise test High Current Laboratory, Warsaw, January 2014.
- D2. Report No EWP/10/E/2014-2e, IEn, Temperature-rise test High Current Laboratory, Warsaw, February 2014.
- D3. Report No EWP/35/E/2013-1e, IEn, Temperature-rise tests, High Current Laboratory, Warsaw, February 2014.
- D4. Report EUR/66/E/13-2 E), Mechanical tests Distribution Equipment Laboratory, Warsaw, December 2013.
- D5. Report No EUR/66/E/13-1 E (Mechanical tests), IEn, Distribution Equipment Laboratory, Warsaw, December 2013.
- D6. Report No EUR/71/E/13-3 E (Short-time current test, combined error measurement, test of strength against short-circuit in the secondary circuit), IEn, Distribution Equipment Laboratory, Warsaw, January 2014.
- D7. Report No EUR/74/E/13 E Short-time current test, Test for composite error), IEn Distribution Equipment Laboratory, Warsaw, December 2013.
- D8. Report No EUR/71/E/13-1 E Short-time current test, IEn Distribution Equipment Laboratory, Warsaw, January 2014.
- D9. Report No EUR/71/E/13-4 E Short-time current test, Test for composite error), IEn, Distribution Equipment Laboratory), Warsaw, January 2014.
- D10. Test report No EWN/145/E/13, Type tests, special tests and additional tests of combined transformers type PVA123a and PVA145a manufactured by ABB sp. z o.o.), IEn, High Voltage Laboratory, Warsaw, January 2014.
- D11. Report No 8281/NZL/NBR/12, IP tests for terminal box IEl, Distribution Equipment Test Laboratory, Warsaw, July 2012.
- D12. Report No EWP/35/E/2013-3c Mechanical impact test, IEn High Current Laboratory), Warsaw, February 2014
- D13. Dimensional drawings:
  - Dimensional drawing: Combined instrument transformer PVA 123a-145a 2GKK614122/ABB R&D\_TS\_KU568/13 (17.12.2013).
  - Dimensional drawing: Combined instrument transformer PVA 123a-145a 2GKK614123/ABB R&D\_TS\_KU570/13 (17.12.2013).

- Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614121/ABB  
R&D\_TS\_KU570/13 (17.12.2013).
- Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614123/ABB  
R&D\_TS\_KU571/13 (17.12.2013).
- Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614123/ABB  
R&D\_TS\_KU572/13 (17.12.2013).
- Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614120/ABB  
R&D\_TS\_KU569/13/A (17.12.2013).
- Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614121/ABB  
R&D\_TS\_KU569/13 (17.12.2013).

D13. Product test reports and accuracy check reports – see reports from D1+10 tests

D14. Rating plates – see reports from D1+10 tests

D15. Electrical diagrams – see reports from D1+10 tests

### 3. Testing laboratory competences

Type tests, product tests and special tests for PVA...a combined transformers were carried out at the following laboratories:

- Laboratorium Wysokich Napięć (High Voltage Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA No AB 272.
- Laboratorium Urządzeń Rozdzielczych (Distribution Equipment Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA No AB 324.
- Laboratorium Wielkopądowe (High Current Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA Nr AB 323.
- Laboratorium Fabryczne ABB Sp. z o.o. (ABB Manufacturing Plant Laboratory) in Przasnysz – Punkt Legalityzacyjny OUM Warszawa (OUM Warsaw Verification Unit) – deviation measurement, and product tests under supervision of Instytut Energetyki (Institute of Power Engineering), Laboratorium Wysokich Napięć (High Voltage Laboratory).
- Laboratorium Badawcze Aparatury Rozdzielczej (Distribution Equipment Test Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA No AB 074.

### 4. Test result list

#### 4.1. Type tests, additional tests

The tests were made on selected PVA ...a combined transformer models (various rated currents for the PVA...a current elements, various main circuit designs, various design of PVA...a transformers secondary circuits, different accuracy classes and various insulation covers, etc.) The test results are valid for the entire combined transformer series acc. to the list as suggested for

certification. Table 1 shows manufacturer's solutions for the PVA...a current circuits. Representatives for short-circuit tests and heating tests were selected from that list. PVA...a combined transformers were selected to temperature-rise test based on the most heat-exposed design solutions.

Voltage tests were made for two combined transformers: PVA 123a. and 145a.

The short-circuit withstand tests were made for PVA...a combined transformers. Representatives were selected based on their exposition to dynamic and thermal effects to the main circuits.

Table 2 shows carried out tests. Their scope meets requirements included in respective standards for: type tests, special tests, routine tests, and some additional requirements. Respective item numbers in PN-EN 61869 and IEC 61869 as well as report numbers with detailed test results are listed.

**Results of all tests were positive.**

#### 4.2. Routine tests

Routine tests and accuracy class tests were carried out at the manufacturer's laboratory for all the combined transformers tested under the IEn supervision.

The tests included:

- oil measurements before filling the instrument transformer.
- verification of markings.
- power-frequency voltage withstand tests on primary terminals.
- power-frequency voltage withstand tests on secondary terminals.
- non-complete discharge intensity.
- inter-winding insulation test.
- test for accuracy.
- over-current coefficient determination.
- magnetisation characteristics determination.
- measurement of capacitance and dielectric dissipation factor.
- winding resistance measurement.

Test results were listed in protocols, their numbers being the same as that of the combined transformer tested. After the voltage tests and short circuit tests, additional routine tests and accuracy class tests were carried out.

**Test result: positive**




Table 1. Main circuit list:

Circuit design description	Current circuit assembly drawing number	Drawing title:	10kA/dyn level assumed	Remarks	Tests carried out with 10kA/dyn current
Red Ø40 AI	2GKN31413A/0001	Main circuit, end Ø40 AI	60/50 kA	Prototype 2	P2 positive test
Red Ø40 AI	2GKN31413A/0001	Main circuit, end Ø40 AI	60/50 kA	Prototype 2	P2 positive test
Red Ø40 AI + pipe Ø40x3 AI	2GKN31413A/0001	Main circuit, end Ø40 AI + pipe Ø40x3 AI	65.4/150-150 kA	Prototype 8	P8 positive test
Red Ø40 AI + pipe Ø40x3 AI + 2 turns of 250 mm <sup>2</sup> cable	2GKN31413A/0001	Main circuit, end Ø40 AI + pipe Ø40x3 AI + 2 turns of 250 mm <sup>2</sup> cable	65.4/150-150-150-100 kA	Prototype 1	P1 positive test
1 turn of 250 mm <sup>2</sup> cable	2GKN31413A/0001	Main circuit, 1 turn of 250 mm <sup>2</sup> cable	40/100 kA	Prototype 3	P1 positive test
2 turns of 250 mm <sup>2</sup> cable	2GKN31413A/0002	Main circuit, 2 turns of 250 mm <sup>2</sup> cable	40/100 kA	Prototype 3	P1 positive test
3 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0001	Main circuit, 3 turns of 120 mm <sup>2</sup> cable	20/50 kA	Prototype 7	P7 positive test
6 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0002	Main circuit, 6 turns of 120 mm <sup>2</sup> cable	20/50 kA	Prototype 7	P7 positive test
9 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0003	Main circuit, 9 turns of 120 mm <sup>2</sup> cable	20/50 kA	Prototype 7	P7 positive test
12 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0004	Main circuit, 12 turns of 120 mm <sup>2</sup> cable	20/50 kA	Prototype 7	P7 positive test
3 + 3 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0001	Main circuit, 3 + 3 turns of 120 mm <sup>2</sup> cable	20/50 / 40-50 kA	Prototype 7	P7 positive test
6 + 6 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0002	Main circuit, 6 + 6 turns of 120 mm <sup>2</sup> cable	20/50 / 50-50 kA	Prototype 7	P7 positive test
3 + 3 + 6 turns of 120 mm <sup>2</sup> cable	2GKN31413A/0001	Main circuit, 3 + 3 + 6 turns of 120 mm <sup>2</sup> cable	20-20-20/50-50-50 kA	Prototype 7	P7 positive test

Table 2. List of tests made for PVA...a combined instrument transformer

Item	Test type	Requirements	Report numbers
<b>TYPE TESTS</b>			
1	Short-time current test	IEC 61869-4, cl. 7.2.201 PN EN 61869-2, cl. 7.2.201	EUR/11/E/13-1 EUR/11/E/13-3 EUR/11/E/13-4 EUR/74/E/13
2	Temperature-rise test	IEC 61869-4, cl. 7.2.2 PN EN 61869-2, cl. 7.2.2 PN EN 61869-2, cl. 7.2.2.204	EWP/10/E/2014-1 EWP/10/E/2014-2 EWP/55/E/2013-1 EWP/07/E/2012-4
3	Impulse voltage withstand test	IEC 61869-4, cl. 7.2.3 PN-EN 61869-1, cl. 7.2.3 PN EN 61869-3, item 7.2.3	EWN/145/E/13
4	Wet test	IEC 61869-4, cl. 7.2.4 PN-EN 61869-1, cl. 7.2.4 PN-EN 61869-3, cl. 7.2.4	EWN/145/E/13
5	Short-circuit withstand capability test	IEC 61869-4, cl. 7.2.301 PN EN 61869-3, item 7.2.301	EUR/33/E/11-2
6	Tests for accuracy and mutual influence test	IEC 61869-4, cl. 7.2.6.401, 7.2.6.402 and 7.3.5 PN EN 61869-2, cl. 7.2.6 PN EN 61869-3, cl. 7.2.6	EWN/145/E/13 and protocols from manufacturer's laboratory
7	RIV test	PN EN 61869-1, cl. 7.2.5.1	EWN/145/E/13
8	Test for composite error	PN EN 61869-2, cl. 7.2.6.203	EUR/71/E/13-3
9	Terminal box verification of the IP coding	PN EN 61869-1, cl. 7.2.7.1 PN-EN 60529, cl. 13.14	EUR/71/E/13-4 828/NZL/NBR/12
10	Mechanical impact test (IK)	PN EN 61869-1, cl. 7.2.7.1 PN-EN 62272	EWP/35/E/2013-3
<b>SPECIAL TESTS</b>			
11	Chopped impulse voltage withstand test on primary terminals.	IEC 61869-4, cl. 7.4.1 PN-EN 61869-1, cl. 7.4.1 PN EN 61869-3, cl. 7.4.1	EWN/145/E/13
12	Mechanical tests	IEC 61869-4, cl. 7.4.5 PN-EN 61869-1, cl. 7.4.5	EUR/66/E/13-1 EUR/66/E/13-2
13	Transmitted overvoltage test	IEC 61869-4, cl. 7.4.4 PN-EN 61869-1, cl. 7.4.4 PN EN 61869-3, cl. 7.4.4	EWN/145/E/13
14	Measurement of capacitance and dielectric dissipation factor	IEC 61869-4, cl. 7.4.3 PN-EN 61869-1, cl. 7.4.3 PN EN 61869-2, cl. 7.4.3 PN EN 61869-3, cl. 7.4.3	and protocols from manufacturer's laboratory
<b>ADDITIONAL TESTS</b>			
15	Capacitor discharge test	C = 6µF. U = 1.1 * √2 * 110V √3 kV No damage, no temperature increase above 65 K.	EWN/145/E/13

**5. SUMMARY**

- Based on the test results for selected representatives of PVA 123a and PVA 145a instrument transformer series as selected and based on analysis of the standards, it was determined that:
  - All tests from the type test range, special tests and additional tests which were carried out were sufficient for a complete evaluation of the apparatuses.
  - Instrument transformer errors tests and instrument transformer secondary circuit designs were analysed, and their metrological properties were confirmed.
- PVA 123a and PVA 145a instrument transformer main circuit designs were analysed. It was determined that the short-circuit tests and heating tests as carried out are binding for all design solutions.
- Tests were made according to requirements of the 61869 series standard (FN and IEC)
- Taken the test results under consideration, the technical data listed in Tables 3 and 4 may be referenced to the PVA 123a and PVA 145a instrument transformer series.
- This document may be a basis for issuing compliance certificates for PVA 123a and PVA 145a instrument transformer series manufactured by ABB Sp. z o.o. Oddział w Przasnyszu. The certificate validity date is suggested to be February 2017.

**Table 3. List of technical data assigned to PVA 123a**

Combined transformer type PVA 123a	
Rated primary voltage [U <sub>pr</sub> ]	110/√3 kV
Highest voltage of combined transformer [U <sub>max</sub> ]	≤ 126 kV
Rated frequency [f <sub>n</sub> ]	50 Hz
Rated insulation level	AC 230 kV / LI 550 kV
Burden class	Fr = 3,600 N
External insulation – creepage distance of insulator	3,640–4,495 mm <sup>1)</sup>
Degree of protection of secondary terminal enclosure	IP55
Degree of protection to mechanical impact of enclosure <sup>2)</sup>	IK7
Current element	
Rated primary current [I <sub>pr</sub> ]	50 A + 3,000 A
Extended current rating	up to 200%
Rated continuous thermal current [I <sub>th</sub> ]	≤ 3,000 A
Rated short-time thermal current [I <sub>sh</sub> ] during 1 sec	20 kA or 40 kA or 63 kA
Rated short-time thermal current [I <sub>sh</sub> ] during 3 sec	20 kA or 40kA
Rated dynamic current [I <sub>dyn</sub> ]	50 kA or 100 kA or 158 kA
Rated secondary current [I <sub>sd</sub> ]	1 A or 5 A
Core power to measurements and to protection (S <sub>c</sub> )	1VA – 200 VA
Measure core accuracy class (cl.)	0.1; 0.2; 0.2S; 0.5; 0.5S; 1; 3; 5
Protective core accuracy class (cl.)	5P; 10P; 5PR; 10PR; PX; PXR; TPX; TPY; TPZ
Voltage element	
Rated voltage factor [F <sub>v</sub> ]/time	1.5/30 sec; 1.9/30 sec or 1.9/8 h
Rated secondary voltage [U <sub>sd</sub> ]	100/√3 V; 110/√3 V;
Windings class to measurements and to protection (cl.)	0.1; 0.2; 0.5; 1; 3; 3P; 6P
Windings power to measurements and to protection (S <sub>w</sub> )	≤ 1,000 VA
Rated voltage of residual voltage winding [U <sub>r,ub-dn</sub> ]	100/3 V; 110/3 V; 100 V; 110 V
Residual voltage winding class (cl.)	0.5; 1; 3; 3P; 6P
Residual voltage winding power (S <sub>r</sub> )	≤ 450 VA
Total thermal limiting output [S <sub>Σ,th</sub> ]	4,000 VA

**REMARKS:**

- <sup>1)</sup> Applies to composite and ceramic insulators.
- <sup>2)</sup> Do not apply to ceramic insulators.

Table 3. List of technical data assigned to PVA 145a

Combined transformer type PVA 145a	
Rated primary voltage [U <sub>1n</sub> ]	132/43 kV
Highest voltage of combined transformer [U <sub>m</sub> ]	≤ 145 kV
Rated frequency [f <sub>r</sub> ]	50 Hz
Rated insulation level	AC 275 kV / LI 650 kV
Burden class	F <sub>p</sub> = 3,600 N
External insulation - creepage distance of insulator	3,640 - 4,495 mm <sup>1)</sup>
Degree of protection of secondary terminal enclosure	IP55
Degree of protection to mechanical impact of enclosure <sup>2)</sup>	IK7
<b>Current element</b>	
Rated primary current [I <sub>1n</sub> ]	50 A ± 3,000 A
Extended current rating	up to 200%
Rated continuous thermal current [I <sub>th</sub> ]	≤ 3,000 A
Rated short-time thermal current [I <sub>th</sub> ] during 1 sec	20 kA or 40 kA or 63 kA
Rated short-time thermal current [I <sub>th</sub> ] during 3 sec	20 kA or 40 kA
Rated dynamic current [I <sub>dyn</sub> ]	50 kA or 100 kA or 158 kA
Rated secondary current [I <sub>2n</sub> ]	1 A or 5 A
Core power to measurements and to protection (S <sub>c</sub> )	1 VA - 200 VA
Measure core accuracy class (cl.)	0.1; 0.2; 0.2S; 0.5; 0.5S; 1; 3; 5
Protective core accuracy class (cl.)	5P; 10P; 5PR; 10PR; PX; PXR; TPX; TPY; TPZ
<b>Voltage element</b>	
Rated voltage factor [F <sub>v</sub> ] / time	1.5/30 sec; 1.9/30 sec or 1.9/8 h
Rated secondary voltage [U <sub>2</sub> ]	100/43 V; 110/43 V;
Windings class to measurements and to protection (cl.)	0.1; 0.2; 0.5; 1; 3; 3P; 6P
Windings power to measurements and to protection (S <sub>w</sub> )	≤ 1,000 VA
Rated voltage of residual voltage winding [U <sub>residual</sub> ]	100/3 V; 110/3 V; 100 V; 110 V
Residual voltage winding class (cl.)	0.5; 1; 3; 3P; 6P
Residual voltage winding power (S <sub>r</sub> )	≤ 450 VA
Total thermal limiting output [S <sub>th</sub> ]	4,000 VA

**REMARKS:**

<sup>1)</sup> Applies to composite and ceramic insulators.

<sup>2)</sup> Do not apply to ceramic insulators.

**APPENDIX**

**Type test reports, special test reports (pages not numbered)**

- D1. Report No EWP/10/E/2014-1e. Temperature-rise test High Current Laboratory. Warsaw. January 2014.
- D2. Report No EWP/10/E/2014-2e. IEn. Temperature-rise test High Current Laboratory. Warsaw. February 2014.
- D3. Report No EWP/35/E/2013-1e. IEn. Temperature-rise tests. High Current Laboratory. Warsaw. February 2014.
- D4. Report EUR/66/E/13-2 E). Mechanical tests Distribution Equipment Laboratory Warsaw. December 2013.
- D5. Report No EUR/66/E/13-1 E (Mechanical tests). IEn. Distribution Equipment Laboratory Warsaw. December 2013.
- D6. Report No EUR/71/E/13-3 E (Short-time current test. combined error measurement. test of strength against short-circuit in the secondary circuit). IEn. Distribution Equipment Laboratory Warsaw. January 2014.
- D7. Report No EUR/74/E/13 E Short-time current test. Test for composite error). IEn Distribution Equipment Laboratory Warsaw December 2013.
- D8. Report No EUR/71/E/13-1 E Short-time current test. IEn Distribution Equipment Laboratory Warsaw. January 2014.
- D9. Report No EUR/71/E/13-4 E Short-time current test. Test for composite error). IEn. Distribution Equipment Laboratory). Warsaw. January 2014.
- D10. Test report No EWN/145/E/13. Type tests, special tests and additional tests of combined transformers type PVA123a and PVA145a manufactured by ABB sp. z o.o.). IEn. High Voltage Laboratory Warsaw. January 2014.
- D11. Report No 8281/NZL/NBR/12. IP tests for terminal box. IEn. Distribution Equipment Test Laboratory Warsaw. July 2012.
- D12. Report No EWP/35/E/2013-3e Mechanical impact test. IEn High Current Laboratory). Warsaw. February 2014



**TEST REPORT No. EUR/04/E/14 E**

**TEST OBJECT:** Combined instrument transformer type PVA 145a with composite insulator  
Serial No. 2GKP013K1486145

**MANUFACTURER:** ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

**TESTS ORDERED BY:** ABB Sp. z o.o., ul. Żegńska 1, 04-713 Warszawa  
order No. 4500531639 dated 20.01.2014

**TYPE OF TESTS:** Short-circuit withstand capability test

**TESTS PROCEDURE:** According to IEC 61869-3:2011

**DATE OF TESTS:** 21/22.01.2014

**TESTS RESULT:** Positive for  
76.2 kV at short-circuit in secondary circuits of VT

Tests result refers only to the test object

**THE TESTS WERE WITNESSED BY:**

Test engineer  
*Tomasz Kaczmarezyk*

Tomasz Kaczmarezyk

**HEAD OF LABORATORY**

*Lidia Gruza*

Lidia Gruza

Warsaw, 03.02.2014

*[Signature]*

Publishing or reproducing of this report in other version than exact and complete without permission in writing from the laboratory is forbidden.

*[Signature]*

*[Signature]*

**Contents**

1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	4
4. Tests and theirs detailed results	5
5. Test results evaluation	5
Annexes: 1. Short-circuit test records	6
2. Photographs taken during the tests	7
3. Routine test report before and after tests	8
4. Documentations delivered by orderer	20

**Report contents:**

numbered pages	22
records (pages not numbered)	3
tables	1
figures	1
photographs	1

**1. TEST OBJECT**

**1.1 Description**

Combined instrument transformer type PVA 145a is used for supplying of measuring and protection circuits in the network of maximum operating voltage 145 kV and frequency 50 Hz. The transformer consists of current and voltage transformers mounted in common housing with composite insulator immersed with transformer oil.

**1.2 Technical data**

The Manufacturer attributed the following construction data to the test object.

Maximum operating voltage	145 kV
Rated frequency	50 Hz
Terminal	150 A      300 A
Rated continuous thermal current	180 A      360 A
Rated short-time current for 1 s	20 kA
Rated dynamic current	50 kA

**1.3 Technical documentation**

For the purpose of tests the orderer delivered the following technical documentation:

- dimensional drawing combined transformer PVA 123a-145a, No. 2GKK614123 (17.12.2013),
  - routine tests report of combined instrument transformer (04.12.2013),
  - routine tests report of combined instrument transformer after short-time current test (27.01.2013),
  - rating plate,
  - instrument transformer electrical diagram prepared by ABB Sp. z o.o (Annex 3 and 4).
- The laboratory proceeded the identification of test object on the base of above documentation and the rating plate. Conformity of manufacturing with constructional documentation is stated in manufacturer's declaration, copy of which presents Annex 4.

**1.4 Preparation for tests**

The test object was prepared for tests in the factory by the manufacturer.

**2. SCOPE OF TESTS**

Test program, agreed with orderer, comprised the following tests according to requirements of IEC 61869-3:2011:


- short-circuit withstand capability test acc. to item 7.2.301 of above standard at parameters:  
 $U_p \geq 76,2 \text{ kV}$ ,  $t_p = 1 \text{ s}$ .
- routine test before and after short-time current test made in factory.



**3. TEST AND MEASURING CIRCUITS**

For the tests the transformer was fixed to the rigid construction of the test stand. Short-circuit withstand capability test were made in one phase circuit presented on fig. 1. The following quantities were recorded during short-circuit withstand capability tests using digital recorder type HIOKI 8842:

- primary voltage and current, secondary current in short-circuited windings: 1a-1n (next 4a-4n and 4a-dn) during short-circuit withstand capability tests of voltage transformer using:
- inductive voltage transformer type U110a class 0,5 with a ratio 110/√3/0,1/√3 kV/kV for primary voltage measurement,
- laboratory current transformer type GE 4461 class 0,2 with a ratio 5/5 A/A for primary current measurement (uncertainty of measurement ±0,013% for k = 2),
- laboratory current transformer type IL 20a class 0,5 with a ratio 2.000/5 A/A for secondary current measurements (uncertainty of measurement ±0,012% for k = 2).



WB110 - back-up circuit-breaker  
PN - voltage transformer  
PP1, PP2 - current transformers

Fig. 1. Test and measuring circuits during short-circuit withstand capability tests



ANNEX 1

Test records

**4. TESTS AND THEIRS DETAILED RESULTS**

Tests results presents tables 1.  
During the tests the following records were made:  
- Nos. 33225, 33226, 33227 – short-circuit withstand capability test,  
(Annex 1 presents the copies of short-circuit test records - all records  
are stored in laboratory's archives),  
- phot. 1 – current transformer on the tests stand  
(Annex 2 presents the photograph).

Table 1. Results of short-circuit withstand capability tests

Test No.	Terminals	U <sub>z</sub>	I <sub>ps</sub>	I <sub>ss</sub>	t <sub>z</sub>	Observations
		kV	A	A	s	
33225	1a - 1n	76,5 <sup>1)</sup>	0,62	1062	1,04	Behaviour of transformer during the tests was correct. After tests no damage nor oil leak was stated.
33226	4a - 4n	76,5 <sup>1)</sup>	0,61	1054	1,02	Behaviour of transformer during the tests was correct. After tests no damage nor oil leak was stated.
33227	da - dn	76,5 <sup>1)</sup>	0,34	1019	1,02	Behaviour of transformer during the tests was correct. After tests no damage nor oil leak was stated.

Legend:

- U<sub>z</sub> - test voltage
- I<sub>ps</sub> - r.m.s. value of primary side test current
- I<sub>ss</sub> - r.m.s. value of secondary side test current
- t<sub>z</sub> - test duration
- 1) - required U<sub>z</sub> ≥ 76,2 kV



As not numbered pages the following copies of records are given:  
33225, 33226, 33227 – short circuit withstand capability test.

Denotations:

- u<sub>z</sub> – test voltage during voltage transformer tests,
- i<sub>N</sub> – test current on primary side of VT,
- i<sub>1a-1n</sub>, i<sub>4a-4n</sub>, i<sub>da-dn</sub> – test current on secondary side of VT.


**5. TESTS RESULTS EVALUATION**

According to criteria given in IEC 61869-3:2011 the results of tests is positive for:  
- 76,2 kV at short-circuit in secondary circuits of voltage transformer.




512

ANNEX 2 Photographs taken during the tests



Phot. 1. PVA 123a after short circuit withstand capability test.





**ANNEX 3 Routine test report before and after tests**

ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Routine tests report of combined instrument transformer		TYPE: PVA145a	Serial no: 2GKP013K1486145
A-N	Insulation level: 132-8 kV / 145275/650 kV	1.0/8th	10/3m [kA]: 20-20	10th [kA]: 225-450	IEC 61898-4 50 Hz
<b>VOLTAGE PART</b>					
Winding		Um [kV]	Sn [VA]	class	Sh [VA]
1a-1n	0.11-3	100	1.0	1.0	1000
2a-2n	0.11-3	100	1.0	1.0	1000
3a-3n	0.11-3	100	100	100	1000
4a-4n	0.11-3	100	100	100	1000
4b-4n	0.11-3	200	300	3.0	450
<b>CURRENT PART</b>					
Winding		Im [A]	Sn [VA]	class	Ratio [A/A]
1S1-1S2	5	30	0.2FS 5	150-300/5	
2S1-2S2	1	40	0.2FS 5	150-300/1	
3S1-3S2	5	80	5P 20	150-300/5	
4S1-4S2	1	80	5P 20	150-300/1	

**List of performed tests:**

- Oil dielectric parameters check before filling (oil after treatment):
  - tg δ acc. IEC 60247, breakdown voltage acc. IEC 60156
  - Verification of terminal
  - Pressure and tightness tests: oil overpressure: 0.6 bar / 24h - no traces of oil on primary windings
  - Power-frequency withstand test: oil overpressure: 0.6 bar / 24h - no traces of oil on primary windings
  - Partial discharge
  - Power-frequency withstand test on secondary
  - Inter-turn overvoltage test for current transformers
  - Determination of the over current factors: FS
  - Determination of capacitance and dielectric dissipation factor - tg δ
  - Measurement of core magnetization characteristics
  - Determination of core magnetization characteristics
  - Measurement of winding resistance
- Oil dielectric parameters check before filling (oil after treatment)
  - Measurement of oil tg δ according to IEC
  - Tg δ = 0.06 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C
- Measurement of breakdown voltage according to IEC 60156
  - Mean breakdown voltage = 78.15 kV, Relative standard deviation = 5.99
  - f = 50Hz, oil temp. = 25 °C, measurement with the allstar, type of electrodes used: partially

Sample	Breakdown voltage [kV]
1	73.7
2	84.3
3	82.8
4	78.4
5	76.8
6	72.5



**Partial discharge measurement**

- Measurement according to procedure A (PD test voltages were reached while decreasing the after the power-frequency withstand test on primary  
Stress voltage: 275 kV / 50 s  
Frequency: 87 Hz

Test voltage	1.2 Um = 174 kV	1.2 Um / √3 = 100.5
Level of partial discharge	2 pC	1.2 pC

Remarks: background noise level: 1 (measured after voltage switch off), measuring circuit was calibrated with 5 pC (calibrating)

**Inter-turn overvoltage test for current transformers**

Winding	Peak voltage on secondary winding [kV(peak)]	Current in primary winding [A]
1S1-1S2	0.368	450
2S1-2S2	4.28	450
3S1-3S2	1.09	450
4S1-4S2	4.5	310

**Determination of voltage part errors (c U%, Ap U min)**

1a-1n: 100 VA	2a-2n: 100VA:3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100 VA	2a-2n: 100 VA:3a-3n: 100 VA: 4a-4n: 100 VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3
1a-1n: 28 VA	1a-1n: 28 VA	1a-1n: 28 VA	1a-1n: 28 VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3
2a-2n: 100 VA	2a-2n: 100 VA	2a-2n: 100 VA	2a-2n: 100 VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3
1a-1n: 100VA:3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:3a-3n: 100VA: 4a-4n: 100VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3
3a-3n: 100 VA	3a-3n: 100 VA	3a-3n: 100 VA	3a-3n: 100 VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3
1a-1n: 100VA:2a-2n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:2a-2n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:2a-2n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:2a-2n: 100VA: 4a-4n: 100VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3
1a-1n: 100VA:2a-2n: 100VA: 3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:2a-2n: 100VA: 3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:2a-2n: 100VA: 3a-3n: 100VA: 4a-4n: 100VA	1a-1n: 100VA:2a-2n: 100VA: 3a-3n: 100VA: 4a-4n: 100VA
ε U	0.8 Un	ε U	0.8 Un
Δp U	-1.3	Δp U	-1.3

3S1-3S2	278,86	0,087	0,1	$\epsilon_c \pm 5\%$	<input checked="" type="checkbox"/>
4S1-4S2	1388,83	0,015	0,08	$\epsilon_c \pm 5\%$	<input checked="" type="checkbox"/>


Measurement of capacitance and dielectric dissipation factor - 8  
 Temperature: 24,2 °C, Frequency: 50

Primary voltage [kV]	Instrument transformer			Current part			Voltage part		
	Tg $\delta$ [%]	Capacity [pF]	Leak current [mA]	Tg $\delta$ [%]	Capacity [pF]	Leak current [mA]	Tg $\delta$ [%]	Capacity [pF]	Leak current [mA]
10 kV	0,23	1404	4,398	0,24	1128	3,572	0,23	278	0,892
63 kV	0,23	1404	27,83	0,24	1128	22,34	0,22	278	5,48
71 kV	0,23	1404	31,36	0,24	1128	23,21	0,22	278	6,156

Core magnetization characteristics:

Winding 1S1-1S2

[V]	[mA]
18	3659
18,7	103,47
15,5	48,71
14,4	27,86
13,5	19,59
13	15,84
12,4	12,69
11,8	10,63
11,3	9,23
10,6	7,96
8,4	5,89
6,1	4,59
4	3,37
1,7	1,96
0,1	0,25



44-4n: 25 VA	p.f. = 0,8 lag.	44-4n: 25 VA	p.f. = 0,8 lag.
14-1n: 100VA; 24-2n: 100VA; 34-3n: 100VA	p.f. = 0,8 lag.	14-1n: 0 VA; 24-2n: 0 VA; 34-3n: 0 VA	p.f. = 0,8 lag.
$\epsilon_U$ 0,02 Un 0,05 Un 0,8 Un 1,0 Un 1,9 Un	0,8 Un 0,8 Un 0,8 Un 1,0 Un 1,2 Un 1,8 Un	$\epsilon_U$ 0,02 Un 0,05 Un 0,8 Un 1,0 Un 1,2 Un 1,8 Un	0,8 Un 0,8 Un 0,8 Un 1,0 Un 1,2 Un 1,8 Un
$\Delta\theta_U$ -0,099 -0,098 0,001 0,002 -0,165	0,179 0,178 0,273 0,274 0,275 0,107	$\Delta\theta_U$ -0,099 -0,098 0,001 0,002 -0,165	0,179 0,178 0,273 0,274 0,275 0,107
$\Delta\theta_U$ -1,0 -1,0 -0,8 -0,6 -4,1	4,8 5,4 6,5 5,5 5,5 2,3	$\Delta\theta_U$ -1,0 -1,0 -0,8 -0,6 -4,1	4,8 5,4 6,5 5,5 5,5 2,3
44-4n: 250 VA	p.f. = 0,8 lag.	44-4n: 250 VA	p.f. = 0,8 lag.
14-1n: 100VA; 24-2n: 100VA; 34-3n: 100VA	p.f. = 0,8 lag.	14-1n: 0 VA; 24-2n: 0 VA; 34-3n: 0 VA	p.f. = 0,8 lag.
$\epsilon_U$ 0,8 Un 1,0 Un 1,2 Un	0,8 Un 1,0 Un 1,2 Un	$\epsilon_U$ 0,8 Un 1,0 Un 1,2 Un	0,8 Un 1,0 Un 1,2 Un
$\Delta\theta_U$ -0,177 -0,169 -0,125	1,053 1,053 1,053	$\Delta\theta_U$ -0,177 -0,169 -0,125	1,053 1,053 1,053
$\Delta\theta_U$ 16,8 16,1 16,3	9,7 9,7 9,8	$\Delta\theta_U$ 16,8 16,1 16,3	9,7 9,7 9,8

\* at 1,8 Un winding de-din is loaded with 200 VA, p.f. = 0,8

Determination of current part errors (  $\epsilon$  %),  $\Delta\theta$  1 min)

Ipn (A): 150		1S1-1S2: 7,50 VA		p.f. = 0,8 lag.		p.f. = 0,8 lag.	
$\epsilon_I$	0,05 In	0,05 In	0,2 In	0,2 In	1,0 In	1,0 In	1,2 In
$\Delta\theta_I$	-0,165	-0,113	-0,044	-0,060	-0,020	-0,017	0,003
$\Delta\theta_I$	4,3	1,7	-0,4	0,8	2,4	1,6	0,4
Ipn (A): 300		1S1-1S2: 7,50 VA		p.f. = 0,8 lag.		p.f. = 0,8 lag.	
$\epsilon_I$	0,05 In	0,05 In	0,2 In	0,2 In	1,0 In	1,0 In	1,2 In
$\Delta\theta_I$	-0,140	-0,140	-0,140	-0,140	-0,140	-0,140	-0,140
$\Delta\theta_I$	1,3	1,3	1,3	1,3	1,3	1,3	1,3

Ipn (A): 300		1S1-1S2: 30 VA		p.f. = 0,8 lag.		p.f. = 0,8 lag.	
$\epsilon_I$	0,05 In	0,05 In	0,2 In	0,2 In	1,0 In	1,0 In	1,2 In
$\Delta\theta_I$	-0,41	-0,10	-0,042	-0,057	-0,043	-0,019	0,004
$\Delta\theta_I$	17,7	1,8	-0,4	0,8	2,1	0,5	0,5
Ipn (A): 300		1S1-1S2: 40 VA		p.f. = 0,8 lag.		p.f. = 0,8 lag.	
$\epsilon_I$	0,05 In	0,05 In	0,2 In	0,2 In	1,0 In	1,0 In	1,2 In
$\Delta\theta_I$	-0,140	-0,140	-0,140	-0,140	-0,140	-0,140	-0,140
$\Delta\theta_I$	0,8	0,8	0,8	0,8	0,8	0,8	0,8

Current part: Measurements  $\epsilon_I = \pm 0,046\%$ ,  $\Delta\theta_I = \pm 2,3$  min  
 Voltage part: Measurements uncertainty:  $\epsilon_U = \pm 0,044\%$ ,  $\Delta\theta_U = \pm 2,2$  min

Determination of the over current factors:

- Instrument security factor (FS) of measuring cores

Winding	$I_n$ [A]	$I_n$ [V]	EPS [V]	Condition	Assessment
1S1-1S2	2,5	17,84	36,02	U < EPS	<input checked="" type="checkbox"/>


- accuracy limit factor (ALF) - test for composite error  $\epsilon_c$  of protective cores

Winding	$E_{ALF}$ [V]	$I_n$ [A]	$\epsilon_c$ [%]	Condition	Assessment
2S1-2S2	960,93	0,015	0,08	$\epsilon_c \pm 5\%$	<input checked="" type="checkbox"/>




Winding 2S1-2S2

[V]	[mA]
1132.4	1427.9
1127.1	877.7
1104.4	263.7
1028.5	26.54
1000.1	17.54
978.	19.07
948.	14.68
894.	13.85
832	12.48
782.	11.95
612	9.3
442	7.32
274.	5.42
103.	2.88
10.2	0.86




Winding 3S1-3S2

[V]	[mA]
375.	7431
331.	241.8
310.	182
304.	148.8
297.	123
282.	101.48
268.	83.09
258.	72.82
239.	65.23
197.	51.48
153.	41.82
111	33.85
68.8	25.08
28.3	13.38
2.4	2.72



Winding 4S1-4S2

[V]	[mA]
1872.8	2020.9
1734.7	80.38
1827.6	35.01
1534.8	23.81
1509.5	21.62
1451	17.85
1389.2	15.51
1338.3	13.82
1280.7	12.48
1052.2	9.76
832.	8.05
608.	6.47
388.	4.93
168.	2.92
10.3	0.82



\*) Average rectifier effective value.

Measurement of windings' resistance

Windings' resistance of current part

	R (23 °C)	Ref (75 °C)
P1-P2 range 150A	1883.0 mΩ	2267.8 mΩ
P1-P2 range 300A	970.0 μΩ	1188.2 μΩ
1S1-1S2	0.238 Ω	0.287 Ω
2S1-2S2	7.980 Ω	8.823 Ω
3S1-3S2	0.388 Ω	0.468 Ω
4S1-4S2	9.450 Ω	11.381 Ω

Windings' resistance of voltage part

	R (23 °C)	Ref (75 °C)
A-N	21.30 kΩ	25.853 kΩ
1a-1n	47.010 mΩ	56.617 mΩ
2a-2n	48.480 mΩ	58.387 mΩ
3a-3n	50.000 mΩ	60.218 mΩ
4a-4n	51.700 mΩ	62.265 mΩ
0B-0n	34.080 mΩ	41.045 mΩ

Checked by: 05.11.2013

Przemyśl, 2013-12-04





ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Routine tests report of combined instrument transformer After short circuit voltage part		TYPE: PVA145a
Serial no: 2GKP013K1486145		Tech [A]: 225-450		
Insulation level: 1.9/0th		Voltage factor: 50-50		
1.9/0th		20-20		
152-03 kV		50-50		
60 Hz		60 Hz		
VOLTAGE PART				
Winding	U <sub>1n</sub> [kV]	S <sub>n</sub> [VA]	class	S <sub>1n</sub> [VA]
1a - 1n	0.11-0.3	100	1.0	1000
2a - 2n	0.11-0.3	100	1.0	1000
3a - 3n	0.11-0.3	100	1.0	1000
4a - 4n	0.11-0.3	100	3.0	1000
0a - 0n	0.11-0.3	200	3.0	450
CURRENT PART				
Winding	I <sub>sn</sub> [A]	S <sub>n</sub> [VA]	class	Ratio [A/A]
1S1-1S2	5	30	0.2FS.5	150-300/5
2S1-2S2	1	40	5P.20	150-300/1
3S1-3S2	5	60	5P.20	150-300/5
4S1-4S2	1	60	5P.20	150-300/1

- List of performed tests:
- Oil dielectric parameters check before filling (oil after treatment):
    - 19.8 acc. IEC 60247, breakdown voltage acc. IEC 60156
    - 2. Verification of terminal
    - 3. Pressure and tightness test: oil overpressure, 0.8 bar / 24h - no increase of oil
    - 4. Power-frequency withstand on primary windings
      - P1+P2): U<sub>1p</sub> = 247.5 kV / 60s, f = 50Hz
      - lower-value (U<sub>1p</sub> peak=4.5kV or U<sub>1p</sub> peak for Icth) / 60s
      - U<sub>1p</sub> = 3 kV/60s
    - 5. Partial discharge
    - 6. Power-frequency withstand test on secondary
    - 7. Inter-turn overvoltage test for current
    - 8. Determination of
    - 9. Determination of the over current factors: FS, ALF
    - 10. Measurement of capacitance and dielectric dissipation factor - 3
    - 11. Determination of core magnetization characteristics
    - 12. Measurement of windings' resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tg δ according to IEC  
Tg δ = 0.06 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C

- Measurement of breakdown voltage according to IEC 60156  
Mean breakdown voltage = 78.15 kV, Relative standard deviation = 5.99  
f = 50Hz, oil temp. = 25 °C, measurement with the stirrer, type of electrodes used: partially

Sample	Breakdown voltage [kV]
1	73.7
2	84.3
3	82.8
4	78.4
5	76.9
6	72.8

Partial discharge measurement  
- Measurement according to procedure B voltage

Stress voltages: 247.5 kV / 60 s  
Frequency: 87 Hz

Test voltage	1.2 U <sub>1n</sub> / √3 = 100.5
Level of partial discharge	2.8 pC

Remarks: background noise level: 1 (measured after voltage switch off),  
measuring circuit was calibrated with 5 pC (calibrating)

Inter-turn overvoltage test for current transformers

Winding	Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]
1S1-1S2	0.384	450
2S1-2S2	4.5	430
3S1-3S2	1.07	450
4S1-4S2	4.5	280

Determination of voltage part errors (± U%, Δp U min)

1a-1n: 100 VA	2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA	p.f. = 0.8 lag.	1a-1n: 100 VA	2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA	p.f. = 0.8 lag.
ε U	0.8 Un	1.0 Un	0.8 Un	1.0 Un	1.0 Un
Δp U	-0.161	-0.159	-0.159	-0.159	-0.159
1a-1n: 25 VA	2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 25 VA</td> <td>2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 25 VA</td> <td>2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 25 VA	2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.8 Un	1.0 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-0.15	-0.013	-0.013	-0.013	0.267
1a-1n: 100 VA	2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100 VA</td> <td>2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 100 VA</td> <td>2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 100 VA	2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.8 Un	1.0 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-0.161	-0.160	-0.160	-0.160	0.121
2a-2n: 25 VA	3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>2a-2n: 25 VA</td> <td>3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	p.f. = 0.8 lag. <td>2a-2n: 25 VA</td> <td>3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	2a-2n: 25 VA	3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.8 Un	1.0 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-0.014	-0.013	-0.013	-0.013	0.267
3a-3n: 100 VA	4a-4n: 100VA <td>p.f. = 0.8 lag. <td>3a-3n: 100 VA</td> <td>4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	p.f. = 0.8 lag. <td>3a-3n: 100 VA</td> <td>4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	3a-3n: 100 VA	4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.8 Un	1.0 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-0.3	-1.4	-1.3	-1.3	5.2
1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.02 Un	0.05 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-0.250	-0.251	-0.149	-0.147	-0.314
1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.02 Un	0.05 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-2.3	-1.3	-0.8	-0.8	-4.2
1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.02 Un	0.05 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-2.8	-1.9	-1.2	-1.2	-4.3
1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.02 Un	0.05 Un	0.8 Un	1.0 Un	1.2 Un
Δp U	-0.257	-0.258	-0.161	-0.160	-0.303
1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td></td>	p.f. = 0.8 lag. <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td></td>	1a-1n: 100VA; 2a-2n: 100VA; 3a-3n: 100VA; 4a-4n: 100VA <td>p.f. = 0.8 lag. </td>	p.f. = 0.8 lag.
ε U	0.011	0.011	0.110	0.112	0.111
Δp U	-1.1	-0.2	0.2	0.3	-3.1



4n-4n: 25 VA	4n-4n: 25 VA	4n-4n: 25 VA	4n-4n: 25 VA
1n-1n: 100VA; 2n-2n: 100VA; 3n-3n: 100VA	1n-1n: 0 VA; 2n-2n: 0 VA; 3n-3n: 0 VA	1n-1n: 0 VA; 2n-2n: 0 VA; 3n-3n: 0 VA	1n-1n: 0 VA; 2n-2n: 0 VA; 3n-3n: 0 VA
ε U	0.02 Un	0.03 Un	0.04 Un
Δp U	-0.03	-0.08	-0.03
ε U	0.03	0.03	0.03
Δp U	-0.03	-0.08	-0.03
ε U	0.03	0.03	0.03
Δp U	-0.03	-0.08	-0.03
ε U	0.03	0.03	0.03
Δp U	-0.03	-0.08	-0.03

\* at 1.8 Un winding da-dn is loaded with 200 VA, p.f. = 0.8

Determination of current part errors (ε %), Δp 1 min

1S1-1S2: 30 VA		1S1-1S2: 7.60 VA	
ε I	0.05 in	ε I	0.05 in
Δp I	-0.175	Δp I	-0.105
ε U	4.8	ε U	1.5
Δp U	-0.4	Δp U	-0.4
ε I	1.0 in	ε I	1.0 in
Δp I	-0.130	Δp I	-0.130
ε U	0.9	ε U	0.9
Δp U	-0.146	Δp U	-0.146
ε I	1.0	ε I	1.0
Δp I	-0.146	Δp I	-0.146

1S1-1S2: 30 VA		1S1-1S2: 30 VA	
ε I	0.05 in	ε I	0.05 in
Δp I	-0.160	Δp I	-0.160
ε U	4.7	ε U	4.7
Δp U	-0.4	Δp U	-0.4
ε I	1.0 in	ε I	1.0 in
Δp I	-0.130	Δp I	-0.130
ε U	0.9	ε U	0.9
Δp U	-0.146	Δp U	-0.146
ε I	1.0	ε I	1.0
Δp I	-0.146	Δp I	-0.146

Current part: Measurements  
Voltage part: Measurements uncertainty: ε I = ±0.045 %, Δp I = ±2.3 min  
ε U = ±0.044 %, Δp U = ±2.2 min

Determination of the over current factors:

Winding	I <sub>0</sub>	U	EFS	Assessment
1S1-1S2	2.5	17.84	35.93	U < EFS

- accuracy limit factor (ALF) - test for composite error ε<sub>c</sub> of protective cores

Winding	EALF	I <sub>0</sub>	ε <sub>c</sub>	Assessment
2S1-2S2	985.1	0.015	0.08	ε <sub>c</sub> ≤ 5%



3S1-3S2	278.51	0.1	0.1	ε <sub>c</sub> ≤ 5%
4S1-4S2	1335.12	0.015	0.08	ε <sub>c</sub> ≤ 5%


Measurement of capacitance and dielectric dissipation factor - 5  
Temperature: 23.2 °C, Frequency: 50



Primary voltage	Instrument transformer			Current part			Voltage part		
	Td δ [μA]	Capacity [pF]	Leak current [mA]	Td δ [%]	Capacity [pF]	Leak current [mA]	Td δ [%]	Capacity [pF]	Leak current [mA]
10 kV	0.23	1394	4.382	0.24	1115	3.33	0.23	276	0.871
63 kV	0.23	1394	27.54	0.23	1115	22.06	0.23	276	5.453
71 kV	0.23	1394	30.01	0.23	1115	24.70	0.23	276	6.122

Core magnetization characteristics:

Winding 1S1-1S2

V [V]	I [mA]
18	3510.8
17	136.6
15.8	57.25
14.7	31.73
13.2	17.13
12.6	13.6
12.1	11.35
11.5	9.58
10.8	8.2
10.3	7.37
8.8	5.62
8.3	4.34
4	3.25
1.7	1.88
0.1	0.24






Measurement of windings' resistance  
Windings' resistance of current part

	R (23 °C)	Rct (75 °C)
PT-PZ range 150A	1706.0 μΩ	2054.6 μΩ
PT-PZ range 300A	881.0 μΩ	1061.0 μΩ
1S1-1S2	0.236 Ω	0.284 Ω
2S1-2S2	7.950 Ω	9.575 Ω
3S1-3S2	0.385 Ω	0.464 Ω
4S1-4S2	9.270 Ω	11.104 Ω

Windings' resistance of voltage part:

	R (23 °C)	Rct (75 °C)
A-N	20.90 KΩ	25.171 KΩ
1s-1n	46.820 mΩ	56.388 mΩ
2s-2n	48.340 mΩ	58.219 mΩ
3s-3n	49.840 mΩ	60.025 mΩ
4s-4n	51.400 mΩ	61.904 mΩ
da-dn	34.010 mΩ	40.860 mΩ



Checked by: OG-1  
Pracznysz, 2014-01-27




**ANNEX 4** Documentations delivered by orderer

 ABB Sp. z o.o.	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
<p><b>DECLARATION OF CONFORMITY No. 0922/2013 (EN)</b> (acc. to ISO/IEC 17050-1)</p> <p>Manufacturer: ABB Sp. z o.o. Dept. in Przasnysz</p> <p>Address: Str. Leszno 59 06-300 Przasnysz / POLAND</p> <p>Product: Combined Instrument Transformer PVA 145a</p>		
<p>Above mentioned product conforms with the following standard :</p> <p>Standard IEC 61869 - 4 Title Edition/Date Combined Instrument Transformers 2013</p>		
<p>Additional information: Serial numbers: 2GKP013K1486145;</p>		
<p>Place and date of issue of declaration Przasnysz 13.01.2014</p>		
(Name)	(Signature)	

ABB Sp. z o.o.  
ul. Zagajnikowa 1, 04-713 Warszawa  
NIP: 528-030-44-54; PL 5255004494  
Region 01007106  
O D Z I A S W O S 05-203 Przasnysz  
ul. Leszno 59  
tel. (22) 223 8921, fax (22) 223 8058

Instytut Inżynierii i Techniki  
ABB Sp. z o.o.  
Odczynki w Przasnysz  
Inżynieria

Inżynier ds. Zapewnienia Jakości  
ABB Sp. z o.o.  
Odczynki w Przasnysz





**ABB**

**Combined Instrument Transformer**

Insulation level	145/275/650 KV	Standard	IEC 61869-4	Type	PVA 145a
Oil type	Nyro Libra	Weight / Oil weight	540 / 150 kg	fn	50 Hz
S/N	2GKP013K1486145	Voltage factor	1.9Un/8h	Temp. range	-50°C → +40°C
				Ue	0.2 mV/kA

**CURRENT PART**

$K_n$	150-300 / 5-1-5-1	A/A	
$I_{n1}/1S$	20-20	kA	$I_{n2}$ 50-50 kA
$I_{dth}$	180-360	A	

1S1-1S2 2S1-2S2 3S1-3S2 4S1-4S2 5S1-5S2 6S1-6S2


A	5	1	5	1
VA	30	40	60	60
KL	0.2	5P	5P	5P
FS/ALF	5	20	20	20
Ext.-%	120			

V	110-√3	110-√3	110-√3	110-√3	110-√3	110-√3
VA	100	100	100	100	100	200
KL	1.0	1.0	1/3P	3/3P	3.0	
VA <sub>max</sub>	1000	1000	1000	1000	1000	450

Transportation Vertical / Horizontal

**VOLTAGE PART**

A-N	132-√3	KV
-----	--------	----



Instrument transformer electrical diagram

- ATTENTION!**
- HIGH VOLTAGE AT OPEN CURRENT SECONDARY TERMINALS XS1 - XS2
  - DURING INSTRUMENT TRANSFORMER OPERATION TERMINALS N, E/7a, 7b MUST BE EARTHED
  - AFTER THREE WINDINGS 6a-6n ARE CONNECTED IN ORDER DELTA THE CIRCUIT SHOULD BE EARTHED IN ONE POINT ONLY


*[Handwritten signature]*

*[Handwritten signature]*

*[Handwritten signature]*

(

(

	<b>INSTYTUT ENERGETYKI</b> INSTITUTE OF POWER ENGINEERING <b>LABORATORIUM WIELKOPRĄDOWE</b> HIGH CURRENT LABORATORY	address: ul. Mory 8 01-330 Warszawa, Poland phone/fax: +48 22 832 80 16 e-mail: ewp@ien.com.pl www.ien.com.pl/ewp
---	--	---

	<b>INSTITUTE OF POWER ENGINEERING</b> <b>HIGH CURRENT LABORATORY</b>	Test Report No. <b>EW7/03/E/2016</b>
---	---	---

**TEST REPORT NO.**  
**EW7/03/E/2016**

**TEST OBJECT:** Combined instrument transformer type PVA 145a

**MANUFACTURER:** ABB Sp. z o.o.  
ul. Leszno 59  
06-300 Przasnysz, Poland

**TESTS ORDERED BY:** ABB Sp. z o.o.  
ul. Żegawska 1  
04-713 Warszawa, Poland  
Order No. 4500709453 dated 19.01.2016

**TYPE OF TESTS:** Temperature-rise test

**TESTS PROCEDURE:** IEC 61869-1:2007, IEC 61869-2:2012, IEC 61869-3:2011,  
IEC 61869-4:2013, IEC 62271-1:2007/A1:2011

**OBJECT DELIVERED:** 18.12.2015

**DATE OF TESTS:** 01.02-02.02.2016

**TESTS RESULTS:** Positive for current  $I_{th} = 3600A$

**THE TESTS WERE WITNESSED BY:**

Authorised by  
**TEST ENGINEER:**  
Grzegorz ZABOKLIŃSKI M.Sc. Eng.

Approved by  
**HEAD OF LABORATORY:**  
Maciej OWSIŃSKI M.Sc. Eng.

*Grzegorz Zabokliński*


*Maciej Owsinski*

Warsaw, 15.02.2015

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Photographic documentation

4	Figures
2	Appendices

Report contains 16 numbered pages with:



323

The Test Report consists of parts from the test object, the test results and the scope of accreditation (details in sub-cl. 4). Publishing or reproducing of this report in other versions is prohibited without written permission of laboratory is forbidden.

1. Description of the test object	
Test object	Combined instrument transformer
Type	PVA 145a
Serial number	2GKP015K1689425
Manufacturer	ABB Sp. z o.o.
Year of production	2015
Insulator	Porcelain insulator
Number of windings	VT part 5, CT part 4
Oil type	Nyro 10XN
Temperature range	-40°C - +40°C
Total weight / oil weight	620 / 150 kg
Dimensions	According to appendix No.1 2GKK614815A1277

The laboratory made the identification of test objects basing on documentation given in sub-cl. 3. The test object is shown in the figure 4. The object was prepared for tests by the Manufacturer.

2. Technical data declared by the Manufacturer	
Rated voltage [kV]	132·√3
Maximum operating voltage [kV]	145
Rated frequency [Hz]	50
Voltage factor and time	1,9U <sub>n</sub> /8h
Rated continuous thermal current, I <sub>cth</sub>	3600 A
Rated short-time thermal current, I <sub>sh</sub> /1s	63 kA
Rated dynamic current, I <sub>dyn</sub>	158 kA

Winding	1a-1n	2a-2n	3a-3n	da-dn
Rated secondary voltage [V]	110·√3	110·√3	110·√3	110
Rated output [VA]	25	25	25	150
Accuracy class	0,2	0,2	0,2/3P	3P
Thermal limiting output [VA]	1000	1000	1000	450

Winding	1S1-1S2	2S1-2S2	3S1-3S2	4S1-4S2
Rated secondary current [A]	5	1	5	1
Rated output [VA]	200	100	20	Rb=5Ω, class TPY 10x13, Rct<= 8Ω, Ts=500 ms, cy/d 100 ms, Tp=50 ms
Accuracy class	0,2	0,1	5P	
FS/ALF	10	5	60	

**3. Technical documentation of the test object**

1. Drawing No. 2GKK614815A1277 – Dimensional drawing combined instrument transformer PVA123a-PVA145a, ABB Sp. z o.o., approved 04.02.2016 – Appendix No. 1

**4. Scope of the tests**

Test program agreed with Orderer comprised of following tests:

No.	Kind of test	Tests according the Standard	Location of the test
1.	Temperature-rise tests	IEC 61869-1:2007 p. 6.4 i 7.2.2, IEC 61869-2:2012 p.6.4.i i 7.2.2.204 IEC 61869-3:2011 p. 6.4.i i p.7.2.2 IEC 61869-4:2013 p. 6.4.i i 7.2.2 IEC 62271-1:2007/A1:2011, table no. 3	EWP

The test was performed in Institute of Power Engineering, by High - Current Laboratory.





5. Tests and their results

Combined transformer was installed at the test stand, as it was during normal operation. The rated voltage with a required value was applied to the primary voltage winding. The secondary voltage windings and the residual voltage winding were loaded with the suitable power, according to the test programme given below, which was agreed with the Orderer. Primary current terminals P1 and P2/A was bridged at the range of 3000 A. According to Manufacturer's request current in primary current winding was equal to  $I_{ch} = 3600$  A. The arrangement of the thermocouples is given in Figure 3. The temperature-rises of windings were measured by the resistance rise method. During the test, the measurements of loaded windings were made every 1-hour. The abstract of the protocol of temperature-rise test is given in Table 1. The summary of test results is given in Table 2.

The temperature-rise of windings were calculated from the follow formula:

$$\Delta t = \frac{R_x}{R_0} (235 + t_0) - 234,5 - t_0$$

- $R_0$  – resistance of winding in cold state
- $R_x$  – resistance of winding in warm state
- $t_0$  – temperature of winding in cold state
- $t_x$  – ambient temperature

Tests were performed according to the IEC 61869-1 sub-cl. 6.4 and 7.2.2; IEC 61869-2 sub-cl. 6.4.1 and 7.2.2.04; IEC 61869-3 sub-cl. 6.4.1 and 7.2.2; IEC 61869-4 sub-cl. 6.4.1 and 7.2.2.

Stage No. 1: Test at the rated load

The voltage value 1,2  $U_n = 91,5$  kV was applied to the P2/A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V; 2a-2n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V; 3a-3n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V; 4a-4n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V. The winding of residual voltage remained open. The secondary current windings were loaded as follows: 1S1-1S2  $\Rightarrow$  200 VA,  $\cos \phi = 1$ ; 2S1-2S2  $\Rightarrow$  100 VA,  $\cos \phi = 1$ ; 3S1-3S2  $\Rightarrow$  20 VA,  $\cos \phi = 1$ ; 4S1-4S2  $\Rightarrow$  5Ω. The test was performed till reached steady state of the measured temperatures.

Stage No. 2: Test of 8 h

The voltage value 1,9  $U_n = 144,8$  kV was applied to the P2/A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V; 2a-2n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V; 3a-3n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V; 4a-4n  $\Rightarrow$  25 VA,  $\cos \phi = 1$ , at the voltage 110/√3 V. The residual winding da-dn was loaded by  $\Rightarrow$  450 VA,  $\cos \phi = 1$ , at the voltage 110 V. The secondary current windings were loaded as follows: 1S1-1S2  $\Rightarrow$  200 VA,  $\cos \phi = 1$ ; 2S1-2S2  $\Rightarrow$  100 VA,  $\cos \phi = 1$ ; 3S1-3S2  $\Rightarrow$  20 VA,  $\cos \phi = 1$ ; 4S1-4S2  $\Rightarrow$  5Ω. The duration of the test was 8 h.



Stage No. 3: Test with thermal limiting output

The voltage value  $U_n = 76,2$  kV was applied to the P2/A terminal. According to Manufacturer's request secondary voltage windings (i.e. 1a-1n, 2a-2n, 3a-3n and 4a-4n) were loaded by limit power 1000 VA at  $\cos \phi = 1$ . The residual winding remained open. The secondary current windings were loaded as follows: 1S1-1S2  $\Rightarrow$  200 VA,  $\cos \phi = 1$ ; 2S1-2S2  $\Rightarrow$  100 VA,  $\cos \phi = 1$ ; 3S1-3S2  $\Rightarrow$  20 VA,  $\cos \phi = 1$ ; 4S1-4S2  $\Rightarrow$  5Ω. The test was performed till reaching the steady state of the measured temperatures.

Measuring equipment

The temperatures were measured by means of type K thermocouples (NiCr – NiAl) with accuracy  $\pm 0,6^\circ\text{C}$ . The ambient temperature was measured using four thermocouples type K immersed into tank filled with oil. These thermocouples were placed in the distance of 1 meter from the tested transformer at the height of 1 meter above floor - the accuracy of measurement  $\pm 0,6^\circ\text{C}$ . The resistance was measured by means of meter type 2291 manufactured by TETTEX Instruments with accuracy  $\pm 0,1$  mΩ.

**ABB**

**Combined Instrument Transformer**

Insulation level	145/275/650 kV	Standard	IEC 61869-4	Type	PVA 145a
Oil type	Nyro 10XN	Weight/Oil weight	620/150 kg	Temp. range	40°C → +40°C
S/N	2GKP015K1689425	Voltage factor	1,9Um/8h	Ue	0,375 mV/kA

---

**CURRENT PART**

$K_n$	1500-3000 / 5-1-5-1	A/A	A-N	132-√3	KV
$I_n/I_s$	63	kA	1,0n	158	kA
$I_{ch}$	3600	A			

A	VA	class	FSALF	Ext. %
1S1-1S2	5	200	0,2	10
2S1-2S2	1	100	0,1	5
3S1-3S2	5	20	5P	60
4S1-4S2	1			

Rb=5 Ω, class TYP 10 x 13, Rct=8 Ω  
Ts=500 ms, c/kl 100 ms, T=50 ms

---

**VOLTAGE PART**

V	VA	1a-1n	2a-2n	3a-3n	4a-4n	da-dn
110-√3	110-√3	110-√3	110-√3	110-√3	110-√3	110
25	25	25	25	25	25	150
0,2	0,2	0,2	0,2	0,2	0,2	0,2/3P
1000	1000	1000	1000	1000	1000	450

Transportation:  Vertical /  Horizontal

Fig. 1. Nameplate of tested combined instrument transformer

The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor k = 2.




Fig. 2. Electrical diagram of terminal box of tested combined instrument transformer




Fig. 3. Arrangement of thermocouples during temperature-rise test:  
1 - oil (over current coil), 2 - head (contraction of the flange connecting the head the the insulator), 3 - under the flange of tank lid, 4 - lower tank (placed inside over earthing terminal), 5 - terminal P1, 6 - terminal P1, 7 - terminal P2/A (3000A), 8 - terminal P2/A (3000A), 9 - current path inside the combined instrument transformer.



Table 2. Temperature-rises given during the tests

		Temperature rise AT [K]	Limit [K]	
Stage No. 1	Windings	1S1-1S2	50,1	
		2S1-2S2	52,3	
		3S1-3S2	52,4	
		4S1-4S2	50,5	
		P1-P2/A	Not measured	
		1a-1n	6,1	
		2a-2n	6,3	
	Thermocouple No. 1	3a-3n	5,9	
		4a-4n	6,1	
		da-dn	6,5	
		A-N	8,2	
	Oil	34,5	55 <sup>1,2,3,4)</sup>	
	Head	29,8		
	Thermocouple No. 2	Under the flange of tank lid	2,9	40 <sup>5)</sup>
	Thermocouple No. 3	Lower tank	2,0	
	Thermocouple No. 4	Terminal P1	52,9	
	Thermocouple No. 5	Terminal P1	55,3	
Thermocouple No. 6	Terminal P2/A	46,8	65 <sup>5)</sup>	
Thermocouple No. 7	Terminal P2/A	45,5		
Thermocouple No. 8	Current path inside the combined instrument transformer	46,5	65 <sup>1,2,3,4)</sup>	
Stage No. 2	Windings	1S1-1S2	55,4	
		2S1-2S2	57,9	
		3S1-3S2	58,0	
		4S1-4S2	56,6	
		P1-P2/A	Not measured	
		1a-1n	11,2	
		2a-2n	11,6	
		3a-3n	11,3	
		4a-4n	11,8	
		da-dn	12,6	
	A-N	13,1		
	Oil	36,2	55+10 <sup>1)</sup>	
	Head	30,9		
	Thermocouple No. 1	Under the flange of tank lid	5,1	40 <sup>5)</sup>
	Thermocouple No. 2	Lower tank	3,8	
	Thermocouple No. 3	Terminal P1	53,8	
	Thermocouple No. 4	Terminal P1	56,5	
Thermocouple No. 5	Terminal P2/A	48,9	65 <sup>5)</sup>	
Thermocouple No. 6	Terminal P2/A	48,4		
Thermocouple No. 7	Current path inside the combined instrument transformer	48,5	65+10 <sup>1,2,3,4)</sup>	
Thermocouple No. 8				
Thermocouple No. 9				



Table 2. Cont.

		Temperature rise AT [K]	Limit [K]	
Stage No. 3	Windings	1S1-1S2	57,6	
		2S1-2S2	60,0	
		3S1-3S2	60,1	
		4S1-4S2	58,8	
		P1-P2/A	48,8	
		1a-1n	22,5	
		2a-2n	24,2	
		3a-3n	25,4	
	Thermocouple No. 1	4a-4n	26,7	
		da-dn	29,4	
		A-N	39,6	
		Oil	37,7	
	Thermocouple No. 2	Head	33,2	55 <sup>1,2,3,4)</sup>
	Thermocouple No. 3	Under the flange of tank lid	5,6	40 <sup>5)</sup>
	Thermocouple No. 4	Lower tank	4,7	
	Thermocouple No. 5	Terminal P1	55,8	
	Thermocouple No. 6	Terminal P1	58,2	
Thermocouple No. 7	Terminal P2/A	50,6	65 <sup>5)</sup>	
Thermocouple No. 8	Terminal P2/A	50,9		
Thermocouple No. 9	Current path inside the combined instrument transformer	50,9	65+10 <sup>1,2,3,4)</sup>	

<sup>1)</sup> acc. to IEC 61869-1, <sup>2)</sup> wg IEC 61869-2, <sup>3)</sup> acc. to IEC 61869-3, <sup>4)</sup> acc. to IEC 61869-4,  
<sup>5)</sup> acc. to IEC 62271-1,



6. Summary

Results of the temperature-rise test for combined transformer type PVA145a with primary continuous thermal current  $I_{th} = 3600A$  are as follows:

- in steady state, at the rated load of secondary voltage and current windings (without residual winding), and supply voltage  $1.2U_n$  (Stage No. 1), permitted temperature-rise limits were not exceeded.
- results of test 8 h at supply voltage  $1.9U_n$  and rated load of voltage and current windings and load of residual winding with thermal limiting output (Stage No. 2), shows that permitted temperature-rise limits were not exceeded.
- in steady state, results of test with thermal limiting output for voltage windings (without residual windings), rated load of current windings and supply voltage  $U_n$  (Stage No. 3), permitted temperature-rise limits were not exceeded.

The tested combined transformer met requirements of IEC 61869-1:2007, IEC 61869-2:2012, IEC 61869-3:2011, IEC 61869-4:2013 and IEC 62271-1:2007/A1:2011 standards.

6. Photographic documentation




Fig. 4. Combined transformer on the test stand during temperature-rise test


*A. Repunov*

Page 13 / 16  
*D.H.*

*[Handwritten signature]*



Appendix No. 1



Appendix No. 2

**ABB** Declaration of conformity

**DECLARATION OF CONFORMITY No. 111/2016 (EN)**  
(acc. to ISO/IEC 17050-1)

Manufacturer: **ABB**

Product: **Combined Instrument Transformer PVA145a**

Above mentioned product conforms with the following standard:

Standard: **IEC 61869-4**; Title: **Instrument Transformers - Part 4: Additional requirements for combined transformers**; Edition/Date: **2013**

Additional information:  
Serial numbers: **2GKP015K1689425**;

Place and date of issue of declaration  
Przasnysz 09.02.2016

Kierownik ds. Zmierzania, Jakości:  
ABB Sp. z o.o.  
Człowiek w Przasnyszu  
Krzysztof Lubicki  
(Signature)

Kierownik Działu PPA  
ABB Sp. z o.o.  
Człowiek w Przasnyszu  
Narcey Dypala  
(Signature)

01-330 Warszawa  
 ul. Mocy 8  
 tel. (22) 34-51-386  
 tel./fax (22) 834-80-16  
 e-mail: ewp@ipm.com.pl  
 http://ipm.com.pl/ce/wvp\_2.php

<b>TEST REPORT No.</b>		<b>EWP/07/E/2012-4c</b>
<b>TEST OBJECT:</b>	Combined instrument transformer type PVA 125	
<b>MANUFACTURER:</b>	ABB Sp. z o.o. Power Products 59 Leszno Str. 06-300 Przasnysz, Poland	
<b>TESTS ORDERED BY:</b>	Institute of Power Engineering High Voltage Department Internal order No. EWN/1/E/12 dated 16.02.2012	
<b>TYPE OF TESTS:</b>	Temperature-rise test	
<b>TEST PROCEDURE:</b>	IEC 60044-3:2002, IEC 60044-1:1996, IEC 60044-2: 1997, IEC 60044-2 1997 /A2:2002	
<b>TEST OBJECT DELIVERED:</b>	10.02.2012	
<b>DATE OF TESTS:</b>	16.02.2012 – 17.02.2012	
<b>TESTS RESULTS:</b>	Positive	
<p>Tests result refers only to the test object.          The Test Report consist tests from and beyond the scope of accreditation (details in sub-cl. 4)          Publishing or reproducing of this report in other version than exact and complete without written permission of laboratory is forbidden</p>		
<b>TEST ENGINEER:</b>	Jacek Tymochowicz M.Sc. Eng. <i>Tymoch</i>	
<b>HEAD OF LABORATORY:</b>	Lidia Gruza M.Sc. Eng. <i>Lidia</i>	

Warsaw, 20.02.2012

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Opinions and interpretations
8.	Photographic documentation

Report contains 17 numbered pages with:	
2	Drawings
3	Photographs
0	Oscillograms
1	Appendix






1. Description of the test object

Test object	Combined instrument transformer
Type	PVA 123
Serial number	2GKFP011K1484707
Manufacturer	ABB Sp. z o.o. Power Products 59 Leszno Str. 06-300 Przasnysz, Poland
Year of production	2011
Insulator	Porcelain insulator
Number of windings *)	VT part - 5, CT part- 4
Oil type	Nytro Libra
Minimum creepage distance	3640 mm
Insulating oil weight	150 kg
Total weight	640 kg
Dimensions	According to drawing no. 2GKKG614213

The laboratory made the identification of test objects on the base of the documentation given in par. 3 - see Appendix.  
The test object is shown in the photographs No. 1, 2 and 3. The object was prepared for testing by the Manufacturer.

2. Technical data declared by the Manufacturer

Maximum operating voltage	123 kV
Rated frequency	50 Hz
Voltage factor and time	1,9U <sub>n</sub> /8h
Rated continuous thermal current, I <sub>th</sub>	1125-2250 A
Rated short-time thermal current, I <sub>sh</sub> / 1s	50-50 kA
Rated dynamic current, I <sub>dyn</sub>	125-125 kA



VT part						
Type of secondary winding	1a-1n	2a-2n	3a-3n	4a-4n	da-dn	
Rated secondary voltage	100·√3 V	100·√3 V	100·√3 V	100·√3 V	100·3 V	
Rated output	30 VA	30 VA	30 VA	60 VA	50 VA	
Accuracy class	0,2	0,2	0,2/3P	0,5/3P	3P	
Thermal limiting output	1000 VA	1000 VA	1000 VA	1000 VA	450 VA	
CT part						
Type of secondary winding	1S1-1S2	2S1-2S2	3S1-3S2	4S1-4S2		
Rated secondary current	5 A	5 A	5 A	1 A		
Rated output	15 VA	10 VA	50 VA	60 VA		
Accuracy class	0,2	5P	5P	5P		
FS/ALF	5	20	30	30		
Rated transformation ratio	750-1500/5 A/A	750- 1500/5 A/A	750- 1500/5 A/A	750- 1500/1 A/A		
Ext.	150 %					

3. Technical documentation of the test object

- Drawing no. 2GKKG614213 - Dimensional drawing. Combined instrument transformer PVA 123, ABB Sp. z o.o. Power Products, approved 19.01.2012
- Combined transformer verification protocol type PVA 123, Series No.: 2GKFP011K1484707. ABB Sp. z o.o., Przasnysz, 19.01.2012
- Construction of combined instrument transformer PVA 123, Serial No. 2GKFP011K1484707, ABB Sp. z o.o., Przasnysz, dated 22.01.2012.
- Kind of current paths of HV instrument transformer type PVA 123, PA 123 (PA 145), ABB Sp. z o.o., Przasnysz, dated 22.01.2012.



<b>4. Scope of the tests</b>		
Test programme agreed with Orderer comprised of tests:		
Kind of test	Tests according the Standard	Location of the test
Temperature-rise tests	IEC 60044-3:2002 sub-cl. 4.2, 7.2b,	EWP
	IEC 60044-1:1996 sub-cl. 4.6, 7.2,	
	IEC 60044-2:1997 sub-cl. 5.4, 8.1, 13.6.1	
	IEC 62271-1:2007, Table No. 3, sub-cl. 4	

EWP The test was performed in Institute of Power Engineering, by High - Current Laboratory.

**5. Tests and their results**

Combined transformer was installed at the test stand, as it was during normal operation. Electric diagram of terminal box of tested combined transformer is given in Fig. 1. The rated voltage with a required value was applied to the primary voltage winding. The secondary voltage windings and the residual voltage winding were loaded with the suitable power, according to the test programme given below, which was agreed with the Orderer. Primary current terminals P1 and P2/A was bridged at the range of 1500 A. According to Manufacturer's request current in primary current winding was equal to  $I_{ch} = 2250$  A. The arrangement of the thermocouples is given in Figure No. 2. The temperature-rises of windings were measured by the resistance rise method. During the test, the measurements of loaded windings were made every 1 hour and registered the deflection of oil level indicator. The resistances of all windings were measured before the tests and after of each stage of tests. The abstract of the protocol of temperature-rise test is given in Table No. 1. The summary of test results is given in Table 2.

The temperature-rise of windings were calculated from the formula:

$$\Delta T = \frac{R}{R_0} \alpha \frac{R_0 - R_0}{R_0} \cdot 0,004$$

**Stage No. 1: Test at the rated load**

Test was performed according to the IEC 60044-1 sub-cl. 4.6, 7.2, IEC 60044-2 sub-cl. 5.4 a), 8.1 and 13.6.1, IEC 60044-3 sub-cl. 4.2, 7.2b). The voltage value  $1,2 U_n = 76,2$  kV was applied to the P2/A terminal.

The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow 30$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V; 2a-2n  $\Rightarrow 30$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V; 3a-3n  $\Rightarrow 30$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V; 4a-4n  $\Rightarrow 60$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V.

The winding of residual voltage remained open.

The secondary current windings of the CT were loaded as follows: 1S1-1S2  $\Rightarrow 15$  VA,  $\cos \varphi = 1$ ; 2S1-2S2  $\Rightarrow 10$  VA,  $\cos \varphi = 1$ ; 4S1-4S2  $\Rightarrow 60$  VA,  $\cos \varphi = 1$ .

Supply (current control) was applied to the secondary current winding 3S1-3S2. Terminals P1 and P2/A were short-circuited at the range 1500 A.

The test was performed till reached steady state of the measured temperatures.

**Stage No. 2: Test of 8 h**

Test was done immediately after the Stage No. 1 according to the IEC 60044-1 sub-cl. 4.6, 7.2, IEC 60044-2 sub-cl. 5.4 c), 8.1, and 13.6.1, IEC 60044-3 sub-cl. 4.2, 7.2b). The voltage value  $1,9 U_n = 119,7$  kV was applied to the P2/A terminal.

The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow 30$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V; 2a-2n  $\Rightarrow 30$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V; 3a-3n  $\Rightarrow 30$  VA at the voltage  $100/\sqrt{3}$  V; 4a-4n  $\Rightarrow 60$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V.

The residual winding da-dn was loaded by  $\Rightarrow 450$  VA,  $\cos \varphi = 1$ , at the voltage  $100/\sqrt{3}$  V.

The secondary windings of the CT part were loaded by powers: 1S1-1S2  $\Rightarrow 15$  VA  $\cos \varphi = 1$ ; 2S1-2S2  $\Rightarrow 10$  VA  $\cos \varphi = 1$ ; 4S1-4S2  $\Rightarrow 60$  VA,  $\cos \varphi = 1$ .

Supply (current control) was applied to the secondary current winding 3S1-3S2. Terminals P1 and P2/A were short-circuited at the range 1500 A.

The duration of the test was 8 h.

**Stage No. 3: Test with thermal limit power**

Test was done immediately after Stage No. 2 according to the IEC 60044-1 sub-cl. 4.6, 7.2, IEC 60044-2 sub-cl. 5.4 a), 8.1, and 13.6.1, IEC 60044-3 sub-cl. 4.2, 7.2b). The voltage value  $U_n = 63$  kV was applied to the P2/A terminal.


According to Manufacturers request secondary voltage windings (i.e. 1a-1n, 2a-2n, 3a-3n and 4a-4n) were loaded by limit power 1000 VA at  $\cos \varphi = 1$ .

The residual winding remained open.

The secondary current winding of the CT part were loaded as follows: 1S1-1S2  $\Rightarrow 15$  VA,  $\cos \varphi = 1$ ; 2S1-2S2  $\Rightarrow 10$  VA; 4S1-4S2  $\Rightarrow 60$  VA,  $\cos \varphi = 1$ .

Supply (current control) was applied to secondary current winding 3S1-3S2. Terminals P1 and P2/A were short-circuited at the range 1500 A.

The test was performed till reaching the steady state of the measured temperatures.




**Measuring instruments**

The temperatures were measured by means of type K thermocouples (NiCr - NiAl) with accuracy  $\pm 0,6^{\circ}\text{C}$ .  
The ambient temperature was measured using four mercurial thermometers immersed into tank filled with oil. These thermometers were placed in the distance of 1 meter from the tested transformer at the height of 1 meter above floor- the accuracy of measurement  $\pm 0,03^{\circ}\text{C}$ .  
The resistance was measured by means of meter type 2291 manufactured by TETTEX Instruments with accuracy  $\pm 0,01 \text{ m}\Omega$ .




Fig. 1. Electrical diagram of terminal box of tested combined instrument transformer

<sup>1</sup> The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor  $k = 2$ .  
<sup>2</sup> The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor  $k = 2$ .  
<sup>3</sup> The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor  $k = 2$ .




Fig. 2. Arrangement of thermocouples during temperature-rise test:  
1 - oil (over current coil), 2 - head (contraction of the flange connecting the head the the insulator), 3 - under the flange of tank lid, 4 - lower tank (placed inside over earthing terminal), 5 - terminal P1, 6 - terminal P1, 7 - terminal P2/A (1500A), 8 - terminal P2/A (1500A).





**Table No. 2. Temperature-rises [K] given during the tests combined instrument transformer PVA 123 serial no. 2GKCP011K1484707 (primary current 2250 A)**

Winding	$\Delta\theta$ after Stage No. 1		$\Delta\theta$ after Stage No. 2		$\Delta\theta$ after Stage No. 3		$\Delta\theta_{exp}$
	$\Delta\theta$	$\Delta\theta$	$\Delta\theta$	$\Delta\theta$	$\Delta\theta$	$\Delta\theta$	
1S1-1S2	44.7	48.4	49.20				
2S1-2S2	47.2	50.9	51.70				75 <sup>1) 2) 3)</sup>
3S1-3S2	49.5	53.4	54.10				
4S1-4S2	39.7	43	43.60				
P1-P2/A	<i>Not measured</i>		<i>Not measured</i>		<i>Not measured</i>		
1a-1n	6.91	17.16	24.56				
2a-2n	6.91	17.64	25.81				
3a-3n	6.87	17.97	26.18				75 <sup>2) 3)</sup>
4a-4n	6.92	18.29	26.50				
da-dn	6.77	19.74	28.74				
P2/A-N	8.32	16.90	45.76				

Thermocouple No.	Location	$\Delta\theta$ after Stage		$\Delta\theta_{exp}$
		No. 1	No. 3	
1	Oil	17.23	16.68	55 <sup>1) 2) 3)</sup>
2	Head - top part next to terminal	13.30	12.23	
3	Under the tank lid from side of terminal box	1.62	4.30	40 <sup>4)</sup>
4	Enclosure of lower tank	1.62	4.05	
5	Terminal P1	25.81	23.28	
6	Terminal P1	24.83	22.30	
7	Terminal P2/A	21.15	17.88	65 <sup>4)</sup>
8	Terminal P2/A	23.38	20.58	

<sup>1)</sup> acc. to IEC 60044-1:1996, <sup>2)</sup> acc. to IEC 60044-2:1997,  
<sup>3)</sup> acc. to IEC 60044-3:2002, <sup>4)</sup> acc. to IEC 62271-1:2007,  
 $\Delta\theta$  - temperature-rise;  $\Delta\theta_{exp}$  - permitted value in steady state

**6. Summary**

In tested combined instrument transformer type PVA 123, with porcelain insulator, as results of temperature rise test with current  $I_{ch} = 2250$  A:

- in steady state, at the rated load of secondary current and voltage windings (without residual winding), at  $\cos \phi = 1$  and supply voltage  $1.2U_n$  (Stage No. 1), permitted temperature-rise limits were not exceeded.
- The tested combined transformer met requirements of IEC 60044-3:2002, IEC 60044-1:1996, IEC 60044-2:1997, IEC 60044-2:1997/A2:2002 and IEC 62271-1:2007 standards.
- results of test 8 h at supply voltage  $1.9U_n$  and rated load of current and voltage windings at  $\cos \phi = 1$  and load of residual winding with thermal limit power (Stage No. 2), shows that permitted temperature-rise limits were not exceeded.
- The tested combined transformer met requirements of IEC 60044-3:2002, IEC 60044-1:1996, IEC 60044-2:1997, IEC 60044-2:1997/A2:2002 and IEC 62271-1:2007 standards.
- results of test with thermal limit power (Stage No. 3) at rated load of current windings at  $\cos \phi = 1$  and supply voltage  $U_n$ , and at the same time loading of all voltage windings (without residual windings) with thermal limit power, shows that permitted temperature-rise limits were not exceeded.
- The tested combined transformer met requirements of IEC 60044-3:2002, IEC 60044-1:1996, IEC 60044-2:1997, IEC 60044-2:1997/A2:2002 and IEC 62271-1:2007 standards.


**7. Opinions and interpretations**

None





337


8. Photographic documentation



Photograph No. 1. Combined transformer on the test stand during temperature-rise test.



Photograph No. 2. The conductors short-circuiting of P1-P2A terminals.



Photograph No. 3. Terminal x of tested combined transformer during temperature-rise test.



INSTITUTE OF POWER ENGINEERING  
HIGH CURRENT LABORATORY

Test Report No.  
EWP/07/E/2012-4c

APPENDIX Documentation delivered by the Orderer

<table border="1"> <tr> <td>1</td> <td>Primary terminal</td> <td>1</td> <td>750 A</td> <td>2</td> <td>1500 A</td> </tr> </table>		1	Primary terminal	1	750 A	2	1500 A			<p>Flot terminals - Aluminium alloy DN 4620E-5 R2</p>				<p>Earthing terminals</p>				<p>Mechanical load</p>		<p>Maximum operating voltage (kV) 123 Insulating amount (kg) 640 Total weight (kg) 150 Wind pressure surface (m<sup>2</sup>) 1.03 Creepage distance (mm) 3640 Mechanical load (kN) 3.6 Fp - Static load (kN) 5.0 Fr - Dynamic load (kN) 5.0</p>		<p>Standard IEC 60044-3</p>		<p>ABB Address: 70000 Västerås, Sweden ABB AB ABB AB, P.O. Box 1000 SE-700 00 Västerås, Sweden ABB AB, P.O. Box 1000 SE-700 00 Västerås, Sweden</p>		<p>Order No. 20KK614213</p>	
1	Primary terminal	1	750 A	2	1500 A																						
<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>		<p>19012012 19012012 19012012</p>											

*Handwritten signature*

*Handwritten signature*

(

(





**INSTYTUT ENERGETYKI**  
**INSTITUTE OF POWER ENGINEERING**  
**LABORATORIUM WIELKOPRAĐOWE**  
**HIGH CURRENT LABORATORY**

address: ul. Mory 8  
 01-530 Warszawa, Poland  
 phone/fax: +48 22 836 80 16  
 e-mail: ewp@iem.com.pl  
 www.iem.com.pl/ewp



**INSTITUTE OF POWER ENGINEERING**  
**HIGH CURRENT LABORATORY**

Test Report No.  
**EWP/65/E/2015**

**TEST REPORT NO.**  
**EWP/65/E/2015**

**TEST OBJECT:** Combined instrument transformer type PVA 145a

**MANUFACTURER:** ABB Sp. z o.o.  
 ul. Leszno 59  
 06-300 Przasnysz, Poland

**TESTS ORDERED BY:** ABB Sp. z o.o.  
 ul. Żegaińska 1  
 04-713 Warszawa, Poland  
 Order No. 4500699879 dated 03.12.2015

**TYPE OF TESTS:** Temperature-rise test

**TESTS PROCEDURE:** IEC 61869-1:2007, IEC 61869-2:2012, IEC 61869-3:2011,  
 IEC 61869-4:2013, IEC 62271-1 :2007/A1 :2011

**OBJECT DELIVERED:** 18.12.2015

**DATE OF TESTS:** 12.01.2016

**TESTS RESULTS:** Positive for current I<sub>cat</sub>=3200A

**THE TESTS WERE WITNESSED BY:**

Authorised by  
**TEST ENGINEER:**  
 Mariusz SUL M.Sc. Eng.

*Mariusz Sul*

Approved by  
**HEAD OF LABORATORY:**  
 Maciej OWSINSKI M.Sc. Eng.

*Maciej Owsinski*

Warsaw, 12.02.2016

341

Contents	
1.	Description of the test object
2.	Technical data declared by the Manufacturer
3.	Technical documentation of the test object
4.	Scope of the tests
5.	Tests and their results
6.	Summary
7.	Photographic documentation

4	Figures
2	Appendices

Report contains 16 numbered pages with:

The Test Report consists from and beyond the scope of accreditation (details in sub-cl. 9)  
 Publishing or reproducing of this report in other version than exact and complete without written permission of laboratory is forbidden

*Maciej Owsinski*

*Mariusz Sul*



1. Description of the test object	
Test object	Combined instrument transformer
Type	PVA 145a
Serial number	2GKF015K1689425
Manufacturer	ABB Sp. z o.o.
Year of production	2015
Insulator	Porcelain insulator
Number of windings	VT part 5, CT part 4
Oil type	Nytro 10XN
Temperature range	-40°C - +40°C
Total weight / oil weight	620 / 150 kg
Dimensions	According to appendix No.1 2GKK614815A1277

The laboratory made the identification of test objects basing on documentation given in sub-cl. 3. The test object is shown in the Figure 4. The object was prepared for tests by the Manufacturer.

2. Technical data declared by the Manufacturer	
Rated voltage [kV]	132-√3
Maximum operating voltage [kV]	145
Rated frequency [Hz]	50
Voltage factor and time	1.9U <sub>n</sub> /8h
Rated continuous thermal current, I <sub>cont</sub>	3200 A
Rated short-time thermal current, I <sub>sh</sub> /1s	63 kA
Rated dynamic current, I <sub>dyn</sub>	158 kA

	1a-1n	2a-2n	3a-3n	da-dn
Rated secondary voltage [V]	110-√3	110-√3	110-√3	110
Rated output [VA]	25	25	25	150
Accuracy class	0.2	0.2	0.2/3P	3P
Thermal limiting output [VA]	1000	1000	1000	450



Winding	1S1-1S2	2S1-2S2	3S1-3S2	4S1-4S2
Rated secondary current [A]	5	1	5	1
Rated output [VA]	200	100	20	Rb=5Ω, class TPY 10x13, Rct<= 8Ω, Ts=500 ms, cy/d 100 ms, Tp=50 ms
Accuracy class	0.2	0.1	5P	
FS/ALF	10	5	60	

### 3. Technical documentation of the test object

1. Drawing No. 2GKK614815A1277 - Dimensional drawing combined instrument transformer PVA123a-PVA145a; ABB Sp. z o.o., approved 04.02.2016 - Appendix No. 1

### 4. Scope of the tests

Test program agreed with Orderer comprised of following tests:

No.	Kind of test	Tests according the Standard	Location of the test
1.	Temperature-rise tests	IEC 61869-1:2007 p. 6.4.i 7.2.2, IEC 61869-2:2012 p.6.4.i 7.2.2.204 IEC 61869-3:2011 p. 6.4.i i p.7.2.2 IEC 61869-4:2013 p. 6.4.i i 7.2.2 IEC 62271-1 :2007/A1:2011, table no. 3	EWP

EWP The test was performed in Institute of Power Engineering, by High - Current Laboratory.

342



5. Tests and their results

Combined transformer was installed at the test stand, as it was during normal operation. The rated voltage with a required value was applied to the primary voltage winding. The secondary voltage windings and the residual voltage winding were loaded with the suitable power, according to the test programme given below, which was agreed with the Orderer. Primary current terminals P1 and P2/A was bridged at the range of 3000 A. According to Manufacturer's request current in primary current winding was equal to  $I_{lab} = 3200A$ . The arrangement of the thermocouples is given in Figure 3. The temperature-rises of windings were measured by the resistance rise method. During the test, the measurements of loaded windings were made every 1-hour. The abstract of the protocol of temperature-rise test is given in Table 1. The summary of test results is given in Table 2.

The temperature-rise of windings were calculated from the follow formula:

$$\Delta t = \frac{R_x}{R_0} (234,5 + t_0) - 234,5 - t_1$$

- $R_0$  - resistance of winding in cold state
- $R_x$  - resistance of winding in warm state
- $t_0$  - temperature of winding in cold state
- $t_1$  - ambient temperature

Tests were performed according to the IEC 61869-1 sub-cl. 6.4 and 7.2.2; IEC 61869-2 sub-cl. 6.4.1 and 7.2.2.04; IEC 61869-3 sub-cl. 6.4.1 and 7.2.2; IEC 61869-4 sub-cl. 6.4.1 and 7.2.2.

Stage No. 1: Test at the rated load

The voltage value 1,2  $U_n = 91,5$  kV was applied to the P2/A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V; 2a-2n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V; 3a-3n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V; 4a-4n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V. The winding of residual voltage remained open. The secondary current windings were loaded as follows: 1S1-1S2  $\Rightarrow$  200 VA,  $\cos\phi = 1$ ; 2S1-2S2  $\Rightarrow$  100 VA,  $\cos\phi = 1$ ; 3S1-3S2  $\Rightarrow$  20 VA,  $\cos\phi = 1$ ; 4S1-4S2  $\Rightarrow$  50Ω. The test was performed till reached steady state of the measured temperatures.

Stage No. 2: Test of 8 h

The voltage value 1,9  $U_n = 144,8$  kV was applied to the P2/A terminal. The secondary voltage windings were loaded as follows: 1a-1n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V; 2a-2n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V; 3a-3n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V; 4a-4n  $\Rightarrow$  25 VA,  $\cos\phi = 1$ , at the voltage 110/√3 V. The residual winding da-dn was loaded by  $\Rightarrow$  450 VA,  $\cos\phi = 1$ , at the voltage 110 V. The secondary current windings were loaded as follows: 1S1-1S2  $\Rightarrow$  200 VA,  $\cos\phi = 1$ ; 2S1-2S2  $\Rightarrow$  100 VA,  $\cos\phi = 1$ ; 3S1-3S2  $\Rightarrow$  20 VA,  $\cos\phi = 1$ ; 4S1-4S2  $\Rightarrow$  50Ω. The duration of the test was 8 h.



Stage No. 3: Test with thermal limiting output

The voltage value  $U_n = 76,2$  kV was applied to the P2/A terminal. According to Manufacturers request secondary voltage windings (i.e. 1a-1n, 2a-2n, 3a-3n and 4a-4n) were loaded by limit power 1000 VA at  $\cos\phi = 1$ . The residual winding remained open. The secondary current windings were loaded as follows: 1S1-1S2  $\Rightarrow$  200 VA,  $\cos\phi = 1$ ; 2S1-2S2  $\Rightarrow$  100 VA,  $\cos\phi = 1$ ; 3S1-3S2  $\Rightarrow$  20 VA,  $\cos\phi = 1$ ; 4S1-4S2  $\Rightarrow$  50Ω. The test was performed till reaching the steady state of the measured temperatures.

Measuring equipment

The temperatures were measured by means of type K thermocouples (NiCr - NiAl) with accuracy  $\pm 0,6^\circ C$ . The ambient temperature was measured using four thermocouples type K immersed into tank filled with oil. These thermocouples were placed in the distance of 1 meter from the tested transformer at the height of 1 meter above floor - the accuracy of measurement  $\pm 0,6^\circ C$ . The resistance was measured by means of meter type 2291 manufactured by TETTEX Instruments with accuracy  $\pm 0,1$  mΩ.

**ABB**

**Combined Instrument Transformer**      Type      PVA 145a

Insulation level	145/27/5/650 kV	Standard	IEC 61869-4	$f_n$	50 Hz
Oil type	Nytrio 10XN	Weight/Oil weight	620 / 150 kg	Temp. range	-40°C → +40°C
S/N	2GKFD15K1689425	Voltage factor	1,9Un/8h	$U_n$	0,375 mV/A

---

**CURRENT PART**      **VOLTAGE PART**

$K_n$	1500-3000 / 5-1-5-1	A/A	A-N	132-√3	kV
$I_{th}/I_S$	63	kA	158	kA	
$I_{ch}$	3200	A			

	A	VA	class	FSALF	Est.%				
1S1-1S2	5	200	0,2	10	-		1a-1n	2a-2n	3a-3n
2S1-2S2	1	100	0,1	5	-		110-√3	110-√3	110-√3
3S1-3S2	5	20	5P	60	-		25	25	25
4S1-4S2	1						0,2	0,2	0,29P
							1000	1000	1000
							110-√3	110-√3	110-√3
							110	110	110
							0,29P	0,29P	0,29P
							3P	3P	3P
							1000	1000	1000
							450	450	450

$R_{th} = 5 \Omega$ ,  $k_{max} = 10 \times 10^3$ ,  $R_{ct} = 8 \Omega$   
 $I_{th} = 500$  mA,  $c_{yld} = 100$  mA,  $t_p = 50$  ms.

Transportation      Vertical / Horizontal

Fig. 1. Nameplate of tested combined instrument transformer

<sup>1</sup> The expanded uncertainty assigned corresponds to a coverage probability of 95 % and the coverage factor  $k = 2$ .




Fig. 2. Electrical diagram of terminal box of tested combined instrument transformer




Fig. 3. Arrangement of thermocouples during temperature-rise test:  
1 - oil (over current coil), 2 - head (contraction of the flange connecting the head the the insulator), 3 - under the flange of tank lid, 4 - lower tank (placed inside over earthing terminal), 5 - terminal P1, 6 - terminal P2/A (3000A), 7 - terminal P1, 8 - terminal P2/A (3000A), 9 - current path inside the combined instrument transformer.



Table 2. Temperature-rises given during the tests

		Temperature rise $\Delta T$ [K]	Limit [K]
Stage No. 1	Windings	1S1-1S2	65 <sup>1,2,3,4)</sup>
		2S1-2S2	
		3S1-3S2	
		4S1-4S2	
		P1-P2/A	
		1a-1n	
		2a-2n	
		3a-3n	
		4a-4n	
		da-dn	
		P2/A-N	
		Oil	
		Head	
		Under the flange of tank lid	
Stage No. 2	Windings	1S1-1S2	65+10 <sup>1,2,3,4)</sup>
		2S1-2S2	
		3S1-3S2	
		4S1-4S2	
		P1-P2/A	
		1a-1n	
		2a-2n	
		3a-3n	
		4a-4n	
da-dn			
P2/A-N			
Oil			
Head			
Under the flange of tank lid			
Lower tank			
Terminal P1			
Terminal P2/A			
Terminal P2/A			
Current path inside the combined instrument transformer			
Stage No. 2	Windings	1S1-1S2	65 <sup>1,2,3,4)</sup>
		2S1-2S2	
		3S1-3S2	
		4S1-4S2	
		P1-P2/A	
		1a-1n	
		2a-2n	
		3a-3n	
		4a-4n	
		da-dn	
		P2/A-N	
		Oil	
		Head	
		Under the flange of tank lid	
Lower tank			
Terminal P1			
Terminal P2/A			
Terminal P2/A			
Current path inside the combined instrument transformer			
Stage No. 3	Windings	1S1-1S2	65 <sup>1,2,3,4)</sup>
		2S1-2S2	
		3S1-3S2	
		4S1-4S2	
		P1-P2/A	
		1a-1n	
		2a-2n	
		3a-3n	
		4a-4n	
da-dn			
P2/A-N			
Oil			
Head			
Under the flange of tank lid			
Lower tank			
Terminal P1			
Terminal P2/A			
Terminal P2/A			
Current path inside the combined instrument transformer			

Table 2. Cont.

		Temperature rise $\Delta T$ [K]	Limit [K]
Stage No. 3	Windings	1S1-1S2	65 <sup>1,2,3,4)</sup>
		2S1-2S2	
		3S1-3S2	
		4S1-4S2	
		P1-P2/A	
		1a-1n	
		2a-2n	
		3a-3n	
		4a-4n	
		da-dn	
		P2/A-N	
		Oil	
		Head	
		Under the flange of tank lid	
Stage No. 3	Thermocouple No. 1	Thermocouple No. 1	55 <sup>1,2,3,4)</sup>
		Thermocouple No. 2	
		Thermocouple No. 3	
		Thermocouple No. 4	
		Thermocouple No. 5	
		Thermocouple No. 6	
		Thermocouple No. 7	
		Thermocouple No. 8	
		Thermocouple No. 9	
Current path inside the combined instrument transformer			

<sup>1)</sup> acc. to IEC 61869-1, <sup>2)</sup> wg IEC 61869-2, <sup>3)</sup> acc. to IEC 61869-3, <sup>4)</sup> acc. to IEC 61869-4,  
<sup>5)</sup> acc. to IEC 62271-1,



6. Summary

Results of the temperature-rise test for combined transformer type PVA145a with primary continuous thermal current  $I_{th}=3200A$  are as follows:

- in steady state, at the rated load of secondary voltage and current windings (without residual winding), and supply voltage  $1,2U_n$  (Stage No. 1), permitted temperature-rise limits were not exceeded.
- results of test 8 h at supply voltage  $1,9U_n$  and rated load of voltage and current windings and load of residual winding with thermal limiting output (Stage No. 2), shows that permitted temperature-rise limits were not exceeded.
- in steady state, results of test with thermal limiting output for voltage windings (without residual windings), rated load of current windings and supply voltage  $U_n$  (Stage No. 3), permitted temperature-rise limits were not exceeded.

The tested combined transformer met requirements of IEC 61869-1:2007, IEC 61869-2:2012, IEC 61869-3:2011, IEC 61869-4:2013 and IEC 62271-1:20007/A1:2011 standards.

6. Photographic documentation





Fig.4. Combined instrument transformer during temperature-rise test

347



Appendix No. 1



Appendix No. 2

**ABB**

**DECLARATION OF CONFORMITY No. 1112016 (EN)**  
(acc. to ISO/IEC 17050-1)

Manufacturer: **ABB**

Product: **Combined Instrument Transformer PVA145a**

Above mentioned product conforms with the following standard:

Standard: **IEC 61869-4**; Title: **Instrument Transformers - Part 4: Additional requirements for combined transformers**; Edition/Date: **2013**

Additional information: **2GKF015K1699425**;  
Serial numbers: **2GKF015K1699425**;


Place and date of issue of declaration  
Przasmysz 09.02.2016

Kierownik Operacji PPHY  
ABB Sp. z o.o.  
Dział Przemysłowy  
(Natomiast Dział)

Kierownik ds. Zastosowań i Jakości  
ABB Sp. z o.o.  
Dział W Przasmyzu  
Krzysztof Lubicki  
(Signature)

348





INSTITUTE OF POWER ENGINEERING  
Certification Department

INSTITUTE OF POWER ENGINEERING Report

Certification Department No DZC/36c/E/2013/2014

Author: mgr inż. Grażyna Wieczorek

2 / 11

**Contents:**

- 1. Introduction 3
- 2. List of applied documents 4
- 3. Testing laboratory competences 5
- 4. Test result list 5
  - 4.1. Type tests 5
  - 4.2. Routine tests 6
- 5. Summary 9

**APPENDIX – Type test reports and special test reports (pages not numbered)**

No DZC/36c/E/2013/2014  
Revision 2, 24.03.2015

**PRODUCT EVALUATION REPORT**

Product name and symbol: **HV combined instrument transformer, single-phase, outdoor, type: PVA 123a and PVA 145a**

None found

Non-conformities observed:

Supplier: **ABB Sp. z o.o., Oddział w Przasnyszu, ul. Leszno 59, 06-300 Przasnysz**

**General evaluation result:**

**Positive**  
Based on the analysis made, herewith I conclude for granting of compliance certificates to the HV combined instrument transformers, types: PVA 123a and PVA145a, with composite or ceramic insulator, manufactured by ABB Sp. z o.o., Oddział w Przasnyszu

Warsaw, March 2015

Grażyna Wieczorek

Full name

24 March 2015

date

## 1. Introduction

Report from evaluation of HV overhead, single-phase, current transformer series, types: PVA 123a and PVA 145a, manufactured by ABB Sp. z o.o., Oddział w Przasnyszu, developed during the certification process carried out by Zespół ds. Certyfikacji (Certification Team) upon manufacturer's application (contract No DZC/36c/E/2013 of the 23 October 2013)

This document concerns the new series of combined instrument transformers featuring design modifications and marked: PVA ...a.

The PVA 123a and PVA 145a combined instrument transformers are used for feeding measurement and protection systems in electric power grids with the highest system voltage of 126 kV or 145 kV and frequency of 50 Hz. Combined transformers consist of a current element and a voltage element located inside a common enclosure with a composite insulator (cover configuration: straight and spiral) or with a ceramic insulator filled with transformer oil.

The PVA transformer tests were carried out on selected representatives at the laboratories of Instytut Energetyki (Institute of Power Engineering) in Warszawa and Instytut Elektrotechniki Oddział w Gdańsku (Electrotechnical Institute, Gdańsk Branch) as well as (for product tests and deviation measurements) at the manufacturer's laboratory. The selection procedure included the most severe conditions resulting from the combined transformer design and occurring during the temperature-rise tests, short-circuit withstand, voltage and mechanical tests such as: values of continuous and short-circuit currents, winding wire size, different main circuits, winding power for measurement and protection, housing types, accuracy classes, etc. Tests were carried out on seven selected combined transformer prototypes. The results are valid for the entire transformer series acc. to the list as suggested for certification. Test results confirming the combined transformers features are listed in the reports in cl. 2 of this document. The test results were compared against requirements in the following standards:

- PN-EN 61869-1:2009  
Instrument transformers - Part 1: General requirements
- PN-EN 61869-2:2013-06  
Instrument transformers - Part 2: Detailed requirements for current transformers
- PN-EN 61869-3:2011  
Instrument transformers - Part 3: Detailed requirements for voltage transformers
- IEC 61869-4 Ed. 1.0  
Instrument transformers - Part 4: Additional requirements for combined transformers
- PN-EN 60529:2003  
Protection class provided by the housing (IP)

- PN-EN 62262:2003

Degrees of protection against external mechanical impacts as provided by electric device enclosures (IK coding)

Customer/manufacturer: ABB Sp. z o.o., Przasnysz holds the complex certificate for the following standards: ISO 9001:2008, ISO 14001:2004 and PN-N-18001:2004 - certificate No 0198 150.01.525 issued by TÜV Rheinland Polska Sp. z o.o.

## 2. List of applied documents

The combined transformers design and the test results were evaluated and analysed based on the following documents delivered by the Manufacturer and included in the reports:

- D1. Report No EWP/10/E/2014-1.e. Temperature-rise test High Current Laboratory, Warsaw, January 2014.
- D2. Report No EWP/10/E/2014-2.e. IEn. Temperature-rise test High Current Laboratory Warsaw, February 2014.
- D3. Report No EWP/55/E/2013-1.e. IEn. Temperature-rise tests, High Current Laboratory Warsaw, February 2014.
- D4. Report EUR/66/E/13-2 E. Mechanical tests Distribution Equipment Laboratory Warsaw, December 2013.
- D5. Report No EUR/66/E/13-1 E (Mechanical tests), IEn, Distribution Equipment Laboratory Warsaw, December 2013.
- D6. Report No EUR/71/E/13-3 E (Short-time current test, combined error measurement, test of strength against short-circuit in the secondary circuit), IEn, Distribution Equipment Laboratory Warsaw, January 2014.
- D7. Report No EUR/74/E/13 E Short-time current test, Test for composite error), IEn Distribution Equipment Laboratory Warsaw December 2013.
- D8. Report No EUR/71/E/13-1 E Short-time current test, IEn Distribution Equipment Laboratory Warsaw, January 2014.
- D9. Report No EUR/71/E/13-4 E Short-time current test, Test for composite error), IEn, Distribution Equipment Laboratory), Warsaw, January 2014.
- D10. Test report No EWN/145/E/13. Type tests, special tests and additional tests of combined transformers type PVA123a and PVA145a manufactured by ABB sp. z o.o.), IEn, High Voltage Laboratory Warsaw, January 2014.
- D11. Report No 8281/NZL/NBR/12. IP tests for terminal box IEL, Distribution Equipment Test Laboratory Warsaw, July 2012.
- D12. Report No EWP/55/E/2013-3e Mechanical impact test, IEn High Current Laboratory), Warsaw, February 2014.
- D13. Report No EUR/23/E/2014 E. Short-time current tests, IEn, Distribution Equipment Laboratory), Warsaw, May 2014.

4.1. Type tests, additional tests

The tests were made on selected PVA ...a combined transformer models (various rated currents for the PVA...a current elements, various main circuit designs, various design of PVA...a transformers secondary circuits, different accuracy classes and various insulation covers, etc.) The tests results are valid for the entire combined transformer series acc. to the list as suggested for certification. Table 1 shows manufacturer's solutions for the PVA...a current circuits. Representatives for short-circuit tests and heating tests were selected from that list.

PVA...a combined transformers were selected to temperature-rise test based on the most heat-exposed design solutions.

Voltage tests were made for two combined transformers: PVA 123a, and 145a.

The short-circuit withstand tests were made for PVA...a combined transformers. Representatives were selected based on their exposition to dynamic and thermal effects to the main circuits.

Table 2 shows carried out tests. Their scope meets requirements included in respective standards for: type tests, special tests, routine tests, and some additional requirements. Respective item numbers in PN-EN 61869 and IEC 61869 as well as report numbers with detailed test results are listed.

Results of all tests were positive.

4.2. Routine tests

Routine tests and accuracy class tests were carried out at the manufacturer's laboratory for all the combined transformers tested under the IEn supervision.

The tests included:

- oil measurements before filling the instrument transformer.
- verification of markings.
- power-frequency voltage withstand tests on primary terminals.
- power-frequency voltage withstand tests on secondary terminals.
- non-complete discharge intensity.
- inter-winding insulation test.
- test for accuracy.
- over-current coefficient determination.
- magnetisation characteristics determination.
- measurement of capacitance and dielectric dissipation factor.
- winding resistance measurement.

INSTITUTE OF POWER ENGINEERING Certification Department D13. Dimensional drawings: Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614122/ABB R&D_TS_KU568/13 (17.12.2013), R&D_TS_KU570/13 (17.12.2013), Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614123/ABB R&D_TS_KU570/13 (17.12.2013), Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614121/ABB R&D_TS_KU570/13 (17.12.2013), Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614123/ABB R&D_TS_KU571/13 (17.12.2013), Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614123/ABB R&D_TS_KU572/13 (17.12.2013), Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614120/ABB R&D_TS_KU569/13/A (17.12.2013), Dimensional drawing Combined instrument transformer PVA 123a-145a 2GKK614121/ABB R&D_TS_KU569/13 (17.12.2013).	Report No DZC/36c/E/2013/2014	page / pages 5 / 11
--	----------------------------------	------------------------

D13. Product test reports and accuracy check reports – see reports from D1+10 tests

D14. Rating plates – see reports from D1+10 tests

D15. Electrical diagrams – see reports from D1+10 tests

3. Testing laboratory competences

Type tests, product tests and special tests for PVA...a combined transformers were carried out at the following laboratories:

- Laboratorium Wysokich Napięć (High Voltage Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA No AB 272.
- Laboratorium Urządzeń Rozdzielczych (Distribution Equipment Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA No AB 324.
- Laboratorium Wieloprądowe (High Current Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA Nr AB 325.
- Laboratorium Fabryczne ABB Sp. z o.o. (ABB Manufacturing Plant Laboratory) in Przasnysz – Punkt Legalizacyjny OUM Warszawa (OUM Warsaw Verification Unit) – deviation measurement, and product tests under supervision of Instytut Energetyki (Institute of Power Engineering), Laboratorium Wysokich Napięć (High Voltage Laboratory).
- Laboratorium Badawcze Aparatury Rozdzielczej (Distribution Equipment Test Laboratory), a unit of Instytut Energetyki (Institute of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research Laboratory PCA No AB 074.



Test results were listed in protocols, their numbers being the same as that of the combined transformer tested. After the voltage tests and short circuit tests, additional routine tests and accuracy class tests were carried out.

Test result: positive

Table 1. Main circuit list:

Circuit design description	Current circuit assembly drawing number	Drawing title	10kV/10kV level assumed	Remarks	Tests carried out with 10kV/10kV current
Rod 400 Cu	ZGNK314130A0001	Main circuit, rod 400 Cu	63/58 kA	Prototype 2	P2 positive test
Rod 400 Al	ZGNK314131A0001	Main circuit, rod 400 Al	63/58 kA	Prototype 8	P8 positive test
Rod 400 Al + pipe 400x4 Al	ZGNK314132A0001	Main circuit, rod 400 Al + pipe 400x4 Al	63-67 / 158-158 kA	Prototype 8	P8 positive test
Rod 400 Al + pipe 400x4 Al + 2 turns of 240 mm <sup>2</sup> cable	ZGNK314133A0001	Main circuit, rod 400 Al + pipe 400x4 Al + 2 turns of 240 mm <sup>2</sup> cable	63-67-407 / 158-158-100 kA	Prototype 1	P1 positive test
1 turn of 240 mm <sup>2</sup> cable	ZGNK314134A0001	Main circuit, 1 turn of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 1	P1 positive test
2 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0002	Main circuit, 2 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 1	P1 positive test
3 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0003	Main circuit, 3 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 6	P6 positive test
4 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0004	Main circuit, 4 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 6	P6 positive test
5 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0005	Main circuit, 5 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 6	P6 positive test
6 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0006	Main circuit, 6 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 6	P6 positive test
7 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0007	Main circuit, 7 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 6	P6 positive test
8 turns of 240 mm <sup>2</sup> cable	ZGNK314134A0008	Main circuit, 8 turns of 240 mm <sup>2</sup> cable	40/100 kA	Prototype 6	P6 positive test
2+2 turns of 240 mm <sup>2</sup> cable	ZGNK314135A0001	Main circuit, 2+2 turns of 240 mm <sup>2</sup> cable	40-407 / 100-100 kA	Prototype 6	P6 positive test
3+3 turns of 240 mm <sup>2</sup> cable	ZGNK314135A0002	Main circuit, 3+3 turns of 240 mm <sup>2</sup> cable	40-407 / 100-100 kA	Prototype 6	P6 positive test
4+4 turns of 240 mm <sup>2</sup> cable	ZGNK314135A0003	Main circuit, 4+4 turns of 240 mm <sup>2</sup> cable	40-407 / 100-100 kA	Prototype 6	P6 positive test
2+3+4 turns of 240 mm <sup>2</sup> cable	ZGNK314135A0004	Main circuit, 2+3+4 turns of 240 mm <sup>2</sup> cable	40-407 / 100-100 kA	Prototype 6	P6 positive test
3 turns of 120 mm <sup>2</sup> cable	ZGNK314137A0001	Main circuit, 3 turns of 120 mm <sup>2</sup> cable	20/90 kA	Prototype 7	P7 positive test
6 turns of 120 mm <sup>2</sup> cable	ZGNK314137A0002	Main circuit, 6 turns of 120 mm <sup>2</sup> cable	20/90 kA	Prototype 7	P7 positive test
9 turns of 120 mm <sup>2</sup> cable	ZGNK314137A0003	Main circuit, 9 turns of 120 mm <sup>2</sup> cable	20/90 kA	Prototype 7	P7 positive test

12 turns of 120 mm <sup>2</sup> cable	ZGNK314137A0004	Main circuit, 12 turns of 120 mm <sup>2</sup> cable	20/90 kA	Prototype 7	P7 positive test
3+3 turns of 120 mm <sup>2</sup> cable	ZGNK314138A0001	Main circuit, 3+3 turns of 120 mm <sup>2</sup> cable	20-20 / 90-90 kA	Prototype 7	P7 positive test
6+6 turns of 120 mm <sup>2</sup> cable	ZGNK314138A0002	Main circuit, 6+6 turns of 120 mm <sup>2</sup> cable	20-20 / 90-90 kA	Prototype 7	P7 positive test
3+3+6 turns of 120 mm <sup>2</sup> cable	ZGNK314139A0001	Main circuit, 3+3+6 turns of 120 mm <sup>2</sup> cable	20-20-207 / 90-90-90 kA	Prototype 7	P7 positive test

Table 2. List of tests made for PYA...a combined instrument transformer

Item	Test type	Requirements	Report numbers
TYPE TESTS			
1	Short-time current test	IEC 61869-4, cl. 7.2.201 PN EN 61869-2, cl. 7.2.201	EUR/71/E/13-1 EUR/71/E/13-3 EUR/71/E/13-4 EUR/23/E/13
2	Temperature-rise test	IEC 61869-4, cl. 7.2.2 PN EN 61869-2, cl. 7.2.2 PN EN 61869-3, cl. 7.2.204	EW/10/E/2014-1 EW/10/E/2014-2 EW/35/E/2013-1 EW/07/E/2012-4
3	Impulse voltage withstand test	IEC 61869-4, cl. 7.2.3 PN EN 61869-1, cl. 7.2.3 PN EN 61869-3, item 7.2.3	EWN/145/E/13
4	Wet test	IEC 61869-4, cl. 7.2.4 PN EN 61869-1, cl. 7.2.4 PN EN 61869-3, cl. 7.2.4	EWN/145/E/13
5	Short-circuit withstand capability test	IEC 61869-4, cl. 7.2.301 PN EN 61869-3, item 7.2.301	EUR/71/E/13-3
6	Tests for accuracy and mutual influence test	IEC 61869-4, cl. 7.2.6.401, 7.2.6.402 and 7.3.5 PN EN 61869-2, cl. 7.2.6 PN EN 61869-3, cl. 7.2.6	EWN/145/E/13 and protocols from manufacturer's laboratory
7	RIV test	PN EN 61869-1, cl. 7.2.5.1	EWN/145/E/13
8	Test for composite error	PN EN 61869-2, cl. 7.2.6.203	EUR/71/E/13-3 EUR/71/E/13-4 EUR/23/E/14
9	Terminal box verification of the IP coding	PN EN 61869-1, cl. 7.2.7.1 PN EN 60529, cl. 13.14	8281/NZL/NBR/12
10	Mechanical impact test (IK)	PN EN 61869-1, cl. 7.2.7.1 PN EN 62272	EWP/35/E/2013-3
SPECIAL TESTS			
11	Chopped impulse voltage withstand test on primary terminals.	IEC 61869-4, cl. 7.4.1 PN EN 61869-1, cl. 7.4.1 PN EN 61869-3, cl. 7.4.1	EWN/145/E/13
12	Mechanical tests	IEC 61869-4, cl. 7.4.5 PN EN 61869-1, cl. 7.4.5	EUR/66/E/13-1 EUR/66/E/13-2
13	Transmitted overvoltage test	IEC 61869-4, cl. 7.4.4	

Rated dynamic current [I <sub>dyn</sub> ]	50 kA or 100 kA or 158 kA
Rated secondary current [I <sub>sc</sub> ]	1 A or 5 A
Core power to measurements and to protection (S)	1 VA – 200 VA
Measure core accuracy class (cl.)	0.1; 0.2; 0.2S; 0.5; 0.5S; 1; 3; 5
Protective core accuracy class (cl.)	5P; 10P; 5PR; 10PR; PX; PXR; TPX; TPY; TPZ
<b>Voltage element</b>	
Rated voltage factor [F <sub>v</sub> ] / time	1.5/30 sec; 1.9/30 sec or 1.9/8 h
Rated secondary voltage [U <sub>sc</sub> ]	100/√3 V; 110/√3 V;
Windings class to measurements and to protection (cl.)	0.1; 0.2; 0.5; 1; 3; 3P; 6P
Windings power to measurements and to protection (S <sub>t</sub> )	≤ 1,000 VA
Rated voltage of residual voltage winding [U <sub>vr(40-60)</sub> ]	100/3 V; 110/3 V; 100 V; 110 V
Residual voltage winding class (cl.)	0.5; 1; 3; 3P; 6P
Residual voltage winding power (S <sub>t</sub> )	≤ 450 VA
Total thermal limiting output [S <sub>tot</sub> ]	4,000 VA

**REMARKS:**

- 1) Applies to composite and ceramic insulators.
- 2) Do not apply to ceramic insulators.

**Table 3. List of technical data assigned to PVA 145a**

<b>Combined transformer type PVA 145a</b>	
Rated primary voltage [U <sub>pr</sub> ]	132/√3 kV
Highest voltage of combined transformer [U <sub>th</sub> ]	≤ 145 kV
Rated frequency [f <sub>r</sub> ]	50 Hz
Rated insulation level	AC 275 kV / LI 650 kV
Burden class	F <sub>R</sub> = 3,600 N
External insulation – creepage distance of insulator	3,640–4,495 mm <sup>1)</sup>
Degree of protection of secondary terminal enclosure	IP55
Degree of protection to mechanical impact of enclosure <sup>2)</sup>	IK7
<b>Current element</b>	
Rated primary current [I <sub>pr</sub> ]	50 A + 3,000 A
Extended current rating	up to 200%
Rated continuous thermal current [I <sub>th</sub> ]	≤ 3,000 A
Rated short-time thermal current [I <sub>sh</sub> ] during 1 sec	20 kA or 40 kA or 63 kA
Rated short-time thermal current [I <sub>sh</sub> ] during 3 sec	20 kA or 40 kA
Rated dynamic current [I <sub>dyn</sub> ]	50 kA or 100 kA or 158 kA
Rated secondary current [I <sub>sc</sub> ]	1 A or 5 A
Core power to measurements and to protection (S <sub>t</sub> )	1 VA – 200 VA
Measure core accuracy class (cl.)	0.1; 0.2; 0.2S; 0.5; 0.5S; 1; 3; 5
Protective core accuracy class (cl.)	5P; 10P; 5PR; 10PR; PX; PXR; TPX; TPY; TPZ
<b>Voltage element</b>	
Rated voltage factor [F <sub>v</sub> ] / time	1.5/30 sec; 1.9/30 sec or 1.9/8 h
Rated secondary voltage [U <sub>sc</sub> ]	100/√3 V; 110/√3 V;
Windings class to measurements and to protection (cl.)	0.1; 0.2; 0.5; 1; 3; 3P; 6P
Windings power to measurements and to protection (S <sub>t</sub> )	≤ 1,000 VA
Rated voltage of residual voltage winding [U <sub>vr(40-60)</sub> ]	100/3 V; 110/3 V; 100 V; 110 V
Residual voltage winding class (cl.)	0.5; 1; 3; 3P; 6P

Measurement of capacitance and dielectric dissipation factor	PN-EN 61869-1, cl. 7.4.4 PN-EN 61869-3, cl. 7.4.4 IEC 61869-4, cl. 7.4.3 PN-EN 61869-1, cl. 7.4.3 PN-EN 61869-2, cl. 7.4.3 PN-EN 61869-3, cl. 7.4.3	EWN/145/E/13 and protocols from manufacturer's laboratory
<b>ADDITIONAL TESTS</b>		
Capacitor discharge test	C = 6 μF U = 1.1 · √2 · 110/√3 kV No damage, no temperature increase above 65 K.	EWN/145/E/13

**5. SUMMARY**

- Based on the test results for selected representatives of PVA 123a and PVA 145a instrument transformer series as selected and based on analysis of the standards, it was determined that:
- All tests from the type test range, special tests and additional tests which were carried out were sufficient for a complete evaluation of the apparatuses.
- Instrument transformer errors tests and instrument transformer secondary circuit designs were analysed, and their metrological properties were confirmed.
- PVA 123a and PVA 145a instrument transformer main circuit designs were analysed. It was determined that the short-circuit tests and heating tests as carried out are binding for all design solutions.
- Tests were made according to requirements of the 61869 series standard (PN and IEC)
- Taken the test results under consideration, the technical data listed in Tables 3 and 4 may be referenced to the PVA 123a and PVA 145a instrument transformer series.
- This document may be a basis for issuing compliance certificates for PVA 123a and PVA 145a instrument transformer series manufactured by ABB Sp. z o.o. Oddział w Przasnyszu. The certificate validity date is suggested to be February 2017.

**Table 3. List of technical data assigned to PVA 123a**

<b>Combined transformer type PVA 123a</b>	
Rated primary voltage [U <sub>pr</sub> ]	110/√3 kV
Highest voltage of combined transformer [U <sub>th</sub> ]	≤ 126 kV
Rated frequency [f <sub>r</sub> ]	50 Hz
Rated insulation level	AC 230 kV / LI 550 kV
Burden class	F <sub>R</sub> = 3,600 N
External insulation – creepage distance of insulator	3,640–4,495 mm <sup>1)</sup>
Degree of protection of secondary terminal enclosure	IP55
Degree of protection to mechanical impact of enclosure <sup>2)</sup>	IK7
<b>Current element</b>	
Rated primary current [I <sub>pr</sub> ]	50 A + 3,000 A
Extended current rating	up to 200%
Rated continuous thermal current [I <sub>th</sub> ]	≤ 3,000 A
Rated short-time thermal current [I <sub>sh</sub> ] during 1 sec	20 kA or 40 kA or 63 kA
Rated short-time thermal current [I <sub>sh</sub> ] during 3 sec	20 kA or 40 kA

*[Handwritten signatures and initials]*

INSTITUTE OF POWER ENGINEERING	Report	page / pages
Certification Department	No DZC/36c/E/2013/2014	11 / 11
Residual voltage winding power [S]	≤ 450 VA	
Total thermal limiting output [S <sub>th</sub> ]	4.000 VA	
<b>REMARKS:</b>		

<sup>1)</sup> Applies to composite and ceramic insulators.  
<sup>2)</sup> Do not apply to ceramic insulators.

◆  
**APPENDIX**

**Type test reports, special test reports (pages not numbered)**

- D1. Report No EWP/10/E/2014-1e. Temperature-rise test High Current Laboratory. Warsaw. January 2014.
- D2. Report No EWP/10/E/2014-2e. IEn. Temperature-rise test High Current Laboratory Warsaw. February 2014.
- D3. Report No EWP/35/E/2013-1e. IEn. Temperature-rise tests. High Current Laboratory Warsaw. February 2014.
- D4. Report EUR/66/E/13-2 E). Mechanical tests Distribution Equipment Laboratory Warsaw. December 2013.
- D5. Report No EUR/66/E/13-1 E (Mechanical tests). IEn. Distribution Equipment Laboratory Warsaw, December 2013.
- D6. Report No EUR/71/E/13-3 E (Short-time current test, combined error measurement, test of strength against short-circuit in the secondary circuit). IEn. Distribution Equipment Laboratory Warsaw, January 2014.
- D7. Report No EUR/74/E/13 E Short-time current test. Test for composite error). IEn Distribution Equipment Laboratory Warsaw December 2013.
- D8. Report No EUR/71/E/13-1 E Short-time current test. IEn Distribution Equipment Laboratory Warsaw, January 2014.
- D9. Report No EUR/71/E/13-4 E Short-time current test. Test for composite error). IEn. Distribution Equipment Laboratory). Warsaw, January 2014.
- D10. Test report No EWN/145/E/13. Type tests, special tests and additional tests of combined transformers type PVA123a and PVA145a manufactured by ABB sp. z o.o.). IEn, High Voltage Laboratory Warsaw, January 2014.
- D11. Report No 8281/NZL/NBR/12. IP tests for terminal box. IEl. Distribution Equipment Test Laboratory Warsaw, July 2012.
- D12. Report No EWP/35/E/2013-3e Mechanical impact test. IEn High Current Laboratory). Warsaw, February 2014.
- D13. Report No EUR/23/E/2014 E. Short-time current tests. IEn. Distribution Equipment Laboratory). Warsaw, May 2014.

<b>ABB ABED</b>	ZCCO Corporate Research	9ADB008898
Issued by department ZCCO/Poland/SSST	Last edit date 2015-05-25	Revision 1.0
Customer ABB PLABB	Lang. English	Page 1/37
	Classification: Confidential	
Doc. title Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level.	Status of document Released	
Project name/ID SST activities - BU9953 - CHTET / 50005877	CR Program CHTET	
Main Author Grzegorz Juszkiewicz/PLCRC/SSST	Case ID: 15101	
Additional Author(s): Marcin Tamowski/PPHV, Pawel Grysztar/PLHV, Jaroslaw Duzdowski/PPHV, Dariusz Siperek/PPHV, Piotr Mikulski/PPHV, Przemyslaw Naslerowski/PPHV Piotr Saj/PLCRC, Marek Florowski/PLCRC		
Keywords simulation, FE method, seismic analysis, frequency modes, response spectrum	Final Approval Date: 2015-05-21	
Approved by: Tomasz_Naszeret Rev.1.0		

Electronic document

# Technical report

Simulation Support Team

Case submitted by	Marcin Tamowski
Business Unit	PPHV
Type of analysis (used tool)	ABAQUS (seismic analysis)
Description of analysis	Seismic analysis different variants of current, voltage and combined transformers (PA123a / PA145a, PV123, PVA123a / PVA145a) according to guidelines described in IEC standard. Consideration of seismic, wind, and dead loads.

## Executive summary

This report covers investigation related to seismic analysis of HV Instrument transformers (PV123, PA123a/PA145a, PVA123a/PVA145a) subjected to various load scenarios. Simulation covered the following load conditions: dead load, wind load, terminal force load, seismic load (AF5 - 0.5 g). Analysis showed that all designs are satisfying required safety criteria.

<b>ABB ABED</b>	ZCCO Corporate Research	9ADB008898
Doc. title Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	Revision 1.0	Page 2/37

## TABLE OF CONTENTS

1 INTRODUCTION .....	4
2 SIMULATION SOFTWARE .....	4
3 SIMULATION SETUP .....	4
3.1 SIMULATION PROCEDURE .....	4
3.2 SIMULATION STEPS .....	4
3.2.1 Natural frequency extraction .....	4
3.2.2 Response spectrum analysis .....	5
3.3 LOADS AND BOUNDARY CONDITIONS .....	6
3.3.1 Loads .....	6
3.3.2 Boundary conditions .....	7
3.4 ACCEPTANCE CRITERIA .....	8
3.5 CURRENT TRANSFORMER - PA 123A/PA 145A .....	8
3.5.1 Model simplifications .....	8
3.6 MATERIAL AND MASS INFORMATION .....	10
3.7 FINITE ELEMENT (FE) MODEL .....	11
3.8 VOLTAGE TRANSFORMER - PV 123 .....	11
3.8.1 Model simplifications .....	11
3.9 MATERIAL AND MASS INFORMATION .....	13
3.10 FINITE ELEMENT (FE) MODEL .....	14
3.11 COMBINED TRANSFORMER - PVA123A/PVA145A .....	14
3.11.1 Model simplifications .....	14
3.12 MATERIAL AND MASS INFORMATION .....	14
3.13 FINITE ELEMENT (FE) MODEL .....	17
4 SIMULATION RESULTS .....	18
4.1 PA123A/PA145A .....	18
4.1.1 Natural frequency extraction .....	18
4.1.2 Dynamic analysis .....	20
4.2 PV 123 .....	24
4.2.1 Natural frequency extraction .....	24
4.2.2 Dynamic analysis .....	26
4.3 PVA123A/PVA145A .....	29
4.3.1 Natural frequency extraction .....	30
4.3.2 Dynamic analysis .....	30
5 CONCLUSIONS .....	33
6 BIBLIOGRAPHY .....	34
7 CHANGE HISTORY .....	34
8 APPENDICES .....	35

356

<b>ABB</b>		<b>ZCCO</b>		<b>9ADB008898</b>	
Doc. title		Corporate Research		Revision	
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level				1.0	
				Page	
8.1	CURRENT INSTRUMENT TRANSFORMER PA123A/PA145A			35	
8.2	VOLTAGE INSTRUMENT TRANSFORMER PV123			36	
8.3	COMBINED INSTRUMENT TRANSFORMER PVA123A/PVA145A			37	

<b>ABB</b>		<b>ZCCO</b>		<b>9ADB008898</b>	
Doc. title		Corporate Research		Revision	
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level				1.0	
				Page	
<b>1 INTRODUCTION</b>				4/37	

## 1 INTRODUCTION

The goal of the analysis was to evaluate seismic performance of PA123a /PA145a (see 8.1), PV123 (see 8.2), PVA145a/PVA123a (8.3) type transformers. Simulation was done using guidelines of IEC TR 62271-300 standard. For more information please see [1].

Computations concerned evaluation of stress field distribution and maximum bending moment between flange and insulator. Present report describes used simulation technique, analysis steps, loads and boundary conditions variations and summarizes obtained results.

## 2 SIMULATION SOFTWARE

All simulations were performed using Abaqus/CAE package. Abaqus includes FEM (finite element method) solver, pre- and post processor and enables performing many types of multiphysics simulations: mechanical, thermal, acoustic, piezoelectric, seismic, and others.

Parts and assemblies can be created in Abaqus, or they can be imported from CAD systems using native file formats. Abaqus functionality enables to define materials, interactions, loads, boundary conditions, mesh. User is also available to set up simulation parameters such as pre-processing memory. It is always possible to change all simulation settings and properties, because they're all parameterized.

Simulation results can be visualized in Abaqus postprocessor or in external software, which is able to import simulation results in Abaqus format. In postprocessor user can view all predefined field outputs, show or hide part instances, create cross-sections, make animations, automatically generate reports, diagnose model (warnings, errors). For more information about ABAQUS please see [2].

## 3 SIMULATION SETUP

Analysis has been made using Finite Element Method.

### 3.1 Simulation procedure

According to [1] analysis included three main simulation steps:

- Static load:
  - Wind load.
  - Terminal load.
  - Gravitational load.
- Natural frequency extraction.
- Dynamic analysis.

### 3.2 Simulation steps

Simulation consisted of three main simulation steps.

#### 3.2.1 Natural frequency extraction

In the first simulation step natural frequency extraction was performed. The frequency extraction procedure performs eigenvalue extraction to calculate the natural frequencies and the corresponding mode shapes of a system.



<b>ABB</b> <b>AFDID</b>	ZCCO Corporate Research	9ADB008898	Page 5/37
Doc. title	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		Revision 1.0

The eigenvalue problem for the natural frequencies of an undamped finite element model can be described by equation (3-1):

$$(-\omega^2 M^{MN} + K^{MN}) \phi = 0 \quad (3-1)$$

where:  $M^{MN}$  – mass matrix (kg);  $K^{MN}$  – stiffness matrix (Pa), which includes initial stiffness effects if the base state (gravitational load);  $\phi$  – eigenvector (the mode of vibration);  $M, N$  – degrees of freedom (-). Based on specification [1] one can assume that most critical frequency modes are in range of 0-35 Hz.

### 3.2.2 Response spectrum analysis

The response spectrum method is a convenient way of describing shock motion in terms of the maximum response of a single degree of freedom (1-DOF) oscillator of arbitrary natural period and damping ratio. Each data point of the response spectrum curve represents the peak response from a time history analysis of the earthquake applied to 1-DOF oscillator system. The ordinate defines the natural period at which the oscillator is tuned. Repeating the procedure for a great many frequencies defines a continuous curve for an assumed level of damping.

A spectral response analysis estimates the maximum displacement of the structure during a 'design' shock load without recourse of direct integration. Finite element implementation of the response spectrum calculate the response of each mode independent, and then combine the scaled response one of a number of established combination rules, to give an estimate of peak response. Spectrum plot used in simulation is presented in Figure 1.




Figure 1. Design response spectrum – 2% damping (red curve)

<b>ABB</b> <b>AFDID</b>	ZCCO Corporate Research	9ADB008898	Page 6/37
Doc. title	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		Revision 1.0

### 3.3 Loads and boundary conditions

#### 3.3.1 Loads

The following static load scenarios have been considered

1. Gravitational load,  $g=9.81 \text{ m/s}^2$ .
2. Terminal operating load, acc. to [3]. According to Table 14, page 90 terminal force are adequate to rated voltage and current level. Applied force values were the following:
  - a. PA123a /PA145a: Longitudinal force-1250 N, Transversal force – 1000 N, Vertical force – 1250 N.
  - b. PV123: Longitudinal force-1750 N, Transversal force – 1250 N, Vertical force – 1500 N.
  - c. PVA123a/PVA145a: Longitudinal force-1750 N, Transversal force – 1250 N, Vertical force – 1500 N.
3. Wind load, 10m/s load. Wind load has been represented as directional pressure evaluated according to drag force equation:

$$F_D = \frac{1}{2} \rho u^2 C_D A \quad (3-1)$$

where:  $F_D$  – drag force [N],  $\rho$  – mass density of the fluid [ $\text{kg/m}^3$ ],  $u$  – flow velocity [m/s],  $A$  – reference area [ $\text{m}^2$ ],  $C_D$  – drag coefficient [-].

Evaluated pressure level for all designs was ca.  $p=71 \text{ Pa}$ .

Seismic load have been predefined according design response spectrum described in the standard [1] – ground acceleration reference AF5. Main input parameters were the following:


- XZ base motion with vertical load equal to 50% of horizontal direction.
- YZ base motion with vertical load equal to 50% of horizontal direction.
- Damping ratio – 2% ([1], page 23, chapter 7.3.2 point b).

As the final outcome from the analysis static loads were combined with the most conservative seismic load.

#### 3.3.2 Boundary conditions

Simulation assumes that the apparatus will be mounted on ground. An example of boundary conditions is presented in

During analysis model has been fixed at the bottom face of used test frame. General view of static loads and boundary conditions is presented in Figure 2. Area highlighted by red has been constrained (Y-rotation released). Base of the bottom tank has been supported in Y direction (as it is placed on the ground). Described boundary conditions have been used for all analyzed models.

 Doc. title	ZCCO Corporate Research	Revision 1.0	Page 7/37
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level			





Figure 2. Boundary conditions – general view

### 3.4 Acceptance criteria

- According to [1] the following acceptance criteria shall be met
- Stresses observed at metallic parts should not exceed yield point of material.
  - The maximum bending moment of the insulator should not exceed ultimate value. For more information please refer to [4] ( Table 1, page 23).

 Doc. title	ZCCO Corporate Research	Revision 1.0	Page 8/37
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level			

### 3.5 Current transformer - PA 123a/PA 145a

This chapter gathers details related to FE model of current transformer PA 123a/PA 145a.

#### 3.5.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 3. Red point indicates center of mass of the transformer.




Figure 3. Simplified representation of the PA 123a/PA 145a transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

### 3.6 Material and mass information

Component naming is presented in Figure 4.




Figure 4. Assembly – component naming

Material and mass information is listed in Table 1

Table 1. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKA310015	Base J123	EN-AC 43200 (grade F)	16.5	69000	80	160
2GKA310404	Insulator	Porcelain	71	100000	140	
	Insulator - Flange	EN-AC 43200 (grade F)	3.5	69000	180	220
2GKA414718	Head	EN-AC 43200 (grade F)	22.5	69000	80	160
2GKK314089	Head cover	EN-AC 43200 (grade F)	20	69000	80	160
	Coil		150			
2GKK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		120			

The maximum allowable bending moment for ceramic insulator is equal to  $M_p=13.3$  kNm.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. © 2015 ABB Ltd.

### 3.7 Finite element (FE) model

General view of FE model is presented in Figure 5.




Figure 5. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 533430
- Total number of elements: 242866
  - 210555 quadratic tetrahedral elements of type C3D10
  - 31050 quadratic hexahedral elements of type C3D20R
  - 1243 quadratic quadrilateral elements of type S8R
  - 18 quadratic triangular elements of type STRI65

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898	Page
Doc. title		Revision	
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		1.0	11/37

### 3.8 Voltage transformer - PV 123

This chapter gathers details related to FE model of voltage transformer PV 123.

#### 3.8.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 6. Red point indicates center of mass of the transformer.




Figure 6. Simplified representation of the PV 123 transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

### 3.9 Material and mass information

Component naming is presented in Figure 7.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898	Page
Doc. title		Revision	
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		1.0	12/37





Figure 7. Assembly - component naming

Material and mass information is listed in Table 2.

Table 2. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GK310150P	Bottom tank	EN-AC 43200 (grade F)	25	69000	80	160
2GK310147P	Core	Steel	22.5	206000	300	370
2GK314005	Tank cover	EN-AC 43200 (grade F)	15.5	69000	80	160
2GK4310404	Insulator	Porcelain	71	100000	140	
	Insulator flange	EN-AC 43200 (grade F)	3.5	69000	180	220
	Coil	-	30			
2GK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		80			

The maximum allowable bending moment for ceramic insulator is equal to  $M_B=13.3 \text{ kNm}$ .

	<b>ZCCO</b> Corporate Research	9ADB008898	Page
			Revision
Doc. title	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		13/37
		1.0	

### 3.10 Finite element (FE) model

General view of FE model is presented in Figure 8.




Figure 8. FE model – general view

Mesh statistics were the following:


- Total number of nodes: 608507
- Total number of elements: 236033
  - 4806 quadratic quadrilateral elements of type S8R
  - 58 quadratic triangular elements of type STR165
  - 58965 quadratic hexahedral elements of type C3D20R
  - 8577 linear hexahedral elements of type C3D8R
  - 163827 quadratic tetrahedral elements of type C3D10

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ADIP Ltd.




	<b>ZCCO</b> Corporate Research	9ADB008898	Page
			Revision
Doc. title	Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		14/37
		1.0	

### 3.11 Combined transformer – PVA123a /PVA145a

This chapter gathers details related to FE model of combined transformer PVA123a /PVA145a.

#### 3.11.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 9. Red point indicates center of mass of the transformer.




Figure 9. Simplified representation of the PVA123a /PVA145a transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

#### 3.12 Material and mass information

Component naming is presented in Figure 7.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ADIP Ltd.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	1.0	15/37





Figure 10. Assembly – component naming  
Material and mass information is listed in Table 3.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	1.0	16/37

Table 3. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK314076	Tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK314084	Core	Steel	33.8	206000	300	370
2GKK314075	Tank cover	EN-AC 43200 (grade F)	18	69000	80	160
2GKK314070	Insulator	Porcelain	131	100000	140	
	Insulator flange	EN-AC 43200 (grade F6)	5	69000	180	220
2GKK314080	Head	EN-AC 43200 (grade F)	23.5	69000	80	160
2GKK314089	Head cover PVA-PA123a / PA1145a-145	EN-AC 43200 (grade F)	23	69000	80	160
2GKK310902	Bellow	Stainless steel	5	190000	200	500
2GKK310014P	Below enclosure	EN-AC 43200 (grade F)	7	69000	80	160
-	Voltage coil	-	30	-	-	-
-	Current coil	-	150	-	-	-
2GKK310802	Epoxy insulator	-	2.5	-	-	-
2GKK31098R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
-	Oil	-	150	-	-	-

The maximum allowable bending moment for ceramic insulator is equal to  $M_B=13.3 \text{ kNm}$ .

	<b>ZCCO</b> Corporate Research	9ADB008898	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	17/37
		Revision	1.0	

### 3.13 Finite element (FE) model

General view of FE model is presented in Figure 11.




Figure 11. FE model – general view


Mesh statistics were the following:


- Total number of nodes: 1009580
- Total number of elements: 463007
  - 58507 quadratic hexahedral elements of type C3D20R
  - 300489 quadratic tetrahedral elements of type C3D10
  - 2519 linear quadrilateral elements of type S4R
  - 97 linear triangular elements of type S3
  - 9900 linear hexahedral elements of type C3D8R
  - 528 quadratic wedge elements of type C3D15
  - 90967 quadratic tetrahedral elements of type C3D10M

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015, ABB Ltd.

	<b>ZCCO</b> Corporate Research	9ADB008898	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	18/37
		Revision	1.0	

## 4 SIMULATION RESULTS

This chapter gathers simulation results evaluated in the analysis. Obtained outcome includes static and the most conservative (design) seismic load.

### 4.1 PA123a /PA145a

#### 4.1.1 Natural frequency extraction

Effective modal mass plot is presented Figure 12. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 6.9 – 8.2 Hz.




Figure 12. Natural frequency extraction – effective modal mass

Effective modes and associated with the shapes are presented in Figure 13.

364

<b>ABB</b>	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	1.0	19/37




Figure 13. Natural frequency extraction - mode shapes  
Summary of modal mass participation is listed in Table 4.

Table 4. Modal mass participation - summary

Mode no	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	6.9	40%	0%	35%
2	8.2	34%	0%	40%
3	38.9	2%	0%	6%
4	39.7	6%	0%	2%
5	46.9	0%	0%	0%
6	98.7	0%	89%	0%
7	129.2	0%	0%	2%
8	150.3	4%	0%	0%
9	166.6	0%	0%	4%
10	167.4	2%	0%	0%

<b>ABB</b>	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	1.0	20/37

#### 4.1.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 14 and Figure 15. Stress scale has been limited to 80 MPa as the maximum allowable stress level.





Figure 14. Von-Mises stress [Pa] distribution - tank (view 01)






Figure 15. Von-Mises stress [Pa] distribution - tank (view 02)

Displacement field is presented in Figure 16.




Figure 16. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=4848 \text{ Nm}$ .
- $M_y=7476 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition. One can observe that stresses evaluated at the base are slightly above yield point of material. Therefore small yielding may occur. One must have in mind that analysis did not cover possible casting imperfections. Design has been also verified according to AF5 seismic level (0.3 g Zero Period Acceleration). Stress distribution for such load scenario is presented from Figure 17 to Figure 18. Obtained stress level was significantly below yield point of material.

365.

<b>ABIB</b>	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers, IEC 62271-300 - AF5 seismic level	1.0	23/37

S. Mises	1.00E+08
Max	1.00E+08
Min	0.00E+00
Avg	1.00E+07
Std	1.00E+07
Max	1.00E+08
Min	0.00E+00
Avg	1.00E+07
Std	1.00E+07




Figure 17. Von-Mises stress [Pa] distribution (AF3) – tank (view 01)

S. Mises	1.00E+08
Max	1.00E+08
Min	0.00E+00
Avg	1.00E+07
Std	1.00E+07
Max	1.00E+08
Min	0.00E+00
Avg	1.00E+07
Std	1.00E+07




Figure 18. Von-Mises stress [Pa] distribution (AF3) – tank (view 02)

<b>ABIB</b>	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers, IEC 62271-300 - AF5 seismic level	1.0	24/37

4.2 PV 123

4.2.1 Natural frequency extraction

Effective modal mass plot is presented Figure 19. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 24,7–25,3 Hz.




Figure 19. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 20.




Figure 20. Natural frequency extraction – mode shapes

Summary of modal mass participation is listed in Table 5.

Table 5. Modal mass participation – summary

Mode no.	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	24.7	24%	0%	0%
2	25.2	0%	0%	24%
3	25.4	0%	0%	0%
4	26.5	0%	0%	0%
5	135.5	37%	0%	0%
6	139.3	0%	0%	36%
7	161.3	0%	34%	0%
8	162.4	0%	0%	0%
9	175.8	0%	0%	0%
10	176.2	0%	0%	0%

4.2.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 21 and Figure 22. As described in chapter 3.8.1 location of center of mass is close to the ground level, therefore expected bending moment and so the stress was low. One can see that the maximum stress level reached ca. 30 MPa and it was located at vicinity of coupling constraint. Stress level satisfies required safety condition.




Figure 21. Von-Mises stress [Pa] distribution – tank (view 01)

*[Handwritten signature]*

368

<b>ABB</b> <b>ABB</b>	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	1.0	27/37

0. Min	1.0
1. Max	2.0
2. Min	3.0
3. Max	4.0
4. Min	5.0
5. Max	6.0
6. Min	7.0
7. Max	8.0
8. Min	9.0
9. Max	10.0
10. Min	11.0
11. Max	12.0
12. Min	13.0
13. Max	14.0
14. Min	15.0
15. Max	16.0
16. Min	17.0
17. Max	18.0
18. Min	19.0
19. Max	20.0
20. Min	21.0
21. Max	22.0
22. Min	23.0
23. Max	24.0
24. Min	25.0
25. Max	26.0
26. Min	27.0
27. Max	28.0
28. Min	29.0
29. Max	30.0
30. Min	31.0
31. Max	32.0
32. Min	33.0
33. Max	34.0
34. Min	35.0
35. Max	36.0
36. Min	37.0
37. Max	38.0
38. Min	39.0
39. Max	40.0
40. Min	41.0
41. Max	42.0
42. Min	43.0
43. Max	44.0
44. Min	45.0
45. Max	46.0
46. Min	47.0
47. Max	48.0
48. Min	49.0
49. Max	50.0
50. Min	51.0
51. Max	52.0
52. Min	53.0
53. Max	54.0
54. Min	55.0
55. Max	56.0
56. Min	57.0
57. Max	58.0
58. Min	59.0
59. Max	60.0
60. Min	61.0
61. Max	62.0
62. Min	63.0
63. Max	64.0
64. Min	65.0
65. Max	66.0
66. Min	67.0
67. Max	68.0
68. Min	69.0
69. Max	70.0
70. Min	71.0
71. Max	72.0
72. Min	73.0
73. Max	74.0
74. Min	75.0
75. Max	76.0
76. Min	77.0
77. Max	78.0
78. Min	79.0
79. Max	80.0
80. Min	81.0
81. Max	82.0
82. Min	83.0
83. Max	84.0
84. Min	85.0
85. Max	86.0
86. Min	87.0
87. Max	88.0
88. Min	89.0
89. Max	90.0
90. Min	91.0
91. Max	92.0
92. Min	93.0
93. Max	94.0
94. Min	95.0
95. Max	96.0
96. Min	97.0
97. Max	98.0
98. Min	99.0
99. Max	100.0




Figure 22. Von-Mises stress [Pa] distribution – tank (view 02)  
Displacement field is presented in Figure 23.

<b>ABB</b> <b>ABB</b>	ZCCO Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	1.0	28/37




Figure 23. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:


- $M_x=2079$  Nm.
- $M_z=2263$  Nm.

Insulator has satisfied the maximum bending moment condition.

**4.3 PVA123a /PVA145a**

**4.3.1 Natural frequency extraction**

Effective modal mass plot is presented Figure 24. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 3.8–4.1 Hz.




**Figure 24. Natural frequency extraction – effective modal mass**

Effective modes and associated with the shapes are presented in Figure 25.



*[Handwritten signature]*



**Figure 25. Natural frequency extraction – mode shapes**

Summary of modal mass participation is listed in Table 6.

**Table 6. Modal mass participation – summary**

Mode no.	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	3.8	35%	0%	32%
2	4.1	32%	0%	35%
3	22.4	7%	0%	0%
4	23.2	0%	2%	8%
5	26.5	0%	95%	0%
6	29.2	0%	0%	1%
7	29.3	1%	0%	0%
8	34.6	10%	0%	0%
9	35.5	0%	0%	8%
10	35.2	0%	0%	3%

**4.3.2 Dynamic analysis**

Stress distribution for tank component is presented in Figure 26 and Figure 27. One can see that the maximum stress level reached ca. 70 MPa. Stress level satisfies required safety condition.

370

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	1.0	31/37




Figure 26. Von-Mises stress [Pa] distribution - tank (view 01)




Figure 27. Von-Mises stress [Pa] distribution - tank (view 02)

Displacement field is presented in Figure 23.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB008898
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level	1.0	32/37





Figure 28. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=6864 \text{ Nm}$ .
- $M_z=7752 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition.

	<b>ZCCO</b> Corporate Research	9ADB008898	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	33/37

## 5 CONCLUSIONS

The goal of the analysis was to investigate family of HV Instrument Transformers using guidelines described in IEC 62271-300. Based on performed analysis main conclusions are the following:


- Current transformer PA 123a/PA 145a. This design has been investigated for two seismic levels: AF5 (0.5 g) and AF3 (0.3 g). For AF5 level stresses were above yield strength of material. These concentrations can be caused by sharp edges which are usually eliminated in real casting process. On the other hand one must have in mind that possible material imperfection were not considered in the simulation. For AF3 load scenario stresses were below yield strength of material. Bushing has satisfied required safety factor for both load scenarios.
- Voltage transformer - PV 123. Seismic level – AF5. Center of mass for this particular design is very close to the ground level. Therefore obtained level of stress and so bending moment was relatively low. Design satisfies required safety factors for AF5 seismic level.
- Combined transformer PVA 123a/PVA 145a. Seismic level – AF5. Obtained stress level was below yield strength of material. Bending moment was also below ultimate value. Whole design should be considered as safe.
- Damping factor used in the analysis was equal to 2%.
- Transformer oil has been modeled as uniformly distributed additional mass.

## Disclaimer

The analysis documented herein has been prepared in accordance with reasonable standards of scientific endeavor and the best knowledge of the author(s).

The simulation results may depend on a variety of factors, including quality of input data, applied model simplifications and chosen numerical methods.




	<b>ZCCO</b> Corporate Research	9ADB008898	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level	34/37


## 6 BIBLIOGRAPHY

- [1] TR 62271-300 – High voltage switchgear and controlgear – Part 300: Seismic qualification and alternating current circuit breakers, Technical report. First edition: 2006-11
- [2] ABAQUS, ABAQUS 6.13 Documentation, DS Simulia, USA, [www.simulia.com](http://www.simulia.com)
- [3] IEC 62271-100 – High voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers, Technical report. Edition 2.0: 2008-04
- [4] IEC 62155-100 – Hollow pressurized and unpressurized ceramic and glass insulators for use in electrical equipment with rated voltages greater than 1 000 V, International standard. First edition: 2003-05

## 7 CHANGE HISTORY


Date	Revision	Author(s)	Change
2015-05-22	Rev. 1	Juszkiewicz Grzegorz	original document

372


	<b>ZCCO</b> Corporate Research	9ADB008898
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		
1.0 35/37		

**8 APPENDICES**


**8.1 Current instrument transformer PA123a/PA145a**



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.


	<b>ZCCO</b> Corporate Research	9ADB008898
Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AF5 seismic level		
1.0 36/37		


**8.2 Voltage instrument transformer PV123**



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.



	<p style="text-align: center;"><b>ZCCO</b> Corporate Research</p>	<p style="text-align: center;">9ADB008898</p>
<p>Doc. title</p>	<p style="text-align: center;">Revision</p>	<p style="text-align: center;">Page</p>
<p>Seismic analyses of HV Instrument Transformers. IEC 62271-300 - AFS seismic level</p>		<p style="text-align: center;">1.0</p>
<p>8.3 Combined instrument transformer PVA123a /PVA145a</p>		<p style="text-align: center;">37/37</p>



*[Handwritten signature]*

Who reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

*[Handwritten signature]*

C.

C.

<b>ABB ABID</b>	ZCCO Corporate Research	9ADB009045
Issued by department ZCCO/Poland/SST	Language English	Revision 1.0
Customer ABB PLABB	Last edit date 2015-08-17	Page 1/38
Classifier Confidential		
Doc. title Seismic analyses of HV Instrument Transformers. IEEE 693- High (0.5g)/moderate(0.25g) seismic level		
Project name/ID Simserv_PPHV_Przasnysz_15172/50005903	CR Program CHTET	
Main Author Grzegorz Juszkiewicz/PLCRC/SST	Case ID 15172	
Additional Author(s) Marcin Tamowski/PPHV, Pawel Gryzta/PPHV, Jaroslaw Duzdowski/PPHV, Dariusz Sperek/PPHV, Piotr Milkuski/PPHV, Przemyslaw Nasierowski/PPHV Piotr Saj/PLCRC, Marek Florowski/PLCRC		
Keywords simulation, FE method, seismic analysis, frequency modes, response spectrum		
Approved by: Technical_Note/08 Rev 1.0	Final Approval Date: 2015-08-17	

## Electronic document

# Technical report

Simulation Support Team

Case submitted by	Marcin Tamowski
Business Unit	PPHV
Type of analysis (used tool)	ABAQUS (seismic analysis)
Description of analysis	Seismic analysis different variants of current, voltage and combined transformers (PA123a/PA145a, PV123, PVA123a/PVA145a) according to guidelines described in IEEE 693 standard. Consideration of seismic and dead loads.

### Executive summary

This report covers investigation related to seismic analysis of HV instrument transformers (PV123, PA123a/PA145a, PVA123a/PVA145a) subjected to various load scenarios. Simulation covered the following load conditions: dead load, terminal force load, seismic load (Moderate - 0.25g; High - 0.5g). Analysis showed that designs: PA123a/PA145a and PVA123a/PVA145a can withstand moderate seismic level, while PV123 can withstand high seismic load scenario.

<b>ABB ABID</b>	ZCCO Corporate Research	9ADB009045
Doc. title Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	Revision 1.0	Page 2/38

## TABLE OF CONTENTS

1	INTRODUCTION	4
2	SIMULATION SOFTWARE	4
3	SIMULATION SETUP	4
3.1	SIMULATION PROCEDURE	4
3.2	SIMULATION STEPS	4
3.2.1	Natural frequency extraction	4
3.2.2	Response spectrum analysis	5
3.3	LOADS AND BOUNDARY CONDITIONS	6
3.3.1	Loads	6
3.3.2	Boundary conditions	6
3.4	ACCEPTANCE CRITERIA	7
3.5	CURRENT TRANSFORMER - PA 123A/PA 145A	8
3.5.1	Model simplifications	8
3.6	MATERIAL AND MASS INFORMATION	8
3.7	FINITE ELEMENT (FE) MODEL	10
3.8	VOLTAGE TRANSFORMER - PV 123	11
3.8.1	Model simplifications	11
3.9	MATERIAL AND MASS INFORMATION	11
3.10	FINITE ELEMENT (FE) MODEL	13
3.11	COMBINED TRANSFORMER - PVA123a/PVA145a	14
3.11.1	Model simplifications	14
3.12	MATERIAL AND MASS INFORMATION	14
3.13	FINITE ELEMENT (FE) MODEL	17
4	SIMULATION RESULTS	18
4.1	PA123a/PA145a	18
4.1.1	Natural frequency extraction	18
4.1.2	Dynamic analysis	20
4.2	PV 123	23
4.2.1	Natural frequency extraction	23
4.2.2	Dynamic analysis	25
4.3	PVA123a/PVA145a	27
4.3.1	Natural frequency extraction	27
4.3.2	Dynamic analysis	29
5	CONCLUSIONS	34
6	BIBLIOGRAPHY	35
7	CHANGE HISTORY	35
8	APPENDICES	36

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

376

<b>ABR ABR</b>		<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>
Doc. title		Revision	
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		1.0	3/38
8.1	CURRENT TRANSFORMER PA123A /PA145A.....		36
8.2	VOLTAGE TRANSFORMER PV123.....		37
8.3	COMBINED TRANSFORMER PVA123A /PVA145A.....		38

<b>ABR ABR</b>		<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>
Doc. title		Revision	
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		1.0	4/38

## 1 INTRODUCTION

The goal of the analysis was to evaluate seismic performance of PA123a/PA145a (see 8.1), PV123 (see 8.2), PVA145a/PVA123a (see 8.3) type transformers. Simulation was done using guidelines of IEEE 693 standard. For more information please see [1].

Computations concerned evaluation of stress field distribution and maximum bending moment between flange and insulator. Present report describes used simulation technique, analysis steps, loads and boundary conditions variations and summarizes obtained results.

## 2 SIMULATION SOFTWARE

All simulations were performed using Abaqus/CAE package. Abaqus includes FEM (finite element method) solver, pre- and post processor and enables performing many types of multiphysics simulations: mechanical, thermal, acoustic, piezoelectric, seismic, and others.

Parts and assemblies can be created in Abaqus, or they can be imported from CAD systems using native file formats. Abaqus functionality enables to define materials, interactions, loads, boundary conditions, mesh. User is also available to set up simulation parameters such as pre-processing memory. It is always possible to change all simulation settings and properties, because they're all parameterized.

Simulation results can be visualized in Abaqus postprocessor or in external software, which is able to import simulation results in Abaqus format. In postprocessor user can view all predefined field outputs, show or hide part instances, create cross-sections, make animations, automatically generate reports, diagnose model (warnings, errors). For more information about ABAQUS please see [2].

## 3 SIMULATION SETUP

Analysis has been made using Finite Element Method.

### 3.1 Simulation procedure

According to [1] analysis included three main simulation steps:

- Static load:
  - Terminal load.
  - Gravitational load.
- Natural frequency extraction.
- Dynamic analysis.

### 3.2 Simulation steps

Simulation consisted of three main simulation steps.

#### 3.2.1 Natural frequency extraction

In the first simulation step natural frequency extraction was performed. The frequency extraction procedure performs eigenvalue extraction to calculate the natural frequencies and the corresponding mode shapes of a system.

The eigenvalue problem for the natural frequencies of an undamped finite element model can be described by equation (3-1):

<b>ABER ABID</b>	ZCCO Corporate Research	9ADB009045	Page
Doc. title		Revision	
		1.0	5/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			


$$(-\omega^2 M^{MN} + K^{MN}) \phi^N = 0 \quad (3-1)$$

where:  $M^{MN}$  – mass matrix (kg);  $K^{MN}$  – stiffness matrix (Pa), which includes initial stiffness effects if the base state (gravitational load);  $\phi$  – eigenvector (the mode of vibration);  $M, N$  – degrees of freedom (-). Based on specification [1] one can assume that most critical frequency modes are in range of 0-35 Hz.

### 3.2.2 Response spectrum analysis

The response spectrum method is a convenient way of describing shock motion in terms of the maximum response of a single degree of freedom (1-DOF) oscillator of arbitrary natural period and damping ratio. Each data point of the response spectrum curve represents the peak response from a time history analysis of the earthquake applied to 1-DOF oscillator system. The ordinate defines the natural period at which the oscillator is tuned. Repeating the procedure for a great many frequencies defines a continuous curve for an assumed level of damping.

A spectral response analysis estimates the maximum displacement of the structure during a 'design' shock load without recourse of direct integration. Finite element implementation of the response spectrum calculate the response of each mode independent, and then combine the scaled response one of a number of established combination rules, to give an estimate of peak response. Spectrum plot used in simulation is presented in Figure 1.



— Moderate required RS - 0.25g    - - - High required RS - 0.5g

Figure 1. Design response spectrum (RS) – 2% damping

*[Handwritten signature]*

<b>ABER ABID</b>	ZCCO Corporate Research	9ADB009045	Page
Doc. title		Revision	
		1.0	6/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

### 3.3 Loads and boundary conditions

#### 3.3.1 Loads

The following static load scenarios have been considered

1. Gravitational load,  $g=9.81 \text{ m/s}^2$ .
2. Terminal operating load. These load conditions were specified according to [3] (Table 7 – Static withstand test loads). For considered voltage-current range static withstand force (Load class II) should be equal to 3000 N. With respect to 'NOTE 1 The sum of the loads acting in routinely operating conditions should not exceed 50% of the specified withstand test load', maximum operating force is equal to 1500 N.

Seismic load have been predefined according design response spectrum described in the standard [1] – ground acceleration reference – Moderate/High Required Response Spectrum. Main input parameters were the following:

- XYZ base motion with vertical load (Y) equal to 80% of horizontal direction.
- Damping ratio – 2%.

As the final outcome from the analysis static loads were combined with the seismic load.

#### 3.3.2 Boundary conditions

Simulation assumes that the apparatus will be mounted on ground. During analysis model has been fixed at the bottom face of used test frame. General view of static loads and boundary conditions is presented in Figure 2. Area highlighted by red has been constrained (Y-rotation released). Base of the bottom tank has been supported in Y direction (as it is placed on the ground). Described boundary conditions have been used for all analyzed models.





Figure 2. Boundary conditions – general view

*[Handwritten signature]*


378

 <small>Doc. title</small>	<b>ZCCO</b> Corporate Research		<b>9ADB009045</b>
	<small>Revision</small> 1.0		<small>Page</small> 7/38
<small>Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level</small>			

**3.4 Acceptance criteria**

With respect to the standard [1] the following acceptance criteria were used

- Seismic load should be combined with dead load and possible normal operating loads.
- The maximum allowable bending moment shall not exceed 6.65 kNm (50% of ultimate load/stress)
- Aluminum components shall not exceed 73 MPa (minimum ultimate tensile strength divided by 2.2 safety factor).


 <small>Doc. title</small>	<b>ZCCO</b> Corporate Research		<b>9ADB009045</b>
	<small>Revision</small> 1.0		<small>Page</small> 8/38
<small>Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level</small>			

**3.5 Current transformer - PA 123a/PA 145a**

This chapter gathers details related to FE model of current transformer PA 123a/PA 145a.

**3.5.1 Model simplifications**

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 3. Red point indicates center of mass of the transformer.



**Figure 3. Simplified representation of the PA 123a/PA 145a transformer**

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

**3.6 Material and mass information**

Component naming is presented in Figure 4.




Figure 4. Assembly – component naming

Material and mass information is listed in Table 1

Table 1. Mass and material data

Drawing number	Component name	Material name	Mass [Kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKA310045	Base J123	EN-AC 43200 (grade F)	16.5	69000	80	160
2GKA310404	Insulator	Porcelain	71	100000	140	
	Insulator - Flange	EN-AC 43200 (grade TB)	3.5	69000	180	220
2GKA414718	Head	EN-AC 43200 (grade F)	22.5	69000	80	160
2GKA314089	Head cover	EN-AC 43200 (grade F)	20	69000	80	160
	Coil	-	150			
2GK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		120			

The ultimate bending moment for ceramic insulator is equal to  $M_B=13.3$  kNm.

### 3.7 Finite element (FE) model

General view of FE model is presented in Figure 5.




Figure 5. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 533430
- Total number of elements: 242866
  - 210555 quadratic tetrahedral elements of type C3D10
  - 31050 quadratic hexahedral elements of type C3D20R
  - 1243 quadratic quadrilateral elements of type S8R
  - 18 quadratic triangular elements of type STR165

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

### 3.8 Voltage transformer - PV 123

This chapter gathers details related to FE model of voltage transformer PV 123.

#### 3.8.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 6. Red point indicates center of mass of the transformer.




Figure 6. Simplified representation of the PV 123 transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

#### 3.9 Material and mass information

Component naming is presented in Figure 7.




Figure 7. Assembly - component naming

Material and mass information is listed in Table 2.


Table 2. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK310150P	Bottom tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK310147P	Core	Steel	22.5	208000	300	370
2GKV314005	Tank cover	EN-AC 43200 (grade F)	15.5	69000	80	160
2GKA310404	Insulator	Porcelain	71	100000	140	
	Insulator flange	EN-AC 43200 (grade F8)	3.5	69000	180	220
	Coil		30			
2GKK311093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
	Oil		60			

The ultimate bending moment for ceramic insulator is equal to  $M_B=13.3 \text{ kNm}$ .

3/0



	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	13/38

### 3.10 Finite element (FE) model

General view of FE model is presented in Figure 8.





Figure 8. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 608507
- Total number of elements: 236033
  - 4806 quadratic quadrilateral elements of type S8R
  - 58 quadratic triangular elements of type STRI65
  - 58965 quadratic hexahedral elements of type C3D20R
  - 8577 linear hexahedral elements of type C3D8R
  - 163827 quadratic tetrahedral elements of type C3D10

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>	Doc. title	Page
			Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	14/38

### 3.11 Combined transformer – PVA123a /PVA145a

This chapter gathers details related to FE model of combined transformer PVA123a /PVA145a.

#### 3.11.1 Model simplifications

For simulation requirements some areas of the model were simplified. Small geometrical features like casting rounding, chamfers were removed in order to improve mesh generation process. Details of the geometry and center of mass can be found in Figure 9. Red point indicates center of mass of the transformer.




Figure 9. Simplified representation of the PVA123a /PVA145a transformer

Concrete between flange and ceramic insulator has been introduced using connector element with predefined rotational stiffness.

Because of the simulation method (dynamics based on modal analysis) components were connected together using bonded connection or conformal mesh.

### 3.12 Material and mass information

Component naming is presented in Figure 10

382

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	15/38




Figure 10. Assembly – component naming  
Material and mass information is listed in Table 3.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	16/38

Table 3. Mass and material data

Drawing number	Component name	Material name	Mass [kg]	Young's modulus [MPa]	Yield strength [MPa]	Ultimate strength [MPa]
2GKK314076	Tank	EN-AC 43200 (grade F)	25	69000	80	160
2GKK314084	Core	Steel	33.8	206000	300	370
2GKK314075	Tank cover	EN-AC 43200 (grade F)	18	69000	80	160
2GKK314070	Insulator	Porcelain	131	100000	140	
	Insulator flange	EN-AC 43200 (grade F)	5	69000	180	220
2GKK314080	Head	EN-AC 43200 (grade F)	23.5	69000	80	160
2GKK314089	Head cover PVA-PA123A PA145A-145	EN-AC 43200 (grade F)	23	69000	80	160
2GKK310902	Bellow	Stainless steel	5	190000	200	500
2GKK310014P	Below enclosure	EN-AC 43200 (grade F)	7	69000	80	160
-	Voltage coil	-	30	-	-	-
-	Current coil	-	150	-	-	-
2GKK310802	Epoxy insulator	-	2.5	-	-	-
2GKK31093R	Control box	EN-AC 43200 (grade F)	5.5	69000	80	160
-	Oil	-	150	-	-	-

The ultimate bending moment for ceramic insulator is equal to  $M_B=13.3$  kNm.

<b>AEP</b> <b>PAEP</b>	ZCCO Corporate Research	9ADB009045	Page
Doc. title		Revision	17/38
		1.0	
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

### 3.13 Finite element (FE) model

General view of FE model is presented in Figure 11.




Figure 11. FE model – general view

Mesh statistics were the following:

- Total number of nodes: 1009580
- Total number of elements: 463007
  - 58507 quadratic hexahedral elements of type C3D20R
  - 300489 quadratic tetrahedral elements of type C3D10
  - 2519 linear quadrilateral elements of type S4R
  - 97 linear triangular elements of type S3
  - 8900 linear hexahedral elements of type C3D8R
  - 528 quadratic wedge elements of type C3D15
  - 90967 quadratic tetrahedral elements of type C3D10M

Description of the coordinate system.

- X – 1<sup>st</sup> horizontal axis.
- Z – 2<sup>nd</sup> horizontal axis.
- Y – vertical axis.

<b>AEP</b> <b>PAEP</b>	ZCCO Corporate Research	9ADB009045	Page
Doc. title		Revision	18/38
		1.0	
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level			

## 4 SIMULATION RESULTS

This chapter gathers simulation results evaluated in the analysis. Obtained outcome includes static and the seismic load.

### 4.1 PA123a /PA145a

#### 4.1.1 Natural frequency extraction

Effective modal mass plot is presented Figure 12. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 6.9 – 8.2 Hz.




Figure 12. Natural frequency extraction – effective modal mass

Effective modes and associated with the shapes are presented in Figure 13.

384

<b>ABB</b> ABB	ZCCO Corporate Research	9ADB009045	Revision	Page
Doc. title			1.0	19/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level				




Figure 13. Natural frequency extraction - mode shapes  
Summary of modal mass participation is listed in Table 4.

Table 4. Modal mass participation - summary

Mode no	Frequency [Hz]	X-direction	Y-direction	Z-direction
1	6.9	40%	0%	35%
2	8.2	34%	0%	40%
3	38.9	2%	0%	6%
4	39.7	6%	0%	2%
5	46.9	0%	0%	0%
6	98.7	0%	89%	0%
7	129.2	0%	0%	2%
8	150.3	4%	0%	0%
9	166.6	0%	0%	4%
10	167.4	2%	0%	0%

<b>ABB</b> ABB	ZCCO Corporate Research	9ADB009045	Revision	Page
Doc. title			1.0	20/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level				

4.1.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 14 and Figure 15. Stress scale has been limited to 73 MPa as the maximum allowable stress level.

St. Minus	0.0
Max	73.0
Avg	1.0
Min	0.0
Max	73.0
Avg	1.0
Min	0.0
Max	73.0
Avg	1.0
Min	0.0
Max	73.0
Avg	1.0




Figure 14. Von-Mises stress [Pa] distribution - tank (view 01)

St. Minus	0.0
Max	73.0
Avg	1.0
Min	0.0
Max	73.0
Avg	1.0
Min	0.0
Max	73.0
Avg	1.0
Min	0.0
Max	73.0
Avg	1.0




Figure 15. Von-Mises stress [Pa] distribution - tank (view 02)  
Displacement field is presented in Figure 16.




Figure 16. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=7961$  Nm.
- $M_z=7992$  Nm.

Insulator has not satisfied the maximum bending moment condition. One can observe that stresses evaluated at the base are slightly above allowable value. Therefore small yielding may occur. One must have in mind that analysis did not cover possible casting imperfections.

Design has been verified according to Moderate seismic level (0.25 g Zero Period Acceleration). Stress distribution for such load scenario is presented from Figure 17 to Figure 18. Obtained stress level was below allowable level.

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=4816$  Nm.
- $M_z=4821$  Nm.

Insulator has satisfied allowable bending moment condition.




Figure 17. Von-Mises stress [Pa] distribution (AF3) – tank (view 01)




Figure 18. Von-Mises stress [Pa] distribution (AF3) – tank (view 02)

	<b>ZCCO</b> Corporate Research	9ADB009045
		Doc. title
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		23/38
Revision 1.0		23/38

#### 4.2 PV 123

##### 4.2.1 Natural frequency extraction

Effective modal mass plot is presented Figure 19. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based on presented plot one can see that the most critical modes were located between 24.7–25.3 Hz.




Figure 19. Natural frequency extraction – effective modal mass  
Effective modes and associated with the shapes are presented in Figure 20.

	<b>ZCCO</b> Corporate Research	9ADB009045
		Doc. title
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		24/38
Revision 1.0		24/38




Figure 20. Natural frequency extraction – mode shapes  
Summary of modal mass participation is listed in Table 5.

Table 5. Modal mass participation – summary

Mode no.	Frequency [Hz]	X- direction	Y- direction	Z- direction
1	24.7	24%	0%	0%
2	25.2	0%	0%	24%
3	25.4	0%	0%	0%
4	26.5	0%	0%	0%
5	135.5	37%	0%	0%
6	139.3	0%	0%	36%
7	161.3	0%	34%	0%
8	162.4	0%	0%	0%
9	175.8	0%	0%	0%
10	176.2	0%	0%	0%

	ZCCO Corporate Research	9ADB009045	Page
			25/38
Doc. title Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		Revision	
		1.0	

#### 4.2.2 Dynamic analysis

Stress distribution for tank component is presented in Figure 21 and Figure 22. As described in chapter 3.8.1 location of center of mass is close to the ground level, therefore expected bending moment and so the stress was low. One can see that the maximum stress level reached ca. 24 MPa and it was located at vicinity of coupling constraint. Stress level satisfies required safety condition.




Figure 21. Von-Mises stress [Pa] distribution – tank (view 01)




Figure 22. Von-Mises stress [Pa] distribution – tank (view 02)

	ZCCO Corporate Research	9ADB009045	Page
			25/38
Doc. title Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		Revision	
		1.0	

Displacement field is presented in Figure 23.




Figure 23. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x = 22224 \text{ Nm}$ .
- $M_z = 22228 \text{ Nm}$ .

Insulator has satisfied the maximum bending moment condition.

387

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers, IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	27/38

4.3 PVA123a /PVA145a

4.3.1 Natural frequency extraction

Effective modal mass plot is presented Figure 24. Bubble size indicated amount of mass which participates in motion at specific frequency range. Based no presented plot one can see that the most critical modes were located between 3.8–4.1 Hz.




Figure 24. Natural frequency extraction – effective modal mass Effective modes and associated with the shapes are presented in Figure 25.

<b>ABB</b>	<b>ZCCO</b> Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers, IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	28/38





Figure 25. Natural frequency extraction – mode shapes Summary of modal mass participation is listed in Table 6.

Table 6. Modal mass participation – summary

Mode no.	Frequency [Hz]	X- direction	Y- direction	Z- direction
1	3.8	35%	0%	32%
2	4.1	32%	0%	35%
3	22.4	7%	0%	0%
4	23.2	0%	2%	8%
5	26.5	0%	95%	0%
6	29.2	0%	0%	1%
7	29.3	1%	0%	0%
8	34.6	10%	0%	0%
9	35.5	0%	0%	8%
10	36.2	0%	0%	3%




 Doc. title	ZCCO Corporate Research	9ADB009045 Revision	1.0 Page

4.3.2 Dynamic analysis  
 Stress distribution for tank component is presented in Figure 26 and Figure 27. One can see that the maximum stress was above 75 MPa allowable limit.



Figure 26. Von-Mises stress [Pa] distribution - tank (view 01)

 Doc. title	ZCCO Corporate Research	9ADB009045 Revision	1.0 Page






Figure 27. Von-Mises stress [Pa] distribution - tank (view 02)  
 Displacement field is presented in Figure 28.



 Doc. title	ZCCO Corporate Research	9ADB009045	Page
		Revision	31/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		1.0	





Figure 28. Displacement [m] field - distribution

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=10451 \text{ Nm}$ .
- $M_z=8515 \text{ Nm}$ .

Insulator has not satisfied the maximum bending moment condition. Stress distribution for moderate seismic level is presented in Figure 29 and Figure 30.

 Doc. title	ZCCO Corporate Research	9ADB009045	Page
		Revision	32/38
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		1.0	





Figure 29. Von-Mises stress [Pa] distribution – tank (view 01)



Figure 30. Von-Mises stress [Pa] distribution – tank (view 02)


 <b>ABB</b> <b>ABB</b>	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>	Page
			Revision
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		1.0	33/38

The maximum bending moment evaluated at the interface between flange and insulator was equal to:

- $M_x=6335 \text{ Nm}$ .
- $M_y=4080 \text{ Nm}$ .

The maximum bending moment satisfies allowable value.




 <b>ABB</b> <b>ABB</b>	<b>ZCCO</b> Corporate Research	<b>9ADB009045</b>	Page
			Revision
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		1.0	34/38

## 5 CONCLUSIONS

The goal of the analysis was to investigate family of HV Instrument Transformers using guidelines described in IEEE 693 standard. Summary of satisfied criteria is presented in Table 7. Column 'IEEE 693' lists allowable seismic level for selected design. Columns (2, 3) list seismic level where obtained stresses/bending moment were below yield strength/ultimate bending moment.

Table 7. Summary of acceptance criteria

Design name	(1) IEEE 693	(2) Yield strength	(3) Ultimate bending load
PA123a /PA145a	MODERATE	HIGH	HIGH
PV 123	HIGH	HIGH	HIGH
PVA123a /PVA145a	MODERATE	HIGH	HIGH

With respect to IEEE 693 criteria main conclusions are the following:

- PA123a/PA145a withstands Moderate seismic qualification level.
- PV 123 withstands High seismic qualification level.
- PVA123a/PVA145a withstand Moderate seismic qualification level.

### Disclaimer

The analysis documented herein has been prepared in accordance with reasonable standards of scientific endeavor and the best knowledge of the author(s).

The simulation results may depend on a variety of factors, including quality of input data, applied model simplifications and chosen numerical methods.

<b>ABB</b> Doc. title		<b>ZCCO</b> Corporate Research		9ADB009045	
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		Revision		Page	
		1.0		35/38	

## 6 BIBLIOGRAPHY

- [1] IEEE 693 – IEEE Recommended Practice for Seismic Design and Substations, The Institute of Electrical and Electronics Engineers, Inc, NY 10016-5997, USA
- [2] ABAQUS, ABAQUS 6.13 Documentation, DS Simulia, USA, [www.simulia.com](http://www.simulia.com)
- [3] IEC 61869-1 – Instrument transformers – Part 1: General requirements, International standard, Edition 1.0 2007-10


## 7 CHANGE HISTORY

Date	Revision	Author(s)	Change
2015-08-31	Rev. 1	Juszkiewicz Grzegorz	original document

<b>ABB</b> Doc. title		<b>ZCCO</b> Corporate Research		9ADB009045	
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level		Revision		Page	
		1.0		36/38	

## 8 APPENDICES


### 8.1 Current transformer PA123a /PA145a



392

	ZCCO Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	37/38

8.2 Voltage transformer PV123




We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.

393

	ZCCO Corporate Research	9ADB009045
Doc. title	Revision	Page
Seismic analyses of HV Instrument Transformers. IEEE 693- high (0.5g)/moderate(0.25g) seismic level	1.0	38/38

8.3 Combined transformer PVA123a /PVA145a



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden.  
© 2015 ABB Ltd.


C

C

**„Доставка на електрически апарати  
110кV“, реф. № PPD 17-064.**

**Обособена позиция 4 – Доставка на  
комбинирани измервателни  
трансформатори 110кV за монтаж на  
открито – 15 бр.**

# **ПРИЛОЖЕНИЕ 5**

A large, stylized handwritten signature in black ink, positioned vertically on the right side of the page. The signature is highly cursive and difficult to decipher, but it appears to be a personal name.

(

(



# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МЛА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА ЛАБОРАТОРИЯ ЗА КАЛИБРИРАНЕ

### № AP 168

Това е, за да се потвърди, че:

**ABB Sp. Z o.o.,  
Ул. Зеганска 1, 04-713 Варшава  
Лаборатория за калибриране  
АББ Продукти Високо Напрежение клон в Пшашниш  
ул. Лешно 59, 06-300 Пшашниш, Полша**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17025:2005

Акредитирана дейност се определя в обхвата на акредитация № AP 168

Тази акредитация остава в сила, при условие че Лабораторията съблюдава изискванията на органа за акредитация, определени в договор № AP 168

Сертификатът за акредитация е валиден до 20.12.2020 г.

Директор  
Лучина Олборска

Варшава, 21 Декември 2016 г.



# POLSKIE CENTRUM AKREDYTACJI

## POLISH CENTRE FOR ACCREDITATION

ABB Sp. z o.o.  
ul. Żegańska 1, 04-713 Warszawa  
00-720 4 004, PL 9280304464  
KRS 00000977168  
BIURO W PRZASNYSZU  
ul. Leszno 59, 06-300 Przasnysz  
tel. (22) 223 8349, fax (22) 223 8958  
(16)



Sygnatariusz EA MLA  
EA MLA Signatory

# CERTYFIKAT AKREDYTACJI

## LABORATORIUM WZORCUJĄCEGO

### ACCREDITATION CERTIFICATE OF CALIBRATION LABORATORY

## Nr AP 168

Potwierdza się, że: / This is to confirm that:


**ABB Sp. z o.o.**  
ul. Żegańska 1, 04-713 Warszawa  
Laboratorium Wzorcujące  
ABB PGHV w Przasnyszu  
ul. Leszno 59, 06-300 Przasnysz

spełnia wymagania normy PN-EN ISO/IEC 17025:2005  
meets requirements of the PN-EN ISO/IEC 17025:2005 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AP 168  
Accredited activity is defined in the Scope of Accreditation No AP 168

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AP 168  
This accreditation remains in force provided the Laboratory observes  
the requirements of Accreditation Body defined in the Contract No AP 168

Certyfikat akredytacji ważny do dnia 20.12.2020 r.  
The certificate of accreditation is valid until 20.12.2020



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI


LUCYNA OLBORSKA

Warszawa, dnia 21 grudnia 2016 roku

(

(

# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МЛА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА СЕРТИФИЦИРАЩ ОРГАН ЗА ПРОДУКТИ № АС 117

Това е, за да се потвърди, че:

**ИНСТИТУТ ПО ЕНЕРГЕТИКА  
ИНСТИТУТ ЗА ИЗСЛЕДВАНИЯ  
отдел СЕРТИФИЦИРАНЕ  
ул. Мори 8, 01-330 Варшава**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17065:2013-03

Акредитирана дейност се определя в обхвата на акредитация № АС 177

Тази акредитация остава в сила, при условие че Организацията съблюдава изискванията на органа за акредитация, определени в договор № АС 117

Сертификатът за акредитация е валиден до 03.02.2021 г.

Акредитацията е предоставена на 04.02.2005 г.

р.о. Директор  
Лучина Олборска

Варшава, 27 Януари 2017 г.

uon

# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МЛА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА ЛАБОРАТОРИЯ ЗА ИЗПИТАНИЯ № АВ 323

Това е, за да се потвърди, че:

**ИНСТИТУТ ПО ЕНЕРГЕТИКА**  
**Лаборатория Високо Напрежение**  
**ул. Мори 8, 01-330 Варшава**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17025:2005

Акредитирана дейност се определя в обхвата на акредитация № АВ 323

Тази акредитация остава в сила, при условие че Лабораторията съблюдава изискванията на органа за акредитация, определени в договор № АВ 323

Сертификатът за акредитация е валиден до 27.12.2019 г.


Акредитацията е предоставена на 28.12.2000 г.

ДИРЕКТОР  
ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ  
Луцина Олборска

Варшава, 16 Ноември 2015 г.

402

# ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ



Подписваща страна ЕА МЛА

## СЕРТИФИКАТ ЗА АКРЕДИТАЦИЯ НА ЛАБОРАТОРИЯ ЗА ИЗПИТАНИЯ № АВ 324

Това е, за да се потвърди, че:

**ИНСТИТУТ ПО ЕНЕРГЕТИКА**  
**Лаборатория Разпределителни Устройства**  
**ул. Мори 8, 01-330 Варшава**

отговаря на изискванията на стандарт PN-EN ISO/IEC 17025:2005

Акредитирана дейност се определя в обхвата на акредитация № АВ 324

Тази акредитация остава в сила, при условие че Лабораторията съблюдава изискванията на органа за акредитация, определени в договор № АВ 324

Сертификатът за акредитация е валиден до 27.12.2019 г.

Акредитацията е предоставена на 28.12.2000 г.

ДИРЕКТОР  
ПОЛСКИ ЦЕНТЪР ЗА АКРЕДИТАЦИЯ  
Луцина Олборска

Варшава, 24 Ноември 2015 г.

C

C



# POLSKIE CENTRUM AKREDYTACJI

## POLISH CENTRE FOR ACCREDITATION



Sygnatariusz EA MLA  
EA MLA Signatory

# CERTYFIKAT AKREDYTACJI

## JEDNOSTKI CERTYFIKUJĄCEJ WYROBY

### ACCREDITATION CERTIFICATE FOR PRODUCT CERTIFICATION BODY

# Nr AC 117

Potwierdza się, że: / This is to confirm that:

**INSTYTUT ENERGETYKI**  
**INSTYTUT BADAWCZY**  
**ZESPÓŁ ds. CERTYFIKACJI**  
ul. Mory 8, 01-330 Warszawa

spełnia wymagania normy PN-EN ISO/IEC 17065:2013-03  
meets requirements of the PN-EN ISO/IEC 17065:2013-03 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AC 117  
Accredited activity is defined in the Scope of Accreditation No AC 117

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AC 117  
This accreditation remains in force provided the Body observes  
the requirements of Accreditation Body defined in the Contract No AC 117

Certyfikat akredytacji ważny do dnia 03.02.2021 r.  
The certificate of accreditation is valid until 03.02.2021

Akredytacji udzielono dnia 04.02.2005 r.  
Accreditation was granted on 04.02.2005



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

LUCYNA OLBORSKA

Warszawa, 27 stycznia 2017 roku

C

O

1  
2  
3

**POLSKIE CENTRUM AKREDYTACJI**  
POLISH CENTRE FOR ACCREDITATION



Sygnatariusz EA MLA  
EA MLA Signatory

**CERTYFIKAT AKREDYTACJI**  
**LABORATORIUM BADAWCZEGO**  
ACCREDITATION CERTIFICATE OF TESTING LABORATORY  
**Nr AB 324**

Potwierdza się, że: / This is to confirm that:

**INSTYTUT ENERGETYKI**  
**LABORATORIUM URZADZEŃ ROZDZIELCZYCH**  
ul. Mory 8, 01-330 Warszawa

spełnia wymagania normy PN-EN ISO/IEC 17025:2005  
meets requirements of the PN-EN ISO/IEC 17025:2005 standard

Akredytowana działalność jest określona w Zakresie Akredytacji Nr AB 324  
Accredited activity is defined in the Scope of Accreditation No AB 324


Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 324  
This accreditation remains in force provided the Laboratory observes  
the requirements of Accreditation Body defined in the Contract No AB 324

Certyfikat akredytacji ważny do dnia 27.12.2019 r.  
The certificate of accreditation is valid until 27.12.2019

Akredytacji udzielono dnia 28.12.2000 r.  
Accreditation was granted on 28.12.2000

DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

*Lucyna Olborska*  
LUCYNA OLBORSKA



**ABB**  
ABB Sp. z o.o.  
Legiańska 1, 01-713 Warszawa  
tel. 22 630 41 91, PL 6090304484  
Regon: 141904716  
**DZIAŁ W PRZASNYSZU**  
ul. Leszno 59, 08-300 Przasnysz  
tel. (22) 223 8849, fax (22) 223 8958  
(16)

Warszawa, 24 listopada 2015 roku

407

**POLSKIE CENTRUM AKREDYTACJI**  
**POLISH CENTRE FOR ACCREDITATION**



Sygnatariusz EA MLA  
EA MLA Signatory

**CERTYFIKAT AKREDYTACJI**  
**LABORATORIUM BADAWCZEGO**  
**ACCREDITATION CERTIFICATE OF TESTING LABORATORY**  
**Nr AB 323**

Potwierdza się, że: / This is to confirm that:

**INSTYTUT ENERGETYKI**  
**LABORATORIUM WIELKOPRĄDOWE**  
**ul. Mory 8, 01-330 Warszawa**

spełnia wymagania normy PN-EN ISO/IEC 17025:2005  
meets requirements of the PN-EN ISO/IEC 17025:2005 standard


Akredytowana działalność jest określona w Zakresie Akredytacji Nr AB 323  
Accredited activity is defined in the Scope of Accreditation No AB 323

Akredytacja pozostaje w mocy pod warunkiem przestrzegania  
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 323  
This accreditation remains in force provided the Laboratory observes  
the requirements of Accreditation Body defined in the Contract No AB 323

Certyfikat akredytacji ważny do dnia 27.12.2019 r.  
The certificate of accreditation is valid until 27.12.2019

Akredytacji udzielono dnia 28.12.2000 r.  
Accreditation was granted on 28.12.2000

**ABD**  
ABD Sp. z o.o.  
Kagańska 1, 01-713 Warszawa  
t. 226-030444, f. 226-0304484  
Reg. D. 010017168  
BIURO W PRZASNYSZU  
ul. Lecznio 59, 08-300 Przasnysz  
t. (22) 223 8849, fax (22) 223 8958  
(16)



DYREKTOR  
POLSKIEGO CENTRUM AKREDYTACJI

LUCYNA OLBORSKA

Warszawa, 16 listopada 2015 roku

408

**„Доставка на електрически апарати  
110кV“, реф. № РРД 17-064.**

**Обособена позиция 4 – Доставка на  
комбинирани измервателни  
трансформатори 110кV за монтаж на  
открито – 15 бр.**

# **ПРИЛОЖЕНИЕ 6**



(

(

Type/ Тип

**ROUTINE TEST PLAN for Combined Instrument Transformers**  
**План за рутинни изпитания на Комбиниран Измервателен Трансформатор**

**ABB**

Valid for order ..... / KU ....  
Валидно за поръчка ..... / KU ....

-- units of Combined Instrument Transformers (-брой Комб. Изм. Трансформатори)

Sl. №	Test Изпитание	Test according to: Изпитание съгл.:	Requirement according to: Изисквания	Place of test Място на	Remarks Забележки	Acceptance	
						Date Дата	Signature Подпис
1	Enclosure tightness test at ambient temperature Изпитване за херметичност при температура на околната среда	IEC 61869-1	Cl. 7.3.7.2	Quality control - ABB Przasnysz Контрол на качеството			
2	Verification of terminal markings and technical parameters Проверка на маркировката на клемите и техническите	IEC 61869-1 IEC 61869-2 IEC 61869-3 IEC 61869-4	Cl. 6.13; 7.3.6 Cl. 6.13 Cl. 6.13 Cl. 6.13	Quality control - ABB Przasnysz Контрол на качеството			
3	Power-frequency voltage withstand tests on primary windings and partial discharge measurement Обявено издържано напрежение с промишлена честота за изолацията на първичната намотка и измерване на частичните разряди.	IEC 61869-1 IEC 61869-2 IEC 61869-3 IEC 61869-4 IEC 60720	Cl. 7.3.1; 7.3.2 Cl. 7.3.1 Cl. 7.3.1; 7.3.2 Cl. 7.3.1;	Quality control - ABB Przasnysz Контрол на качеството			
4	Determination of the secondary and primary windings resistance Определение на съпротивлението на първичната и вторичните намотки	IEC 61869-2 -- --	Cl. 7.3.201 Order (if special requirements) Поръчка (при специални изисквания)	Quality control - ABB Przasnysz Контрол на качеството			
Prepared by Подготвено от				Date Дата	Checked by Проверено от		Date Дата
Ł. Lubieniecki				27.07.2015	J. Duzdowski		27.07.2015
					P. Dębski		27.07.2015

*(Handwritten signatures and initials)*

ABB

**ROUTINE TEST PLAN for Combined Instrument Transformers**  
**План за рутинни изпитания на Комбиниран Измервателен Трансформатор**

Number / Номер  
2GKK614153

Page / Страница 1  
Pages / Общо 4

Type / Тип

-- units of Combined Instrument Transformers (-брой Комб. Изм. Трансформатори)

Valid for order ..... / KU ....  
 Валидно за поръчка ..... / KU ....

Sl. №	Test Изпитание	Test according to: Изпитание съгл.:	Requirement according to: Изисквания	Place of test Място на	Remarks Забележки	Date Дата	Acceptance Приемане	Signature Подпис
5	Power-frequency voltage withstand tests on secondary terminals and between sections (if applicable) Обявено издържано напрежение с промишлена честота за изолацията на вторичните клеми и между секциите (ако е приложимо)	IEC 61869-1	Cl. 7.3.3; 7.3.4	Quality control - ABB Przasnysz Контрол на качеството				
6	Measurement of factors: FS/ALF/Ts/Ek/Ie/Kr and magnetizing characteristic of the Current Transformer Измерване на фактори: FS/ALF/Ts/Ek/Ie/Kr и намагнитващите характеристики на ТТ.	IEC 61869-2	Cl. 7.2.6.202; 7.3.5.203; 7.3.5.205; 7.3.202; 7.3.203; 7.2.6.206 Order	Quality control - ABB Przasnysz Контрол на качеството				
7	Inter-turn overvoltage test of the Current Transformer Изпитание на пренапрежение на вътрешните намотки на ТТ	IEC 61869-2	Cl. 7.3.204 Поръчка	Quality control - ABB Przasnysz Контрол на качеството				
Prepared by Подготвено от		Checked by Проверено от		Date Дата		Approved by Одобрено от		Date Дата
Ł. Lubieniecki		J. Duzdowski		27.07.2015		P. Dębski		27.07.2015

442



<b>ABB</b> <b>ROUTINE TEST PLAN for Combined Instrument Transformers</b> <b>План за рутинни изпитания на Комбиниран Измервателен Трансформатор</b>		Number / Номер <b>2GKK614153</b>		Page / Страница 1 Pages / Общо 4				
		Type / Тип						
Valid for order ..... / KU .... Валидно за поръчка ..... / KU ....								
Sl. №	Test Изпитание	Test according to: Изпитание съгл.:	Requirement according to: Изисквания съгласно:	Place of test Място на изпитанието	Remarks Забележки	Date Дата	Acceptance Приемане	Signature Подпис
8	Test for accuracy of the current transformer: • Tests for ratio error and phase displacement of measuring CT; • Tests for ratio error and phase displacement of class P, PR, TRX, TPX and TPZ protective CT • Test for turns ratio error for class PX and PXR protective CT Изпитание на точността на ТТ: Изпитание на грешката и фазовото отместване на ТТ за мерене; • Изпитание на грешката и фазовото отместване на клас P, PR, TRX, TPX, TPZ на ТТ за защита • Проверка за грешка в съотношението на напрежението за клас PX и PXR на ТТ за защита	IEC 61869-2  IEC 61869-4	Cl. 7.3.5.201, 7.3.5.202, 7.3.5.204, 7.3.5.206  Cl. 7.3.5.401	Quality control - ABB Przasnysz  Контрол на качеството				
9	Test for accuracy of the voltage transformer: • Tests for ratio error and phase displacement of measuring VT; • Tests for ratio error and phase displacement of protective VT Изпитание на точността на НТ: • Изпитания за грешка в съотношението и фазовото изместване на НТ за мерене; • Изпитания за грешка в съотношението и фазовото изместване на НТ за защита	IEC 61869-3  IEC 61869-4	Cl. 7.3.5.301; 7.3.5.302  Cl. 7.3.5.401	Quality control - ABB Przasnysz  Контрол на качеството				
Prepared by Подготвено от		Checked by Проверено от		Date Дата	Approved by Одобрено от		Date Дата	
Ł. Lubieniecki		J. Duzdowski		27.07.2015	P. Dębski		27.07.2015	

414

<b>ABB</b> <b>ROUTINE TEST PLAN for Combined Instrument Transformers</b> <i>План за рутинни изпитания на Комбиниран Измервателен Трансформатор</i>		Number / Номер <b>2GKK614153</b>		Page / Страница 1 Pages / Общо 4	
		Type / Тип			
Valid for order ..... / KU .... <i>Валидно за поръчка ..... / KU ....</i>					
-- units of Combined Instrument Transformers (-брой Комб. Изм. Трансформатори)					
10	Capacitance and dielectric dissipation factor measurement <i>Измерване на капацитет и фактор на диелектрично разсейване</i>	IEC 61869-1 IEC 61869-2 IEC 61869-3	Cl. 7.4.3 Cl. 7.4.3 Cl. 7.4.3	Quality control - ABB Przasnysz  <i>Контрол на качеството</i>	
11	Inspection : visual check & verification of parameters according to order  <i>Инспекция: Визуална проверка и проверка на параметрите по поръчка</i>	--  --	Order  <i>Поръчка</i>	Quality control - ABB Przasnysz  <i>Контрол на качеството</i>	
Prepared by Подготвено от	Date Дата	Checked by Проверено от	Date Дата	Approved by Одобрено от	Date Дата
Ł. Lubieniecki	27.07.2015	J. Duzdowski	27.07.2015	P. Dębski	27.07.2015



**ROUTINE TEST PLAN for Combined Instrument Transformers**  
**Plan próby wyrobu dla Przekładników Kombinowanych**

Number / Numer  
 2GKK614153

Page / Strona 1  
 Pages / Stron 4

Type/Typ

Valid for order ..... / KU ....  
 Obowiązuje do zam. dla ..... / KU ....

— units of Combined Instrument Transformers (— szt. Przekładników Kombinowanych)

Sl.	Test	Test according to: Badanie według:	Requirement according to: Wymaganie według:	Place of test Miejsce badania	Remarks Uwagi	Date Data	Acceptance Akceptacja	Signature Podpis
1	Badanie Enclosure tightness test at ambient temperature	IEC 61869-1	Cl. 7.3.7.2	Quality control - ABB Przasnysz			<input type="checkbox"/>	
2	Sprawdzenie szczelności obudowy w temperaturze otoczenia Verification of terminal markings and technical parameters	IEC 61869-1 IEC 61869-2 IEC 61869-3 IEC 61869-4	Cl. 6.13; 7.3.6 Cl. 6.13 Cl. 6.13 Cl. 6.13	Kontrola Jakości			<input type="checkbox"/>	
3	Sprawdzenie oznakowania zacisków i parametrów technicznych Power-frequency voltage withstand tests on primary terminals and partial discharge measurement	IEC 61869-1 IEC 61869-2 IEC 61869-3 IEC 61869-4 IEC 60720	Cl. 7.3.1; 7.3.2 Cl. 7.3.1 Cl. 7.3.1; 7.3.2 Cl. 7.3.1;	Quality control - ABB Przasnysz			<input type="checkbox"/>	
4	Próba izolacji uzwojeń pierwotnych napięciem o częstotliwości sieciowej oraz pomiar wyładowań niezupętnych. Determination of the secondary and primary windings resistance	IEC 61869-2 -- --	Cl. 7.3.201 Order (if special requirements) Zamówienie (jeśli specjalne wym.)	Kontrola Jakości			<input type="checkbox"/>	
Wyznaczenie rezystancji uzwojeń wtórnych i pierwotnych				Quality control - ABB Przasnysz			<input type="checkbox"/>	
Prepared by Opracował		Date Data	Checked by Sprawdził	Date Data	Approved by Zatwierdził	Date Data		
Ł. Lubieniecki		27.07.2015	J. Duzdowski	27.07.2015	P. Dębski	27.07.2015		

*[Handwritten signatures]*

418

# ROUTINE TEST PLAN for Combined Instrument Transformers

## Plan próby wyrobu dla Przekładników Kombinowanych

Number / Numer  
**2GKK614153**

Page / Strona 2  
Pages / Stron 4

Type/ Typ

-- units of Combined Instrument Transformers (-- szt. Przekładników Kombinowanych)

Valid for order ..... / KU ....  
Obowiązuje do zam. dla ..... / KU ....

Sl. No	Test <i>Badanie</i>	Test according to:		Requirement according to: <i>Wymaganie według:</i>	Place of test <i>Miejsce badania</i>	Remarks <i>Uwagi</i>	Acceptance		Signature <i>Podpis</i>
		<i>Badanie według:</i>					<i>Data</i>	<i>Akceptacja</i>	
5	Power-frequency voltage withstand tests on secondary terminals and between sections (if applicable)  <i>Próba izolacji uzwojeń wtórnych oraz między sekcjami uzwojeń jeśli ma zastosowanie) napięciem o częstotliwości sieciowej</i>	IEC 61869-1	Cl. 7.3.3; 7.3.4	Quality control - ABB Przasnysz  <i>Kontrola Jakości</i>		<input type="checkbox"/>			
6	Measurement of factors: FS/ALF/Ts/Ek/Ie/Kr and magnetizing characteristic of the Current Transformer  <i>Pomiar współczynników: FS/ALF/Ts/Ek/Ie/Kr i charakterystyka magnesowania przekładnika prądowego.</i>	IEC 61869-2	Cl. 7.2.6.2.02; 7.3.5.2.03; 7.3.5.2.05; 7.3.2.02; 7.3.2.03; 7.2.6.2.06  <i>Order</i>	Quality control - ABB Przasnysz  <i>Kontrola Jakości</i>		<input type="checkbox"/>			
7	Inter-turn overvoltage test of the Current Transformer  <i>Próba izolacji międzyzwojowej przekładnika prądowego</i>	IEC 61869-2	Cl. 7.3.2.04  <i>Zamówienie</i>	Quality control - ABB Przasnysz  <i>Kontrola Jakości</i>		<input type="checkbox"/>			
Prepared by <i>Opracował</i>		Checked by <i>Sprawdził</i>		Date <i>Data</i>		Approved by <i>Zatwierdził</i>		Date <i>Data</i>	
Ł. Lubieniecki		J. Duzdowski		27.07.2015		P. Dębski		27.07.2015	

**ROUTINE TEST PLAN for Combined Instrument Transformers**  
**Plan próby wyrobu dla Przekładników Kombinowanych**

Number / Numer  
 2GKK614153

Page / Strona 3  
 Pages / Stron 4

Type/ Typ

Valid for order ..... / KU ....  
 Obowiązuje do zam. dla ..... / KU ....

-- units of Combined Instrument Transformers (- szt. Przekładników Kombinowanych)

Sl. No	Test	Test according to:	Requirement according to:	Place of test	Remarks	Date	Acceptance	Signature
	<i>Badanie</i>	<i>Badanie według:</i>	<i>Wymaganie według:</i>	<i>Miejsce badania</i>	<i>Uwagi</i>	<i>Data</i>	<i>Akceptacja</i>	<i>Podpis</i>
8	Test for accuracy of the current transformer: • Tests for ratio error and phase displacement of measuring CT; • Tests for ratio error and phase displacement of class P, PR, TPX, TPY and TPZ protective CT • Test for turns ratio error for class PX and PXR protective CT  Próby dokładności przekładnika prądowego: • Próby błędów przekładni i przesunięcia kąтового przekładnika pomiarowego; • Próby błędów przekładni i przesunięcia kąтового przekładnika zabezpieczeniowego o klasach P, PR, TPX, TPY, TPZ • Próba błędów przekładni swojowej dla klas PX i PXR przekładnika zabezpieczeniowego	IEC 61869-2  IEC 61869-4	Cl. 7.3.5.201, 7.3.5.202, 7.3.5.204, 7.3.5.206  Cl. 7.3.5.401	Miejsce badania - ABB Przasnysz  Quality control - ABB Przasnysz			<input type="checkbox"/>	
9	Test for accuracy of the voltage transformer: • Tests for ratio error and phase displacement of measuring VT; • Tests for ratio error and phase displacement of protective VT  Próby dokładności przekładnika napięciowego: • Próby błędów przekładni i przesunięcia kąтового przekładnika pomiarowego; • Próby błędów przekładni i przesunięcia kąтового przekładnika zabezpieczeniowego	IEC 61869-3  IEC 61869-4	Cl. 7.3.5.301; 7.3.5.302  Cl. 7.3.5.401	Kontrola Jakości Quality control - ABB Przasnysz			<input type="checkbox"/>	

Prepared by Opracował	Date Data	Checked by Sprawdził	Date Data	Approved by Zatwierdził	Date Data
Ł. Lubieniecki	27.07.2015	J. Duzdowski	27.07.2015	P. Dębski	27.07.2015

318

<b>ABB</b> <b>ROUTINE TEST PLAN for Combined Instrument Transformers</b> <i>Plan próby wyrobu dla Przekładników Kombinowanych</i>		Number / Numer 2GKK614153		Page / Strona 4 Pages / Stron 4	
		Type/ Typ			
-- units of Combined Instrument Transformers ( -- szt. Przekładników Kombinowanych)		Valid for order ..... / KU .... Obowiązuje do zam. dla ..... / KU ....			
10	Capacitance and dielectric dissipation factor measurement <i>Pomiar pojemności i współczynnika strat dielektrycznych</i>	IEC 61869-1 IEC 61869-2 IEC 61869-3	Cl. 7.4.3 Cl. 7.4.3 Cl. 7.4.3	Quality control - ABB Przasnysz <i>Kontrola Jakości</i>	<input type="checkbox"/>
11	Inspection : visual check & verification of parameters according to order <i>Oględziny – sprawdzenie zgodności parametrów z zamówieniem</i>	--	Order  Zamówienie	Quality control - ABB Przasnysz <i>Kontrola Jakości</i>	<input type="checkbox"/>
Prepared by <i>Opracował</i>		Checked by <i>Sprawdził</i>		Approved by <i>Zatwierdził</i>	
Date <i>Data</i>		Date <i>Data</i>		Date <i>Data</i>	
Ł. Lubieniecki		J. Duzdowski		P. Dębski	
27.07.2015		27.07.2015		27.07.2015	



## ДЕКЛАРАЦИЯ

за приемане на условията в проекта на договор


Долуподписаните Екехарт Нойрайтер и Стефан Минчев в качеството ни на представляващи АББ България ЕООД участник в обществена поръчка с предмет: „Доставка на електрически апарати 110kV“, реф. № PPD 17-064 Обособена позиция 4 - Доставка на комбинирани измервателни трансформатори 110 kV за монтаж на открито – 15 бр.

### ДЕКЛАРИРАМЕ, ЧЕ:

Приемаме условията в проекта на договор, приложен в документацията за участие.

Дата: 11.07.2017

Декларатор:

  
.....  
Екехарт Нойрайтер  
Управител  
АББ България ЕООД


  
.....  
Стефан Минчев  
Управител  
АББ България ЕООД

ABB Bulgaria EOOD  
Main Office  
9, Hristofor Kolumb Blvd., fl. 3  
Mladost, Sofia-grad  
1592 Sofia, Bulgaria  
Phone: +359 (0) 2 807 55 00  
Fax: +359 (0) 2 807 55 99  
Web: [www.abb.bg](http://www.abb.bg)  
E-mail: [office@bg.abb.com](mailto:office@bg.abb.com)

UIC: 831133152  
VAT Nr.: BG 831133152  
Bank details:  
ING Bank, branch Sofia  
IBAN: BG13INGB91451000027317 (BGN)  
IBAN: BG60INGB91451400027311 (EUR)  
BIC: INGBBGSF



03.2017

C

(





ДЕКЛАРАЦИЯ  
за срока на валидност на офертата

Долуподписаните,

Екехарт Бернхард Нойрайтер, притежаващ лична карта ID N: L8XHOJRMР издадена на 11.03.2013 – Германия, адрес гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД

и

Стефан Василев Минчев, притежаващ лична карта №641790843, издадена на 11.01.2011 от МВР – гр. София, адрес: гр. София, бул. Христофор Колумб № 9, ет.3,

в качеството ми на Управител на АББ България ЕООД,


участник в процедура за възлагане на обществена поръчка с предмет: „Доставка на електрически апарати 110кV“, реф. № PPD 17-064, Обособена позиция 4 - Доставка на комбинирани измервателни трансформатори 110 kV за монтаж на открито – 15 бр.

ДЕКЛАРИРАМЕ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажменти са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите.

Дата: 11.07.2017

Декларатор:

  
Екехарт Нойрайтер  
Управител  
АББ България ЕООД


  
Стефан Минчев  
Управител  
АББ България ЕООД

ABB Bulgaria EOOD  
Main Office  
9, Hristofor Kolumb Blvd., fl. 3  
Mladost, Sofia-grad  
1592 Sofia, Bulgaria  
Phone: +359 (0) 2 807 55 00  
Fax: +359 (0) 2 807 55 99  
Web: www.abb.bg  
E-mail: office@bg.abb.com

UIC: 831133152  
VAT Nr.: BG 831133152  
Bank details:  
ING Bank, branch Sofia  
IBAN: BG13ING891451000027317 (BGN)  
IBAN: BG60ING891451400027311 (EUR)  
BIC: INGBBG5F



03.2017

6

6