



INSTRUCTIONS FOR USE AND MAINTENANCE

MOE_G_MALT_02_GB

Portable equipment for earthing and short-circuiting

Range of use: indoor and outdoor.
Normal climatic category (N): operating temperature -25°C to + 55°C

Maintenance

To ensure the correct functioning of the device and guarantee it fulfils its essential safety role, it is essential to ensure that it is in good condition at all times.

Insulating stick or handle

- store away from light and humidity
- wipe before and after use with silicone-treated cloth
- check that it is free of scratches or traces of impact

Line clamps and earth connectors:

- clean and corrosion-free, particularly on the contact studs
- no seizing up on threaded parts: lubricate them regularly with a neutral grease
- no seizing up on mobile joints and mechanisms
- no traces of impact

Cables:

- no ~~cuts~~ perforations in the cable sheath
- do not cut strands, particularly close to connections
- free of oxidation
- seals in good condition

Care shall also be taken when handling this equipment:

- avoid knocking or dropping
- do not drag the device along the ground when transporting it
- avoid excessive or rough tightening of the connectors
- make sure that storage conditions are adequate

Repairing the equipment

Never disassemble or reassemble the main components of the device: line clamp(s), cable(s), earth end connector(s). In general, the replacement of all or part of any of these components is prohibited.

If necessary, or if in any doubt, return the complete device to FAMECA, which will check the device and repair it if necessary.

For obvious safety reasons, it is absolutely necessary to discard the entire device exposed to short-circuit current, without seeking to repair or retrieve components.

Precautions prior to use

The maximum short circuit current (Icc) admissible by an earthing or short-circuiting device will be determined by the component bearing the lowest current in the chain of the device.

This value is clearly indicated on the device on the short-circuit cable and it is the responsibility of the user to check before use if the device's Icc is appropriate to the use envisaged and the risk of short-circuiting involved.

Installing the equipment

The following steps must be followed completely and in the correct order:

Checking the absence of voltage

Switch off the line or the installation, and then check the absence of voltage using an appropriate device.

Connecting the equipment to the earth

Always begin by connecting the device's earthing clamp or vice to the installation earth system (earth network, metallic tower, earthing rod, etc...).

For screw-type clamps and vices, tighten them firmly, but not excessively or roughly.

The earthing cable must be completely unwound.

Connecting the line clamps

Using the insulating stick or handle, position and fasten the line clamps onto the conductors. For screw-type clamps, tighten them firmly, but not excessively or roughly.

All the short-circuit cables must be completely unwound and must not be tangled.

Removing the equipment

The following steps must be followed completely and in the correct order:

Removing the line clamps


Using the insulating stick or handle, unfasten and remove all the line clamps from the conductors.

Removing the earth connection

This operation must always be done last.

Storing the equipment

Clean and visually inspect the equipment.
Store it correctly in its carrying bag or case, and/or in its storage place.



ap. 206

ОТКРИТА ПРОЦЕДУРА ЗА СКЛЮЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфазиране"

Обособена позиция № 1: „Преносими заземители“



**ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА
ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“**


5. Документи за Преносими заземители за Ср.Н. за шини за ЗРУ Ср.Н. – със заземителен кабел и кабел за свързване на късо (гъвкави медни въжета) – 50 мм²

Приложение № 5.3

Декларация за съответствие, придружена с превод на български език

Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg

<p>Доставчик: SIBILLE FAMECA ELECTRIC Адрес: 815 B chemin du razas, ZI les plaines 26780 MALATAVERNE Франция</p> <p>Клиент: „ИНТЕРКОМПЛЕКС“ ООД Адрес: бул. „Пещерско шосе“ 201 4015 Пловдив България</p>		<p>ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ (NFL 00-015C)</p> <p>Декларация №: DEVSFE1500670A</p> <p>Брой стр.: 1/1</p>	
<p>Договор №: Заземления</p>			
Обозначение	Референция/тип	Количество	Стандарт
МГВ 35 мм ²	TSC35		IEC61138
МГВ 50 мм ²	TSC50		IEC61138
МГВ 95 мм ²	TSC95		IEC61138
Клема с байонетен накрайник	MT535B		IEC61230
Заземителна клема NB8 6 до 25	NB8		IEC61230
Клема Cr.H.	MT535URUB		IEC61230
PXV 1070 В	PXV		IEC60855
PXV 1150 В	PXV		IEC60855
PXV 1250 В	PXV		IEC60855
<p>С настоящата декларация гарантираме, че, освен ако изрично не са посочени изключения, изброеното оборудване съответства на изискванията на процедурата/ договора и че, след преминаване на необходимите изпитания, то напълно съответства на всички посочени стандарти, както и останалите приложими стандарти и регулатии.</p>			
<p>Мениджър – управление на качеството Име: Grira Sabri – QSE Дата: 20/10/2015 /подпись нечетлив/</p>			



Supplier : SIBILLE FAMECA ELECTRIC

Company : 815 B CHEMIN DU RAZAS
ZI les Plaines
26780 MALATAVERNE
France



**STATEMENT OF CONFORMITY
(NF L 00-015C)**

Customer : INTERCOMPLEX LTD
Company : 201 PESHTERSKO SHOSSE STR.
4015 PLOVDIV
Bulgaria

Statement no : DEV-SFE1500670A
Number of pages : 1 / 1

Designation	Reference or type	Serial or batch number	Quantity	Complies to
Cable section 35 mm ²	TSC35			IEC61138
Cable section 50 mm ²	TSC50			IEC61138
Cable section 95 mm ²	TSC95			IEC61138
Clamp MT535 with bayonet end fitting	MT535B			IEC61230
Earthing clamp 6 to 25 type NB8	NB8			IEC61230
Middle voltage clamp	MT535URUB			IEC61230
PXV 1070 B	PXV			IEC60855
PXV 1150 B	PXV			IEC60855
PXV 1250 B	PXV			IEC60855


We hereby declare, barring exceptions, reservations, or exemptions listed in this statement of conformity, that the listed supplies comply with the contract requirements and that, after completion of testing and verification, they completely satisfy all specified requirements, and applicable standards and regulations.

Supplier Quality Manager

Name and title :

На основание чл.36а ал.3 от ЗОП

Date : 20/10/2015



отр. 208

ОТКРИТА ПРОЦЕДУРА ЗА СКЛЮЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфазиране"

Обособена позиция № 1: „Преносими заземители“

ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА

ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“

5. Документи за Преносими заземители за Ср.Н. за шини за ЗРУ Ср.Н. – със заземителен кабел и кабел за свързване на късо (гъскави медни въжета) – 50мм²

Приложение № 5.4

Приложение № 5.5

Сертификат за изследване на типа, издаден съгласно процедурата за оценяване на съответствието „Изследване на типа“ в съответствие с НСИОСЛПС или еквивалентен нормативен акт на държави-членки на ЕО, на Европейската икономическа зона/Европейската асоциация за свободна търговия (EACT), с които Република България има подписани и влезли в сила споразумения за взаимно признаване на резултатите от оценяване на съответствието и приемане на промишлените продукти (заверено копие)

Протоколи от проведените проверки и изпитвания на ПЗ в рамките на процедурата за оценяване на съответствието с приложени резултати от изпитванията (заверени копия)

_____ *_____*
Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg

LABEIN-Tecnalia


• Parque Tecnológico de Bizkaia
C/ Galdio - Edificio 200
48160 - Denero (Bizkaia)
Tel. +34 94 404 14 44
Fax +34 94 404 14 45

• Vega de Tapia, 9/II
48903 - Burzetaña (Bizkaia)
Tel. +34 94 607 34 90
Fax +34 94 607 34 95

• Parque Tecnológico de Bizkaia
Edificio 101
48170 - Zamudio (Bizkaia)

• Pol. Industrial Basabe
Pabellón E-3
20500 - Aretxabaleta (Gipuzkoa)

<http://www.te-c.es>

**LABEIN FOUNDATION – ENERGY UNIT
ELECTRICAL EQUIPMENT LABORATORY****Test report**

Page 1 of 8

No CE35-08-AM-05

Short circuit current test**TEST OBJECT:**

Portable equipment for earthing and short-circuiting

DESIGNATION:

MT535URU

NB8

REQUESTED BY:

FAMECA

2 Rue Gutenberg Rixheim (France)

MANUFACTURER:

FAMECA

STANDARD:

IEC 61230:1993

RECEPTION DATE:

February 18th 2008

TESTS DATE:

February 19th-21st 2008

The test object has been subjected to the tests required by the applicant, applying the procedures specified in the standard indicated before.

THE PRESENT REPORT CONSISTS OF:

No of pages: 8 (and annex of 16)

Drawings: Annex

Photographs: Annex

Oscillograms: Annex

На основание чл.36а ал.3 от ЗОП

На основание чл.36а ал.3 от ЗОП




Head of Electrical Equipment Laboratory

This document is a copy in pdf of the original Report,
as requested by the client

Barakaldo, June 4th 2008

* The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.

* The partial reproduction of the present document is categorically forbidden without the permission in writing of de LABEIN.



INDEX


1. TEST OBJECT DESIGNATION.....	3
2. TESTS PERFORMED. STANDARD	4
3. PHASE TO PHASE SHORT-CIRCUIT TESTS.....	5
3.1. Test description.....	5
3.2. Results	6
4. PHASE TO EARTH SHORT-CIRCUIT TEST.....	7
4.1. Test description	7
4.2. Results	8

ANNEX

DRAWINGS

PHOTOGRAPHS

OSCILLOGRAMS



1. TEST OBJECT DESIGNATION

Portable equipment for earthing and short-circuiting.

Manufacturer: FAMECA

Designation:

Line clamp: MT535URU

Earth clamp: NB8

Short-circuiting cable: TFK950275 (section of 95 mm² and 2.75 m length)

Earthing cable: TFK3510 (section of 35 mm² and 10 m length)

Rated current, Ir: 25 kA, 1 s (phase-to-phase short circuit)

6 kA, 1 s (phase-to-earth short circuit)

Definition dossier reference: diMT535URU01

diNB8

diTFK02

See photographs and drawings of the test object in the annex.

2. TESTS PERFORMED. STANDARD

Short-circuit current tests.

The tests have been performed according to the procedure specified in the following standard:

- IEC 61230:1993 and CDV IEC 61230 ed. 2: December 2007 "Live working- Portable equipment for earthing or earthing and short-circuiting"


The calculation of the uncertainties of the measurements is available.

3. PHASE TO PHASE SHORT-CIRCUIT TESTS

3.1. Test description

The test is carried out according to the specifications of the manufacturer and in accordance with subclause 6.6 of the standard IEC 61230.

The scheme of the test is the following, figures in mm:



The test circuit is arranged at 2.6 m height from the ground.

According to the manufacturer, line clamps have been submitted, previously, to a salt fog test of 64 hours following IEC 68-2-11 (see CETIM CERMAT test report n° HD/HD/08E0102-5).

4 Tests with aluminium flexible cable of diameter 31 mm are performed with the following parameters:

I_{test} (r.m.s.): 25 kA

I_{test} (peak): 62.5 kA

Time: 1 s

Torque (line clamp): 20 Nm

See photographs of the test arrangement in the annex.


3.2. Results

Registered values are the following:

Oscillogramm no.	34	35	36	37
Short-time r.m.s. current I_{th} (kA)	25.8	25.8	25.6	25.7
Short-time peak value current, I_{dyn} (kA)	64.6	64.8	64.3	64.5
Duration (s)	1.005	1.005	1.005	1.006
Joule integral I^2t (AAs. 10^8)	6.92	6.96	6.82	6.86
Frequency (Hz)	50	50	50	50

Result: The test objects withstand the test current during 1 s. There is neither current interruption nor arcing during the test time.

ВАРИОС
ОРИГИНАЛА




4. PHASE TO EARTH SHORT-CIRCUIT TEST

4.1. Test description

The test is carried out according to the specifications of the manufacturer and in accordance with subclause 6.6 of the standard IEC 61230.

The scheme of the test is the following:



b: 6.5 m

a: 2 m

c: Approximately 1.5 m

19: Line cable

3: Earthing cable

2: Line clamp

1: Earth clamp

According to the manufacturer, line clamps and earth clamps have been submitted, previously, to a salt fog test of 64 hours following IEC 68-2-11 (see CETIM CERMAT test report n° HD/HD/08E0102-5).

Two tests have been performed with the following parameters:

Line conductor: Aluminium flexible cable of diameter 31 mm

Earth conductor: Earth rod 701

Test parameters:

I_{test} (r.m.s.): 6 kA
 I_{test} (peak): 15 kA
 Time: 1 s
 Torque (earth clamp): 20 Nm
 Torque (line clamp): 20 Nm

See photographs of the test arrangement in the annex.

4.2. Results

Oscillogramm no.	26	27
Short-time r.m.s. current I _{th} (kA)	6.2	6.1
Short-time peak value current, I _{dyn} (kA)	15.9	15.7
Duration (s)	1.005	1.004
Joule integral I ² t (AAs.10 ⁷)	3.99	3.93
Frequency (Hz)	50	50

Result: The test objects withstand the test current during 1 s. There is neither current interruption nor arcing during the test time.

See oscillograms in the annex.



DOSSIER D'IDENTIFICATION

Testing, Evaluation & Consultancy Services

TESTING EVALUATION OF CLOTHING

TESTING ENVIRONMENT CONSIDERATIONS

Digitized by srujanika@gmail.com

MT535URU


REFERENCES

dMT5351RU

[View Details](#)

Page 6/10

5. PLAN D'ENSEMBLE




Code pince avec visserie: MT535URUAP

Ce document est la propriété de FAMECA, il ne peut être reproduit ou communiqué sans son autorisation écrite.


Report No CE35-08-AM-05

Annex. Page 1 of 16


ВЯРНІС
ОРИГІНАЛ



cp. 217


FAMEGA		DOSSIER D'IDENTIFICATION		NB8																																																		
				DINB8																																																		
				Page 6/9																																																		
 <p>Goupille élastique Ø5,11</p>																																																						
<p>Capacité de serrage: Ø6 à 25mm Barres plates 0 à 25mm</p> <p>Étau sans visserie référence: NB8SV</p> <table border="1"> <tr> <td>Poids brut:</td> <td></td> </tr> <tr> <td>Poids usiné: 0,365kg</td> <td></td> </tr> <tr> <td colspan="2">FAMEGA</td> </tr> <tr> <td colspan="2">68 RIXHEIM / FRANCE</td> </tr> <tr> <td colspan="2">Tel. 03.89.64.54.00 ; Fax 03.89.65.43.53</td> </tr> <tr> <td colspan="2">A CREATION DU PLAN</td> <td>01/06/05</td> <td>MG</td> <td>01/06/05KR</td> </tr> <tr> <td>Matière :</td> <td>Ind.</td> <td>Modifications</td> <td>Dates</td> <td>Visas</td> </tr> <tr> <td colspan="5">Plan réalisé en DAO/CAO ne peut être modifié qu'en DAO/CAO</td> </tr> <tr> <td colspan="2">TOLERANCES GÉNÉRALES D'USAGES : SPECIFICATION PRED003</td> <td colspan="3"></td> </tr> <tr> <td>Dimensions linéaires : de 0,5 à 100 : ±0,25</td> <td>Dimensions circulaires : Jø13-Jø13</td> <td>Dimensions angulaires pour longueur côté court de l'angle de 50 à 120 mm: ±0'20'</td> <td>N° code article : NB8</td> <td>N° Code de fabrication FAB 404</td> </tr> <tr> <td>Designation: ETAU NB8</td> <td>Echelle 1</td> <td>N° du dessin 49497</td> <td>Ind. A</td> <td></td> </tr> <tr> <td colspan="5">CE PLAN EST LA PROPRIÉTÉ EXCLUSIVE DE LA SOCIÉTÉ FAMEGA. NE DOIT EN AUCUN CAS ÊTRE COPIÉ OU TRANSMIS À DES Tiers SANS NOTRE AUTORISATION écrite.</td> </tr> <tr> <td colspan="5">Ce document est la propriété de FAMEGA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.</td> </tr> </table>					Poids brut:		Poids usiné: 0,365kg		FAMEGA		68 RIXHEIM / FRANCE		Tel. 03.89.64.54.00 ; Fax 03.89.65.43.53		A CREATION DU PLAN		01/06/05	MG	01/06/05KR	Matière :	Ind.	Modifications	Dates	Visas	Plan réalisé en DAO/CAO ne peut être modifié qu'en DAO/CAO					TOLERANCES GÉNÉRALES D'USAGES : SPECIFICATION PRED003					Dimensions linéaires : de 0,5 à 100 : ±0,25	Dimensions circulaires : Jø13-Jø13	Dimensions angulaires pour longueur côté court de l'angle de 50 à 120 mm: ±0'20'	N° code article : NB8	N° Code de fabrication FAB 404	Designation: ETAU NB8	Echelle 1	N° du dessin 49497	Ind. A		CE PLAN EST LA PROPRIÉTÉ EXCLUSIVE DE LA SOCIÉTÉ FAMEGA. NE DOIT EN AUCUN CAS ÊTRE COPIÉ OU TRANSMIS À DES Tiers SANS NOTRE AUTORISATION écrite.					Ce document est la propriété de FAMEGA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.				
Poids brut:																																																						
Poids usiné: 0,365kg																																																						
FAMEGA																																																						
68 RIXHEIM / FRANCE																																																						
Tel. 03.89.64.54.00 ; Fax 03.89.65.43.53																																																						
A CREATION DU PLAN		01/06/05	MG	01/06/05KR																																																		
Matière :	Ind.	Modifications	Dates	Visas																																																		
Plan réalisé en DAO/CAO ne peut être modifié qu'en DAO/CAO																																																						
TOLERANCES GÉNÉRALES D'USAGES : SPECIFICATION PRED003																																																						
Dimensions linéaires : de 0,5 à 100 : ±0,25	Dimensions circulaires : Jø13-Jø13	Dimensions angulaires pour longueur côté court de l'angle de 50 à 120 mm: ±0'20'	N° code article : NB8	N° Code de fabrication FAB 404																																																		
Designation: ETAU NB8	Echelle 1	N° du dessin 49497	Ind. A																																																			
CE PLAN EST LA PROPRIÉTÉ EXCLUSIVE DE LA SOCIÉTÉ FAMEGA. NE DOIT EN AUCUN CAS ÊTRE COPIÉ OU TRANSMIS À DES Tiers SANS NOTRE AUTORISATION écrite.																																																						
Ce document est la propriété de FAMEGA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.																																																						

Report No CE35-08-AM-05




copy. 218

FAMECA		DOSSIER D'IDENTIFICATION		CABLE MALT																																													
				diTFK																																													
				Page 6/13																																													
5. PLAN D'ENSEMBLE																																																	
<p>a) TFK</p>																																																	
<table border="1"> <tr> <td>FAMECA</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>68 RUEHEIM / FRANCE</td> <td>B</td> <td>Rejout codes articles</td> <td>6/09/</td> <td>HF MIN</td> </tr> <tr> <td>Tel. 05 64 54 00 ; Fax 05 64 54 01</td> <td>A</td> <td>Création du plan</td> <td>25/09/</td> <td>HF MM</td> </tr> <tr> <td>Adresses :</td> <td></td> <td>Modifications</td> <td>Date de</td> <td>Vosces Verifications</td> </tr> <tr> <td>Tel. Universale</td> <td>Ind.</td> <td>Pas. tout en 040/040 ne peut être modifié qu'en DSY/040</td> <td colspan="2">A la date de conception :</td> </tr> <tr> <td>0 6 100 13225 et étiquette 013-113</td> <td></td> <td>Par code article</td> <td colspan="2">FAB 590</td> </tr> <tr> <td></td> <td></td> <td>TFK, ...</td> <td colspan="2">Ind.</td> </tr> <tr> <td colspan="5">Désignations:</td> </tr> <tr> <td colspan="5">CABLE/CONNEXIONS TUBULAIRES 1 36839 B</td> </tr> </table>					FAMECA					68 RUEHEIM / FRANCE	B	Rejout codes articles	6/09/	HF MIN	Tel. 05 64 54 00 ; Fax 05 64 54 01	A	Création du plan	25/09/	HF MM	Adresses :		Modifications	Date de	Vosces Verifications	Tel. Universale	Ind.	Pas. tout en 040/040 ne peut être modifié qu'en DSY/040	A la date de conception :		0 6 100 13225 et étiquette 013-113		Par code article	FAB 590				TFK, ...	Ind.		Désignations:					CABLE/CONNEXIONS TUBULAIRES 1 36839 B				
FAMECA																																																	
68 RUEHEIM / FRANCE	B	Rejout codes articles	6/09/	HF MIN																																													
Tel. 05 64 54 00 ; Fax 05 64 54 01	A	Création du plan	25/09/	HF MM																																													
Adresses :		Modifications	Date de	Vosces Verifications																																													
Tel. Universale	Ind.	Pas. tout en 040/040 ne peut être modifié qu'en DSY/040	A la date de conception :																																														
0 6 100 13225 et étiquette 013-113		Par code article	FAB 590																																														
		TFK, ...	Ind.																																														
Désignations:																																																	
CABLE/CONNEXIONS TUBULAIRES 1 36839 B																																																	
<p>Ce document est la propriété de FAMECA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.</p>																																																	




Test object after the first phase to phase test




Line clamps after the first phase to phase test

Report No CE35-08-AM-05




Annex, Page 4 of 16

exp. 220




Test object after the second phase to phase test




Line clamps after the second phase to phase test


Report No CE35-08-AM-05



copy. 224




Test object after the third phase to phase test




Line clamps after the third phase to phase test

Report No CE35-08-AM-05



copy. 222




Test object after the fourth phase to phase test



Line clamps after the fourth phase to phase test

Report No CE35-08-AM-05

Annex. Page 7 of 16




copy 223



[Handwritten signature]

Test arrangement for the phase to earth short-circuit tests




Earth clamp connexion to the earth rod


Report No CE35-08-AM-05

ВАРИЧОС
ОРИГИНАЛ

Annex, Page 8 of 16



с.п. 224





Earth clamp after the first phase to earth short circuit test




Line clamp after the first phase to earth short circuit test

Report No CE35-08-AM-05





Earth clamp after the second phase to earth short circuit test




Earth and line clamps after the second phase to earth short circuit test

V (eficaz/RMS)	549.97 V
I (eficaz/RMS)	6.19 kA
I (cresta/peak)	15.87 kA
I _{2-L}	3.99E+07 AAs
t _i	0.059 s
t _e	1.064 s
t _{total} (t _e -t _i)	1.005 s

Fecha / Date: 20/02/08


Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 26



Report No CE35-08-AM-05

Annex. Page 11 of 16




cpt. 227

V (eficaz/RMS)	547.32 V
(eficaz/RMS)	6.14 kA
(cresta/peak)	15.67 kA
I ₂ -I	3.93E+07 AAs
t _i	0.059 s
t _e	1.063 s
t _{total} (t _e -t _i)	1.004 s

Fecha / Date: 20/02/08


Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 27



Report No CE35-08-AM-05

Annex. Page 12 of 16




CP. 228

V (eficaz/RMS)	739.49 V
I (eficaz/RMS)	25.78 kA
I (cresta/peak)	64.58 kA
Z _t	6.92E+08 AAs
t _i	0.060 s
t _e	1.065 s
t _{total} (t _e -t _i)	1.005 s

Fecha / Date: 21/02/08


Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 34



Report No CE35-08-AM-05

Annex. Page 13 of 16




07.228

V (eficaz/RMS)	740.07 V
I (eficaz/RMS)	25.84 kA
I (cresta/peak)	64.83 kA
Z-t	6.96E+08 AAs
i _e	0.060 s
t _e	1.065 s
t _{total} (t _e -t _i)	1.005 s


Fecha / Date: 21/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 35



Report No CE35-08-AM-05





07.230

V (eficaz/RMS)	771.12 V
I (eficaz/RMS)	25.57 kA
(cresta/peak)	64.26 kA
$\int^2 I \cdot t$	6.82E+08 AAs
t_1	0.060 s
t_0	1.065 s
$t_{total} (t_0-t_1)$	1.005 s

Fecha / Date: 21/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 36




V (eficaz/RMS)	774.52 V
(eficaz/RMS)	25.66 kA
crestas/peak)	64.48 kA
Z,t	6.86E+08 AAs
t _i	0.060 s
t _e	1.066 s
t _{total} (t _e -t _i)	1.006 s


Fecha / Date: 21/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 37



Report No CE35-08-AM-05



op. 232



TEST REPORT

N° 135086 – 671357 B-Cr17/02/10

English version – Original in French

ISSUE TO

: FAMECA
2, rue Gutenberg
BP 13
68173 RIXHEIM CEDEX

OBJET

: TESTS ACCORDING TO THE STANDARD IEC 60855-1 (10:2009)
INSULATING FOAM-FILLED TUBES FOR LIVE WORKING.

Model tested

: Tubes ø28mm red and ø32mm yellow

Test date

: May 2015

Composition of this document: 19 pages

Document initially released on: July 10, 2015

Corrected on: February 10, 2017

Test supervised by:
The test technician,

D. TELLIER

На основание чл.36а ал.3 от ЗОП


This document shall not be reproduced, except in full, without the written approval of the LCIE. This document contains results related only to the item tested. It does not imply the conformity of the whole production to the item tested. Unless otherwise specified, the decision of conformity takes into account the uncertainty of measures. The LCIE's liability applies only to the French version. English version of test report n°135086-671357A. Original in French established on July 10th, 2015.

LCIE
Laboratoire Central
des Industries Electriques
Une société de Bureau Veritas

33 av du Général Leclerc
BP 8
92366 Fontenay-aux-Roses cedex
France

Tel : +33 1 40 95 00 60
Fax : +33 1 40 95 06 50
e-mail: contact@lcie.fr
www.lcie.fr

СОУДНОЕ
ПРИСУЖДАЛА
Сообщение о
согласии с
результатами
испытаний
на изоляционные
трубы для рабочих
в жилых помещениях
в соответствии с
стандартом IEC 60855-1
(10:2009) на
изолированные
трубы диаметром
28 и 32 мм красного
и желтого цветов.
Испытания проводились
в мае 2015 года.
Лаборатория Центр
по изучению электрических
индустрий (LCIE),
одной из компаний
Bureau Veritas



чп. 233



1 – TESTED PRODUCT

Two diameter tubes red 28mm and yellow 32mm.

Designation		Marking	
Tube ø28mm	Red	FAMECA ø28 037/15 CEI 60855-1	
Tube ø32mm	Yellow	FAMECA ø32 048/15 CEI 60855-1	

2 – TEST PROGRAM



The test program, established with the customer, was to realize in the local society FAMECA, under supervision of LCIE, type tests of the IEC 60855-1 of October 2009.
Crushing test on tube has been made at CETIM and validated by LCIE.

3 – EXECUTION MODALITIES

The execution modalities have been those of the corresponding paragraph of the specification above.

Chronological order of type tests:

Tests	Group 1	Group 2	Group 3	Group 4	Group 5	Group 6	Group 7
Dimensional check	<u>Note:</u> Control has not been performed on each before cutting lengths; control was performed on the control sample Group 8.						
Durability of marking	1	1	1	1	1	1	1
Visual check	2	2	2	2	2	2	2
Dielectric test after water exposition	3						
Wet test		3					
Bending test			3				
Torsion test				3			
Crushing test on tube					3		
Bending ageing test						3	
Dielectric test after mechanical ageing						4	
Dye penetration test							3



Group and samples :

Group	Number of test pieces
1	3 x 0.3m
2	3 x 1.2m (cut at 0.1)
3	3 x 2.5m
4	3 x 1.2m
5	3 x (3 x ø ext. at ±5%)mm
6	3 x 2.5m
7	3 x (100±5)mm (cut at least to 0.1m from the end of initial length of cube)
8	1 x 2m (specimen)

4 – RESULTS

The following results have been obtained:


4.1 – Dimensional check (article 5.3.3 table B.1)

Tube	Tolerance	Prescribed		Measures 1	Measures 2	Measures 3
		Min.	Max.			
Ø28mm	Ø < 30mm (± 0.5mm)	27.5mm	28.5mm	27.87mm	27.85mm	27.84mm
Ø32mm	30 ≤ Ø ≤ 40mm (± 0.55mm)	31.45mm	32.55mm	32.03mm	32.02mm	32.17mm

Satisfactory results**4.2 – Durability of marking (article 5.5.6 table B.1)**

The markings shall be rubbed for 1min, with a clean soaked in water then with a clean cloth soaked in isopropanol.


Sample test	Prescribed	Observation
Tube ø28mm	The markings must still legible and the characters do not run or smear.	Nothing to report
Tube ø32mm		Nothing to report

Satisfactory results

c17. 23

4.3 – Visual check (article 5.3.2 table B.1)

Group	Prescribed	Observation	
		Ø28	Ø32
1		Nothing to report	Nothing to report
2		Nothing to report	Nothing to report
3	Each test, each group must not have:	Nothing to report	Nothing to report
4	- Before cutting, defects in type of air bubble surface, bumps, dirt, strange body ...	Nothing to report	Nothing to report
5		Nothing to report	Nothing to report
6	- After cutting, the internal defects at the apparent section detachment of the foam (open - cracks)	Nothing to report	Nothing to report
7		Nothing to report	Nothing to report
8		Nothing to report	Nothing to report

Satisfactory results4.4 – Dielectric test after exposure to water (article 5.4.2 table B.1)

AC voltage applied: 100kV (f=50Hz)


Distance between electrode: 30cm

Duration of application: 1min

4.4.1 – With a conditioning by humidity

Before the test: Each test should be cleaned with isopropanol and dry for 15 minutes at ambient air.
 Test conditioning: 24h in water at 20 ° C.

Ø28	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1		0.8			Nothing to report
Sample.2	≤ 48	0.7	≥ 50°	90°	Nothing to report
Sample.3		0.89			Nothing to report

Satisfactory results

ctp. 23C



TEST REPORT N° 135086-671357B-Cr17/02/10

page 5

Ø32	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1	≤ 49.2	0.78	$\geq 50^\circ$	90°	Nothing to report
Sample.2		0.84			Nothing to report
Sample.3		0.81			Nothing to report


Satisfactory results4.4.2 – With a conditioning by immersion

Before the test: Each test should be cleaned with isopropanol and dry for 15 minutes at ambient air.
Test conditioning: 24h in water at 20 ° C.

Ø28	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1	≤ 48	0.77	$\geq 50^\circ$	90°	Nothing to report
Sample.2		0.67			Nothing to report
Sample.3		0.73			Nothing to report

Satisfactory results

Ø32	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1	≤ 49.2	0.81	$\geq 50^\circ$	90°	Nothing to report
Sample.2		0.81			Nothing to report
Sample.3		0.78			Nothing to report

Satisfactory results




L C I E

TEST REPORT N° 135086-671357B-Cr17/02/10

page 6

4.5 – Wet test (article 5.4.3 table B.1)

Before the test: Each test should be cleaned with isopropanol and dry for 15 minutes at ambient air..




AC voltage applied: 100kV
 Duration of application: 1h
 Average precipitation rate: 1,5mm/min
 Ambiant temperature: 19.4°C
 Water temperature: 19.0°C
 Humidity « H% » : 49.1%
 Water resistivity : 100Ω.m
 Inclination samples : 45°

Ø28	Elevated temperature (°C)		Visual check	
	Prescribed	Recorded	Prescribed	Observation
Sample.1	< 20	< 1	No flashover during the test. No sparkover or puncture. No visual sign of tracking. No erosion on the surface.	Nothing to report
Sample.2		< 1		Nothing to report
Sample.3		< 1		Nothing to report

Satisfactory results


Ø32	Elevated temperature (°C)		Visual check	
	Prescribed	Recorded	Prescribed	Observation
Sample.1	< 20	< 1	No flashover during the test. No sparkover or puncture. No visual sign of tracking. No erosion on the surface.	Nothing to report
Sample.2		< 1		Nothing to report
Sample.3		< 1		Nothing to report

Satisfactory results





4.6 – Bending test (article 5.5.1 table B.1)




Rate of the applied force: 200 N/s

Fd « Ø28mm »: 890N (pages 7 - 9)

Fd « Ø32mm »: 1100N (pages 10 - 12)

Ø28		Initial orientation at 0°						
Sample		Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			
		At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd	
Sample.1		22.44	44.23	70.05	≤ 35	21.8	25.82	
Sample.2		23.05	49.01	75.85		26.0	26.8	
Sample.3		24.52	46.50	71.87		22.0	25.4	
Sample		Residual deflection after 1min at 0N (mm)		Variation of the residual deflection / deflection at Fd (%)				
				Prescribed	Results			
Sample.1		0.25		≤ 6	0.4			
Sample.2		0.48			0.6			
Sample.3		0.27			0.4			

Satisfactory results



07.238




L C I E

Ø28	Initial orientation at 90°						
Sample	Recorded deflection after 30sec (mm))			Difference between recorded deflection after 30sec (mm)			
	At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd	
Sample.1	21.03	43.62	69.44	≤ 35	22.6	25.8	
Sample.2	24.40	49.79	76.87		25.4	27.1	
Sample.3	23.54	46.88	71.64		23.3	24.8	
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)			
				Prescribed	Results		
Sample.1	0.49			≤ 6	0.7		
Sample.2	0.29				0.4		
Sample.3	0.43				0.6		

Satisfactory results

Ø28	Initial orientation at 180°						
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			
	At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd	
Sample.1	23.11	46.63	73.48	≤ 35	23.5	26.9	
Sample.2	25.62	48.92	69.0		23.3	20.1	
Sample.3	25.13	47.96	73.18		22.8	25.2	
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)			
				Prescribed	Results		
Sample.1	0.46			≤ 6	0.6		
Sample.2	0.53				0.8		
Sample.3	0.47				0.6		

Satisfactory results



97.240



L C I E

Ø28	Initial orientation at 270°						
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			
	At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	Prescribed	between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd	
Sample.1	22.16	44.86	72.40	≤ 35	22.7	27.5	
Sample.2	23.52	47.57	75.92		24.1	28.4	
Sample.3	24.70	48.42	73.96		23.7	25.5	
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)			
				Prescribed	Results		
Sample.1	0.59			≤ 6	0.8		
Sample.2	0.55				0.7		
Sample.3	0.45				0.6		


Satisfactory results

Ø28	Variation of the deflection (%)									
	Prescribed	0° → 90°			90° → 180°			180° → 270°		
		1/3Fd	2/3Fd	Fd	1/3Fd	2/3Fd	Fd	1/3Fd	2/3Fd	
Sample.1	≤ 15	-6.3	-1.4	-0.9	9.9	6.9	5.8	-4.1	-1.8	-1.5
Sample.2		5.9	1.6	1.3	5.1	-1.7	-10.2	-8.2	-2.8	10.0
Sample.3		-4.0	0.8	-0.3	6.7	2.3	2.1	-1.7	1.0	1.1

Satisfactory results

Ø28	F = 1740 N / t = 30sec		Breaking load (N)
	Prescribed	Observations	
Sample.1	No sign of failure	Nothing to report	2500
Sample.2		Nothing to report	2400
Sample.3		Nothing to report	2500

Satisfactory results



op. 241




1 C 1 E

Ø32		Initial orientation at 0°									
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd			
	At 367N (1/3Fd)	At 733N (2/3Fd)	At 1100N (Fd)	Prescribed							
Sample.1	19.77	41.23	64.72	≤ 35	21.5	23.5	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd			
Sample.2	19.94	41.31	65.73		21.4	24.4					
Sample.3	19.58	41.69	65.70		22.1	24.0					
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)							
				Prescribed	Results						
Sample.1	1.01			≤ 6	1.6						
Sample.2	0.39				0.6						
Sample.3	0.41				0.6						

Satisfactory results

Ø32		Initial orientation at 90°									
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd			
	At 367N (1/3Fd)	At 733N (2/3Fd)	At 1100N (Fd)	Prescribed							
Sample.1	20.55	42.42	64.39	≤ 35	21.9	22.0	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd			
Sample.2	19.75	41.17	65.79		21.4	24.6					
Sample.3	20.05	42.30	65.86		22.3	23.6					
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)							
				Prescribed	Results						
Sample.1	0.49			≤ 6	0.8						
Sample.2	0.37				0.6						
Sample.3	0.50				0.8						

Satisfactory results



ctj. 242




Ø32		Initial orientation at 180°						
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)				
	At 367N (1/3Fd)	At 733N (2/3Fd)	At 1100N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd		
Sample.1	19.13	43.52	65.85	≤ 35	24.4	22.3		
Sample.2	19.40	41.00	62.12		21.6	21.1		
Sample.3	19.53	41.76	64.38		22.2	22.6		
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)				
				Prescribed	Results			
Sample.1	0.35			≤ 6	0.5			
Sample.2	0.43				0.7			
Sample.3	0.46				0.7			

Satisfactory results

Ø32		Initial orientation at 270°						
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)				
	At 367N (1/3Fd)	At 733N (2/3Fd)	At 1100N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd		
Sample.1	21.07	42.03	64.83	≤ 35	21.0	22.8		
Sample.2	19.52	42.09	65.78		22.6	23.7		
Sample.3	20.52	42.00	65.60		21.5	23.6		
Sample	Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)				
				Prescribed	Results			
Sample.1	0.04			≤ 6	< 0.1			
Sample.2	0.57				0.9			
Sample.3	0.53				0.8			

Satisfactory results



- 243



L C I E

TEST REPORT N° 135086-671357B-Cr17/02/10

page 12

Ø32	Variation of the deflection (%)									
	Prescribed	0° → 90°			90° → 180°			180° → 270°		
		1/3Fd	2/3Fd	Fd	1/3Fd	2/3Fd	Fd	1/3Fd	2/3Fd	Fd
Sample.1	≤ 15	3.9	2.9	-0.5	-6.9	2.6	2.3	10.1	-3.4	-1.5
Sample.2		-0.9	-0.3	1.6	-1.8	-0.4	-5.6	0.6	2.7	5.9
Sample.3		2.4	1.5	0.2	-2.6	-1.3	-2.2	5.1	0.6	1.9

Satisfactory results

Ø32	F= 1740 N / t = 30sec		Breaking load (N)
	Prescribed	Observations	
Sample.1	No sign of failure	Nothing to report	3390
Sample.2		Nothing to report	3330
Sample.3		Nothing to report	3250

Satisfactory results

ap. 244




L C I E

TEST REPORT N° 135086-671357B-Cr17/02/10

page 13

4.7 - Torsion test (article 5.5.2 table B.1)




Ø28	Angle of deflection after 30s at Cd = 35N.m (°)			Residual angle of deflection after 1min at Cd = 0Nm (°)	
	Prescribed	Recorded	Observations	Prescription	Recorded
Sample.1	< 35	8.5	Nothing to report	< 1	< 0.1
Sample.2		9.5	Nothing to report		0.5
Sample.3		10.0	Nothing to report		0.1

Satisfactory results

Ø28	after 30s at Cr = 70N.m		Rise to failure (N.m)
	Prescribed	Observations	
Sample.1	No cracks	Nothing to report	> 95 *
Sample.2		Nothing to report	> 92 *
Sample.3		Nothing to report	> 93 *

Satisfactory results

* Samples were slipped into their mountings, impossible to achieve the value of the breaking torque.



07-245





Ø32	Angle of deflection after 30s at Cd = 40N.m (°)			Residual angle of deflection after 1min at Cd = 0 N.m (°)	
	Prescribed	Recorded	Observations	Prescribed	Recorded
Sample.1	< 35	8.0	Nothing to report	< 1	0.4
Sample.2		9.0	Nothing to report		0.5
Sample.3		10.0	Nothing to report		0.5

Satisfactory results

Ø32	after 30s at Cr = 80N.m		Rise to failure (N.m)
	Prescription	Observations	
Sample.1	No cracks	Nothing to report	130
Sample.2		Nothing to report	129
Sample.3		Nothing to report	113

Satisfactory results



ctp 246

**4.8 – Crushing test (article 5.5.3 table B.1)**

Length of test pieces: 150mm

Speed: 2mm/min

Temperature: 23±2°C

Humidity : 50±10%

Fd : Minimum value of F where first linearity is lost related to a loss of $\Delta F \geq 0,01 F_d$ Fr : Maximum value of F recorded during the 3 first minutes of test (displacement $\leq 6\text{mm}$)


Ø28	Fd (N)		Fr (N)	
	Prescribed	Recorded	Prescribed	Recorded
Sample.1	> 700	4884	> 1400	3376
Sample.2		5119		3318
Sample.3		4878		4338

Satisfactory results

Ø32	Fd (N)		Fr (N)	
	Prescribed	Recorded	Prescribed	Recorded
Sample.1	> 700	3407	> 1400	3117
Sample.2		1256		2318
Sample.3		2448		4338

Satisfactory results

Test reports issued by CETIM CERMA numbers MAT0005232 and MAT0005272 dated of June 15, 2015.


Used machine: Wolpert TT1220 checked in June 2015 regulated provider.Cell type: 25kN



TEST REPORT N° 135086-671357B-Cr17/02/10

page 16

4.9 – Bending ageing test (article 5.5.4.1 table B.1)



Applied force ø28mm : 1100N

Applied force ø32mm : 1100N

Frequency : 2 cycles/min

Number of cycles : 1000 for each orientation

Number of directions : 4
(0° ; 90° ; 180° ; 270°)

Ø28	Prescribed	Observation after 1000 cycles			
		0°	90°	180°	270°
Sample.1	No signs of deterioration, or have any permanent set	Nothing to report	Nothing to report	Nothing to report	Nothing to report
Sample.2		Nothing to report	Nothing to report	Nothing to report	Nothing to report
Sample.3		Nothing to report	Nothing to report	Nothing to report	Nothing to report

Satisfactory results


Ø32	Prescribed	Observation after 1000 cycles			
		0°	90°	180°	270°
Sample.1	No signs of deterioration, or have any permanent set	Nothing to report	Nothing to report	Nothing to report	Nothing to report
Sample.2		Nothing to report	Nothing to report	Nothing to report	Nothing to report
Sample.3		Nothing to report	Nothing to report	Nothing to report	Nothing to report

Satisfactory results





ВЯРНО С
ОРИГИНАЛА





TEST REPORT N° 135086-671357B-Cr17/02/10


page 17

4.10 – Dielectric test after mechanical ageing (article 5.5.4.1 table B.1)

Cutting of 2 test pieces of 0.3m from each half of the samples having undergone the 4000 cycles bending test.

Conditioning : 168h at 23°C and 93% HR

At the end of the conditioning period, dielectric test at the ambient conditions of the test area after the test pieces have been wiped with a clean dry lint free cloth and after the ends of the test pieces have been covered with conducting adhesive tape.



AC voltage test : 100kV (f=50Hz)

Distance of electrode : 30cm


Duration of application : 1min

Ø28		Current I (μ A)		Phase angle		Contournement
		Prescribed	Recorded	Prescribed	Recorded	
Sample.1	.1	≤ 48	0.73	≥ 50°	90°	Nothing to report
	.2		0.79			Nothing to report
Sample.2	.1	≤ 48	0.80	≥ 50°	90°	Nothing to report
	.2		0.84			Nothing to report
Sample.3	.1	≤ 48	0.79	≥ 50°	90°	Nothing to report
	.2		0.80			Nothing to report

Satisfactory results

Ø32		Current I (μ A)		Phase angle		Contournement
		Prescribed	Recorded	Prescribed	Recorded	
Sample.1	.1	≤ 48	0.82	≥ 50°	90°	Nothing to report
	.2		0.72			Nothing to report
Sample.2	.1	≤ 48	0.74	≥ 50°	90°	Nothing to report
	.2		0.79			Nothing to report
Sample.3	.1	≤ 48	0.81	≥ 50°	90°	Nothing to report
	.2		0.71			Nothing to report

Satisfactory results





TEST REPORT N° 135086-671357B-Cr17/02/10

page 18

4.11 – Dye penetration test (article 5.5.5 table B.1)

Conditioning : Immersing the specimens in a container containing a coloring solution in water, under vacuum (pressure less than 6500Pa) for one hour.

The test pieces after removed from the solution are dried for 24 hours at a temperature of 35 ° C.


After drying the test pieces are cut to 5 mm from each end, and then cut longitudinally.

Ø28	Pictures		
	Sample 1	Sample 2	Sample 3
	Prescribed	Observation	
Sample.1	No sign of solution dye penetration in either the foam, at the junction of the foam and the tube, or in the tube.	Nothing to report	
Sample.2		Nothing to report	
Sample.3		Nothing to report	

Satisfactory results

Ø32	Pictures		
	Sample 1	Sample 2	Sample 3
	Prescribed	Observation	
Sample.1	No sign of solution dye penetration in either the foam, at the junction of the foam and the tube, or in the tube.	Nothing to report	
Sample.2		Nothing to report	
Sample.3		Nothing to report	

Satisfactory results



07.200

ОТКРИТА ПРОЦЕДУРА ЗА СКЛОЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфазиране"

Обособена позиция № 1: „Преносими заземители“

ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА

ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“

5. Документи за Преносими заземители за Ср.Н. за шини за ЗРУ Ср.Н. – със заземителен кабел и кабел за свързване на късо (гъвкави медни въжета) – 50 mm²

Приложение № 5.6

Инструкция за употреба на български език съгласно НСИОСЛПС, включително изисквания за правилно поддържане и използване и изисквания за периодичност на необходимите контролни изпитвания по време на експлоатация

Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg



ИНСТРУКЦИИ ЗА УПОТРЕБА И ПОДДРЪЖКА

Преносимо оборудване за заземяване и късо съединение

Обхват на употреба: на закрито и на открито.

Нормална климатична категория (N): работна температура -25°C to +55°C.

Поддръжка

За да сте сигури, че оборудването ще функционира правилно и ще изпълни съществената си роля по отношение на безопасността, е необходимо да гарантите, че във всеки един момент то е добро състояние:

Изолационна щанга и/или ръкохватка

- Съхранявайте далеч от пряка светлина и влага;
- Преди и след употреба почистете с кърпа със спирин;
- Проверете дали няма драскотини или следи от удар.
- Фазови клепи и заземителни накрайници
- чисти и без корозия, особено на контактните болтове;
- без ползване на труби частици върху разбованите части, редовно ги омасливайте с неутрална греч;
- без разлабване на мобилните връзки и механизми;
- без следи от удар.

Забележки:

- без прорези или отвори в изолацията на кабела;

- без преучуване на проводниците, особено в близост до връзките;

- без окисяване;

- добро състояние на оплетката.

Необходимо е с оборудването да се работи внимателно:

Избегвайте удряне или изпускане

- Не влагайте оборудването по земята при местне

- Избегвайте прекомерно или трубо затягане на свързващите елементи

- Уверете се, че условията за съхранение са подходящи

Ремонт на оборудването

Никога не разглобявайте или сглобявайте повторно основните компоненти на устройството: клепма (и), кабел(ите) заземителния(ите) накрайник(и). Най-общо, замяната на всички или някои от тези компоненти е забранена.



Съхранявайте го правилно в съответния калъф или куфар или на съответното място за съхранение.

FAMECA

2 rue Gutenberg -- BP13 -- 68173 RIXHEIM – France – Tel.: +33-(0)-3-89-64-54-00 / Fax: +33-(0)-3-89-65-43-33
e-mail: adv@fameca.com / web: www.sf-electric.com



При необходимост, или при възникване на някакви съмнения, върнете цялото устройство на FAMECA, където ще го проверят и, ако е необходимо, ремонтират.
По очевидни причини, свързани с безопасността, е абсолютно необходимо да използвате цялото устройство, което е било изложено на ток на късо съединение, без да се опитвате да ремонтирате или подменяте негови компоненти.

Предпазни мерки преди употреба:

Максималният ток на късо съединение (Isc), приемлив за дадено устройство за заземяване или късо съединение, се определя от компонента, изтържащ на най-нисък ток във Веригата на устройството.

Тази стойност за съответното устройство е ясно посочена върху кабела за свързване на късо съединение и е отговорност на потребителя, преди да пристъпи към употреба, да провери дали Isc на устройството е подходящ за предвидената употреба и съществуващия рисков от късо съединение.

Монтаж на оборудването:

Необходимо е изцяло и в съответната последователност да извършите следните стъпки:
Съвръзане на клемите
Изключете захранващата линия или инсталациите, след което проверете отсъствието на напрежение чрез подходящо устройство.
Съвръзане на оборудването към земя
Биннати започнайте чрез свързване на заземителната клема на устройството или заземителна пета на заземителна система на инсталациите (заземителна мрежа, метална кула, заземителен кот и пр.).
При винтови клепи или заземителни пети, ги затягайте здраво, но не прекалено или грубо.

Заземителният кабел трябва да бъде изцяло развит.
Демонтаж на клемите
Като използвате изолационната шанга или ръкохватка, поставете и закопчайте клемите на проводниците. При винтови клепи, ги затягайте здраво, но не прекалено или грубо.
Всички кабели за късо съединение трябва да бъдат напълно развити и да не се оплитат.

Демонтаж на оборудването:

Необходимо е изцяло и в съответната последователност да извършите следните стъпки:
Демонтаж на заземителния накрайник
Почистете и прегладете оборудването
Съхранявайте го в съответния калъф или куфар

При операция трябва внимателно да се извърши последна съхранение.

МЕТОДИКА И СРОКОВЕ ЗА ПЕРИОДИЧНИ ИЗПИТАНИЯ В ПЕРИОДА НА ЕКСПЛОАТАЦИЯ НА ПРЕНОСИМИ ЗАЗЕМИТЕЛИ

Съгласно Наредба № 22 от 8 май 2006 г. за изпитване на електрозащитни средства в експлоатация, Раздел II - Изпитване, проверки и оценяване на резултатите, преносимите заземители не се подлагат на периодични изпитвания в лаборатория.

Когато преносимите заземители са комплектовани с щанги, е необходимо изолационните щанги да бъдат изпитвани на всеки 12 месеца в оторизирана лаборатория съгласно изискванията на приложимите стандарти и регулатции, както следва:

BDC EN 62193:2004 Работа под напрежение.

Телескопични пръти и телескопични измервателни пръти/ IEC 62193

**BDC EN 60855:2001 Изолиращи пенопалънни тръби и
масивни щанги за работа под напрежение/ IEC 60855-1**

ASTM F 1826

ASTM F711.

Преди всяко използване на заземителя се извършва оглед и проверка за:

1. наличието и състоянието на всички елементи на заземителя - проводници (въжета) и предпазна обвивка (шлаух), присъединителни клеми;
2. видимо изменение на цвета на проводниците и/или следи от преминал през заземителя ток на късо съединение;
3. състоянието на изолиращата щанга за поставяне на заземителите.

Преносим заземител с установени при огледа дефекти се маркира за несъответствие и не се допуска за употреба. От употреба се изважда и заземител, който е бил подложен на еднократно въздействие от ток на късо съединение.

При необходимост, или при възникване на някакви съмнения, върнете изделието на производителя или на негов оторизиран представител, където ще го проверят и, ако е необходимо, ремонтират.

Оторизиран представител на SFE International за българския пазар е фирма „Интеркомплекс“ ООД, гр. Пловдив.

гр. Пловдив

29.05.2020 г.

На основание чл.36а ал.3 от ЗОП

Упр

ер. 202

ОТКРИТА ПРОЦЕДУРА ЗА СКЛОЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфазиране"

Обособена позиция № 1: „Преносими заземители“



**ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА
ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“**

6. Документи за Преносими заземители за ВН за шини за уредби 110 kV – със заземителен кабел и кабел за свързване на късо (гъвкави медни въжета) – 95 mm²

Приложение № 6.1

Последно издание на каталога на производителя


Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg



TECHNICAL SHEET

■ MT535URU

→ Screw clamp for bare MV overhead lines



► STANDARD(S)

IEC 61230

► USE

For short-circuiting and earthing bare overhead lines from the post.

► SPECIFICATIONS

Clamping range on line conductor 3 to 32 mm.

Max Isc : 25 kA/1s.



Material : Aluminium.

The central clamp can be fitted with one or two attachment rods for one or two extra phase clamps.

DMT535URU : Made to measure earthing and short-circuiting device please contact us.

► ADVANTAGES

Lightweight, very compact clamp.



Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne France
+33 (0)4 75 50 58 00 - www.sfe-electric.com





TECHNICAL SHEET

Reference	Description	Dimensions (mm)	Weight (g)
MT535URUAP	Clamp with AP end fitting (hexagonal 12 mm)	44 x 100 x 180	620
MT535URUB	Clamp with B end fitting (VDE-type bayonet)	44 x 100 x 180	620
MT535URUCR	Clamp with CR end fitting (ring for hooked stick)	44 x 100 x 180	620
MT535URUCR1	Clamp with CR end fitting and 1 attachment rod	97 x 100 x 180	720
MT535URUCR2	Clamp with CR end fitting and 2 attachment rods	150 x 100 x 180	850
MT535URUAP2	Clamp with CR end fitting and 2 attachment rods	150 x 100 x 180	850
MT535URUB2	Clamp with B end fitting and 2 attachment rods	150 x 100 x 180	850

TABLE LEGEND

Other end fittings available on request.

Document not contractually binding, errors and omissions excepted.



8158, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sfelectric.com



ELECTRICAL SAFETY PRODUCTS

CDR. 204



TECHNICAL SHEET

■ NB8

→ Earthing clamp



☒ STANDARD(S)

IEC 61230

☒ USE

For connection to the earthing conductor. Can be positioned on the earth rod (type 701 or PTT130).

☒ SPECIFICATIONS

Made of aluminium bronze
Contact pad for cable lug for TFK type cable.
M10 stainless steel screws included.

Reference	Description	Capacity	Max. Isc	Material	Dimensions (mm)	Weight (kg)
NB8	Earthing clamp	Ø 6 to 27 mm / flat 0 to 25 mm / hexagonal 19 mm	20 kA/1 s	cupro-alu	100 x 100 x 40	0,5

Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sf-electric.com





TECHNICAL SHEET

■ PXV

→ Connectable insulating sticks made of Ø
32 mm tube

► STANDARD(S)

IEC 60855-1 / EN 50508

► USE

All weather use.

- No-voltage testing.
- Earthing on MV/LV lines and substations.
- Disconnector operation.
- All work involving medium mechanical loads.

► SPECIFICATIONS

Made up of 1, 2, 3 or 4 sections with :

- Fibreglass composite tube, Ø 32 mm, polyurethane foam-filled, compliant with IEC 60855 (series tested against penetration of humidity).

Longitudinal dielectric strength 100 kV/30 cm guaranteed in humid atmosphere.

- Screw connectors ref. S37, light alloy.

- Elastomer hand guard marks the gripping zone.

PVX sticks are supplied off the shelf with these end fittings:


- U : notched universal
- APV : multi-purpose, 12 mm 6-sided with automatic locking
- B : bayonet.
- others : on request.

Please specify when ordering.

Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sf-electric.com



Division






TECHNICAL SHEET

ADVANTAGES


Ribbed non-slip shaft.

Reference	Description	Overall length (m)	Insulating length (mm)	Weight (kg)	Number of elements	Max voltage EN 50508	Cover
PXVH100	Stick shaft PXVH for insulating stick PXV	1,00	300	0,70			
PXVH150	Stick shaft PXVH for insulating stick PXV	1,50	500	0,95			
PXVH188	Stick shaft PXVH for insulating stick PXV	1,88	680	1,10			
PXVH200	Stick shaft PXVH for insulating stick PXV	2,00	800	1,20			
PXVH250	Stick shaft PXVH for insulating stick PXV	2,50	1100	1,50			
PXVH300	Stick shaft PXVH for insulating stick PXV	3,00	1600	1,75			
PSM100	Stick extension PSM (intermediary element) for insulating stick PXV	1,00	850	0,80			
PSM150	Stick extension PSM (intermediary element) for insulating stick PXV	1,50	1385	1,00			
PSM188	Stick extension PSM (intermediary element) for insulating stick PXV	1,88	1730	1,20			
PSM200	Stick extension PSM (intermediary element) for insulating stick PXV	2,00	1850	1,30			
PSM250	Stick extension PSM (intermediary element) for insulating stick PXV	2,50	2350	1,50			
PSM300	Stick extension PSM (intermediary element) for insulating stick PXV	3,00	2850	1,80			
PSM100*	Upper element PSM for insulating stick PXV	1,00	850				
PSM150*	Upper element PSM for insulating stick PXV	1,50	1385				
PSM188*	Upper element PSM for insulating stick PXV	1,88	1730				
PSM200*	Upper element PSM for insulating stick PXV	2,00	1850				
PSM250*	Upper element PSM for insulating stick PXV	2,50	2350				
PSM300*	Upper element PSM for insulating stick PXV	3,00	2850				
PXV1080*	Connectable insulating stick PXV	0,80	550	0,50	1	15 kV	HTR1950
PXV1125*	Connectable insulating stick PXV	1,25	1000	0,90	1	45 kV	H10

Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sfelectric.com



Division






TECHNICAL SHEET

Reference	Description	Overall length (m)	Insulating length (mm)	Weight (kg)	Number of elements	Max voltage EN 50508	Cover
PXV1150*	Connectable insulating stick PXV	1,50	1100	1,00	1	45 kV	H10
PXV1200*	Connectable insulating stick PXV	2,00	1300	1,40	1	66 kV	H11
PXV1250*	Connectable insulating stick PXV	2,50	1800	1,60	1	132 kV	HTR12750
PXV1300*	Connectable insulating stick PXV	3,00	2000	2,00	1	150 kV	H12
PXV2200*	Connectable insulating stick PXV	2,00	1300	1,50	2	66 kV	H30
PXV2300*	Connectable insulating stick PXV	3,00	2000	2,10	2	150 kV	H31
PXV2400*	Connectable insulating stick PXV	4,00	2800	2,60	2	220 kV	H32
PXV2500*	Connectable insulating stick PXV	5,00	3600	3,30	2	220 kV	H20
PXV2600*	Connectable insulating stick PXV	6,00	4600	4,10	2	480 kV	H21
PXV3300*	Connectable insulating stick PXV	3,00	2300	2,15	3	150 kV	H30
PXV3450*	Connectable insulating stick PXV	4,50	3500	2,90	3	220 kV	H31
PXV3600*	Connectable insulating stick PXV	6,00	4800	4,30	3	480 kV	H32
PXV4400*	Connectable insulating stick PXV	4,00	3300	3,20	4	220 kV	H30
PXV4600*	Connectable insulating stick PXV	6,00	5000	4,50	4	480 kV	H31
PXV4750*	Connectable insulating stick PXV	7,50	6300	5,20	4	480 kV	H31
PXV4800*	Connectable insulating stick PXV	8,00	6800	5,40	4	480 kV	H32

TABLE LEGEND

* Add the end fitting code at the end of the reference (ex : PSM250U / PXV3450APV).

Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sf-electric.com





TECHNICAL SHEET

■ Flexible copper cables

→ Flexible copper earthing and short-circuiting cables

STANDARD(S)

IEC / EN 61138

USE

Cable for portable earthing and short-circuiting devices according to IEC 61230 (EN 61230).

SPECIFICATIONS

TSC type : extra flexible PVC sheathed copper cable (ST11) for use from -25°C to +55°C.

SX type : silicone sheathed copper cable for use from -40°C to + 70°C.

Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sf-electric.com



97-253



TECHNICAL SHEET

Reference	Description	Cable cross-section	Ø over copper core	Cable heats up to 350°C at end of s/c	Cable heats up to 700°C at end of s/c	Item n° with silicone sheath	Weight (g)
TSC16	Flexible copper earthing and short-circuiting cables	16 mm ²	5 mm	4 kA/0,5s - 3 kA/1s	6 kA/0,5s - 4 kA/1s	SX016	160
TSC25	Flexible copper earthing and short-circuiting cables	25 mm ²	6,4 mm	6,5 kA/0,5s - 4,5 kA/1s	9,5 kA/0,5s - 6,5 kA/1s	SX025	300
TSC35	Flexible copper earthing and short-circuiting cables	35 mm ²	8,2 mm	9,5 kA/0,5s - 6,5 kA/1s	13 kA/0,5s - 10,5 kA/1s	SX035	350
TSC40	Flexible copper earthing and short-circuiting cables	40 mm ²	8,2 mm	10,5 kA/0,5s - 7,5 kA/1s	15 kA/0,5s - 9 kA/1s	/	350
TSC50	Flexible copper earthing and short-circuiting cables	50 mm ²	9,2 mm	13 kA/0,5s - 9,5 kA/1s	18,5 kA/0,5s - 13 kA/1s	SX050	550
TSC70	Flexible copper earthing and short-circuiting cables	70 mm ²	12 mm	18,5 kA/0,5s - 13 kA/1s	26 kA/0,5s - 18,5 kA/1s	SX070	750
TSC75	Flexible copper earthing and short-circuiting cables	75 mm ²	12,2 mm	20 kA/0,5s - 14 kA/1s	28 kA/0,5s - 20 kA/1s	/	800
TSC95	Flexible copper earthing and short-circuiting cables	95 mm ²	13 mm	25 kA/0,5s - 18 kA/1s	35,5 kA/0,5s - 25 kA/1s	SX095	980
TSC120	Flexible copper earthing and short-circuiting cables	120 mm ²	14,8 mm	31,5 kA/0,5s - 22,5 kA/1s	45 kA/0,5s - 31,5 kA/1s	SX120	1305
TSC150	Flexible copper earthing and short-circuiting cables	150 mm ²	18 mm	40 kA/0,5s - 28 kA/1s	56 kA/0,5s - 40 kA/1s	SX150	1620
TSC10	Flexible copper earthing and short-circuiting cables	10 mm ²	4 mm	2,6 kA/0,5s - 1,9 kA/1s	3,7 kA/0,5s - 2,6 kA/1s	/	100

Document not contractually binding, errors and omissions excepted.



815B, chemin de Razas - 26780 Malataverne - France
+33 (0)4 75 90 58 00 - www.sfe-electric.com



070-260

ОТКРИТА ПРОЦЕДУРА ЗА СКЛЮЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфаизиране"

Обособена позиция № 1: „Преносими заземители“



**ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА
ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“**

6. Документи за Преносими заземители за ВН за шини за уредби 110 kV – със заземителен кабел и кабел за свързване на късо (гъвкави медни въжета) – 95 mm²

Приложение № 6.2

*Чертежи с размери и инструкция за експлоатация на български език съгласно
т. 4.10 от БДС EN 61230:2008*



Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg






ЧЕРТЕЖ



Продукт: Преносим заземител за шини в електрически уредби 110 кВ

Съкратено наименование на материала: Заземители за шини В.Н.


Изпълнение: ПЗ ЕУ 110кВ 3x3,5 м. + 5 м.



**Устройство за затягане на фазовата съединителна клема
(съгласно DIN 48087)**



стр. 261



ИНСТРУКЦИИ ЗА УПОТРЕБА И ПОДДРЪЖКА

Преносимо оборудване за заземяване и късо съединение

При необходимост, или при възникване на някакви съмнения, върнете цялото устройство на FAMECA, където ще го проверят и, ако е необходимо, ремонтират.
По очевидни причини, свързани с безопасността, е абсолютно необходимо да извадите цялото устройство, кое то е било изложено на ток на късо съединение, без да се опитвате да ремонтирате или подменяте негови компоненти.

Поддръжка

За да сте сигури, че оборудването ще функционира правилно и ще изпълни съществената си роля по отношение на безопасността, е необходимо да гарантирате, че във всеки един момент то е добро състояние:

Изолационна щанга или ръковдатка

- Съхранявайте дланчето от пръка светлина и влага;
- Преди и след употреба почистете сърпата със силник;
- Проверете дали няма драскотини или следи от удар.
- Чисти и без корозия, особено на контактните болтове;
- без полепване на труби частици върху разбованите части, редовно ги омаслявайте с неутрална трес;
- без разхлабане на мобилните връзки и механизми;
- без следи от удар.

Кабели

- без пропривези или отвори в изолацията на кабела;
- без прекуване на проводниците, особено в близост до връзките;
- без окисляване;
- добро състояние на оплетката.

Необходимо е с оборудването да се работи внимателно:

- Избягвайте удари или изпускане
- Не влагайте оборудването под земята при мъстение
- Избегвайте прекомерно или трубо затягане на свързващите елементи
- Уверете се, че условията за съхранение са подходящи

Ремонт на оборудването

Никога не разлобявайте или слобобнайте повторно основните компоненти на устройството: клеми (и), кабел(ите) заземителни(и) изолационни(и) и т.н. Най-общо, замяната на всички или няколко от тези компоненти е забранена.

FAMECA

Съхранение на оборудването
Понисте и прегледайте оборудването.
Съхранявайте го правилно в съответния калъф или куфар или на съответното място за съхранение.

e-mail: adv@fameca.com / web: www.sf-selectric.com

ДОКУМЕНТ
ЗА
ПОДДРЪЖКА
С2

СГ. 262



INSTRUCTIONS FOR USE AND MAINTENANCE

	MDE_G_MALI_02_6B
--	------------------

Portable equipment for earthing and short-circuiting

Range of use: indoor and outdoor.

Normal climatic category (N); operating temperature -25°C to + 55°C

Maintenance

To ensure the correct functioning of the device and guarantee it fulfils its essential safety role, it is essential to ensure that it is in good condition at all times:

Insulating stick or handle

- store away from light and humidity
- wipe before and after use with a silicone-treated cloth
- check that it is free of scratches or traces of impact

Line clamps and earth connectors:

- clean and corrosion-free, particularly on the contact studs
- no seizing up on threaded parts: lubricate them regularly with a neutral grease
- no seizing up on mobile joints and mechanisms
- no traces of impact

Cables:

- no cuts or perforations in the cable sheath
- no cut strands, particularly close to connections
- free of oxidation
- seals in good condition

Care shall also be taken when handling this equipment:

- avoid knocking or dropping
- do not drag the device along the ground when transporting it
- avoid excessive or rough tightening of the connectors
- make sure that storage conditions are adequate

Repairing the equipment

Never disassemble or reassemble the main components of the device: line clamp(s), cable(s), earth end connector(s). In general, the replacement of all or part of any of these components is prohibited.

If necessary, or if in any doubt, return the complete device to FAMECA, which will check the device and repair it if necessary.

For obvious safety reasons, it is absolutely necessary to discard the entire device exposed to short-circuit current, without seeking to repair or retrieve components.

Precautions prior to use

The maximum short circuit current (Icc) admissible by an earthing or short-circuiting device will be determined by the component bearing the lowest current in the chain of the device.

This value is clearly indicated on the device on the short-circuit cable and it is the responsibility of the user to check before use if the device's Icc is appropriate to the use envisaged and the risk of short-circuiting involved.

Installing the equipment

The following steps must be followed completely and in the correct order:

Checking the absence of voltage

Switch off the line or the installation, and then check the absence of voltage using an appropriate device.

Connecting the equipment to the earth

Always begin by connecting the device's earthing clamp or vice to the installation earth system (earth network, metallic tower, earthing rod, etc.).

For screw-type clamps and vices, tighten them firmly, but not excessively or roughly.

The earthing cable must be completely unwound.

Connecting the line clamps

Using the insulating stick or handle, position and fasten the line clamps onto the conductors. For screw-type clamps, tighten them firmly, but not excessively or roughly.

All the short-circuit cables must be completely unwound and must not be tangled.

Removing the equipment

The following steps must be followed completely and in the correct order:

Removing the line clamps


Using the insulating stick or handle, unfasten and remove all the line clamps from the conductors.

Removing the earth connection

This operation must always be done last.

Storing the equipment

Clean and visually inspect the equipment.
Store it correctly in its carrying bag or case, and/or in its storage place.



263

ОТКРИТА ПРОЦЕДУРА ЗА СКЛОЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфазиране"

Обособена позиция № 1: „Преносими заземители“

ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА
ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“


6. Документи за Преносими заземители за ВН за шини за уредби 110 kV – със заземителен кабел и кабел за свързване на късо (гъвкави медни въжета) – 95 mm²

Приложение № 6.3

Декларация за съответствие, придруженна с превод на български език

Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg

<p>Доставчик: SIBILLE FAMECA ELECTRIC Адрес: 815 B chemin du razas, ZI les plaines 26780 MALATAVERNE Франция</p>		<p>ДЕКЛАРАЦИЯ ЗА СЪОТВЕТСТВИЕ (NF L 00-015C)</p>																																										
<p>Клиент: „ИНТЕРКОМПЛЕКС“ ООД Адрес: бул. „Пещерско шосе“ 201 4015 Пловдив България</p>		<p>Декларация №: DEVSFE1500670A Брой стр.: 1/1</p>																																										
<p>Договор №: Заземления</p> <table border="1"> <thead> <tr> <th>Обозначение</th> <th>Референция/тип</th> <th>Количество</th> <th>Стандарт</th> </tr> </thead> <tbody> <tr> <td>МГВ 35 мм²</td> <td>TSC35</td> <td></td> <td>IEC61138</td> </tr> <tr> <td>МГВ 50 мм²</td> <td>TSC50</td> <td></td> <td>IEC61138</td> </tr> <tr> <td>МГВ 95 мм²</td> <td>TSC95</td> <td></td> <td>IEC61138</td> </tr> <tr> <td>Клема с байонетен накрайник</td> <td>MT535B</td> <td></td> <td>IEC61230</td> </tr> <tr> <td>Заземителна клема NB8 6 до 25</td> <td>NB8</td> <td></td> <td>IEC61230</td> </tr> <tr> <td>Клема Ср.Н.</td> <td>MT535URUB</td> <td></td> <td>IEC61230</td> </tr> <tr> <td>PXV 1070 В</td> <td>PXV</td> <td></td> <td>IEC60855</td> </tr> <tr> <td>PXV 1150 В</td> <td>PXV</td> <td></td> <td>IEC60855</td> </tr> <tr> <td>PXV 1250 В</td> <td>PXV</td> <td></td> <td>IEC60855</td> </tr> </tbody> </table>					Обозначение	Референция/тип	Количество	Стандарт	МГВ 35 мм ²	TSC35		IEC61138	МГВ 50 мм ²	TSC50		IEC61138	МГВ 95 мм ²	TSC95		IEC61138	Клема с байонетен накрайник	MT535B		IEC61230	Заземителна клема NB8 6 до 25	NB8		IEC61230	Клема Ср.Н.	MT535URUB		IEC61230	PXV 1070 В	PXV		IEC60855	PXV 1150 В	PXV		IEC60855	PXV 1250 В	PXV		IEC60855
Обозначение	Референция/тип	Количество	Стандарт																																									
МГВ 35 мм ²	TSC35		IEC61138																																									
МГВ 50 мм ²	TSC50		IEC61138																																									
МГВ 95 мм ²	TSC95		IEC61138																																									
Клема с байонетен накрайник	MT535B		IEC61230																																									
Заземителна клема NB8 6 до 25	NB8		IEC61230																																									
Клема Ср.Н.	MT535URUB		IEC61230																																									
PXV 1070 В	PXV		IEC60855																																									
PXV 1150 В	PXV		IEC60855																																									
PXV 1250 В	PXV		IEC60855																																									
<p>С настоящата декларация гарантираме, че, освен ако изрично не са посочени изключения, изброеното оборудване съответства на изискванията на процедурата/ договора и че, след преминаване на необходимите изпитания, то напълно съответства на всички посочени стандарти, както и останалите приложими стандарти и регулатии.</p>																																												
<p>Мениджър – управление на качеството Име: Grira Sabri – QSE Дата: 20/10/2015 /подпись нечетлив/</p>																																												



от. 264

Supplier : SIBILLE FAMECA ELECTRIC

Company : 815 B CHEMIN DU RAZAS
ZI les Plaines
26780 MALATAVERNE
France



STATEMENT OF CONFORMITY
(NF L 00-015C)

Customer : INTERCOMPLEX LTD
Company : 201 PESHTERSKO SHOSSE STR.
4015 PLOVDIV
Bulgaria

Statement no : DEVSFE1500670A
Number of pages : 1 / 1

Designation	Reference or type	Serial or batch number	Quantity	Complies to
Cable section 35 mm ²	TSC35			IEC61138
Cable section 50 mm ²	TSC50			IEC61138
Cable section 95 mm ²	TSC95			IEC61138
Clamp MT535 with bayonet end fitting	MT535B			IEC61230
Earthing clamp 6 to 25 type NB8	NB8			IEC61230
Middle voltage clamp	MT535URUB			IEC61230
PXV 1070 B	PXV			IEC60855
PXV 1150 B	PXV			IEC60855
PXV 1250 B	PXV			IEC60855


We hereby declare, barring exceptions, reservations, or exemptions listed in this statement of conformity, that the listed supplies comply with the contract requirements and that, after completion of testing and verification, they completely satisfy all specified requirements, and applicable standards and regulations.

Supplier Quality Manager

Name and title : Grira Sabri - QSE

Signature :

Date : 20/10/2015



ap. 265

ОТКРИТА ПРОЦЕДУРА ЗА СКЛЮЧВАНЕ НА РАМКОВО СПОРАЗУМЕНИЕ

Реф. № PPD 20-028

с предмет: "Доставка на преносими заземители, детектори за напрежение, оперативни щанги и указатели за сфазиране"

Обособена позиция № 1: „Преносими заземители“

 ПРИЛОЖЕНИЯ КЪМ ПРЕДЛОЖЕНИЕ ЗА ИЗПЪЛНЕНИЕ НА ПОРЪЧКАТА


ОБОСОБЕНА ПОЗИЦИЯ № 1: „ПРЕНОСИМИ ЗАЗЕМИТЕЛИ“ 

6. Документи за Преносими заземители за ВН за шини за уредби 110 kV – със заземителен кабел и кабел за свързване на късо (гъвкави медни въжета) – 95 mm²

Приложение № 6.4
Приложение № 6.5

Сертификат за изследване на типа, издаден съгласно процедурата за оценяване на съответствието „Изследване на типа“ в съответствие с НСИОСЛПС или еквивалентен нормативен акт на държави-членки на ЕО, на Европейската икономическа зона/Европейската асоциация за свободна търговия (EACT), с които Република България има подписани и влезли в сила споразумения за взаимно признаване на резултатите от оценяване на съответствието и приемане на промишлените продукти (заверено копие)

Протоколи от проведените проверки и изпитвания на ПЗ в рамките на процедурата за оценяване на съответствието с приложени резултати от изпитванията (заверени копия)


Участник: "ИНТЕРКОМПЛЕКС" ООД
гр. Пловдив, бул. "Пещерско шосе" № 201
тел./факс: (032) 24 14 14; 24 14 15
e-mail: sales@intercomplex.bg


Labein-Tecnalia

- Parque Tecnológico de Bizkaia
C/ Geldo - Edificio 700
48160 - Derio (Bizkaia)
Tel. +34 94 404 14 41
Fax +34 94 404 14 45

- Vega de Tapia, s/n
48903 - Burdeos (Bizkaia)
Tel. +34 94 607 34 90
Fax +34 94 607 34 95

- Parque Tecnológico de Bizkaia
Edificio 101
48170 - Zamudio (Bizkaia)

- Pol. Industrial Basabe
Pabellón 1-3
20500 - Aretxabaleta (Gipuzkoa)

<http://www.te-c.es>**LABEIN FOUNDATION – ENERGY UNIT
ELECTRICAL EQUIPMENT LABORATORY****Test report**

Page 1 of 8

No CE35-08-AM-05

Short circuit current test**TEST OBJECT:**

Portable equipment for earthing and short-circuiting

DESIGNATION:

MT535URU

NB8

REQUESTED BY:

FAMECA

2 Rue Gutenberg Rixheim (France)

MANUFACTURER:

FAMECA

STANDARD:

IEC 61230:1993

RECEPTION DATE:

February 18th 2008

TESTS DATE:

February 19th-21st 2008

• C.I.F.: G48975767

Razón Social: Fundación

The test object has been subjected to the tests required by the applicant, applying the procedures specified in the standard indicated before.

THE PRESENT REPORT CONSISTS OF:

No of pages: 8 (and annex of 16)

Drawings: Annex

Photographs: Annex

Oscillograms: Annex

На основание чл.36а ал.3 от ЗОП
На основание чл.36а ал.3 от ЗОП

Head of Electrical Equipment Laboratory
This document is a copy in pdf of the original Report,
as requested by the client

Barakaldo, June 4th 2008

- * The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.
- * The partial reproduction of the present document is categorically forbidden without the permission of Labein.




INDEX

1. TEST OBJECT DESIGNATION.....	3
2. TESTS PERFORMED. STANDARD	4
3. PHASE TO PHASE SHORT-CIRCUIT TESTS.....	5
3.1. Test description.....	5
3.2. Results	6
4. PHASE TO EARTH SHORT-CIRCUIT TEST.....	7
4.1. Test description.....	7
4.2. Results	8

ANNEX

DRAWINGS
PHOTOGRAPHS
OSCILLOGRAMS



1. TEST OBJECT DESIGNATION

Portable equipment for earthing and short-circuiting.

Manufacturer: FAMECA

Designation:

Line clamp: MT535URU

Earth clamp: NB8

Short-circuiting cable: TFK950275 (section of 95 mm² and 2.75 m length)

Earthing cable: TFK3510 (section of 35 mm² and 10 m length)

Rated current, Ir: 25 kA, 1 s (phase-to-phase short circuit)

6 kA, 1 s (phase-to-earth short circuit)

Definition dossier reference: diMT535URU01

diNB8

diTFK02

See photographs and drawings of the test object in the annex.


2. TESTS PERFORMED. STANDARD

Short-circuit current tests.

The tests have been performed according to the procedure specified in the following standard:

IEC 61230:1993 and CDV IEC 61230 ed. 2: December 2007 "Live working- Portable equipment for earthing or earthing and short-circuiting"

The calculation of the uncertainties of the measurements is available.




3. PHASE TO PHASE SHORT-CIRCUIT TESTS

3.1. Test description

The test is carried out according to the specifications of the manufacturer and in accordance with subclause 6.6 of the standard IEC 61230.

The scheme of the test is the following, figures in mm:



The test circuit is arranged at 2.6 m height from the ground.

According to the manufacturer, line clamps have been submitted, previously, to a salt fog test of 64 hours following IEC 68-2-11 (see CETIM CERMAT test report n° HD/HD/08E0102-5).

4 Tests with aluminium flexible cable of diameter 31 mm are performed with the following parameters:

I_{test} (r.m.s.): 25 kA

I_{test} (peak): 62.5 kA

Time: 1 s

Torque (line clamp): 20 Nm


See photographs of the test arrangement in the annex.

3.2. Results

Registered values are the following:

Oscillogramm no.	34	35	36	37
Short-time r.m.s. current I_{th} (kA)	25.8	25.8	25.6	25.7
Short-time peak value current, I_{dyn} (kA)	64.6	64.8	64.3	64.5
Duration (s)	1.005	1.005	1.005	1.006
Joule integral I^2t (AAs. 10^8)	6.92	6.96	6.82	6.86
Frequency (Hz)	50	50	50	50

Result: The test objects withstand the test current during 1 s. There is neither current interruption nor arcing during the test time.




4. PHASE TO EARTH SHORT-CIRCUIT TEST

4.1. Test description

The test is carried out according to the specifications of the manufacturer and in accordance with subclause 6.6 of the standard IEC 61230.

The scheme of the test is the following:



b: 6.5 m

a: 2 m

c: Approximately 1.5 m

19: Line cable

3: Earthing cable

2: Line clamp

1: Earth clamp

According to the manufacturer, line clamps and earth clamps have been submitted, previously, to a salt fog test of 64 hours following IEC 68-2-11 (see CETIM CERMAT test report n° HD/HD/08E0102-5).

Two tests have been performed with the following parameters:

Line conductor: Aluminium flexible cable of diameter 31 mm

Earth conductor: Earth rod 701

Test parameters:

I_{test} (r.m.s.): 6 kA
I_{test} (peak): 15 kA
Time: 1 s
Torque (earth clamp): 20 Nm
Torque (line clamp): 20 Nm


See photographs of the test arrangement in the annex.

4.2. Results

Oscillogramm no.	26	27
Short-time r.m.s. current I _{th} (kA)	6.2	6.1
Short-time peak value current, I _{dyn} (kA)	15.9	15.7
Duration (s)	1.005	1.004
Joule integral I ² t (AAs.10 ⁷)	3.99	3.93
Frequency (Hz)	50	50

Result: The test objects withstand the test current during 1 s. There is neither current interruption nor arcing during the test time.

See oscillograms in the annex.



FAMECA


DOSSIER D'IDENTIFICATION

MT535URU

dMT535URU


Page 6/10

5. PLAN D'ENSEMBLE



Code pince avec visserie: MT535URUAP

Ce document est la propriété de FAMECA, il ne peut être reproduit ou communiqué sans son autorisation écrite.

FAMECA		DOSSIER D'IDENTIFICATION		NB8																																													
				DINB8																																													
				Page 6/9																																													
 <p><u>Goupille élastique Ø5.11</u></p>																																																	
<p>Capacité de serrage: Ø6 à 25mm Barres plates 0 à 25mm</p> <p>Étau sans visserie référence: NB8SV</p> <table border="1"> <tr> <td>Poids brut:</td> <td></td> </tr> <tr> <td>Poids usiné: 0.365kg</td> <td></td> </tr> <tr> <td colspan="2">FAMECA</td> </tr> <tr> <td colspan="2">68 RIXHEIM / FRANCE</td> </tr> <tr> <td colspan="2">Tel. 03.89.84.54.00 ; Fax 03.89.85.43.53</td> </tr> <tr> <td colspan="2">A CREATION DU PLAN</td> <td>01/06/05</td> <td>MG</td> <td>01/06/05KR</td> </tr> <tr> <td>Matière :</td> <td>Ind.</td> <td>Modifications</td> <td>Date</td> <td>Vécos</td> </tr> <tr> <td colspan="2">TOLERANCES GÉNÉRALES D'USAGES : SPECIFICATION FREIGS</td> <td colspan="3">Plan réalisé en DAO/CAO ne peut être modifié qu'en DAO/CAO</td> </tr> <tr> <td>Dimensions linéaires : de 05 à 100 : ±0.25 de 100 à 400 : ±0.5</td> <td>Dimensions circulaires : Jø13-Jø13</td> <td>Dimensions angulaires pour longueur très court de l'angle de 50 à 120 mm: ±5°/20'</td> <td>N° code article : NB8</td> <td>N° Code de fabrication FAB 404</td> </tr> <tr> <td colspan="2">Designation: ETAU NB8</td> <td>Echelle 1</td> <td>N° du dessin 49497</td> <td>Ind. A</td> </tr> <tr> <td colspan="5">CE DOCUMENT EST LA PROPRIÉTÉ EXCLUSIVE DE LA SOCIÉTÉ FAMECA. IL NE DOIT EN AUCUN CAS Être COPIÉ OU TRANSMIS À DES Tiers SANS NOTRE AUTORISATION écrite.</td> </tr> <tr> <td colspan="5">Ce document est la propriété de FAMECA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.</td> </tr> </table>					Poids brut:		Poids usiné: 0.365kg		FAMECA		68 RIXHEIM / FRANCE		Tel. 03.89.84.54.00 ; Fax 03.89.85.43.53		A CREATION DU PLAN		01/06/05	MG	01/06/05KR	Matière :	Ind.	Modifications	Date	Vécos	TOLERANCES GÉNÉRALES D'USAGES : SPECIFICATION FREIGS		Plan réalisé en DAO/CAO ne peut être modifié qu'en DAO/CAO			Dimensions linéaires : de 05 à 100 : ±0.25 de 100 à 400 : ±0.5	Dimensions circulaires : Jø13-Jø13	Dimensions angulaires pour longueur très court de l'angle de 50 à 120 mm: ±5°/20'	N° code article : NB8	N° Code de fabrication FAB 404	Designation: ETAU NB8		Echelle 1	N° du dessin 49497	Ind. A	CE DOCUMENT EST LA PROPRIÉTÉ EXCLUSIVE DE LA SOCIÉTÉ FAMECA. IL NE DOIT EN AUCUN CAS Être COPIÉ OU TRANSMIS À DES Tiers SANS NOTRE AUTORISATION écrite.					Ce document est la propriété de FAMECA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.				
Poids brut:																																																	
Poids usiné: 0.365kg																																																	
FAMECA																																																	
68 RIXHEIM / FRANCE																																																	
Tel. 03.89.84.54.00 ; Fax 03.89.85.43.53																																																	
A CREATION DU PLAN		01/06/05	MG	01/06/05KR																																													
Matière :	Ind.	Modifications	Date	Vécos																																													
TOLERANCES GÉNÉRALES D'USAGES : SPECIFICATION FREIGS		Plan réalisé en DAO/CAO ne peut être modifié qu'en DAO/CAO																																															
Dimensions linéaires : de 05 à 100 : ±0.25 de 100 à 400 : ±0.5	Dimensions circulaires : Jø13-Jø13	Dimensions angulaires pour longueur très court de l'angle de 50 à 120 mm: ±5°/20'	N° code article : NB8	N° Code de fabrication FAB 404																																													
Designation: ETAU NB8		Echelle 1	N° du dessin 49497	Ind. A																																													
CE DOCUMENT EST LA PROPRIÉTÉ EXCLUSIVE DE LA SOCIÉTÉ FAMECA. IL NE DOIT EN AUCUN CAS Être COPIÉ OU TRANSMIS À DES Tiers SANS NOTRE AUTORISATION écrite.																																																	
Ce document est la propriété de FAMECA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.																																																	



DOSSIER D'IDENTIFICATION


CABLE MALT

diTFK

Page 6/13


5. PLAN D'ENSEMBLE

a) TFK




FAMECA		Relatif codes articles		Modifications		Photo module en DAO/DAD ne peut être modifiée qu'en DAO/DAD	
68 RUE DE LA FRANCE	B	Relatif codes articles	6/0/5	H.F.	M.M.		
TELEGRAMME : FAMETECA	A	Creation du plan	25/9/00	H.F.	M.M.		
Modif :	Ind.	Modifications	Date	Priore	Verificat		
Ref. Utilisation	N° emm et numero fili. emprunté	N° photo module	N° photo de fabrication				
de 0 à 100 : 6425	jeu 23-03-13	407 15'	FAB 590	Int.			
en-dessous 6425-6413							
Distributeur:	TFK...						
CABLE / CONNEXIONS TUBULAIRES	1	EMI	36839	1	B		


Ce document est la propriété de FAMECA. Il ne peut être reproduit ou communiqué sans son autorisation écrite.



Test object after the first phase to phase test




Line clamps after the first phase to phase test





[Handwritten signature]

Test object after the second phase to phase test




Line clamps after the second phase to phase test






[Handwritten signature]

Test object after the third phase to phase test




Line clamps after the third phase to phase test







Test object after the fourth phase to phase test




Line clamps after the fourth phase to phase test




Test arrangement for the phase to earth short-circuit tests




Earth clamp connexion to the earth rod







Earth clamp after the first phase to earth short circuit test




Line clamp after the first phase to earth short circuit test



Earth clamp after the second phase to earth short circuit test



Earth and line clamps after the second phase to earth short circuit test




V (eficaz/RMS)	549.97 V
I (eficaz/RMS)	6.19 kA
I (cresta/peak)	15.87 kA
I ² t	3.99E+07 AAs
f _i	0.059 s
f _e	1.064 s
t _{total} (t _e -t _i)	1.005 s


Fecha / Date: 20/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 26



БЯРНО С
ОРИГИНАЛА





V (eficaz/RMS)	547.32 V
I (eficaz/RMS)	6.14 kA
I (cresta/peak)	15.67 kA
I ² ·t	3.93E+07 AAs
t _i	0.059 s
t _e	1.063 s
t _{total} (t _e -t _i)	1.004 s

Fecha / Date: 20/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 27





V (eficaz/RMS)	739.49 V
I (eficaz/RMS)	25.78 kA
crest/peak	64.58 kA
Z _t	6.92E+08 AAs
t _r	0.060 s
t _e	1.065 s
t _{total} (t _e -t _r)	1.005 s

Fecha / Date: 21/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 34




V (eficaz/RMS)	740.07 V
I (eficaz/RMS)	25.84 kA
I (cresta/peak)	64.83 kA
$I^2 \cdot t$	6.96E+08 AAs
t_i	0.060 s
t_e	1.065 s
$t_{total} (t_e - t_i)$	1.005 s

Fecha / Date: 21/02/08


Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 35



Report No CE35-08-AM-05

ВЕРНОСТЬ
ГИНАЛА
Annex. Page 14 of 16




copy 287

V (eficaz/RMS)	771.12 V
I (eficaz/RMS)	25.57 kA
I (cresta/peak)	64.26 kA
I _{2-t}	6.82E+08 AAs
t _i	0.060 s
t _e	1.065 s
t _{total} (t _e -t _i)	1.005 s

Fecha / Date: 21/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 36




\sqrt{V} (eficaz/RMS)	774.52 V
I (eficaz/RMS)	25.66 kA
$ I $ (cresta/peak)	64.48 kA
$I^2 \cdot t$	6.86E+08 AAs
t_i	0.060 s
t_e	1.066 s
$t_{total} (t_e - t_i)$	1.006 s


Fecha / Date: 21/02/08

Nº EXPEDIENTE: CE35-08-AM

Nº OSCILOGRAMA: 37



ВЯРНО С
ЗАРУГИНАЛА





LE CIRCUIT

TEST REPORT

N° 135086 – 671357 B-Cr17/02/10

English version – Original in French

ISSUE TO:

: FAMECA
2, rue Gutenberg
BP 13
68173 RIXHEIM CEDEX

OBJET

: TESTS ACCORDING TO THE STANDARD IEC 60855-1 (10:2009)
INSULATING FOAM-FILLED TUBES FOR LIVE WORKING.

Model tested

: Tubes ø28mm red and ø32mm yellow

Test date

: May 2015

Composition of this document: 19 pages

Document initially released on: July 10, 2015

Corrected on: February 10, 2017

Test supervised by:
The test technician,

D. TELLIER

На основание чл.36а ал.3 от ЗОП


This document shall not be reproduced, except in full, without the written approval of the LCIE. This document contains results related only to the item tested. It does not imply the conformity of the whole production to the item tested. Unless otherwise specified, the decision of conformity takes into account the uncertainty of measures. The LCIE's liability applies only to the French version. English version of test report n°135086-671357A. Original in French established on July 10th, 2015.

LCIE
Laboratoire Central
des Industries Electriques
Une societe de Bureau Veritas

33, av du Général Leclerc
BP 8
92266 Fontenay-aux-Roses cedex
France

Tél : +33 1 46 95 60 60
Fax : +33 1 46 95 86 56
e-mail : contact@lcie.fr
www.lcie.fr

Société par Actions Simplifiée
au capital de 57 15 981 €
ROS Nanterre R. 303 174



ap 200



1 - TESTED PRODUCT

Two diameter tubes red 28mm and yellow 32mm.

Designation	Marking	
Tube ø28mm	Red	FAMECA ø28 037/15 CEI 60855-1
Tube ø32mm	Yellow	FAMECA ø32 048/15 CEI 60855-1

2 - TEST PROGRAM

The test program, established with the customer, was to realize in the local society FAMECA, under supervision of LCIE, type tests of the IEC 60855-1 of October 2009.
Crushing test on tube has been made at CETIM and validated by LCIE.


3 - EXECUTION MODALITIES

The execution modalities have been those of the corresponding paragraph of the specification above.

Chronological order of type tests:

Tests	Group 1	Group 2	Group 3	Group 4	Group 5	Group 6	Group 7
Dimensional check	<u>Note:</u> Control has not been performed on each before cutting lengths; control was performed on the control sample Group 8.						
Durability of marking	1	1	1	1	1	1	1
Visual check	2	2	2	2	2	2	2
Dielectric test after water exposition	3						
Wet test		3					
Bending test			3				
Torsion test				3			
Crushing test on tube					3		
Bending ageing test						3	
Dielectric test after mechanical ageing						4	
Dye penetration test							3

ВІРНОСТЬ
ОРИГІНАЛА



Group and samples :

Group	Number of test pieces
1	3 x 0.3m
2	3 x 1.2m (cut at 0.1)
3	3 x 2.5m
4	3 x 1.2m
5	3 x (3 x ø ext. at ±5%)mm
6	3 x 2.5m
7	3 x (100±5)mm (cut at least to 0.1m from the end of initial length of cube)
8	1 x 2m (specimen)

4 – RESULTS

The following results have been obtained:


4.1 – Dimensional check (article 5.3.3 table B.1)

Tube	Tolerance	Prescribed		Measures 1	Measures 2	Measures 3
		Min.	Max.			
Ø28mm	Ø < 30mm (± 0.5mm)	27.5mm	28.5mm	27.87mm	27.85mm	27.84mm
Ø32mm	30 ≤ Ø ≤ 40mm (± 0.55mm)	31.45mm	32.55mm	32.03mm	32.02mm	32.17mm

Satisfactory results4.2 – Durability of marking (article 5.5.6 table B.1)


The markings shall be rubbed for 1min, with a clean soaked in water then with a clean cloth soaked in isopropanol.

Sample test	Prescribed	Observation
Tube ø28mm	The markings must still legible and the characters do not run or smear.	Nothing to report
Tube ø32mm		Nothing to report

Satisfactory results

4.3 – Visual check (article 5.3.2 table B.1)

Group	Prescribed	Observation	
		Ø28	Ø32
1		Nothing to report	Nothing to report
2		Nothing to report	Nothing to report
3	Each test, each group must not have:	Nothing to report	Nothing to report
4	- Before cutting, defects in type of air bubble surface, bumps, dirt, strange body ...	Nothing to report	Nothing to report
5		Nothing to report	Nothing to report
6	- After cutting, the internal defects at the apparent section detachment of the foam (open - cracks)	Nothing to report	Nothing to report
7		Nothing to report	Nothing to report
8		Nothing to report	Nothing to report

Satisfactory results4.4 – Dielectric test after exposure to water (article 5.4.2 table B.1)

AC voltage applied: 100kV (f=50Hz)


Distance between electrode: 30cm

Duration of application: 1min

4.4.1 – With a conditioning by humidity

Before the test: Each test should be cleaned with isopropanol and dry for 15 minutes at ambient air.
 Test conditioning: 24h in water at 20 ° C.

Ø28	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1		0.8			Nothing to report
Sample.2	≤ 48	0.7	≥ 50°	90°	Nothing to report
Sample.3		0.89			Nothing to report

Satisfactory results



Ø32	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1	≤ 49.2	0.78	≥ 50°	90°	Nothing to report
Sample.2		0.84			Nothing to report
Sample.3		0.81			Nothing to report

Satisfactory results4.4.2 - With a conditioning by immersion


Before the test: Each test should be cleaned with isopropanol and dry for 15 minutes at ambient air.

Test conditioning: 24h in water at 20 °C.

Ø28	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1	≤ 48	0.77	≥ 50°	90°	Nothing to report
Sample.2		0.67			Nothing to report
Sample.3		0.73			Nothing to report

Satisfactory results

Ø32	Current I (μ A)		Phase angle		Observation
	Prescribed	Recorded	Prescribed	Recorded	
Sample.1	≤ 49.2	0.81	≥ 50°	90°	Nothing to report
Sample.2		0.81			Nothing to report
Sample.3		0.78			Nothing to report

Satisfactory results

cop. 289




TEST REPORT N° 135086-671357B-Cr17/02/10

page 6

4.5 – Wet test (article 5.4.3 table B.1)

Before the test: Each test should be cleaned with isopropanol and dry for 15 minutes at ambient air..




AC voltage applied: 100kV
Duration of application: 1h
Average precipitation rate: 1,5mm/min
Ambiant temperature: 19.4°C
Water temperature: 19.0°C
Humidity « H% » : 49.1%
Water resistivity : 100Ω.m
Inclination samples : 45°

Ø28	Elevated temperature (°C)		Visual check	
	Prescribed	Recorded	Prescribed	Observation
Sample.1	< 20	< 1	No flashover during the test. No sparkover or puncture. No visual sign of tracking. No erosion on the surface.	Nothing to report
Sample.2		< 1		Nothing to report
Sample.3		< 1		Nothing to report


Satisfactory results

Ø32	Elevated temperature (°C)		Visual check	
	Prescribed	Recorded	Prescribed	Observation
Sample.1	< 20	< 1	No flashover during the test. No sparkover or puncture. No visual sign of tracking. No erosion on the surface.	Nothing to report
Sample.2		< 1		Nothing to report
Sample.3		< 1		Nothing to report

Satisfactory results



ap. 25


4.6 - Bending test (article 5.5.1 table B.1)

Rate of the applied force: 200 N/s

Fd « ø28mm »: 890N (pages 7 - 9)

Fd « ø32mm »: 1100N (pages 10 - 12)

Ø28		Initial orientation at 0°										
Sample		Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd		
		At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	30sec	(mm)						
Sample.1		22.44	44.23	70.05	≤ 35		Prescribed	21.8	25.82			
Sample.2		23.05	49.01	75.85				26.0	26.8			
Sample.3		24.52	46.50	71.87				22.0	25.4			
Sample.		Residual deflection after 1min at 0N (mm)			Variation of the residual deflection / deflection at Fd (%)							
					Prescribed				Results			
Sample.1		0.25			≤ 6				0.4			
Sample.2		0.48							0.6			
Sample.3		0.27							0.4			

Satisfactory results


ap. 286



Ø28		Initial orientation at 90°								
Sample	Recorded deflection after 30sec (mm))			Difference between recorded deflection after 30sec (mm)			Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd	
	At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd				
Sample.1	21.03	43.62	69.44	≤ 35	22.6	25.8				
Sample.2	24.40	49.79	76.87		25.4	27.1				
Sample.3	23.54	46.88	71.64		23.3	24.8				
Sample	Residual deflection after 1min at ON (mm)			Variation of the residual deflection / deflection at Fd (%)						
				Prescribed	Results					
Sample.1	0.49			≤ 6	0.7					
Sample.2	0.29				0.4					
Sample.3	0.43				0.6					

Satisfactory results

Ø28		Initial orientation at 180°								
Sample	Recorded deflection after 30sec (mm)			Difference between recorded deflection after 30sec (mm)			Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd	
	At 300N (1/3Fd)	At 600N (2/3Fd)	At 890N (Fd)	Prescribed	Between 2/3Fd and 1/3Fd	Between Fd and 2/3Fd				
Sample.1	23.11	46.63	73.48	≤ 35	23.5	26.9				
Sample.2	25.62	48.92	69.0		23.3	20.1				
Sample.3	25.13	47.96	73.18		22.8	25.2				
Sample	Residual deflection after 1min at ON (mm)			Variation of the residual deflection / deflection at Fd (%)						
				Prescribed	Results					
Sample.1	0.46			≤ 6	0.6					
Sample.2	0.53				0.8					
Sample.3	0.47				0.6					

Satisfactory results

с.п. 287