



ПРЕДЛОЖЕНИЕ

за изпълнение на обществената поръчка

ДО: „ЧЕЗ РАЗПРЕДЕЛЕНИЕ БЪЛГАРИЯ“ АД,

ОТ: АББ България ЕООД

адрес: гр. София, 1592 бул. „Христофор Колумб“, № 9, ет. 3

тел.: +359 (0) 2 807 55 00; факс: +359 (0) 2 807 55 99; e-mail: office@bg.abb.com

Единен идентификационен код: 831133152,

Представявано от Екехарт Нойрайтер и Стефан Минчев – Управители

Лице за контакти: Стефан Минчев, тел +35928075521, факс: +35928075599, e-mail: stefan.minchev@bg.abb.com

УВАЖАЕМИ ГОСПОЖИ И ГОСПОДА,

Предоставяме на Вашето внимание предложението ни за изпълнение на обществена поръчка с предмет „Доставка на електрически апарати 110kV“, реф. № PPD 17-064.

Обособена позиция 2 – Доставка на токови измервателни трансформатори 110kV за монтаж на открито – 21бр.

1. В случай, че бъдем избрани за изпълнител, ще изпълним предмета на поръчката в пълно съответствие с изискванията на Възложителя, като се задължаваме да спазваме изискванията на нормативната уредба на Република България.

2. Представям техническите спецификации от раздел II на документацията с попълнени всички изисквани стойности за всички позиции от стоката по предмета на поръчката.

3. Декларирам, че предлаганото от нас оборудване отговаря на минималните технически изисквания на Възложителя, които не съдържат графа „Гарантирано предложение“ в таблиците на техническите спецификации на стоката, приложение към настоящото предложение за изпълнение на поръчката.

4. Представям всички изисквани данни и документи, посочени в Приложение 2 от настоящото техническо предложение. Запознат съм с изискването, че представените документи трябва да бъдат на български език или с превод на български език, придружени с оригиналните документи, с изключение на каталозите и протоколи от изпитания *в случай, че се изискват* за материалите, които могат да се представят и само на английски език.

5. Запознат съм, че представените от нас технически документи са доказателство за декларираните от мен технически данни и параметри в техническите спецификации на стоката.

6. Потвърждавам, че представяните от нас стоки, описани в Техническото ни предложение, ще отговарят на посочените от възложителя стандарти или на еквивалентни. В случай, че даден материал отговаря на стандарт, еквивалентен на посочения се задължаваме да го отразим в отделен документ и да представим доказателства за еквивалентността на двата стандарта.

7. Предлагам гаранционен срок за предлаганите стоки – 36 (тридесет и шест) месеца, от датата на приемо – предавателен протокол за получаване на стоката от Възложителя.

8. Срок за доставка на предлаганите стоки – 90 (деветдесет) дни от датата на поръчка от Възложителя до Изпълнителя

Приложения:

1. Приложение 1 - Технически изисквания и спецификации за изпълнение на поръчката – раздел II от документацията за участие – попълнени на съответните места;

2. Приложение 2 - Изисквани документи от приложение - Технически изисквания и спецификации;

Дата: 14.07.2017 г.
София

С уважение:

Екехарт Нойрайтер
Управител
АББ България ЕООД

Стефан Минчев
Управител
АББ България ЕООД

ABB Bulgaria EOOD
Main Office
9, Hristofor Kolumb Blvd., fl. 3
Mladost, Sofia-grad
1592 Sofia, Bulgaria
Phone: +359 (0) 2 807 55 00
Fax: +359 (0) 2 807 55 99
Web: www.abb.bg
E-mail: office@bg.abb.com

UIC: 831133152
VAT Nr.: BG 831133152
Bank details:
ING Bank, branch Sofia
IBAN: BG13INGB91451000027317 (BGN)
IBAN: BG60INGB91451400027311 (EUR)
BIC: ING8BGSGF



4/2020

**ИЗИСКВАНИЯ КЪМ ДОКУМЕНТАЦИЯТА И ИЗПИТВАНИЯТА ПО ОБОСОБЕНА ПОЗИЦИЯ № 2
„ДОСТАВКА НА ТОКОВИ ИЗМЕРВАТЕЛНИ ТРАНСФОРМАТОРИ 110 KV, ЗА МОНТАЖ НА
ОТКРИТО“**

№	Документи при участие	Приложение № (или текст)
1.	Точно обозначение на типа на токовете измервателни трансформатори, производителя и страната на произход и последно издание на каталога на производителя	PA 123a ABB Sp. zo.o., Полша Приложение 1 - PA_123a_karta_en
2.	Удостоверение за одобряване на типа на токовете измервателни трансформатори, издадено по реда и при условията на Закона за измерванията	Приложение 2 - Удостоверение за одобрен тип - PA123a PA145a
3.	Техническо описание на токовете измервателни трансформатори, гарантирани параметри и характеристики, тегло и др.	Приложение 3.1 - Технически параметри на ТТ PA123a Приложение 3.2 - Чертеж на ТТ PA123a Приложение 3.3 - Волтамперна характеристика на ядрата ТТ PA123a Приложение 3.4 - Чертеж на табелата на ТТ PA123a Приложение 3.5 - Ел. схема на ТТ PA123a Приложение 3.6 - Чертеж на клемната кутия на ТТ PA123a Приложение 3.7 - Instrukcja PA 123a-145a EN_lo-res Приложение 3.8 - Сертификат за съответствие PAa_123_ABB Приложение 3.9 - Nytro_10XN_PO_EN_SDS Приложение 3.10 - Nytro_Libra_PO_EN_SDS
4.	Протоколи от типови изпитвания на токовете измервателни трансформатори на английски или български език, проведени от независима изпитателна лаборатория с приложени резултати от изпитванията	Приложение 4 - Протоколи от типови изпитания на ТТ PA123a
5.	Сертификат/акредитация на независимата изпитателна лаборатория, провела типовите изпитвания – заверено копие	Приложение 5.1 - ISO 17025_ABB Przasnysz Приложение 5.2 - Сертификат за акредитация 117 323 324
6.	Информация за провежданите от производителя контролни (рутинни) изпитвания	Приложение 6 - Routine Test Plan for Current Transformer

ТАБЛИЦА 1

Стандарт на материала за токови измервателни трансформатори 110 kV за монтаж на открито

Технически параметри на токови измервателни трансформатори 110 kV, за монтаж на открито, които се попълват от Участника в графа „Гарантирано предложение“:

Наименование на материала		Токов измервателен трансформатор 110 kV, 200/400/800/5/5/5/5 A за монтиране на открито	
Съкратено наименование на материала		ТИТ 110 kV, 200/400/800/5/5/5/5 A, OM	
№	Параметър	Изискване	Гарантирано предложение
1.	Тип/референтен номер съгласно каталога на производителя	Да се посочи	PA 123a
2.	Производител	Да се посочи	ABB Sp. zo.o., Полша

Характеристика на материала:

Токови индуктивни еднополюсни подпорни измервателни трансформатори 110 kV, с изолаторно тяло от порцелан/полимер, и вътрешна изолационна среда - масло (без PCB), за монтиране на открито, с първично превключване на коефициента на трансформация, с обявени коефициенти на трансформация 200/400/800//5/5/5/5 A като вторичните намотки са както следва:

- две намотки за целите на измерването;
- две намотки за целите на защитата.

Токовете измервателни трансформатори са от одобрен тип, преминали са през първоначална метрологична проверка и са маркирани със съответния знак по реда и при условията на „Наредба за средствата за измерване, които подлежат на метрологичен контрол“ по чл. 28, от Закона за измерванията.

Използване:

Handwritten signature

Токовете измервателни трансформатори са предназначени за хранване на токовете вериги на електромерите за търговско и контролно измерване на електрическа енергия, на релейните защиты и на контролно-измервателните апарати и сигнализацията в електрическите разпределителни уредби.

Съответствие на предложеното изпълнение със стандартизационните документи:

Токовете измервателни трансформатори трябва да отговарят на:

- БДС EN 61869-2:2012 „Измервателни трансформатори. Част 2: Допълнителни изисквания за токови трансформатори (IEC 61869-2:2012)“ и на неговите валидни изменения и допълнения или еквивалентно/и.

Параметри на електрическата разпределителна мрежа

№	Параметър	Стойност
1.	Обявено напрежение	110 000 V
2.	Максимално работно напрежение	123 000 V
3.	Най-високо напрежение между фаза-земя при нормални условия	71 kV
4.	Обявена честота	50 Hz
5.	Заземяване на звездния център	Директно заземен

Характеристики на работната среда и място на монтиране

№	Характеристика /място на монтиране	Стойност/описание
1.	Максимална околна температура	+ 40°C
2.	Минимална околна температура	Минус 25°C
3.	Относителна влажност	До 95 %
4.	Замърсяване с прах, пушек, агресивни газове и пари	Умерено
5.	Надморска височина	До 1 000 m
6.	Място на монтиране	В открити разпределителни уредби 110 kV

Конструктивни характеристики и др. данни за токови измервателни трансформатори 110 kV за монтаж на открито, за които Участникът декларира в техническото си предложение – Раздел V от настоящата документация, че предложеното от него оборудване отговаря на посочените минимални технически изисквания на Възложителя, посочени в таблицата по-долу:

№	Характеристика	Минимални технически изисквания
1.	Конструкция	а) Токовете измервателни трансформатори трябва да бъдат от подпорен тип с изолаторно тяло от порцелан/полимер и вътрешна изолираща среда от масло (без PCB)
		б) Токовете измервателни трансформатори трябва да бъдат съоръжени с подходящи клеми с винтови съединения, за свързване на първичната намотка и клемен блок за свързване на вторичните вериги.
2.	Вторични намотки - брой и предназначение	а) две намотки за целите на измерването; б) две намотки за целите на защитата
3.	Монтиране	Токовете измервателни трансформатори трябва да позволяват монтиране във вертикално положение.
4.	Клеми за свързване на първичната намотка	Клемите трябва да бъдат изработени от подходящ метал или метална сплав, недопускащи електрохимична корозия.
5.	Клемен блок за свързване на вторичните вериги	а) Клемният блок трябва да бъде поместен в защитна клемна кутия с IP44, с възможност за пломбиране
		б) Клемите на клемният блок трябва да бъдат изработени от месинг или друга подходяща некорозираща сплав.
6.	Резбови и скрепителни съединения	Всички резбови и скрепителни съединения трябва да бъдат изработени от подходящи некорозиращи метали или метални сплави.
7.	Маркиране на обявените стойности	Токовете измервателни трансформатори трябва да бъдат маркирани с информация за обявените стойности върху табелка съгласно изискванията на т. 6.13 от БДС EN 61869-2 или еквивалентно/и.

Handwritten mark at the top of the page.

№	Характеристика	Минимални технически изисквания
8.	Маркиране на изводите	Изводите на токовете измервателни трансформатори трябва да бъдат маркирани трайно и четливо съгласно изискванията на т. 6.13 от БДС EN 61869-2 или еквивалентно/и.
9.	Първоначална проверка и знаци за удостоверяване (съгласно разпоредбите на Закона за измерванията)	а) При доставка, токовете измервателни трансформатори трябва да бъдат с извършена, валидна към момента първоначална метрологична проверка.
		б) Първоначалната метрологична проверка трябва да бъде удостоверена със знак за първоначална проверка и копие на протокола от проведените изпитвания.
10.	Транспортна опаковка	Токовете измервателни трансформатори трябва да бъдат защитени посредством подходяща опаковка, предпазваща ги от повреди и въздействия на околната среда, подредени и закрепени на транспортни палети.
11.	Експлоатационна дълготрайност	≥ 25 години

Общи технически параметри, характеристики и др. данни за токови измервателни трансформатори 110 kV за монтаж на открито, за които Участникът декларира в техническото си предложение – Раздел V от настоящата документация, че предложеното от него оборудване отговаря на посочените минимални технически изисквания на Възложителя, посочени в таблицата по-долу:


№	Параметър	Минимални технически изисквания
1	Обявени коефициенти на трансформация	200/400/800//5/5/5/5 A
2	Превключване на коефициента на трансформация	Първично
3	Изолаторно тяло	Порцелан или полимер
4	Класове на точност:	
-	измервателната намотка - търговско мерене	≤ 0,2 S
-	измервателна намотка - контролно мерене	≤ 0,2 S
-	2 бр. намотки за защитите: 1 бр. за резервна МТЗ; и 1 бр. за НДЗ	≤ 10 P
5	Номинална вторична мощност:	
-	измервателни намотки	≥ 15 VA
-	защитни намотки	≥ 30 VA
6	Обявен първичен ток, I_{pr}	200/400/800 A
7	Обявени вторични токове	x/5/5/5/5 A
8	Обявен продължителен термичен ток, I_{cth}	≥ 1,2 x I_{pr}
9	Обявен първичен ток на термична устойчивост, I_{th}	≥ 31,5 kA/1s
10	Обявен електродинамичен ток, I_{dyn}	≥ 78.8 kA
11	Номинален коефициент на безопасност - FS	≥ 5
12	Обявено издържано напрежение с промишлена честота за изолацията на първичната намотка	230 kV (ефективна стойност)
13	Обявено издържано напрежение с мълниев импулс за изолацията на първичната намотка	550 kV (върхова стойност)
14	Обявено издържано напрежение с промишлена честота на изолацията за вторичните намотки	3 kV (ефективна стойност)
15	Най-високо напрежение за съоръженията, U_m	123 kV (ефективна стойност)
16	Допустими нива на частичния разряд при 1,2 $U_m/√3$	≤ 20 pC
17	Път на пропълзване по повърхността на изолатора	≥ 31 mm/kV
18	Сеизмична устойчивост	≥ 0.3 g

Handwritten mark on the right side of the table.

Handwritten signature at the bottom of the page.

Дата: 14.07.2017 г.
София

С уважение:



Екехарт Нойрайтер
Управител
АББ България ЕООД



Стефан Минчев
Управител
АББ България ЕООД

Signature

Certificate

Standard **ISO 9001:2015**

Certificate Registr. No. 01 100 1541808

Certificate Holder: **ABB Sp. z o.o.**
ul. Żegańska 1
04-713 Warszawa

including the locations according to annex

Scope: Research and development as well as design, programming, manufacturing, sale, process and final testing, services and turnkey execution:

- distribution and power transformers, insulation klts as well as painting and welding works; dry transformers including also components for dry transformers, components for traction transformers
- low, medium and high voltage electrical apparatus and power systems;
- automation products including control and measurement equipment, motors, Interlocks
- and protection, informative as well as automation systems for power facilities and industry;
- gas compressor and metering stations, gas compressor units and equipment, underground gas storages, gas pipelines and similar services for gas industry
- petroleum refineries and petrochemical industry;
- robots and industrial robotics stations;
- supercharging of diesel and gas engines;
- main host;
- production of low voltage motors;
- production of power electronics and medium voltage drives.
- Computer software production and implementation.

Technical training in scope of automatics, robotics and electrical power equipment and systems

Programs science and research in the fields of power and automation

Proof has been furnished by means of an audit that the requirements of ISO 9001:2015 are met.

Validity: The certificate is valid from 2016-11-29 until 2019-11-28.
First certification 2013

2016-11-24

Gregor Guabka

TÜV Rheinland Cert GmbH
Am Grauen Stein · 51105 Köln

www.tuv.com



TÜVRheinland®
Precisely Right.

Signature

Signature

Annex to certificate

Standard **ISO 9001:2015**

Certificate Registr. No. 01 100 1541808



No.	Location	Scope
0198 113 00113 /01	ABB Sp. z o.o. ul. Żegańska 1 04-713 Warszawa	As for certificate
0198 113 00113 /02	Oddział w Łodzi ABB Sp. z o.o. ul. Aleksandrowska 67/93 91-205 Łódź	
0198 113 00113 /03	Oddział w Aleksandrowie Łódzkim ABB Sp. z o.o. ul. Placydowska 27 95-070 Aleksandrów Łódzki	
0198 113 00113 /04	Oddział w Krakowie ABB Sp. z o.o. ul. Wadowicka 12 30-415 Kraków	
0198 113 00113 /05	Oddział w Krakowie ABB Sp. z o.o. ul. Starowiślna 13A 31-038 Kraków	
0198 113 00113 /06	Oddział w Elblągu ABB Sp. z o.o. ul. Królewiecka 11 82-300 Elbląg	

© TÜV, TÜV and TÜV are registered trademarks. Any use of application requires prior approval.

Page 1 of 2

www.tuv.com

 **TÜVRheinland®**
Precisely Right.

34

LMW

Annex to certificate

Standard **ISO 9001:2015**

Certificate Registr. No. 01 100 1541808

0198 113 00113 /07 **Oddział w Przasnyszu**
ABB Sp. z o.o.
ul. Leszno 59
06-300 Przasnysz

0198 113 00113 /08 **Oddział we Wrocławiu**
ABB Sp. z o.o.
ul. Graniczna 8B
54-610 Wrocław

0198 113 00113 /09 **Oddział we Wrocławiu**
ABB Sp. z o.o.
ul. Bacciarellego 54
51-649 Wrocław

2016-11-24


Gregorz Guabka

TÜV Rheinland Polska Sp. z o.o.
ul. 17 Stycznia 56 02-146 Warszawa

© TÜV, TÜV and TÜV are registered trademarks. Any use or application requires prior approval.

LMW

[Handwritten signature]



Page 2 of 2



[Handwritten signature]

(

(

СЕРТИФИКАТ

/превод от английски език/

Стандарт **ISO 9001:2015**
Рег. Ном.: 01 100 1541808
Носител на сертификата: АББ Сп. з о.о.
ул. Зеганска 1
04-713 Варшава
включително локациите съгласно приложението

Обхват: Проучване и разработване, както и проектиране, програмиране, производство, продажба, процедуриране и финално изпитване, сервизни услуги и цялостно изпълнение „под ключ“ на следното:

- Разпределителни и силови трансформатори, изолационни комплекти, както и работи по боядисване и заваряване; сухи трансформатори включително също компоненти за сухи трансформатори, компоненти за тягови трансформатори
- Електрически апарати за ниско, средно и високо напрежение и електрически системи
- Продукти за автоматизация включително апаратура за управление и измерване, двигатели и блокировки
- И защита, информативна както и система за автоматизация за енергийни обекти и индустрията
- Газ-компресорни и измервателни станции, газ-компресорни блокове и оборудване, подземни хранилища за газ, газопроводи и подобни услуги за газовата индустрия петролни рафинерии и нефтената химическа промишленост
- Главно хранилище
- Роботи и индустриални роботизирани станции
- Суперзареждане на дизелови и газ двигатели
- Производство на двигатели ниско напрежение
- Производство на силова електроника и задвижвания за двигатели средно напрежение
- Производство на компютърен програмен софтуер и внедряване.

Техническо обучение в обхват на автоматика, роботика и електрическо силово оборудване и системи.

Доказателства са представени , въз основа на проведения одит, че изискванията съгласно ISO 9001:2015 са изпълнени.

Валидност: Този сертификат е валиден от 29.11.2016г. до 28.11.2019 г.
Първа сертификация 2013 г.

24.11.2016 г.

Подпис /не се чете/
ТЮВ Реиланд Серт
Am Grauen Stein, 51105 Кьолн

57

Приложение към СЕРТИФИКАТ

Стандарт **ISO 9001:2015**

Рег. Ном.: 01 100 1541808

№	Локация:	Обхват
0198 113 00113/01	АББ Сп. з о.о. ул. Зеганска 1 ПЛ 04-713 Варшава	както е в сертификата
0198 113 00113/02	Клон в Луч, АББ Сп. з о.о. ул. Александровска67/93, ПЛ-91-205 Луч	
0198 113 00113/03	Клон в Александровие Лучким, АББ Сп. з о.о. ул. Плачидовска 27 ПЛ-95-070 Александров Лучким	
0198 113 00113/04	Клон в Краков, АББ Сп. з о.о. ул. Вадовичка 12 ПЛ-30-415 Краков	
0198 113 00113/05	Клон в Краков, АББ Сп. з о.о. ул. Старовислна 13А ПЛ-31-038 Краков	
0198 113 00113/06	Клон в Елблаг, АББ Сп. з о.о. ул. Кролевиецка 11 ПЛ-82-300 Елблаг	

Handwritten mark

Приложение към СЕРТИФИКАТ

Стандарт **ISO 9001:2015**

Рег. Ном.: 01 100 1541808

0198 113 00113/07 Клон в Пшаснич,
АББ Сп. з о.о.
ул. Лесно 59
ПЛ-06-300 Пшаснич

0198 113 00113/08 Клон в Вроцлав,
АББ Сп. з о.о.
ул. Гранична 8В
ПЛ-54-610 Вроцлав

0198 113 00113/09 Клон в Вроцлав,
АББ Сп. з о.о.
ул. Бачиарелего 54
ПЛ-51-649 Вроцлав

24.11.2016 г.

Подпис /не се чете/
ТЮВ Реиланд Полска Сп. з о.о.
ул. 17 Стижна 56 02-146 Варшава

Handwritten signature

Стр.2 от 2

Handwritten signature

(

(

2

Handwritten mark

Certificate

Standard **ISO 14001:2015**

Certificate Registr. No. 01 104 1541809

Certificate Holder: **ABB Sp. z o.o.**
ul. Żegańska 1
04-713 Warszawa

including the locations according to annex

Scope: Research and development as well as design, programming, manufacturing, sale, process and final testing, services and turnkey execution:

- distribution and power transformers, insulation kits as well as painting and welding works; dry transformers including also components for dry transformers, components for traction transformers
- low, medium and high voltage electrical apparatus and power systems;
- automation products including control and measurement equipment, motors, interlocks
- and protection, informative as well as automation systems for power facilities and industry;
- gas compressor and metering stations, gas compressor units and equipment, underground gas storages, gas pipelines and similar services for gas industry petroleum refineries and petrochemical industry;
- robots and industrial robotics stations;
- supercharging of diesel and gas engines;
- main host;
- production of low voltage motors;
- production of power electronics and medium voltage drives.
- Computer software production and implementation.

Technical training in scope of automatics, robotics and electrical power equipment and systems

Programs science and research in the fields of power and automation

Handwritten mark

Proof has been furnished by means of an audit that the requirements of ISO 14001:2015 are met.

Validity:

The certificate is valid from 2016-11-29 until 2019-11-28.
First certification 2013


2016-11-24

Gregorz Guabka

TÜV Rheinland Cert GmbH
Am Grauen Stein · 51105 Köln

www.tuv.com

Large handwritten signature



TÜVRheinland®
Precisely Right.

Handwritten signature

Annex to certificate

Standard **ISO 14001:2015**


Certificate Registr. No. 01 100 1541809



No.	Location	Scope
0198 113 00113 /01	ABB Sp. z o.o. ul. Żegańska 1 04-713 Warszawa	As for certificate
0198 113 00113 /02	Oddział w Łodzi ABB Sp. z o.o. ul. Aleksandrowska 67/93 91-205 Łódź	
0198 113 00113 /03	Oddział w Aleksandrowie Łódzkim ABB Sp. z o.o. ul. Placydowska 27 95-070 Aleksandrów Łódzki	
0198 113 00113 /04	Oddział w Krakowie ABB Sp. z o.o. ul. Wadowicka 12 30-415 Kraków	
0198 113 00113 /05	Oddział w Krakowie ABB Sp. z o.o. ul. Starowiślna 13A 31-038 Kraków	
0198 113 00113 /06	Oddział w Elblągu ABB Sp. z o.o. ul. Królewiecka 11 82-300 Elbląg	

TÜV Rheinland ist ein eingetragenes Unternehmen der TÜV Group AG, ein Unternehmen der TÜV Group AG, ein Unternehmen der TÜV Group AG

Page 1 of 2


www.tuv.com

 **TÜVRheinland®**
Precisely Right.

42

Logo

Annex to certificate

Standard **ISO 14001:2015**

Certificate Registr. No. 01 100 1541809

0198 113 00113 /07 **Oddział w Przasnyszu**
ABB Sp. z o.o.
ul. Leszno 59
06-300 Przasnysz

0198 113 00113 /08 **Oddział we Wrocławiu**
ABB Sp. z o.o.
ul. Graniczna 8B
54-610 Wrocław

0198 113 00113 /09 **Oddział we Wrocławiu**
ABB Sp. z o.o.
ul. Bacciarellego 54
51-649 Wrocław

2016-11-24

Gregorz Guabka

TÜV Rheinland Polska Sp. z o.o.
ul. 17 Stycznia 56 02-146 Warszawa

[Handwritten mark]

[Large handwritten signature]

[Faint rectangular stamp]

Page 2 of 2



[Handwritten signature]

(

(

1997

СЕРТИФИКАТ

/превод от английски език/

Стандарт **ISO 14001:2015**
Рег. Ном.: 01 104 1541809
Носител на сертификата: АББ Сп. з о.о.
ул. Зеганска 1
04-713 Варшава
включително локациите съгласно приложението

Обхват: Проучване и разработване, както и проектиране, програмиране, производство, продажба, процедуриране и финално изпитване, сервизни услуги и цялостно изпълнение „под ключ“ на следното:

- Разпределителни и силови трансформатори, изолационни комплекти, както и работи по боядисване и заваряване; сухи трансформатори включително също компоненти за сухи трансформатори, компоненти за тягови трансформатори
- Електрически апарати за ниско, средно и високо напрежение и електрически системи
- Продукти за автоматизация включително апаратура за управление и измерване, двигатели и блокировки
- И защита, информативна както и система за автоматизация за енергийни обекти и индустрията
- Газ-компресорни и измервателни станции, газ-компресорни блокове и оборудване, подземни хранилища за газ, газопроводи и подобни услуги за газовата индустрия петролни рафинерии и нефтената химическа промишленост
- Главно хранилище
- Роботи и индустриални роботизирани станции
- Суперзареждане на дизелови и газ двигатели
- Производство на двигатели ниско напрежение
- Производство на силова електроника и задвижвания за двигатели средно напрежение
- Производство на компютърен програмен софтуер и внедряване.

Техническо обучение в обхват на автоматика, роботика и електрическо силово оборудване и системи.

Доказателства са представени , въз основа на проведения одит, че изискванията съгласно ISO14001:2015 са изпълнени.

Валидност: Този сертификат е валиден от 29.11.2016г. до 28.11.2019 г.
Първа сертификация 2013 г.

24.11.2016 г.

Подпис /не се чете/
ТЮВ Реиланд Серт
Am Grauen Stein, 51105 Кьолн

Приложение към СЕРТИФИКАТ

Стандарт **ISO 14001:2015**

Рег. Ном.: 01 104 1541809

№	Локация:	Обхват
0198 113 00113/01	АББ Сп. з о.о. ул. Зеганска 1 ПЛ 04-713 Варшава	както е в сертификата
0198 113 00113/02	Клон в Луч, АББ Сп. з о.о. ул. Александровска67/93, ПЛ-91-205 Луч	
0198 113 00113/03	Клон в Александровие Лучким, АББ Сп. з о.о. ул. Плачидовска 27 ПЛ-95-070 Александров Лучким	
0198 113 00113/04	Клон в Краков, АББ Сп. з о.о. ул. Вадовичка 12 ПЛ-30-415 Краков	
0198 113 00113/05	Клон в Краков, АББ Сп. з о.о. ул. Старовислна 13А ПЛ-31-038 Краков	
0198 113 00113/06	Клон в Елблаг, АББ Сп. з о.о. ул. Кролевиецка 11 ПЛ-82-300 Елблаг	

2/6

Handwritten mark

Приложение към СЕРТИФИКАТ

Стандарт **ISO 14001:2015**

Рег. Ном.: 01 104 1541809

0198 113 00113/07
Клон в Пшаснич,
АББ Сп. з о.о.
ул. Лесно 59
ПЛ-06-300 Пшаснич

0198 113 00113/08
Клон в Вроцлав,
АББ Сп. з о.о.
ул. Гранична 8В
ПЛ-54-610 Вроцлав

0198 113 00113/09
Клон в Вроцлав,
АББ Сп. з о.о.
ул. Бачиарелего 54
ПЛ-51-649 Вроцлав

24.11.2016 г.

Handwritten signature
Подпис /не се чете/
ТЮВ Реиланд Полска Сп. з о.о.
ул. 17 Стижна 56 02-146 Варшава

Стр.2 от 2

Handwritten signature

47

C.

C.

11.11.75

**„Доставка на електрически апарати
110кV“, реф. № РРД 17-064.**


**Обособена позиция 2 – Доставка на
токови измервателни трансформатори
110кV за монтаж на открито – 21бр.**

ПРИЛОЖЕНИЕ 1

(

(

2008



High Voltage Products

Current transformers PA 123a and PA 145a

2008

Product description

The PVA 123a and PVA 145a current transformers are used for feeding measurement and protection systems in electric power grids with the highest system voltage of 123 kV or 145 kV, respectively, and frequency of 50 Hz. They are designed to operate in grids with effectively earthed or insulated neutral points as well as in compensated earthed systems. The transformers are suitable to operate in outdoor conditions with ambient temperature from 233 K (-40°C) to 313 K (+40°C) and at relative humidity of up to 100% at 303 K (+30°C), at an altitude not exceeding 1000 m above sea level. Two designs are available: with composite or porcelain insulator.

Current transformers type PA 123a and PA 145a feature a top core design; active parts are placed in a tight enclosure filled with PCB-free transformer oil.

The covered transformer's stainless steel compensation bellows in casing is fixed to the head. The compensation bellows compensates for thermal changes in oil volume.

Top core construction

The use of the top core design in the current transformer makes it possible to achieve high values of thermal and dynamic short-circuit currents as well as a broad range of rated primary currents and burdens of secondary windings.

Primary and secondary windings and accuracy classes

The primary and secondary windings are made of electrical copper and aluminum. For clients requiring high transformation accuracy with low values of selected rated primary currents, we are able to deliver a solution comprising the use of special classes 0.2S and 0.5S. We guarantee very high transformation accuracy in the special classes, from 1% to 120%, 150% and even to 200% of the value of selected primary current for both secondary currents of 1 A and 5 A.

Secondary windings for protection purposes are offered in all accuracy classes, namely: 5P, 10P, 5PR, 10PR, TPX, TPY, TPZ, PX, PXR.

Our laboratory for measurements of accuracy classes of instrument transformers is one of the most advanced and well-equipped research facilities in the country. We are accredited by the Polish Central Office of Measures.

Current range switching

The transformer can be switched on the primary side as well as on the secondary side. A metal jumper is used for current range switching on the primary side. It shall be placed in appropriate location in accordance with the terminal board. This solution does not require performance of additional operations related to change of location of line connections.

Main insulation

The main insulation is made of insulation paper impregnated with transformer oil. We utilize high quality oil conforming to IEC 60296 Standard requirements. This oil does not contain PCBs or any other highly toxic substances and has low environmental impact.

Hollow insulator

The standard insulator is made of brown porcelain with creepage distance required for the 3rd pollution zone. A grey composite insulator with creepage distance required for the 4th pollution zone is available upon request. All materials used in the production of our insulators conform to relevant IEC Standards.

Enclosure

All external parts are robust and made of corrosion resistant materials. All enclosure joints are leak proof due to O-ring sealing system. Each completely assembled unit is subject to stringent leakage checks during routine testing. The expansion bellows is equipped with a large oil level indicator that enables observations of changes in oil volume even from a large distance.

Primary terminals

The standard primary terminals are flat, made of aluminum, and their width is 100 mm or 200 mm. Upon request we can offer pin type primary terminals, made of copper or aluminum, with a diameter of 30 mm or 40 mm.

Terminal box

The terminal box is made of aluminum and fixed to the transformer's bottom tank. Tightness -- according to IP55. Secondary terminals are available for connection of conductors with cross-section of up to 10 mm². Sealing of current measurement terminals is also possible upon request. The standard terminal box is equipped with two M40 cable glands (for cables from Ø 19 mm to Ø 28 mm). We offer terminal boxes with different number of cable glands upon request. IT's with two secondary boxes are available upon request (possibility of splitting into measuring and protective part).

Technical specifications

Handwritten mark

General information

Parameter	Value	
Type	PA 123a	PA 145a
Compliance with standards	IEC 61869-2; PN-EN 61869-2	
Highest system voltage	123 kV	145 kV
Power-frequency withstand test voltage	50 Hz 230 kV	50 Hz 275 kV
Rated lighting-impulse withstand voltage	1,2/50 μ s 550 kV	1,2/50 μ s 650 kV
Minimum creepage distance	16; 20; 25; 31 mm/kV	
Rated frequency	50 Hz	
Total weight [max.]	420; 360* kg	

*Composite insulator.


Current module

Rated current [A]	Short-circuit thermal current 1 s [kA]	Dynamic short-circuit current [kA]
50-3000	up to 63	up to 157

Switched design 1:2 or 1:2:4 on request.

Parameter	Value
Rated secondary current	1 A; 5 A
Extended current range	120%; 150%; 200%
Number of cores	1-6
Measuring cores parameters:	
- total rated output	1-200 VA
- accuracy class	0,1; 0,2; 0,2S; 0,5; 0,5S; 1; 3; 5
Protection cores parameters:	
- total rated output	1-200 VA
- accuracy class	5P, 10P, 5PR, 10PR, TPX, TPY, TPZ, PX, PXR

Dimensional drawing



*) The dimension depends on the insulator and the type of a primary terminal

Handwritten mark

Handwritten signature

More information

ABB Contact Center

ph.: +48 22 22 37 777

e-mail: kontakt@pl.abb.com

ABB Sp. z o.o.

Branch Office in Przasnysz

ul. Leszno 59

06-300 Przasnysz

ph.: +48 22 22 38 931, +48 22 22 39 255

fax: +48 22 22 38 958

www.abb.pl

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights to this document and its subject matter, as well as illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB.

© Copyright 2014 ABB
All rights reserved

Handwritten mark

**„Доставка на електрически апарати
110кV“, реф. № PPD 17-064.**

**Обособена позиция 2 – Доставка на
токови измервателни трансформатори
110кV за монтаж на открито – 21бр.**

ПРИЛОЖЕНИЕ 2

Handwritten mark

Handwritten mark

(

(



РЕПУБЛИКА БЪЛГАРИЯ
Български институт по метрология

REPUBLIC OF BULGARIA
Bulgarian Institute of Metrology



УДОСТОВЕРЕНИЕ
ЗА ОДОБРЕН ТИП СРЕДСТВО ЗА ИЗМЕРВАНЕ
Measuring Instrument Type-approval Certificate


№ 16.05.5104

Издадено на производител: ABB Sp. zo. o., Poland
Issued to manufacturer: 06-300 Przasnysz, ul. Leszno 59

На основание на: чл. 32, ал. 1 от Закона за измерванията (ДВ, бр. 46 от
In Accordance with: 2002 г., изм. бр. 88 от 05 г., изм. и доп. бр. 95 от 2005 г.)

Относно: измервателни токови трансформатори тип PA 123а, PA 145а
In Respect of:

Знак за одобрен тип:
Type Approval Mark:



Технически и метрологични характеристики: приложение, неразделна част от настоящото
Technical and metrological characteristics: удостоверение за одобрен тип средство за измерване

Срок на валидност: 12.05.2026 г.
Valid until:

Вписва се в регистъра на одобрените за използване типове средства за измерване под №: 5104
Reference №:

Дата на издаване на удостоверението за одобрен тип: 12.05.2016 г.
Date:

И. Д. ПРЕДСЕДАТЕЛ
Паун Илчев



страница 1 от 2

Приложение към удостоверение за одобрен тип № 16.05.5104

Издадено на производител: ABB Sp. zo. o., Poland, 06-300 Przasnysz, ul. Leszno 59
Относно: измервателни токови трансформатори тип PA 123a, PA 145a

1. Описание на типа:

Измервателните токови трансформатори тип PA 123a и PA 145a се използват за измерване и защита на електрически мрежи с максимално допустимо работно напрежение до 123 kV и 145 kV и честота 50 Hz. Те са проектирани да работят в системи с ефективно заземен или изолиран звезден център, както и в компенсирани системи. Предназначени са за външен монтаж.

Активната част на токовите трансформатори се състои от първична намотка, вторични намотки и ядро, разположени в херметичен корпус запълнен с трансформаторно масло, не съдържащо полихлорирани бифинили РСВ. Ядрата са разположени в горната част на токовия трансформатор.

Първичната и вторичната намотки са направени от висококачествена електротехническа мед, позволяваща висок клас на точност започващ от 0,1 при ниски стойности на номиналния първичен ток. При измервателните токови трансформатори тип PA 123a и PA 145a има възможност за превключване на първичната намотка.

Изолаторът може да бъде направен от порцелан с път на утечка 25 mm/kV или 31 mm/kV. Възможно е той да бъде изработен и от полимерен композитен материал с път на утечка 31 mm/kV.

Токовите трансформатори тип PA 123a и PA 145a са подходящи за работа в условия на открито с температура на околната среда от -40 °C до +40 °C при относителна влажност на въздуха до 100% при 30 °C и надморска височина до 1000 m. Трансформаторите са изработени за общо механично натоварване от скоростта на вятъра до 34 m/s, поледица с дебелина до 20 mm и до опъване на проводника не повече от 500 N.

Вторичните клеми са обозначени със стандартни маркировки на изводите. Всички външни метални части са изработени от корозоустойчиви материали.

2. Технически и метрологични характеристики:

Характеристика	Трансформатори тип PA 123a	Трансформатори тип PA 145a
Максимално работно напрежение, kV	123	145
Честота, Hz	50	
Номинален първичен ток, A	от 50 до 3000	
Клас на точност: - измервателна намотка: - защитна намотка:	0,1; 0,2S; 0,2; 0,5S; 0,5; 1; 3; 5 5P; 10P; 5PR; 10PR; PX; PXR; TPX; TPY; TPZ;	
Коефициент на сигурност, FS	FS5; FS10	
Номинален вторичен ток, A	1; 5	
Мощност, VA	до 200	

3. Типово означение: PA 123a, PA 145a.

4. Описание на местата, предназначени за поставяне на знаци от метрологичен контрол:

- Знакът за одобрен тип (марка за залепване) се поставя на табелката с технически данни;
- Знакът за първоначална проверка (марка за залепване) се поставя до знака за одобрен тип.

**„Доставка на електрически апарати
110кV“, реф. № РРД 17-064.**

**Обособена позиция 2 – Доставка на
токови измервателни трансформатори
110кV за монтаж на открито – 21бр.**

ПРИЛОЖЕНИЕ 3

ABB**Технически данни : Токов Трансформатор**

дата : 2017-06-20
 ССР Number: -
 Наш реф. : KU 596/17
 Проект : CEZ Bulgaria

Име : bozena.trajer@pl.abb.com
 Ревизия : А

Общи данни

Количество 21
 Тип PA 123a
 Стандарти IEC 61869-2
 Монтаж Открит
 изолация Масло / хартия херметичен
 Производител, страна ABB, Полша

Работни условия

Най-високо напрежение на с-мата (фаза-фаза) U_{sys} kV r.m.s. 123
 Номинална честота f_R Hz 50
 Температура на околната среда °C -40/ +40
 Средна темп. на околната среда (период 24ч) °C ≤ 35
 Надморска височина m 1000
 Сеизмична активност съгл. IEC 62271-300 AF3

Номинално изолационно ниво

Най-високо напрежение за оборудването (фаза-фаза) U_m kV r.m.s. 123
 Обявено издържано напрежение с мълниев импулс 1,2/50 μ s kV peak 550
 Обявено издържано напрежение с промишлена честота, сухо kV r.m.s. 230
 Обявено издържано напрежение с промишлена честота, мокро kV r.m.s. 230

Отношения на тока

Номинален първичен ток I_{pr} A r.m.s. 200 - 400 - 800
 Ном. продължителен термичен ток I_{cth} A r.m.s. 240-480-960
 Ном. Краткосрочен термичен ток I_{th} / време kA r.m.s./s 31,5-31,5-31,5/1
 Номинален динамичен ток I_{dyn} kA peak 80 - 80 - 80
 Превключване Първично 1:2:4

Класове на точност

Ядро №.	Клеми	отношение A / A	Точност	Rct75	Брой клемна кутия	Капак за пламбиране
1, 2	[x]S1-[x]S2	200-400- 800/5	1-15VA 0,2S ext.120% FS5	-	1	-
3, 4	[x]S1-[x]S2	200-400- 800/5	30VA 10P10	-	1	-

[x] – означава даден номер на ядрото

Данни за продукта

Оразмерителен чертеж 2GKA614717A0596;rev.A
 Език на табелката Тип български Композитен /
 изолатор / цвят сив
 Мин. път на утечка mm 4411
 Мин. дъгово разстояние mm 1174
 Тип на първичните клеми Al плоска шина 100x120 T=20 mm;
 4xD=14/50x50mm
 Тип на заземителните клеми 2 x ϕ 14 / 45-60mm
 Тип на вторичните клеми Phoenix rail клемни блокове;
 пружинна връзка, тип ST 10
 Кабелни уплътнения – клемна кутия No. 1 Без кабелни уплътнения;

ABB

Изпитано издържано FRнатоварване на първичните клеми	(Статично/Дин.)N	3600/5000
Боядисване (цвят)		
- Корпус над изолятора		Не е боядисан
- Корпус под изолятора		Не е боядисан
Общо тегло	kg	315
Тегло на маслото	kg	130
Тип на изолационното масло		Nynas Nytro 10XN – Inhibited Минерално изолационно масло съгл. IEC 60296
Опаковане		Вертикално-3-броя в дървена каса
Тегло на пратката	kg/Зброя	1115
Размери на пратката	cm x cm x cm/Зброя	242x106x263
Обем на пратката	m ³ /Зброя	6,4

ABB**Data Schedule : Current Transformer**

Date :	2017-06-20	Name :	bozena.trajer@pl.abb.com
CCP Number:	-	Revision :	A
Our ref :	KU 596/17		
Project :	CEZ Bulgaria		

General data

Quantity	21
Type	PA 123a
Standards	IEC 61869-2
Design	Outdoor
Insulation	Oil / paper hermetic
Manufacturer, country	ABB, Poland

Service conditions

Highest voltage of a system (phase-to-phase) U_{sys}	kV r.m.s.	123
Rated frequency f_R	Hz	50
Ambient air temperature (Temperature category)	°C	-40/ +40
Average ambient air temp. (period 24h)	°C ≤	35
Altitude	m	1000
Seismic activity acc. to IEC 62271-300		AF3

Rated insulation level

Highest voltage for equipment (phase-to-phase) U_m	kV r.m.s.	123
Rated lightning impulse withstand voltage 1,2/50 μ s	kV peak	550
Rated power-frequency withstand voltage, dry	kV r.m.s.	230
Rated power-frequency withstand voltage, wet	kV r.m.s.	230

Current ratings

Rated primary current I_{pr}	A r.m.s.	200 - 400 - 800
Rated continuous thermal current I_{cth}	A r.m.s.	240-480-960
Rated short-time thermal current I_{th} / time	kA r.m.s./s	31,5-31,5-31,5/1
Rated dynamic current I_{dyn}	kA peak	80 - 80 - 80
Reconnection		Primary 1:2:4

Accuracy ratings

Core No.	Terminals	Ratio A / A	Accuracy	Rct75	No. of terminal box	Cover for sealing
1, 2	[x]S1-[x]S2	200-400-800/5	1-15VA 0,2S ext.120% FS5	-	1	-
3, 4	[x]S1-[x]S2	200-400-800/5	30VA 10P10	-	1	-




[x] – means given number of the core

Product data

Dimension drawing	2GKA614717A0596;rev.A	
Rating plate language	Bulgarian	
Insulator type / colour	Composite / grey	
Minimum creepage distance	mm	4411
Minimum arcing distance	mm	1174
Primary terminal type	Al flat pad 100x120 T=20 mm; 4xD=14/50x50mm	
Earthing terminals type	2 x ϕ 14 / 45-60mm	
Secondary terminal type	Phoenix rail terminal blocks; spring connection, type ST 10	
Cable glands – terminal box No. 1	without cable glands;	



Withstand test load on primary terminal FR	(Static/Dyn)N	3600/5000
Painting (colour)		
- Housing above insulator		Not painted
- Housing below insulator		Not painted
Total weight	kg	315
Weight of oil	kg	130
Insulating oil type		Nynas Nytro 10XN – Inhibited mineral insulating oil acc. to IEC 60296
Packing		Vertical -3-pack wooden crate
Shipping weight	kg/3unit	1115
Shipping dimensions	cm x cm x cm/3unit	242x106x263
Shipping volume	m3/3unit	6,4

LMU



Maximum operating voltage	(kV)	123
Total weight	(kg)	315
Insulating oil amount	(kg)	130
Wind pressure surface	(m ²)	0,65
Creepage distance	(mm)	4411
Mechanical load:		
FR - Static load	(kN)	3,6
FR - Dynamic load	(kN)	5,0
Standard	IEC 61869-2	

Comments	Order	Units	Format
Prepared 22.06.2017 P.Mikulski	Based on	mm	A3
Reviewed	Responsible department		
Approved 22.06.2017 J.Duzdowski	PGH/PLABB/IT/TS		
	Document kind		
	Document id.		
	Revision		
	Language		EN
	Page		1
	Revision		A



We reserve all rights in this document and in the information contained herein. All rights are reserved. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without express authority in writing from ABB Ltd.

Zostawiamy sobie wszelkie prawa do tego dokumentu i zawieszamy w nim informację, że wszelkie prawa do niego są zastrzeżone. Żadną część tego dokumentu nie można kopiować, przechowywać w systemie informacji, ani przekazywać w inny sposób bez wyrażenia pisemnej zgody ABB Sp. z o.o.

APR


65

(

(

KU596/17
1S1-1S2 = 2S1-2S2

Teoretyczna charakterystyka wzbudzenia 1S1-1S2




Handwritten signature

Handwritten signature

Handwritten signature

3S1-3S2 = 4S1-4S2



Low

ABB Токов трансформатор

ISO 146043

Тип	PA 123a	Сериен №	2GGKAnnnnnnn	Производство година	yyyy
Изолационно ниво	123/230/550 kV	Стандарт	IEC 61869-2	Темп.	-40/40
Транспортиране	Вертикално	f _R	50 Hz	F	3,6 kN
				Клас изолация	A
I _{th}	31,5-31,5-31,5 kA/1s	I _{dyn}	80-80-80 kA	I _{cth}	240-480-960

- 1S1-1S2 200-400-800/5A 1-15VA cl.0,2S ext.120% FS5
- 2S1-2S2 200-400-800/5A 1-15VA cl.0,2S ext.120% FS5
- 3S1-3S2 200-400-800/5A 30VA cl.10P10
- 4S1-4S2 200-400-800/5A 30VA cl.10P10

Тегло	315 kg	Тегло на маслото	130 kg
Тип на маслото	Nynas Nytro 10XN ISO-L-NTIO-2960130		

Внимание: Херметични устройство, не разпечатва. Масло за вземане на проби в съответствие с инструкциите на производителя.


180

Serial number 2GGKAnnnnnnn
Production year yyyy = Actual year of production

Marking of the plate performed by laser engraving method.

of a registered system. successfully approved. The marked in the "Approved"-field. and in the information or disclosure to third parties forbidden. ABB Sp. z o.o. do tego dokumentu i wszelkich innych i przekazaniach osobom trzecim. ABB Sp. z o.o.	Aluminium sheet: EN AW-5754(AlMg3) Material standard: EN 485-1/EN 573-3	Anodizing: ISO 7599 Layer thickness: 20µm
	Material:	Coating: /
Prepared by: P.Mikutski	Date: 22.06.2017	Replacement of: _____ Application: _____
Name of item: _____		Title: _____

Handwritten signature



Електрическа схема на измервателен трансформатор

ВНИМАНИЕ!

1. ВИСОКО НАПРЕЖЕНИЕ ПРИ ОТВОРЕНИ ТОКОВИ ВТОРИЧНИ КЛЕМИ XS1 – XS2
2. ПО ВРЕМЕ НА РАБОТА НА ИЗМЕРВАТЕЛНИЯ ТРАНСФОРМАТОР КЛЕМА tgδ ТРЯБВА ДА БЪДЕ ЗАЕМЕНА

180

Marking of the plate performed by laser engraving method.

Content and in the information of a computerized system, or disclosure to third parties without the prior written consent of the manufacturer.

This document is a technical drawing of a measuring transformer. It is intended for use in the production of the transformer.

Aluminium sheet:
 EN AW-5754(AIMg3)
 Material standard:
 EN 485-1/EN 573-3

Material:

Anodizing: ISO 7599
 Layer thickness: 20µm

Coating: /

Prepared by: P.Mikulski

Date: 22.06.2017

Replacement of: _____


Application: _____

This document is issued by means of a computerized system. The digitally stored original is electronically approved. The approved document has a date entered in the Approved-field. A manual signature is not required.

Ma

- Other types / executions of secondary terminals — on request.
1. Current secondary terminals [we offer spring-cage feed-through terminals of Phoenix make type ST or screw connection type UT]
 2. Current coil screen terminal 'tg 2'
 3. Earthing jumper [crosswise plug-in bridge]
 4. Rething plate
 5. Schematic diagram plate
 6. Resin bushing
 7. Earthing coil
 8. Screws used for sealing of terminal box
 9. Locking [for padlock]
 10. Ventilation valve
 12. Cable panel [detachable]

Dimensions are given in mm.



We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure of this document is prohibited without the written permission of the ABB Group. For more information, please contact your local ABB representative.

Zaštitni znak i naziv tvrtke ABB su zaštićeni znakovi i oznake zaštićeni znakovi tvrtke ABB. Sva prava su zadržana.

Prepared by	P. Mikulski	Date	22.06.2017	Replacement of	
Modified by		Date		Responsible department	PG-IV
Approved by	J. Duzdowski	Date	22.06.2017	Take over department	
Revision	A				


ABB Sp. z o.o. Power Grids

Secondary terminal box of current transformer

Document no. 26KA7143

Current Transformers PA 123a and PA 145a Installation and operation manual

sm



Your safety first!

This is the reason why our manual begins with the following guidelines:

- Use the transformer for its intended purpose.
- Observe the technical data given in the rating plate and in the specification.
- To facilitate the installation and ensure high quality standards, the installation should be carried out by specially trained personnel or supervised by the service department of ABB.
- Operations have to be carried out by specially trained electricians who are familiar with the following instructions.
- It is recommended to observe the standards (DIN VDE/IEC) and local OHS regulations, as well as the requirements of the local electric authority.
- Transformer work should be changed over in accordance with the instructions in the manual.
- All documentation should be available to all persons involved in installation, maintenance and operation.
- Operating personnel shall bear all responsibility for all aspects related to the operational safety as stated in EN 50110 (VDE 0105) and national regulations.
- Observe the safety rules, which are compliant with EN 50110 (VDE 0105). This standard regards ensuring a no-voltage condition at the site for works to be carried out on the transformer.

If you have any questions regarding the Information contained in this manual, our organisation will provide the necessary information.

Important information

This manual is intended to explain the mode of operation and installation of the product.



NOTE:

All descriptions contained in this document are for general information only and do not make consideration for specific design requirements. Please refer to the exact design documentation while connecting the device.

Operating the device without first reading the manual may entail property damage, serious injury or death. The person responsible for the installation of the device should read the following instructions and follow the recommendations contained herein.

For your own safety:

- Make sure that all installation, service and maintenance works are carried out by professionals.

- Make sure that all applicable regulations will be preserved during all the work phases (installation, service, maintenance).
- Make sure that the guidelines contained in this manual are followed.

Basic guidelines for this manual

Read the relevant chapters of this manual to provide adequate work.

Chapters in this manual are marked according to their meaning.



For the purposes of this manual, failure to follow the instructions concerning the dangers could result in death, serious injury and damage of equipment.

Table of Contents



1. Introduction	4
2. Delivery of transformer.....	4
3. Transportation, unpacking, lifting	4
4. Storage	4
5. Installation	4
5.1. Earthing terminals	4
5.2. Primary terminals.....	4
5.3. Secondary terminals	5
6. Bolt tightening torques.....	6
7. Operation and maintenance	6
7.1 Operation	6
7.2. Corrosion protection.....	7
8. Structure of the transformer	7
9. Recycling and disposal.....	9
9.1. Recycling and disposal proceedings.....	9
10. Checklist	10
10.1. Before the first energising	10
10.2. After the first energising	10
11. Conclusion.....	10

Current Transformers PA 123a and PA 145a

1. Introduction

The subject of this manual are type PA 123a and PA 145a overhead current transformers. These transformers are used for feeding measurement and protection systems in power networks with maximum system voltage of 123 kV and 145 kV or lower (the greatest effective value of phase-to-phase voltage) and 50 Hz frequency. They are designed for operation in power systems with earthed or insulated neutral points as well as in compensated networks.

2. Delivery of transformer

Typically, the transformers are delivered in bulk packaging (3 pcs) where they are stacked vertically. The packaging is in the form of a complete crate. The delivered transformers are fully assembled, tested and ready for direct use. Product test protocols are delivered together with the transformers.

Immediately after the delivery, check the transformer for any transport damage. Check the transport packaging. A damaged packaging may indicate a careless handling of the transformer. Then, check the transformer. Special attention should be paid to possible damage of sheds and binder at insulator flanges, the transformer tightness and the correct oil level indication in the device. One should ensure that technical parameters of the transformer given in the rating plate are in accordance with the parameters given when submitting the order and in accordance with the design documentation parameters.

Any damage or other defects should be immediately notified to the manufacturer and, if appropriate, the carrier. Photos will be helpful for any damage assessment.

3. Transportation, unpacking, lifting

Transformers should be transported in a vertical position. Transformers should be transported in accordance with transport manual No 2GKA612015.

Transformers should be transported in wooden complete crates, 3 pcs in each. Due to the high centre of gravity, transformers must be additionally protected with boards attached at the level of the head.

4. Storage

Transformers should be stored on a levelled and hardened surface, preferably in the original packaging. In the case of long storage, it is recommended to protect contact surfaces against corrosion.

Transformers can be stored in the open air for up to two years. If this period is exceeded, it is recommended to place transformers in a well-ventilated room or under a roof, and to insert silica gel or another moisture absorbent into terminal boxes.

5. Installation

The support structure should be flat and horizontal. The level correction can be carried out using shims placed between the transformer and the support structure. Provisions of the transport manual No 2GKA612015 should be followed while erecting the transformer. Use bolts of correct size for fastening the transformer to the support structure. The support structure and fastening elements are not included in the delivery. The transformer should be placed in the vertical position at least 24 h before energization.

5.1. Earthing terminals

Two earthing terminals are located diagonally in the bottom of the transformer. Prior to connection, the contact surface of the terminals should be thoroughly cleaned from the oxide layer so it becomes uniform and smooth. Additionally, a thin layer of conducting grease should be applied in order to improve contact. The earthing should be connected using stainless bolts.

5.2. Primary terminals

Primary terminals of the transformer, marked as P1 and P2, are placed on the opposite sides of the head. The transformer can be switched on the primary side as well as on the secondary side. A metal jumper is used for current range switching on the primary side.

The primary winding should be switched to the required current range by locating a moving jumper, fastened with two M16 bolts in the respective position.



Note:

Jumper tightening torque 90 Nm

Current range jumper positions are shown on the rating plate.

Handwritten signature




Fig. 1. Example: Rating plate with current range jumper positions.

All contact surfaces of the primary terminals should be even and cleaned from the oxide layer before connecting. In the case of copper terminals, use of extraction naphtha is usually sufficient. Conducting grease can be applied in order to improve contact. Use M10 bolts (stainless steel is recommended) to connect wire lugs with the terminals. Incorrect primary connection could induce the transformer to overheat, which can cause failures. Primary connections should be made in such a way so as to minimise mechanical static loads of the transformer terminals. The maximum allowable static load of each transformer terminal is equal


to 3,600 N in any direction. Only one terminal may be loaded with such force at a time.

5.3. Secondary terminals

Secondary windings are connected to terminal blocks in the terminal box on the bottom tank of the transformer. These are typically Phoenix Contact ST spring connectors with terminals adapted for the connection of cables of cross-section up to 10 mm² or up to 6 mm². Each terminal is described in compliance with the markings given on the rating and schematic diagram plates. Yellow-green terminals (with the earthing mark) are intended for earthing the secondary windings with the use of push-in cross-bridges. The crosswise bridge can be removed with a screwdriver by inserting it in the slit and levering.

Optionally, the connectors to which metering windings are connected may be adapted for sealing with the use of a transparent cover. The current coil screen is led out with a pin through the resin casting (tg δ terminal).

A rating plate is placed on the external side of the door, with the schematic diagram plate placed inside. The plate with the secondary circuit wire glands is located on the terminal box bottom wall. Typically, they are two M40 glands with the diameter range of Φ 19–28 mm. An example of a terminal box for secondary windings of the transformer is shown in Figure 2.



Connect external circuits to secondary terminals of the current module of the transformer pursuant to the wiring shown on the schematic diagram plate and in accordance with the design documentation.

The current coil screen terminal (tg δ) should be earthed with a jumper during normal transformer operation.

Connectors inside the terminal box are arranged so that, when using crosswise bridges, earthing is possible for any secondary terminal of a given winding.

Transformer with taps on the secondary side:

- In the case of a transformer with the secondary side switching option, the unused taps must remain unearthed. Only connect the earthing to one of the terminals, which are connected with the external circuit for the selected secondary winding.

Unused windings:

- The first and the last terminals (for the secondary side switching option: those terminals correspond to the highest transformer ratio) of the unused secondary winding should be connected with each other (minimum wire size: 6 mm²) and earthed with a crosswise bridge. Each unused winding should be earthed in one point only.



Note:

Opening the current module secondary circuit in the standard operation mode causes high voltage on terminals of this circuit. This is hazardous to the staff and may damage the transformer insulation.

6. Bolt tightening torques

Primary terminal bolts M10	40 Nm
M16 Bolts fastening the Jumper	90 Nm
Bolts fastening the transformer to the support structure	280 Nm

7. Operation and maintenance



Note:

Combined transformers are HV devices, hence appropriate safety precautions shall be observed during their operation. The transformer measurement range is only guaranteed within the operating range determined based on the ratings in compliance with the respective standards. The standard number is shown on the transformer rating plate. The measurement range of the transformer is also shown in the product test protocol as delivered with the transformer. The measurement parameters are not guaranteed off that range.

7.1. Operation

The combined transformers do not require any special maintenance procedures. Visual inspection is usually sufficient. The maintenance schedule is included at the end of this manual.

Visual inspection

The visual inspection should include the checking of:

- position of the oil level indicator,
- tightness of the transformer,
- lack of mechanical damage,
- condition of the insulator and binder connecting the insulator with flanges.

From time to time, primary terminals torque should be checked. The transformer tightness is of a particular importance as air could penetrate the device in the case of oil leaks.

Oil level indicator:

Changes of the oil level indicator position depend on oil temperature in the transformer. The indicator should remain within the green field range. Shifting of the indicator to the upper or lower red field points out to an incorrect transformer operation. In this case, the transformer should be put out of service, and the manufacturer should be contacted.

On the lid covering the head stainless steel expansion bellows are placed, used for compensation of oil volume thermal changes in the transformer. The oil level indicator (2) is placed on the surface of the bellows. The bellows is seated in a metal housing (3) equipped with a window (4). Cover removal does not result in unsealing of the transformer. The whole compensation system is shown in Figure 3.



Note:

Oil level indication for all three transformers installed in adjacent phases should be almost equal.

Measurement of the dielectric loss factor tg δ :

During measurement of the dielectric loss factor tg δ , the measuring bridge should be connected to the correct terminal marked with the tg δ symbol, after the previous removal of the earthing jumper from this terminal. Remember to earth the terminal again after the measurement. Typically, the test voltage should be 1 kV RMS and should be applied between the closed primary terminals and terminal tg δ .

Handwritten signature or mark at the top of the page.




Fig. 3. Construction of the compensation system

Oil sampling:

Due to the fact that transformers are airtight, they do not require periodical oil checking. Oil used in the transformer meets the requirements of PN-EN 60296 (IEC 60296). Oil check is recommended after 15–20 years of operation or after a fault, if any suspicion as to the transformer efficiency exists.

Contact the manufacturer in order to obtain necessary instructions for the oil sampling procedure. Oil sampling without the manufacturer's permission during the guarantee period is the reason for the guarantee cancellation.

7.2. Corrosion protection


External components of the transformer casing are made of corrosion-proof cast aluminium alloy. Casts can be unpainted or painted. Standard colours for the paint coat: light-grey (RAL 7035), grey-green (RAL 7033). The remaining metal elements, such as bolts, are made of stainless steel.

Position of the oil level indicator	Interpretation
Indicator in the green area	Correct operation of the transformer
Indicator on the upper red field	Oil pressure too low Transformer overloading Oil gasification (insulation degradation) Further inspection necessary
Indicator on the lower red field	Oil level too low Suspicion of oil leakage (moisture ingress) penetration of air Further inspection necessary

8. Structure of the transformer

PA 123a and PA 145a type current transformers comprise a primary current coil in tight casing filled with transformer oil.

This is a "top core" type structure, where the magnetic cores are located in the transformer head. The cores with secondary windings are additionally encapsulated in a metal can connected via a tube to terminal box to terminal. Both the metal can and the tube are insulated with oil impregnated electric paper.



- 1. base
- 2. hollow insulator
- 3. head
- 4. expansion bellows in housing
- 5. current coil
- 6. terminal box for secondary circuits
- 7. P2 primary terminal
- 8. P1 primary terminal
- 9. openings for fastening the transformer
- 10. holders for lifting the transformer
- 11. oil level indicator
- 12. earthing terminal

Fig. 4. Structure of PA 123a and PA 145a current transformers

Smw

The distribution of electric stresses in the paper insulation is capacitor controlled. An exterior screen is located external to the coil, connected to the primary terminal inside the head.

External insulation comprises a hollow insulator made out of electrical porcelain with brown enamel or a glass reinforced plastic (FRP) tube coated with grey silicon rubber. O-ring seals are made of NBR oil-resistant rubber.

If calibration of measuring windings has been performed, respective marking (designations) have been placed on the transformer and the rating plate (where required).

9. Recycling and disposal

During correct operation and if no mechanical damage occurs, the transformer should operate over 30 years. Once this period of time has expired or if the operation is no longer required, it is recommended to dispose of the transformer.

Primary materials used in the transformer:

No	Material	Quantity
1	Copper (Cu -- ETP)	
2	Aluminium alloy AC-Al Si10Mg (Cu)	
3	Steel	
4	Transformer sheet steel	
5	Permalloy (iron-nickel alloy)	
6	Mineral transformer oil	
7	Electrical grade paper	
8	Solid insulation materials (epoxy resin, bakelite paper)	
9	Porcelain	
10	Composite Insulator	

Items 9 and 10 alternatively.

The above values are approximate.

9.1. Recycling and disposal proceedings

Recycling and disposal should meet national (or local) regulations. On the territory of the Republic of Poland, the transformer disposal procedure is defined in "The Waste Act" ("Ustawa o odpadach" of 14 December 2012, as published in Journal of Laws of 21/2013, as amended).

For more information please contact:

ABB Contact Center

Phone: +48 22 22 37 777

e-mail: kontakt@pl.abb.com

ABB Sp. z o.o.

Branch Office in Przasnysz

ul. Leszno 59

06-300 Przasnysz

Phone: +48 22 22 38 931; +48 22 22 39 255

Fax: +48 22 223 89 58

www.abb.pl

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the terms and conditions agreed shall apply. ABB Sp. z o.o. does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights to this document and the subject matter and illustrations contained herein. Any reproduction, disclosure to third parties or utilisation of contents — in whole or in parts — is forbidden without prior written consent of ABB Sp. z o.o.

© Copyright 2014 ABB
All rights reserved





AC 117

ИНСТИТУТ ПО ЕНЕРГЕТИКА
ИНСТИТУТ ЗА ИЗСЛЕДВАНИЯ
ул. Мори 8, 01-330 Варшава
тел.: +48 22 34 51299
факс: +48 22 836 63 63
instytut.energetyki@ien.com.pl

СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

№ 079/2014

Издание №2 от 05.03.2015

Име и адрес на притежателя на сертификата:

ABB Sp. z o.o.
ул. Зеганска 1
04-713 Варшава, Полша

Име на продукта:

Токов трансформатор

Тип:

РА 123а

Производител:

ABB Sp. z o.o. клон в Пшашниш
ул. Лешно 59
06-300 Пшашниш, Полша

Параметри и приложение на продукта:

Съгласно Приложение
Токов трансформатор, предназначен за монотрансформаторно, в електрически мрежи с номинални напрежения 110 kV

Продуктът отговаря на изискванията на:

IEC 61869-1 изд. 1.0 (2007) и IEC 61869-2 изд. 1.0

Според доклада, изработен от:

Институт по енергетика

Номер на доклада за оценка:

DZC/135с/Е/2014-1

Период на валидност:

от Ноември 2014 г. до Ноември 2017

Правото на използване на сертификата за съответствие, в рамките на срока на валидност, важи само за:

- тези копия, които отговарят на изискванията, посочени по-горе и имат същите характеристики (параметри), като модела/продукта представен за изпитания,
- притежателя на сертификата или негов оторизиран представител.



AC.117

ПРИЛОЖЕНИ КЪМ СЕРТИФИКАТ ЗА СЪОТВЕТСТВИЕ

№ 079/2014


Издание №2 от 05.03.2015

СПИСЪК НА ДОКАЗАНИТЕ ПАРАМЕТРИ

Токов трансформатор тип PA 123a	
Макс. напрежение на токовия трансформатор [U _m]	≤ 123 kV
Номинална честота [f _R]	50 Hz
Номинално изолационно ниво	AC 230 kV / LI 550 kV
Клас на натоварване	F _R =3600N
Външна изолация – път на утечка на изолятора	
- порцеланов изолатор	3640 mm
- композитен изолатор	3800 mm
Степен на защита от механично въздействие на обвивката ¹⁾	IK7
Степен на защита на вторичната клемна кутия	IP55
Токова част	
Номинален първичен ток [I _{pn}]	50 A ÷ 3000 A
Разширен токов обхват	Δо 200%
Номинален продължителен ток на термична устойчивост [I _{cth}]	≤ 3000 A
Номинален ток на термична устойчивост [I _{th}], 1s	20 kA или 40 kA или 63 kA
Номинален ток на термична устойчивост [I _{th}], 3s	20 kA или 40 kA
Номинален ток на динамична устойчивост [I _{dyn}]	50 kA или 100 kA или 158 kA
Номинален вторичен ток [I _{cth}]	1 A или 5 A
Номинална мощност на намотките за мерене и за защита (S _r)	1 VA – 200 VA
Клас на точност на намотките за мерене (кл.)	0,1; 0,2; 0,2S; 0,5; 0,5S; 1; 3
Клас на точност на намотките за защита (кл.)	5P, 10P, 5PR, 10PR, PX, PXR, TPX, TPY, TPZ

ЗАБЕЛЕЖКА:

¹⁾ Не е приложимо е за порцеланови изолатори.



AC 117

INSTYTUT ENERGETYKI
Research Institute
01-330 Warszawa, ul. Mory 8
phone. +48 22 34 51 299
fax. +48 22 836 63 63
instytut.energetyki@ien.com.pl

CERTIFICATE OF CONFORMITY

No. 079/2014

Issue No. 02 from 05.03.2015 r.

Name and address
owner of certificate:

ABB Sp. z o.o.
1 Żegarska Str.
04-713 Warszawa, Poland

Name of the product:

Current transformer

Type:

PA 123a

Manufacturer:

ABB Sp. z o.o. Branch Office in Przasnysz
59 Leszno Str.
06-300 Przasnysz, Poland

Parameters and
application of product:

According to appendix
Outdoor current transformer assigned for power systems of rated
voltages 110 kV

The product meets
requirements of the:

IEC 61869-1 ed. 1.0 (2007) and IEC 61869-2 ed. 1.0 (2012)

According to the
report made by:

Instytut Energetyki

Number of the
assessment report:

DZC/135c/E/2014-1

Period of validity:

from November 2014 until November 2017

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing.
- certificate owner or his authorized representative.

The appendices to certificate of conformity including the list of evidenced parameters.

Number of appendices: 1

The system of product certification 1a (PN-EN ISO/IEC 17067:2014-01) includes:
- tests and quality assessment of project

pp of the DIRECTOR OF



AC 117

APPENDIX TO CERTIFICATE OF CONFORMITY

No. 079/2014


Issue No. 02 from 05.03.2015 r.

LIST OF EVIDENCED PARAMETERS

Current transformer type PA 123a	
Highest voltage of current transformer [U _m]	≤ 123 kV
Rated frequency [f _R]	50 Hz
Rated insulation level	AC 230 kV / LI 550 kV
Burden class	F _R =3600N
External insulation – minimal creepage distance of insulator:	
• Ceramic insulator	3640 mm
• Composite insulator	3800 mm
Degree of protection to mechanical impact of enclosure ¹⁾	IK7
Degree of protection of secondary terminal enclosure	IP55
Current element	
Rated primary current [I _{pr}]	50 A ÷ 3 000 A
Extended current rating	to 200%
Rated continuous thermal current [I _{cth}]	≤ 3000 A
Rated short-time thermal current [I _{th}] during 1 s	20 kA or 40 kA or 63kA
Rated short-time thermal current [I _{th}] during 3 s	20 kA or 40kA
Rated dynamic current [I _{dyn}]	50 kA or 100 kA or 158 kA
Rated secondary current [I _{sr}]	1 A or 5 A
Core power to measurements and to protection (S _c)	1VA – 200 VA
Measure core accuracy class (kl.)	0,1; 0,2; 0,2S; 0,5; 0,5S; 1; 3; 5
Protective core accuracy class (kl.)	5P; 10P; 5PR; 10PR; PX; PXR; TPX; TPY; TPZ

NOTES:

¹⁾ Do not apply to ceramic insulators.





2015-09-11	
2015-09-11	
No previous validation	
1	

Classification of the substance/mixture and of the company/undertaking

Nytro 10 XN
 Insulating oil
 Liquid,
 Oils

Subsidiants- Industrial
 in and closed systems - Professional
 ce - Industrial
 cking of substances and mixtures - Industrial
 nce - Industrial
 essional

Reason
to be used in applications other than those on 1, without first seeking the advice of the

Head office:
 Nynas AB
 P.O. Box 10700
 SE-121 29 Stockholm
 SWEDEN
 +46 8 602 12 00 (Office hours 8 am - 4,30 pm (CET))
 www.nynas.com
 ProductHSE@nynas.com

Nynas sp. z o.o.
 ul. Kolberga 48D
 PL-44 100 Gilwice
 POLAND
 +48 32 232 74 10

Number
 /Poison Centre
 +44 (0) 1235 239 670
 24 hour service

Conforms to Regulation No. 1907/2006 (REACH), Annex II
 Nytro 10 XN

SECTION 2: Hazards identification

2.1 Classification of the substance or mixture
 Mixture
 Classification according to Regulation (EC) No. 1272/2008 [CLP/GHS]
 Asp. Tox. 1, H304
 Aquatic Chronic 3, H412
 The product is classified as hazardous according to Regulation (EC) 1272/2008 as amended.
 See Section 16 for the full text of the H statements declared above.
 See Section 11 for more detailed information on health effects and symptoms.

2.2 Label elements
 Hazard pictograms



Signal word
 Hazard statements
 P273 - Avoid release to the environment
 P301 - IF SWALLOWED:
 P310 - Immediately call a POISON CENTER or physician.
 P331 - Do NOT induce vomiting.
 Not applicable.
 P501 - Dispose of contents and container in accordance with all local, regional, national and international regulations.
 Not applicable.

Precautionary statements

Prevention
 Response
 Storage
 Disposal


Annex XVII - Restrictions on the manufacture, placing on the market and use of certain dangerous substances, mixtures and articles

2.3 Other hazards
 Substance meets the criteria for PBT according to Regulation (EC) No. 1907/2006, Annex XIII
 Substance meets the criteria for vPvB according to Regulation (EC) No. 1907/2006, Annex XIII
 Not applicable.
 Not applicable.

SECTION 3: Composition/information on ingredients

3.2 Mixtures
 Mixture

Product/ingredient name	Identifiers	%	Classification Regulation (EC) No. 1272/2008 [CLP]	Type
Distillate (petroleum), hydro-treated light naphthenic	REACH #: 01-2119480375-34 EC: 255-155-5	>99	Asp. Tox. 1, H304	[1]



Composition/information on ingredients	
01-2119555270-46 EC: 204-881-4 CAS: 128-37-0	Aquatic Chronic 1, H410 See Section 16 for the full text of the H statements declared above.

to the base oil(s) in this product. Note L - The classification as a carcinogen need not apply if it substance contains less than 3 % DMSO extract as measured by IP 346. Ingredients present which, within the current knowledge of the supplier and in the table, are classified as hazardous to health or the environment, are PBTs or vPvBs or have been exposure limit and hence require reporting in this section.

with a health or environmental hazard workplace exposure limit criteria for PBT according to Regulation (EC) No. 1907/2006, Annex XIII criteria for vPvB according to Regulation (EC) No. 1907/2006, Annex XIII

First aid measures

First aid measures

Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. If irritation, blurred vision or swelling occurs and persists, obtain medical advice from a specialist.

If breathing is difficult, remove victim to fresh air and keep at rest in a position comfortable for breathing. If casualty is unconscious and: if not breathing, if breathing is irregular or if respiratory arrest occurs, provide artificial respiration or oxygen by trained personnel. Get medical attention if adverse health effects persist or are severe. Maintain an open airway.

Wash with soap and water. Remove contaminated clothing and shoes. Handle with care and dispose of in a safe manner. Seek medical attention if skin irritation, swelling or redness develops and persists.

Accidental high pressure injection through the skin requires immediate medical attention. Do not wait for symptoms to develop.

Always assume that aspiration has occurred. Do not induce vomiting. Can enter lungs and cause damage. If vomiting occurs, the head should be kept low so that vomit does not enter the lungs. Seek professional medical attention or send the casualty to a hospital. Do not wait for symptoms to develop.

Never give anything by mouth to an unconscious person. If unconscious, place in recovery position and get medical attention immediately. Maintain an open airway. Loosen tight clothing such as a collar, tie, belt or waistband.

No action shall be taken involving any personal risk or without suitable training. It may be dangerous to the person providing aid to give mouth-to-mouth resuscitation.

Before attempting to rescue casualties, isolate area from all potential sources of ignition including disconnecting electrical supply. Ensure adequate ventilation and check that a safe, breathable atmosphere is present before entry into confined spaces.

Symptoms and effects, both acute and delayed

Eye contact may cause redness and transient pain. Inhalation of oil mist or vapour may cause irritation of the respiratory tract.

SECTION 4: First aid measures

4.3 Indication of any immediate medical attention and special treatment needed
 Notes to physician

No action shall be taken involving any personal risk or without suitable training. It may be dangerous to the person providing aid to give mouth-to-mouth resuscitation. Before attempting to rescue casualties, isolate area from all potential sources of ignition including disconnecting electrical supply. Ensure adequate ventilation and check that a safe, breathable atmosphere is present before entry into confined spaces.

Always assume that aspiration has occurred.

Specific treatments

SECTION 5: Fire-fighting measures

5.1 Extinguishing media

Suitable extinguishing media

Use dry chemical, CO₂, water spray (fog) or foam.

Unsuitable extinguishing media

Do not use direct water jets on the burning product; they could cause splattering and spread the fire. Simultaneous use of foam and water on the same surface is to be avoided as water destroys the foam.

5.2 Special hazards arising from the substance or mixture

Hazards from the substance or mixture

In a fire or if heated, a pressure increase will occur and the container may burst. This substance will float and can be reignited on surface water. Fire water contaminated with this material must be contained and prevented from being discharged to any waterway, sewer or drain.

Hazardous thermal decomposition products

Incomplete combustion is likely to give rise to a complex mixture of airborne solid and liquid particulates, gases, including carbon monoxide, H₂S, SO_x (sulfur oxides) or sulfuric acid and unidentified organic and inorganic compounds.

5.3 Advice for firefighters

Special precautions for firefighters

Promptly isolate the scene by removing all persons from the vicinity of the incident if there is a fire. No action shall be taken involving any personal risk or without suitable training.

Special protective equipment for fire-fighters

Fire-fighters should wear appropriate protective equipment and self-contained breathing apparatus (SCBA) with a full face-piece operated in positive pressure mode.

SECTION 6: Accidental release measures

6.1 Personal precautions, protective equipment and emergency procedures

For non-emergency personnel

Avoid breathing vapour or mist. Keep non-involved personnel away from the area of spillage. Alert emergency personnel. Except in case of small spillages, the feasibility of any actions should always be assessed and advised, if possible, by a trained, competent person in charge of managing the emergency. Stop leak if safe to do so. Avoid direct contact with the product. Stay upwind/keep distance from source. In case of large spillages, alert occupants in downwind areas.

Eliminate all ignition sources if safe to do so. Spillages of limited amounts of product, especially in the open air when vapours will be usually quickly dispersed, are dynamic situations, which will presumably limit the exposure to dangerous concentrations.

Note : recommended measures are based on the most likely spillage scenarios for this material; however, local conditions (wind, air temperature, wave/current direction and speed) may affect the exposure to dangerous concentrations.

Personal release measures

Small spillages: normal antistatic working clothes are usually adequate.
Large spillages: full body suit of chemically resistant and thermal resistant material should be used. Work gloves providing adequate chemical resistance, specifically to aromatic hydrocarbons. Note : gloves made of PVA are not water-resistant, and are not suitable for emergency use. Safety helmet, antistatic non-skid safety shoes or boots. Goggles and /or face shield, if splashes or contact with eyes is possible or anticipated.

Respiratory protection : A half or full-face respirator with filter(s) for organic vapours (and when applicable for H2S) a Self Contained Breathing Apparatus (SCBA) can be used according to the extent of spill and predictable amount of exposure. If the situation cannot be completely assessed, or if an oxygen deficiency is possible, only SCBA's should be used.

Water polluting material. May be harmful to the environment if released in large quantities. Inform the relevant authorities if the product has caused environmental pollution (sewers, waterways, soil or air). Prevent product from entering sewers, rivers or other bodies of water. If necessary dike the product with dry earth, sand or similar non-combustible materials. In case of soil contamination, remove contaminated soil and treat in accordance with local regulations.

In case of small spillages in closed waters (i.e. ports), contain product with floating barriers or other equipment. Collect spilled product by absorbing with specific floating absorbents.

If possible, large spillages in open waters should be contained with floating barriers or other mechanical means. If this is not possible, control the spreading of the spillage, and collect the product by skimming or other suitable mechanical means. The use of dispersants should be advised by an expert, and, if required, approved by local authorities.

for containment and cleaning up
Stop leak if without risk. Absorb spilled product with suitable non-combustible materials.

Large spillages may be cautiously covered with foam, if available, to limit vapour cloud formation. Do not use water jet. When inside buildings or confined spaces, ensure adequate ventilation. Transfer collected product and other contaminated materials to suitable containers for recovery or safe disposal. Note: see Section 1 for emergency contact information and Section 13 for waste disposal. See Section 8 for information on appropriate personal protective equipment.

See Section 1 for emergency contact information.
See Section 8 for information on appropriate personal protective equipment.
See Section 13 for additional waste treatment information.

Handling and storage

Section contains generic advice and guidance. The list of Identified Uses in Section 1 should be able use-specific information provided in the Exposure Scenario(s).

Obtain special instructions before use. Hazard of slipping on spilt product. Keep away from heat/sparks/open flames/hot surfaces. - No smoking. Use and store only outdoors or in a well-ventilated area.

Avoid release to the environment.

handling

SECTION 7: Handling and storage

Protective measures
Do not ingest. Do not breathe dust/fume/gas/mist/vapours/spray. Avoid contact with eyes, skin and clothing.

Prevent the risk of slipping. Take precautionary measures against static discharge. Avoid splash filling of bulk volumes when handling hot liquid product.

Avoid release to the environment.

Nota : See Section 8 for information on appropriate personal protective equipment. See section 13 for waste disposal information.

Ensure that proper housekeeping measures are in place. Contaminated materials should not be allowed to accumulate in the workplaces and should never be kept inside the pockets. Eating, drinking and smoking should be prohibited in areas where this material is handled, stored and processed. Wash hands thoroughly after handling. Change contaminated clothes at the end of working shift. See also Section 8 for additional information on hygiene measures.

7.2 Conditions for safe storage, including any incompatibilities
Storage area layout, tank design, equipment and operating procedures must comply with the relevant European, national or local legislation. Storage area layout, tank design, equipment and operating procedures must comply with the relevant regional, national or local legislation. Storage installations should be designed with adequate bunds in case of leaks or spills. Cleaning, inspection and maintenance of internal structure of storage tanks must be done only by properly equipped and qualified personnel as defined by national, local or company regulations.

Store separately from oxidising agents.

Recommended materials for containers, or container linings use mild steel, stainless steel. Not suitable : Some synthetic materials may be unsuitable for containers or container linings depending on the material specification and intended use. Compatibility should be checked with the manufacturer.

Keep only in the original container or in a suitable container for this kind of product. Keep container tightly closed and sealed until ready for use. Do not store in unlabelled containers. Containers that have been opened must be carefully resealed and kept upright to prevent leakage. Empty containers may contain harmful flammable/combustible or explosive residue or vapours. Do not cut, grind, drill, weld, reuse or dispose of containers unless adequate precautions are taken against these hazards. Store locked up. Protect from sunlight.

7.3 Specific end use(s)

Recommendations
Industrial sector specific solutions

Not available.
Not available.

SECTION 8: Exposure controls/personal protection

The list of Identified Uses in Section 1 should be consulted for any available use-specific information provided in the Exposure Scenario(s).

8.1 Control parameters
Occupational exposure limits

Product/ingradient name	Exposure limit values
Oil mist	[Air contaminants] Rozporządzenie Ministra Pracy i Polityki Społecznej (Dz.U. 2014 poz. 817) (Poland, 6/2014). TWA: 5 mg/m ³ 8 hours, Form: Inhalable fraction

Exposure controls/personal protection

If this product contains ingredients with exposure limits, personal, workplace atmosphere or biological monitoring may be required to determine the effectiveness of the ventilation or other control measures and/or the necessity to use respiratory protective equipment. Reference should be made to appropriate monitoring standards. Reference to national guidance documents for methods for the determination of hazardous substances will also be required.

name	Type	Exposure	Value	Population	Effects
h, hydrotreated	DNEL	Long term Inhalation	5.4 mg/m ³	Workers	Local

The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrosisk model.

Mechanical ventilation and local exhaust will reduce exposure via the air. Use oil resistant material in construction of handling equipment. Store under recommended conditions and if heated, temperature control equipment should be used to avoid overheating.

Wash hands, forearms and face thoroughly after handling chemical products, before eating, smoking and using the lavatory and at the end of the working period. Ensure that eyewash stations and safety showers are close to the workstation location. Wash contaminated clothing before reuse. Recommended: Safety glasses with side shields.

4 - 8 hours (breakthrough time): nitrile rubber
 Wear protective clothing if there is a risk of skin contact. Change contaminated clothes at the end of working shift.
 Appropriate footwear and any additional skin protection measures should be selected based on the task being performed and the risks involved and should be approved by a specialist before handling this product.
 Respirator selection must be based on known or anticipated exposure levels, the hazards of the product and the safe working limits of the selected respirator. Use a properly fitted, particulate filter respirator complying with an approved standard if a risk assessment indicates this is necessary.
 Emissions from ventilation or work process equipment should be checked to ensure they comply with the requirements of environmental protection legislation. In some cases, fume scrubbers, filters or engineering modifications to the process equipment will be necessary to reduce emissions to acceptable levels.

Physical and chemical properties

Physical and chemical properties

- Liquid.
- Light yellow
- Odourless/Light petroleum.
- Not applicable.
- Not applicable.
- 60 °C
- >250 °C

Mytro 10 XV

SECTION 9: Physical and chemical properties

- Evaporation rate: Not available.
- Flammability (solid, gas): Not available.
- Upper/lower flammability or explosive limits: Not available.
- Vapour pressure: 160 Pa @ 100 °C
- Density: 0.88 g/cm³ [15°C]
- Solubility(ies): Insoluble in water.
- Partition coefficient: n-octanol/water: Not available.
- Auto-ignition temperature: >270 °C
- Decomposition temperature: >280 °C
- Viscosity: Kinematic (40 °C): 0.076 cm²/s (7.6 cSt)
- Explosive properties: Not available.
- Oxidising properties: Not available.
- DMSO extractable compounds for base oil substance(s) according to IP346: < 3%

SECTION 10: Stability and reactivity

- 10.1 Reactivity: No specific test data related to reactivity available for this product or its ingredients.
- 10.2 Chemical stability: Stable under normal conditions.
- 10.3 Possibility of hazardous reactions: Under normal conditions of storage and use, hazardous reactions will not occur.
- 10.4 Conditions to avoid: Oxidising agent.
- 10.5 Incompatible materials: Keep away from extreme heat and oxidizing agents.
- 10.6 Hazardous decomposition products: Incomplete combustion is likely to give rise to a complex mixture of airborne solid and liquid particulates, gases, including carbon monoxide, H₂S, SO_x (sulfur oxides) or sulfuric acid and unidentified organic and inorganic compounds.

SECTION 11: Toxicological information

11.1 Information on toxicological effects
Acute toxicity

Product/ingrediant name	Result	Species	Dose	Exposure	Remarks
Distillate (petroleum), hydrotreated light naphthenic	LC50 Inhalation Dusts and mists	Rat - Male, Female	>5.63 mg/l	4 hours	EMBSI 1988a (similar material)
	LD50 Dermal	Rabbit	>5000 mg/kg	-	API 1982 (similar material)
	LD50 Oral	Rat	>5000 mg/kg	-	API 1986a (similar material)
2,6-di-tert-butyl-p-cresol	LD50 Dermal	Rat	>5000 mg/kg	-	Supplier's information
	LD50 Oral	Rat	>5000 mg/kg	-	Supplier's information

Conclusion/Summary: No known skin sensitization data.

Ecological information

Result	Species	Score	Observation	Remarks
Skin - Non-irritant to skin.	Rabbit	0 to 0.8	24 to 72 hours	UBTL 1984e (similar material)
Eyes - Non-irritating to the eyes.	Rabbit	0.17 to 0.33	24 to 72 hours	UBTL 1984f (similar material)
Eyes - Redness of the conjunctivae	Rabbit	0.5	-	Supplier's information
Eyes - Iris lesion	Rabbit	0	-	Supplier's information
Eyes - Oedema of the conjunctivae	Rabbit	0.1	-	-

No known significant effects or critical hazards.
 No known significant effects or critical hazards.
 No known significant effects or critical hazards.

Route of exposure	Species	Result	Remarks
skin	Guinea pig	Not sensitizing	UBTL 1984j,k,l (similar material)

No known significant effects or critical hazards.
 No known significant effects or critical hazards.

Test	Experiment	Result	Remarks
OECD 473 473 In vitro Mammalian Chromosomal Aberration Test	Experiment In vitro	Negative	-
	Subject Mammalian-Animal Metabolic activation: with and without		

No known significant effects or critical hazards.

Result	Species	Dose	Exposure	Remarks
Negative - Dermal	Mouse - Female	0.22 to 0.25 ml	78 weeks; Various	Doak, 1983, McKee, 1989 (similar material)

The base oil(s) in this product is based on an severely hydrotreated distillate. The product should not be regarded as a carcinogen.

No known significant effects or critical hazards.

Result	Species	Dose	Exposure	Remarks

SECTION 11: Toxicological information

Conclusion/Summary No known significant effects or critical hazards.

Aspiration hazard

Product/ingredient name	Result
Distillate (petroleum), hydrotreated light naphthenic	ASPIRATION HAZARD - Category 1

Information on the likely routes of exposure Not available.

Potential acute health effects

Eye contact
 Inhalation
 Skin contact
 Ingestion
 Potential chronic health effects

Eye contact may cause redness and transient pain.
 Inhalation of oil mist or vapours at elevated temperatures may cause respiratory irritation.
 No known significant effects or critical hazards.
 May be fatal if swallowed and enters airways.

Product/ingredient name	Result	Species	Dose	Exposure
2,6-Di-tert-butyl-p-cresol	Chronic NOAEL Oral	Rat	25 mg/kg	28 days; 7 days per week

General
 Carcinogenicity
 Mutagenicity
 Teratogenicity
 Developmental effects
 Fertility effects

No known significant effects or critical hazards.
 The base oil(s) in this product is based on an severely hydrotreated distillate. The product should not be regarded as a carcinogen.
 No known significant effects or critical hazards.
 No known significant effects or critical hazards.
 No known significant effects or critical hazards.
 No known significant effects or critical hazards.

Other information Not available.
 Specific hazard

SECTION 12: Ecological information

12.1 Toxicity

Product/ingredient name	Result	Species	Exposure
Distillate (petroleum), hydrotreated light naphthenic	Acute LL50 >10000 mg/l	Aquatic invertebrates.	96 hours
	Acute LL50 >100 mg/l	Fish	96 hours
	Acute NOEL >100 mg/l	Algae	72 hours
	Chronic NOEL 10 mg/l	Aquatic invertebrates.	21 days
	Acute EC50 0.61 mg/l	Daphnia - Magna	48 hours
	Acute IC50 >0.4 mg/l	Algae - Desmodesmus	72 hours
		Subspicatus	
	Chronic NOEC 0.316 mg/l	Daphnia - Magna	21 days

Conclusion/Summary Harmful to aquatic life with long lasting effects.

12.2 Persistence and degradability

Product/ingredient name	Aquatic half-life	Photolysis	Biodegradability
Distillate (petroleum), hydrotreated light naphthenic	-	-	Inherent
2,6-Di-tert-butyl-p-cresol	-	-	Not readily

Conclusion/Summary Inherently biodegradable.

Ecotoxicological information

Name	Log ₁₀ K _{ow}	BCF	Potential
Anthracene	2 to 6	<500	low
Polystyrene	5,1	>500	high

The product has a potential to bioaccumulate.

High mobility in soil predicted, based on log K_{ow} > 3.0.

VPVB assessment

- Not applicable.
- Not applicable.

Effects: Insoluble in water. Spills may form a film on water surfaces causing physical damage to organisms. Oxygen transfer could also be impaired.

Disposal considerations

This section contains generic advice and guidance. The list of Identified Uses in Section 1 should be able to use specific information provided in the Exposure Scenario(s).

Methods

Where possible (e.g. in the absence of relevant contamination), recycling of used substance is feasible and recommended. This substance can be burned or incinerated, subject to national/local authorizations, relevant contamination limits, safety regulations and air quality legislation. Contaminated or waste substance (not directly recyclable): Disposal can be carried out directly, or by delivery to qualified waste handlers. National legislation may identify a specific organization, and/or prescribe composition limits and methods for recovery or disposal.

Yes.
aque.(EWC)

Waste designation
mineral-based non-chlorinated insulating and heat transmission oils

The generation of waste should be avoided or minimised wherever possible. Waste packaging should be recycled. Incineration or landfill should only be considered when recycling is not feasible.

Transport information

Regulations

ADR/RID	ADN	IMO/MDG Classification	ICAO/IATA Classification
regulated.	Not regulated.	Not regulated.	Not regulated.
-	-	-	-
-	-	-	-

SECTION 14: Transport information

14.5 Environmental hazards	No.	No.	No.
Additional Information	-	-	-

14.6 Special precautions for user

Transport within user's premises: always transport in closed containers that are upright and secure. Ensure that persons transporting the product know what to do in the event of an accident or spillage.

14.7 Transport in bulk

according to Annex I of MARPOL 73/78 and the IBC Code

Oils

SECTION 15: Regulatory information

15.1 Safety, health and environmental regulations/legislation specific for the substance or mixture
EU Regulation (EC) No. 1907/2006 (REACH)

Annex XIV - List of substances subject to authorisation

Annex XIV

- None of the components are listed.
- Substances of very high concern
- None of the components are listed.
- Annex XVII - Restrictions on the manufacture, placing on the market and use of certain dangerous substances, mixtures and articles

Not applicable.

Other EU regulations

Seveso Directive

This product is not controlled under the Seveso Directive.

International lists

National Inventory

Australia

Canada

China

Japan

Malaysia

New Zealand

Philippines

Republic of Korea

Taiwan

United States

- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.

15.2 Chemical Safety Assessment

Complete.



Industrial

Other information

Not available.

that has changed from previously issued version.

- ADN = European Provisions concerning the International Carriage of Dangerous Goods by Inland Waterway
- ADR = The European Agreement concerning the International Carriage of Dangerous Goods by Road
- ATE = Acute Toxicity Estimate
- CLP = Classification, Labelling and Packaging Regulation [Regulation (EC) No. 1272/2008]
- CMR = Carcinogen, Mutagen or Reproductive toxicant
- CSA = Chemical Safety Assessment
- CO₂ = carbon dioxide
- DNEL = Derived No Effect Level
- EC50 = Half maximal effective concentration
- EUH statement = CLP-specific Hazard statement
- IATA = International Air Transport Association
- IC50 = Half maximal inhibitory concentration
- IMDG = International Maritime Dangerous Goods
- LC50 = Median lethal concentration
- LD50 = Median lethal dose
- PNEC = Predicted No Effect Concentration
- PBT = Persistent, Bioaccumulative and Toxic
- RID = The Regulations concerning the International Carriage of Dangerous Goods by Rail
- REACH = Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation [Regulation (EC) No. 1907/2006]
- SCBA = Self-Contained Breathing Apparatus
- SVHC = Substances of Very High Concern

the classification according to Regulation (EC) No. 1272/2008 (CLP/GHS)

Classification	Justification
----------------	---------------

	Calculation method	Calculation method
H304	May be fatal if swallowed and enters airways.	
H400	Very toxic to aquatic life.	
H410	Very toxic to aquatic life with long lasting effects.	
H412	Harmful to aquatic life with long lasting effects.	
Aquatic Acute 1, H400	ACUTE AQUATIC HAZARD - Category 1	
Aquatic Chronic 1, H410	LONG-TERM AQUATIC HAZARD - Category 1	
Aquatic Chronic 3, H412	LONG-TERM AQUATIC HAZARD - Category 3	
Asp. Tox. 1, H304	ASPIRATION HAZARD - Category 1	
2015-09-11		
2015-09-11		
No previous validation		
1		

edge, the information contained herein is accurate. However, neither the above-named subsidiaries, assumes any liability whatsoever for the accuracy or completeness of the information. Liability of any material is the sole responsibility of the user. All materials may present unknown hazards with caution. Although certain hazards are described herein, we cannot guarantee that no other hazards exist.

Identification of the substance or mixture

Product definition
Mixture

Product name
Nytro 10 XN

Section 1 - Title

Short title of the exposure scenario

List of use descriptors

Use in formulations in lubricants- Industrial (2,6-di-tert-butyl-p-creso)

Identified use name: Use in formulations in lubricants- Industrial

Process Category: PROC01, PROC02, PROC03, PROC04, PROC05, PROC08a, PROC08b, PROC09

Substance supplied to that use in form of: As such

Sector of end use: SU03, SU10

Subsequent service life relevant for that use: No.

Environmental Release Category: ERC02

Market sector by type of chemical product: PC17, PC24, PC25

Environmental contributing scenarios

Health Contributing scenarios

Number of the ES

Industry Association

Generic exposure scenario

Processes and activities covered by the exposure scenario

Additional Information

Not applicable.

Not applicable.

Not applicable.

Covers the use of formulated lubricants within closed or contained systems including incidental exposures during material transfers, operation of machinery/engines and similar articles, equipment maintenance and disposal of wastes.

Industrial

Section 2 - Exposure controls

Product characteristics

solid

Melting/Freezing Point (°C): 69.8

5100%

Concentration of substance in mixture or article

Amounts used

Annual site tonnage
110 t/a

Frequency and duration of use

Continuous release(d/a): 300

Environment factors not influenced by risk management

Local freshwater dilution factor 10

Receiving surface water flow is 18000 m³/d.

Local marine water dilution factor 100

Other given operational conditions affecting environmental exposure

Technical conditions and measures at process level (source) to prevent release

Not applicable.

% Release fraction to wastewater from process (initial release prior to RMM) 0.2

% Release fraction to air from process (initial release prior to RMM) 0.01

% Release fraction to soil from process (initial release prior to RMM) 0

Technical on-site conditions and measures to reduce or limit discharges, air emissions and releases to soil

On-site wastewater treatment required.

Ensure all waste water is collected and treated via a waste water treatment plant.

Floors should be impervious, resistant to liquids and easy to clean.

Ensure operatives are trained to minimise exposures

Organisational measures to

Exposure controls

Size of industrial sewage treatment plant (m³/d): 2000, Removal Efficiency (total)94

No special measures are required. General information, See section 13 for waste disposal information.

See section 13 for waste disposal information.

Controlling worker exposure for 0:

Melting/Freezing Point (°C): 69.8

≤100%

solid

Solid, medium dustiness

Exposure duration per day: 8 h (full shift).

Exposure duration per year: 230 d

Respiratory (m³/d): 10

The product should be handled at room temperature.

No special measures required.

Handle only in a place with local exhaust ventilation (or other adequate ventilation).

Ensure operatives are trained to minimise exposures.

related to personal protection and hygiene

Wear protective clothing. See Section 8 of the safety data sheet (personal protective equipment).

Exposure estimation and reference to its source

Not available.

reference to its source - Environment 2:

Used EUSES model.(V2.1)

Risk characterisation ratio (PEC/PNEC): <1

reference to its source - Workers: 1:

Used ECETOC TRA model (May 2010 release). (04/2010)

Risk characterisation ratio DNELs <1

Use to DU to evaluate whether he works inside the boundaries set

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

Environment
Health

Not available.
Not available.

Environment
Health

Not applicable.
Wear protective gloves/protective clothing/eye protection/face protection.
Wear respiratory protection.
See Section 8 for information on appropriate personal protective equipment.



Safety Data Sheet (eSDS)

Professional

Substance or mixture

Mixture
Nytro 10 XN

Use as lubricant in open and closed systems- Professional (2,6-di-tert-butyl-p-cresol)

Identified use name: Use as lubricant in open and closed systems - Professional
Process Category: PROC01, PROC02, PROC03, PROC04, PROC05, PROC07, PROC08a, PROC08b, PROC09, PROC10, PROC11, PROC13
Substance supplied to that use in form of: As such
Sector of end use: SU22
Subsequent service life relevant for that use: No.
Environmental Release Category: ERC08a, ERC08d, ERC09a, ERC09b
Market sector by type of chemical product: PC17, PC24

Not applicable.

Not applicable.

Not applicable.

Covers the use of formulated lubricants in closed and open systems including transfer operations, operation of engines and similar articles, reworking on reject articles, equipment maintenance and disposal of waste oil.

Professional

Exposure controls

solid
Melting/freezing point 69.8
52%

Annual site tonnage
50.16 t/a (Closed system)
50.03 t/a open systems

Continuous release(d/a): 300

Local freshwater dilution factor 10

Receiving surface water flow is 18000 m³/d.

Local marine water dilution factor 100

Not applicable.

% Release fraction to wastewater from process (initial release prior to RMM) 0.2

% Release fraction to air from process (initial release prior to RMM) 0.01

% Release fraction to soil from process (initial release prior to RMM) 1

On-site wastewater treatment required.

Ensure all waste water is collected and treated via a waste water treatment plant.

Floors should be impervious, resistant to liquids and easy to clean.

Nytro 10 XN

Use as lubricant in open and closed systems- Professional
(2,6-di-tert-butyl-p-cresol)

Section 2 - Exposure controls

Conditions and measures related to municipal sewage treatment plant

Size of industrial sewage treatment plant (m³/d): 2000 , Removal Efficiency (total) 94%

Conditions and measures related to external treatment of waste for disposal

No special measures are required. See section 13 for waste disposal information.

Conditions and measures related to external recovery of waste

See section 13 for waste disposal information.

Contributing scenario controlling worker exposure for 0:

Product characteristics Melting/Freezing Point (°C): 69.8

Concentration of substance in mixture or article 52%

Physical state solid

Dust Solid, medium dustiness

Frequency and duration of use Exposure duration per year: 230 days
Exposure duration per day: 8 h (full shift).

Human factors not influenced by risk management Respiratory m³/d: 10

Other given operational conditions affecting workers

exposure The product should be handled at room temperature.
Lubricants (Closed system)

Technical conditions and measures at process level No special measures required.

(source) to prevent release

Technical conditions and measures to control dispersion from source towards the worker

Handle only in a place with local exhaust ventilation (or other adequate ventilation).

Organisational measures to prevent/limit releases, dispersion and exposure Ensure operatives are trained to minimise exposures.

Conditions and measures related to personal protection and hygiene

Personal protection Wear protective clothing. See Section 8 of the safety data sheet (personal protective equipment).

Section 3 - Exposure estimation and reference to its source

Websites:

Not available.

Exposure estimation and reference to its source - Environment: 2:

Exposure assessment Used EUSES model. (v2.1)

(environment):

Exposure estimation Risk characterisation ratio (PEC/PNEC): <1

Exposure estimation and reference to its source - Workers: 1:

Exposure assessment Used ECETOC TRA model (May 2010 release).

(human):

Exposure estimation Risk characterisation ratio DNELs <1

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set

Use as lubricant in open and closed systems- Professional
(2,6-di-tert-butyl-p-cresol)

ance to DU to evaluate whether he works inside the boundaries set

Not available.
Not available.

Not available.
Wear protective gloves/protective clothing/eye protection/face protection.
Wear respiratory protection.
See Section 8 for information on appropriate personal protective equipment.

Nytro 10 XN

Annex to the extended Safety Data Sheet (eSDS)



Identification of the substance or mixture
Product definition: Mixture
Product name: Nytro 10 XN

Industrial

Section 1 Title

Short title of the exposure scenario
List of use descriptors

Distribution of substance- Industrial (Other Lubricant Base Oils, IP346-3%, H304)

Identified use name: Distribution of substance - Industrial
Process Category: PROC01, PROC02, PROC03, PROC04, PROC08a, PROC08b, PROC09, PROC15
Substance supplied to that use in form of: Substance
Sector of end use: SU03
Subsequent service life relevant for that use: No
Environmental Release Category: ERC04, ERC05, ERC06a, ERC06b, ERC06c, ERC06d, ERC07, ESVOC SpERC 1.1b.v1
Market sector by type of chemical product: Not applicable.
Article category related to subsequent service life: Not applicable.
Distribution of substance

Environmental contributing scenarios

Health Contributing scenarios

Number of the ES	Industry Association	Generic exposure scenario	Processes and activities covered by the exposure scenario	Additional information
9.3.1b	Concawe	01a	Bulk loading (including marine vessel/barge, rail/road car and IBC loading) of substance within closed or contained systems, including incidental exposures during its sampling, storage, unloading, maintenance and associated laboratory activities.	Industrial

Section 2 Exposure controls

Product characteristics
Amounts used

Substance is complex UVCB.. Predominantly hydrophobic
Fraction of EU tonnage used in region 0.1
Regional use tonnage 8.5E+5
Fraction of Regional tonnage used locally 1
Maximum daily site tonnage 1.7E+4
Continuous release

Frequency and duration of use

Emission Days (days/year) 100
Local freshwater dilution factor 10
Local marine water dilution factor 100

Environment factors not influenced by risk management

Other given operational conditions affecting environmental exposure
Technical conditions and measures at process level (source) to prevent release
Technical on-site conditions

Release fraction to air from process (initial release prior to RMM) 1.0E-4
Release fraction to wastewater from process (initial release prior to RMM) 1.0E-7
Release fraction to soil from process (initial release prior to RMM) 0.00001
Common practices vary across sites thus conservative process release estimates used.

Risk from environmental exposure is estimated to be low

Risk from environmental exposure is estimated to be low

Section 2 - Exposure controls

Drum and small package filling
 No other specific measures identified.

Equipment cleaning and maintenance
 Drain down and flush system prior to equipment break-in or maintenance.

Storage
 Store substance within a closed system.

Conditions and measures related to personal protection and hygiene
 See Section 8 of the safety data sheet (general health and safety measures).
 Personal protection
 See Section 8 of the safety data sheet (personal protective equipment).

Section 3 - Exposure estimation and reference to its source

Website:
 Not applicable.

Exposure estimation and reference to its source - Environment: 2: Distribution of substance
 Exposure assessment (environment):
 Not available.

Exposure estimation
 The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrorisk model.

Exposure estimation and reference to its source - Workers: 1: Distribution of substance
 Exposure assessment (human):
 Not available.

Exposure estimation
 The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

Environment
 Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using on-site/off-site technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SPERC factsheet. Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet.

Health
 The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. Kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.

A DNEL (derived no effect levels) cannot be derived.

This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.

However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.

Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.

There are no routine anticipated exposures by ingestion related to any supported uses of the substance. The risk arising from aspiration hazard is solely related to the

Exposure controls

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 64.4

If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 0

Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Estimated substance removal from wastewater via on-site sewage treatment 94.7

Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs 94.7

Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removal: 1E+5

Assumed on-site sewage treatment plant flow: 2000

External treatment and disposal of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

Controlling worker exposure for 0: Distribution of substance

Liquid, vapour pressure < 0.5 kPa at STP

Covers percentage substance in the product up to 100% (unless stated differently).

Liquid
 Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature) Assumes a good basic standard of occupational hygiene is implemented

Aspiration hazard if swallowed.

Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.

Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.

This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.

Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.

Do not induce vomiting as there is high risk of aspiration.

IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures

General exposures (closed systems)
 No other specific measures identified.

General exposures (open systems)
 No other specific measures identified.

Process sampling
 No other specific measures identified.

Laboratory activities
 No other specific measures identified.

Bulk transfers closed systems
 No other specific measures identified.

ance to DU to evaluate whether he works inside the boundaries set

communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Nytro 10 XN

Annex to the extended Safety Data Sheet (eSDS)



Identification of the substance or mixture
 Product definition Mixture
 Product name Nytro 10 XN

Industrial

Section 1 Title

Short title of the exposure scenario
 List of use descriptors

Formulation & (re)packing of substances and mixtures - Industrial (Other Lubricant Base Oils, IP346-3%)
 Identified use name: Formulation and (re)packing of substances and mixtures - Industrial
 Process Category: PROC01, PROC02, PROC03, PROC04, PROC05, PROC06, PROC08a, PROC08b, PROC09, PROC14, PROC15
 Substance supplied to that use in form of: Substance
 Sector of end use: SU10
 Subsequent service life relevant for that use: No.
 Environmental Release Category: ERC02, ESVOC SpERC 2.2.V1
 Market sector by type of chemical product: Not applicable.
 Article category related to subsequent service life: Not applicable.
 Formulation and (re)packing of substances and mixtures

Environmental contributing scenarios

Health Contributing scenarios

Number of the ES	9.4.1b
Industry Association	Concawe 2012
Generic exposure scenario	02
Processes and activities covered by the exposure scenario	Formulation, packing and re-packing of the substance and its mixtures in batch or continuous operations, including storage, materials transfers, mixing, tableting, compression, pelletisation, extrusion, large and small scale packing, sampling, maintenance and associated laboratory activities.
Additional Information	Industrial

Section 2 Exposure controls

Product characteristics
 Amounts used

Substance is complex UVCB.. Predominantly hydrophobic
 Fraction of EU tonnage used in region 0.1
 Regional use tonnage 8.5E+5
 Fraction of Regional tonnage used locally 1
 Annual site tonnage 3.0E+4
 Maximum daily site tonnage 1.0E+5

Frequency and duration of use

Environment factors not influenced by risk management

Other given operational conditions affecting environmental exposure
 Technical conditions and measures at process level (source) to prevent releases

Local marine water dilution factor 100
 Local freshwater dilution factor 10
 Continuous release
 Emission Days (days/year)300
 Release fraction to air from process (initial release prior to RMM)2.5E-3
 Release fraction to wastewater from process (initial release prior to RMM)5.0E-6
 Release fraction to soil from process (initial release prior to RMM) 0.0001
 Common practices vary across sites thus conservative process release estimates used.

Handwritten signature

Section 2 - Exposure controls

Laboratory activities	No other specific measures identified. Bulk transfers Dedicated facility
No other specific measures identified.	
Mixing operations (open systems)	No other specific measures identified.
No other specific measures identified.	
Transfer from/pouring from containers	Manual Non-dedicated facility
No other specific measures identified.	
Drum/batch transfers	Dedicated facility
No other specific measures identified.	
Production of preparation or articles by tableting, compression, extrusion or pelletisation	No other specific measures identified.
No other specific measures identified.	
Drum and small package filling	No other specific measures identified.
No other specific measures identified.	
Equipment cleaning and maintenance	Drain down and flush system prior to equipment break-in or maintenance.
Drain down and flush system prior to equipment break-in or maintenance.	
Storage	Store substance within a closed system.
Personal protection and hygiene	See Section 8 of the safety data sheet (general health and safety measures).
Personal protection	See Section 8 of the safety data sheet (personal protective equipment).

Section 3 - Exposure estimation and reference to its source

Website:	Not applicable.
Exposure estimation and reference to its source - Environment 2: Formulation and (re)packing of substances and mixtures	
Exposure assessment (environment):	Not available.
Exposure estimation	The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrorisk model.
Exposure estimation and reference to its source - Workers: 1: Formulation and (re)packing of substances and mixtures	
Exposure assessment (human):	Not available.
Exposure estimation	The EGETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

Environment	Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using on-site/off-site technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SoFRC factsheet. Scaled local assessments for EU refineries have been performed in
-------------	---

Exposure controls

Treat air emission to provide a typical removal efficiency of 100

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 99.5

If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 100

Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Not applicable as there is no release to wastewater.

Estimated substance removal from wastewater via on-site sewage treatment 94.7

Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs94.7

Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removals. 7E+5

Assumed on-site sewage treatment plant flow 2000

External treatment and disposal of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

Controlling worker exposure for 0: Formulation and (re)packing of substances and mixtures

Liquid, vapour pressure < 0.5 kPa at STP

Covers percentage substance in the product up to 100% (unless stated differently).

Liquid

Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature) Assumes a good basic standard of occupational hygiene is implemented

Aspiration hazard if swallowed.

Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.

Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.

This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.

Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.

Do not induce vomiting as there is high risk of aspiration.

IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures

General exposures (closed systems)

No other specific measures identified.

General exposures (open systems)

No other specific measures identified.

Batch processes at elevated temperatures

No other specific measures identified.

Use in contained batch processes

No other specific measures identified.

ance to DU to evaluate whether he works inside the boundaries set

The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful: may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.

A DNEL (derived no effect levels) cannot be derived.
This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.

However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.

Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.

There are no routine anticipated exposures by ingestion related to any supported uses of the substance. The risk arising from aspiration hazard is solely related to the physico-chemical properties of the substance. The risk can therefore be controlled by implementing risk management measures tailored to this specific risk.

For any substance, classified as H304 (R65), these measures should be communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Nytro 10 XN

Annex to the extended Safety Data Sheet (eSDS)

Identification of the substance or mixture
Product definition: Mixture
Product name: Nytro 10 XN

Industrial

Section 1 - Title

Short title of the exposure scenario

Manufacturer of substance- Industrial (Other Lubricant Base Oils, IP346-3%, H304)

List of use descriptors

Identified use name: Manufacture of substance - Industrial
Process Category: PROC01, PROC02, PROC03, PROC04, PROC08a, PROC08b, PROC15
Substance supplied to that use in form of: Substance
Sector of end use: SU03, SU08, SU09
Subsequent service life relevant for that use: No
Environmental Release Category: ERC04, ESVOC SpERC 1.1.V1
Market sector by type of chemical product: Not applicable.
Article category related to subsequent service life: Not applicable.
Manufacture of substance

Environmental contributing scenarios

Health Contributing scenarios
Manufacture of substance

Number of the ES

9.1.1b

Industry Association

Concawe 2012

Generic exposure scenario

01

Processes and activities covered by the exposure scenario

Manufacture of the substance or use as a process chemical or extraction agent within closed or contained systems. Includes incidental exposures during recycling/recovery, material transfers, storage, sampling, associated laboratory activities, maintenance and loading (including marine vessel/barge, road/rail car and bulk container).

Additional information

Industrial

Section 2 - Exposure controls

Product characteristics

Amounts used

Substance is complex UVCB. Predominantly hydrophobic
Fraction of EU tonnage used in region 0.1
Regional use tonnage 8.5E+5
Fraction of Regional tonnage used locally 1
Annual site tonnage 6.0E+5
Maximum daily site tonnage 2.0E+6

Frequency and duration of use

Continuous release

Environment factors not influenced by risk management

Emission Days (days/year) 300

Other given operational conditions affecting environmental exposure

Local freshwater dilution factor 10

Technical conditions and measures at process level (source) to prevent release

Local marine water dilution factor 100

Release fraction to air from process (initial release prior to RMM) 1.0e-4

Release fraction to wastewater from process (initial release prior to RMM) 1.0e-5

Release fraction to soil from process (initial release prior to RMM) 0.0001

Common practices vary across sites thus conservative process release estimates used.

Common practices vary across sites thus conservative process release estimates used.

Technical conditions and measures at process level (source) to prevent release

Nytr 10 XV
Manufacturer of substance - Industrial (Other Lubricant Base Oils, IP346-3%, H304)

Section 2 - Exposure controls
No other specific measures identified.
Equipment cleaning and maintenance
Drain down and flush system prior to equipment break-in or maintenance.
Bulk product storage
Store substance within a closed system.
Personal protection
See Section 8 of the safety data sheet (general health and safety measures).
See Section 8 of the safety data sheet (personal protective equipment).

Section 3 - Exposure estimation and reference to its source
Website: Not applicable.
Exposure estimation and reference to its source - Environment: 2: Manufacture of substance
Exposure assessment (environment): Not available.
Exposure estimation: The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petronisk model.
Exposure estimation and reference to its source - Workers: 1: Manufacture of substance
Exposure assessment (human): Not available.
Exposure estimation: The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES
Environment
Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using onsite/offsite technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SPERC factsheet (<http://cefic.org/en/reach-for-industries-libraries.html>) Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet.
The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.
A DNEL (derived no effect levels) cannot be derived.
This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.
However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.
Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.
There are no routine anticipated exposures by ingestion related to any supported uses of the substance. The risk arising from aspiration hazard is solely related to the physico-chemical properties of the substance. The risk can therefore be controlled by

Health
Contributing scenarios - Operational conditions and risk management measures
General exposures (closed systems)
No other specific measures identified.
General exposures (open systems)
No other specific measures identified.
Process sampling
No other specific measures identified.
Laboratory activities
No other specific measures identified.

Manufacturer of substance - Industrial (Other Lubricant Base Oils, IP346-3%, H304)

Exposure controls
Treat air emission to provide a typical removal efficiency of 90
On-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 84.8
If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 0
Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.
Estimated substance removal from wastewater via on-site sewage treatment 94.7
Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs 94.7
Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removals 5.7E+6
Assumed on-site sewage treatment plant flow 10000
During manufacturing, no waste of the substance is generated.
During manufacturing, no waste of the substance is generated.

Controlling worker exposure for 0: Manufacture of substance
Liquid, vapour pressure < 0.5 kPa at STP
Covers percentage substance in the product up to 100% (unless stated differently).
Liquid With potential for aerosol generation
Covers daily exposures up to 8 hours (unless stated differently)
Operation is carried out at elevated temperature (> 20°C above ambient temperature) Assumes a good basic standard of occupational hygiene is implemented
Aspiration hazard if swallowed.
Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.
Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.
This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.
Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.
Do not induce vomiting as there is high risk of aspiration.
IF SWALLOWED: Immediately call a POISON CENTER or physician.
Contributing scenarios - Operational conditions and risk management measures
General exposures (closed systems)
No other specific measures identified.
General exposures (open systems)
No other specific measures identified.
Process sampling
No other specific measures identified.
Laboratory activities
No other specific measures identified.

Manufacturer of substance - Industrial (Other Lubricant Base Oils, IP346-3%, H304)

If swallowed then seek immediate medical assistance.

Predicted exposures are not expected to exceed the DN(M)EL when the risk management measures/operational conditions outlined in section 2 are implemented.

Where other risk management measures/operational conditions are adopted, then users should ensure that risks are managed to at least equivalent levels.

Available hazard data do not enable the derivation of a DNEL for dermal irritant effects. Available hazard data do not support the need for a DNEL to be established for other health effects. Risk management measures are based on qualitative risk characterisation.

Nytro 10 XN

Annex to the extended Safety Data Sheet (eSDS)



Identification of the substance or mixture
 Product definition: Mixture
 Product name: Nytro 10 XN

Industrial

Section 1 - Title

Short title of the exposure scenario
 List of use descriptors

Uses in Functional fluids - Industrial (Other Lubricant Base Oils, IP346-3%, H304)

Identified use name: Functional Fluids - Industrial
Process Category: PROC01, PROC03, PROC08a, PROC08b, PROC02, PROC04, PROC09
Substance supplied to that use in form of: Substance
Sector of end use: SUJ03
Subsequent service life relevant for that use: No.
Environmental Release Category: ERC07,
Market sector by type of chemical product: Not applicable.
Article category related to subsequent service life: Not applicable.

Environmental contributing scenarios

Health Contributing scenarios

Functional Fluids

Number of the ES	9.37.1b
Industry Association	Concawe 2012
Generic exposure scenario	13a
Processes and activities covered by the exposure scenario	Use as functional fluids e.g. cable oils, transfer oils, coolants, insulators, refrigerants, hydraulic fluids in Industrial equipment including maintenance and related material transfers.
Additional information	Industrial

Section 2 - Exposure controls

Product characteristics

Amounts used

Substance is complex UVCB. Predominantly hydrophobic

Fraction of EU tonnage used in region 0.1

Regional use tonnage 1.2E+3

Fraction of Regional tonnage used locally 1

Annual site tonnage 1.0E+1

Maximum daily site tonnage 5.0E+2

Continuous release

Emission Days (days/year) 20

Local freshwater dilution factor 10

Local marine water dilution factor 100

Frequency and duration of use

Environment factors not influenced by risk management

Other given operational conditions affecting environmental exposure

Technical conditions and measures at process level (source) to prevent release

Technical on-site conditions

Release fraction to air from process (initial release prior to RMM) 5.0E-4
 Release fraction to wastewater from process (initial release prior to RMM) 1.0E-6
 Release fraction to soil from process (initial release prior to RMM) 0.001
 Common practices vary across sites thus conservative process release estimates used.

Risk from environmental exposure is driven by freshwater releases

Section 2 - Exposure controls

Remanufacture of reject articles
 No other specific measures identified.

Equipment cleaning and maintenance
 Drain down system prior to equipment break-in or maintenance.

Storage
 Store substance within a closed system.

Conditions and measures related to personal protection and hygiene
 See Section 8 of the safety data sheet (general health and safety measures).

Personal protection
 See Section 8 of the safety data sheet (personal protective equipment).

Section 3 - Exposure estimation and reference to its source

Website:
 Not applicable.

Exposure estimation and reference to its source - Environment: 2: Functional Fluids
 Exposure assessment (environment):
 Not available.

Exposure estimation
 The Hydrocarbon Block Method has been used to calculate environmental exposure with the PetroRisk model.

Exposure estimation and reference to its source - Workers: 1: Functional Fluids
 Exposure assessment (numar):
 Not available.

Exposure estimation
 The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

Environment
 Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using onsite/offsite technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SpERC factsheet. (<http://cefic.org/reach-for-industries-libraries.html>) Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETROKISK file - "Site-Specific Production" worksheet.

Health
 The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.
 A DNEL (derived no effect levels) cannot be derived.
 This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.
 However, implementation of risk management measures (RMMS) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.
 Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMS will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.
 There are no routine anticipated exposures by ingestion related to any supported

Exposure controls

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 84.4
 If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 10
 Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Estimated substance removal from wastewater via on-site sewage treatment 84.7
 Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMS 94.7
 Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removal 3.3E+3
 Assumed on-site sewage treatment plant flow 2000
 External treatment and disposal of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

Controlling worker exposure for 0: Functional Fluids

Liquid, vapour pressure < 0.5 kPa at STP
 Covers percentage substance in the product up to 100% (unless stated differently).

Liquid With potential for aerosol generation
 Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature) Assumes a good basic standard of occupational hygiene is implemented
 Aspiration hazard if swallowed.
 Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.
 Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.
 This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.
 Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.
 Do not induce vomiting as there is high risk of aspiration.
 IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures
 Bulk transfers - Closed system
 No other specific measures identified.

Drum/batch transfers - Dedicated facility
 No other specific measures identified.

Filling of articles/equipment - closed systems
 No other specific measures identified.

Filling/preparation of equipment from drums or containers - Non-dedicated facility
 No other specific measures identified.

General exposures (closed systems)
 No other specific measures identified.

ance to DU to evaluate whether he works inside the boundaries set

For any substance, classified as H304 (R65), these measures should be communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Predicted exposures are not expected to exceed the DN(M)EL when the risk management measures/operational conditions outlined in section 2 are implemented.

Where other risk management measures/operational conditions are adopted, then users should ensure that risks are managed to at least equivalent levels.

Available hazard data do not enable the derivation of a DNEL for dermal irritant effects. Available hazard data do not support the need for a DNEL to be established for other health effects. Risk management measures are based on qualitative risk characterisation.

Nytro 10 XN

Annex to the extended Safety Data Sheet (eSDS)

Identification of the substance or mixture
 Product definition: Mixture
 Product name: Nytro 10 XN

Professional

Section 1 - Title

Short title of the exposure scenario
 List of use descriptors

Uses in Functional fluids - Professional (Other Lubricant Base Oils, IP346-3%, H304)

Identified use name: Functional Fluids - Professional
Process Category: PROC01, PROC02, PROC03, PROC08a, PROC09, PROC20
Substance supplied to that use in form of: Substance
Sector of end use: SU22

Subsequent service life relevant for that use: No.
Environmental Release Category: ERC09a, ERC09b, ESVOC SpERC 9.13b.v1
Market sector by type of chemical product: Not applicable.
Article category related to subsequent service life: Not applicable.

Environmental contributing scenarios

Health Contributing scenarios

Health Contributing scenarios	Functional Fluids
Number of the ES	9.36.1b
Industry Association	Concawe 2012
Generic exposure scenario	13b
Processes and activities covered by the exposure scenario	Use as functional fluids e.g. cable oils, transfer oils, coolants, insulators, refrigerants, hydraulic fluids in professional equipment including maintenance and related material transfers.
Additional Information	Professional

Section 2 - Exposure controls

Product characteristics

Amounts used

Substance is complex UVCB. Predominantly hydrophobic
 Fraction of EU tonnage used in region 0.1
 Regional use tonnage 1.2E+3
 Fraction of Regional tonnage used locally 1
 Annual site tonnage 6.0E-1
 Maximum daily site tonnage 1.6E+0
 Continuous release
 Emission Days (days/year) 365
 Local freshwater dilution factor 10
 Local marine water dilution factor 100

Frequency and duration of use
 Environment factors not influenced by risk management

Other given operational conditions affecting environmental exposure
 Technical conditions and measures at process level (source) to prevent release
 Technical on-site conditions and measures to reduce or limit discharge

Release fraction to air from process (initial release prior to RMM) 0.05
 Release fraction to wastewater from process (initial release prior to RMM) 0.025
 Release fraction to soil from process (initial release prior to RMM) 0.025
 Common practices vary across sites thus conservative process release estimates used.

Risk from environmental exposure is driven by freshwater sediment if discharging to domestic sewage treatment plant, no on-site wastewater treatment.

Section 2 - Exposure controls

Remanufacture of reject articles
 No other specific measures identified.

Equipment cleaning and maintenance
 Drain down system prior to equipment break-in or maintenance.

Storage
 Store substance within a closed system.

Conditions and measures related to personal protection and hygiene
 See Section 8 of the safety data sheet (general health and safety measures).
 Personal protection
 See Section 8 of the safety data sheet (personal protective equipment).

Section 3 - Exposure estimation and reference to its source

Website: Not applicable.

Exposure estimation and reference to its source - Environment: 2: Functional Fluids
 Exposure assessment (environment): Not available.
 Exposure estimation: The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrosisk model.

Exposure estimation and reference to its source - Workers: 1: Functional Fluids
 Exposure assessment (human): Not available.
 Exposure estimation: The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

Environment
 Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using onsite/offsite technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SPERC factsheet. (<http://cafcic.org/en/reach-for-industries-libraries.html>) Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet.

Health
 The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful, may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.
 A DNEL (derived no effect levels) cannot be derived.
 This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.
 However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.
 Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.
 There are no specific anticipated exposures by ingestion related to any supported

Exposure controls

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 64.9
 If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 70

Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Estimated removal from wastewater via on-site sewage treatment 84.7
 Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs 94.7
 Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removal 1.1E+1
 Assumed on-site sewage treatment plant flow 2000

External treatment and disposal of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

Controlling worker exposure for 0: Functional Fluids

Liquid, vapour pressure < 0.5 kPa at STP
 Covers percentage substance in the product up to 100% (unless stated differently).

Liquid With potential for aerosol generation
 Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature)
 Assumes a good basic standard of occupational hygiene is implemented
 Aspiration hazard if swallowed.
 Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.

Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.
 This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.
 Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.
 Do not induce vomiting as there is high risk of aspiration.
 IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures

Bulk transfers - Closed system
 No other specific measures identified.

Drum/batch transfers - Dedicated facility
 No other specific measures identified.

Filling of articles/equipment - closed systems
 No other specific measures identified.

Filling/preparation of equipment from drums or containers - Non-dedicated facility
 No other specific measures identified.

General exposures (closed systems)
 No other specific measures identified.

ance to DU to evaluate whether he works inside the boundaries set

For any substance, classified as H304 (R65), these measures should be communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Predicted exposures are not expected to exceed the DN(M)EL when the risk management measures/operational conditions outlined in section 2 are implemented.

Where other risk management measures/operational conditions are adopted, then users should ensure that risks are managed to at least equivalent levels.

Available hazard data do not enable the derivation of a DNEL for dermal irritant effects. Available hazard data do not support the need for a DNEL to be established for other health effects. Risk management measures are based on qualitative risk characterisation.



2015-09-17
 2015-09-17
 No previous validation
 1

ification of the substance/mixture and of the company/undertaking

Nyro Libra
 Insulating oil
 Liquid,
 Oils

e - Industrial
 eking of substances and mixtures - Industrial
 ce - Industrial
 e - Industrial
 strial
 ssonal

Reason

... used in applications other than those
 on 1, without first seeking the advice of the

of the safety data sheet

Head office:
 Nynas AB
 P.O. Box 10700
 SE-121 23 Stockholm
 SWEDEN
 +46 8 602 12 00 (Office hours 8 am - 4.30 pm (CET))
 www.nynas.com
 ProductHSE@nynas.com

Nynas sp. z o.o.
 ul. Kolberga 48D
 PL-44 100 Gilwice
 POLAND
 +48 32 232 74 10

e number

Poison Centre
 +44 (0) 1235 239 670
 24 hour service

Conforms to Regulation, No. 1907/2006 (REACH), Annex II

Nyro Libra

SECTION 2: Hazards identification

2.1 Classification of the substance or mixture
 Mixture
 Product definition
 Classification according to Regulation (EC) No. 1272/2008 [CLP/GHS]
 Asp. Tox. 1, H304

The product is classified as hazardous according to Regulation (EC) 1272/2008 as amended.
 See Section 16 for the full text of the H statements declared above.
 See Section 11 for more detailed information on health effects and symptoms.

2.2 Label elements

Hazard pictograms



Signal word

Danger
 H304 - May be fatal if swallowed and enters airways.

Hazard statements

Precautionary statements

Prevention
 Response
 Storage
 Disposal

Not applicable.
 P301 + P310 + P331 - IF SWALLOWED: Immediately call a POISON CENTER or physician. Do NOT induce vomiting.
 P405 - Store locked up.
 P501 - Dispose of contents and container in accordance with all local, regional, national and international regulations.
 Not applicable.

Annex XVII - Restrictions on the manufacture, placing on the market and use of certain dangerous substances, mixtures and articles

2.3 Other hazards

Substance meets the criteria for PBT according to Regulation (EC) No. 1907/2006, Annex XIII
 Substance meets the criteria for vPvB according to Regulation (EC) No. 1907/2006, Annex XIII
 Not applicable.
 Not applicable.

SECTION 3: Composition/information on ingredients

3.2 Mixtures

Mixture

Product/ingredient name	Identifiers	%	Classification Regulation (EC) No. 1272/2008 [CLP]	Type
Distillate (petroleum), hydrotreated light naphthenic	REACH #: 01-2119480375-34 EC: 265-156-6 CAS: 64742-53-6 Index: 649-466-00-2 REACH #:	50 - 70	Asp. Tox. 1, H304	[1]
Distillate (petroleum)	REACH #:	0 - 50	Asp. Tox. 1, H304	[1]

Composition/information on ingredients

CAS: 64742-55-8 REACH #: 01-2119484627-25	0 - 50	Not classified.	-
EC: 265-157-1 CAS: 64742-54-7 Index: 649-467-00-8 REACH #: 01-2119474878-16	0 - 50	Asp. Tox. 1, H304	[1]
EC: 276-737-9 CAS: 72623-86-0 Index: 649-482-00-X REACH #: 01-2119483621-38	0 - 5	Not classified.	-
EC: 265-097-6 CAS: 64741-96-4 Index: 649-457-00-3 REACH #: 01-2119480374-36	0 - 5	Asp. Tox. 1, H304	[1]

See Section 16 for the full text of the H statements declared above.

the base oil(s) in this product. Nota L - The classification as a carcinogen need not apply if the substance contains less than 3 % DMSO extract as measured by IP 346.
Ingredients present which, within the current knowledge of the supplier and in the % are classified as hazardous to health or the environment, are PBTs or vPvBs or have been
exposure limit and hence require reporting in this section.

with a health or environmental hazard
place exposure limit
criteria for PBT according to Regulation (EC) No. 1907/2006, Annex XIII
criteria for vPvB according to Regulation (EC) No. 1907/2006, Annex XIII
concern

First aid measures

measures
Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. If irritation, blurred vision or swelling occurs and persists, obtain medical advice from a specialist.
If breathing is difficult, remove victim to fresh air and keep at rest in a position comfortable for breathing. If casualty is unconscious and: if not breathing, if breathing is irregular or if respiratory arrest occurs, provide artificial respiration or oxygen by trained personnel. Get medical attention if adverse health effects persist or are severe. Maintain an open airway.
Wash with soap and water. Remove contaminated clothing and shoes. Handle with care and dispose of in a safe manner. Seek medical attention if skin irritation, swelling or redness develops and persists.
Accidental high pressure injection

SECTION 4: First aid measures

Ingestion

Always assume that aspiration has occurred. Do not induce vomiting. Can enter lungs and cause damage. If vomiting occurs, the head should be kept low so that vomit does not enter the lungs. Seek professional medical attention or send the casualty to a hospital. Do not wait for symptoms to develop.

Never give anything by mouth to an unconscious person. If unconscious, place in recovery position and get medical attention immediately. Maintain an open airway. Loosen tight clothing such as a collar, tie, belt or waistband.
No action shall be taken involving any personal risk or without suitable training. It may be dangerous to the person providing aid to give mouth-to-mouth resuscitation.

Protection of first-aiders

Before attempting to rescue casualties, isolate area from all potential sources of ignition including disconnecting electrical supply. Ensure adequate ventilation and check that a safe, breathable atmosphere is present before entry into confined spaces.

4.2 Most important symptoms and effects, both acute and delayed

Potential acute health effects

- Eye contact
Inhalation
Skin contact
Ingestion
- Eye contact may cause redness and transient pain.
Inhalation of oil mist or vapours at elevated temperatures may cause respiratory irritation.
No known significant effects or critical hazards.
May be fatal if swallowed and enters airways.

4.3 Indication of any immediate medical attention and special treatment needed

- Notes to physician
No action shall be taken involving any personal risk or without suitable training. It may be dangerous to the person providing aid to give mouth-to-mouth resuscitation.
Before attempting to rescue casualties, isolate area from all potential sources of ignition including disconnecting electrical supply. Ensure adequate ventilation and check that a safe, breathable atmosphere is present before entry into confined spaces.

Specific treatments

Always assume that aspiration has occurred.

SECTION 5: Firefighting measures

5.1 Extinguishing media

Suitable extinguishing media
Use dry chemical, CO₂, water spray (fog) or foam.

Unsuitable extinguishing media

Do not use direct water jets on the burning product; they could cause splattering and spread the fire. Simultaneous use of foam and water on the same surface is to be avoided as water destroys the foam.

5.2 Special hazards arising from the substance or mixture

- Hazards from the substance or mixture
In a fire or if heated, a pressure increase will occur and the container may burst.
This substance will float and can be reignited on surface water.
Incomplete combustion is likely to give rise to a complex mixture of airborne solid and liquid particulates, gases, including carbon monoxide, H₂S, SO_x (sulfur oxides) or sulfuric acid and unidentified organic and inorganic compounds.

5.3 Advice for firefighters

Special precautions for firefighters
Promptly isolate the scene by removing all persons from the vicinity of the incident if there is a fire. No action shall be taken involving any personal risk or without suitable training.

ental release measures

protective equipment and emergency procedures

Avoid breathing vapour or mist. Keep non-involved personnel away from the area of spillage. Alert emergency personnel. Except in case of small spillages, the feasibility of any actions should always be assessed and advised, if possible, by a trained, competent person in charge of managing the emergency. Stop leak if safe to do so. Avoid direct contact with the product. Stay upwind/keep distance from source. In case of large spillages, alert occupants in downwind areas.

Eliminate all ignition sources if safe to do so. Spillages of limited amounts of product, especially in the open air when vapours will be usually quickly dispersed, are dynamic situations, which will presumably limit the exposure to dangerous concentrations.

Note : recommended measures are based on the most likely spillage scenarios for this material; however, local conditions (wind, air temperature, wave/current direction and speed) may significantly influence the choice of appropriate actions. For this reason, local experts should be consulted when necessary. Local regulations may also prescribe or limit actions to be taken.

Small spillages: normal antistatic working clothes are usually adequate.

Large spillages: full body suit of chemically resistant and thermal resistant material should be used. Work gloves providing adequate chemical resistance, specifically to aromatic hydrocarbons. Note : gloves made of PVA are not water-resistant, and are not suitable for emergency use. Safety helmet, antistatic non-skid safety shoes or boots. Goggles and/or face shield, if splashes or contact with eyes is possible or anticipated.

Respiratory protection : A half or full-face respirator with filter(s) for organic vapours (and when applicable for H2S) or a Self Contained Breathing Apparatus (SCBA) can be used according to the extent of spill and predictable amount of exposure. If the situation cannot be completely assessed, or if an oxygen deficiency is possible, only SCBA's should be used.

Prevent product from entering sewers, rivers or other bodies of water. If necessary dilute the product with dry earth, sand or similar non-combustible materials. In case of soil contamination, remove contaminated soil and treat in accordance with local regulations.

In case of small spillages in closed waters (i.e. ports), contain product with floating barriers or other equipment. Collect spilled product by absorbing with specific floating absorbents.

If possible, large spillages in open waters should be contained with floating barriers or other mechanical means. If this is not possible, control the spreading of the spillage, and collect the product by skimming or other suitable mechanical means. The use of dispersants should be advised by an expert, and, if required, approved by local authorities.

al for containment and cleaning up
Stop leak if without risk. Absorb spilled product with suitable non-combustible materials.

Large spillages may be cautiously covered with foam, if available, to limit vapour cloud formation. Do not use water jet. When inside buildings or confined spaces, ensure adequate ventilation. Transfer collected product and other contaminated materials to suitable containers for recovery or safe disposal. Note: see Section 1 for emergency contact information and Section 13 for waste disposal. See Section 8 for information on appropriate personal protective equipment.

SECTION 7: Handling and storage

The information in this section contains generic advice and guidance. The list of identified Uses in Section 1 should be consulted for any available use-specific information provided in the Exposure Scenario(s).

General information

Obtain special instructions before use. Hazard of slipping on spill product. Keep away from heat/sparks/open flames/hot surfaces. - No smoking. Use and store only outdoors or in a well-ventilated area.

Avoid release to the environment.

7.1 Precautions for safe handling

Protective measures

Do not ingest. Do not breathe dust/fume/gas/mist/vapours/spray. Avoid contact with eyes, skin and clothing.

Prevent the risk of slipping. Take precautionary measures against static discharge. Avoid splash filling of bulk volumes when handling hot liquid product.

Note : See Section 8 for information on appropriate personal protective equipment. See section 13 for waste disposal information.

Advice on general occupational hygiene

Ensure that proper housekeeping measures are in place. Contaminated materials should not be allowed to accumulate in the workplaces and should never be kept inside the pockets. Eating, drinking and smoking should be prohibited in areas where this material is handled, stored and processed. Wash hands thoroughly after handling. Change contaminated clothes at the end of working shift. See also Section 8 for additional information on hygiene measures.

7.2 Conditions for safe storage, including any incompatibilities

Storage area layout, tank design, equipment and operating procedures must comply with the relevant European, national or local legislation. Storage area layout, tank design, equipment and operating procedures must comply with the relevant regional, national or local legislation. Storage installations should be designed with adequate bunds in case of leaks or spills. Cleaning, inspection and maintenance of internal structure of storage tanks must be done only by properly equipped and qualified personnel as defined by national, local or company regulations.

Store separately from oxidising agents.

Recommended materials for containers, or container linings use mild steel, stainless steel. Not suitable : Some synthetic materials may be unsuitable for containers or container linings depending on the material specification and intended use. Compatibility should be checked with the manufacturer.

Keep only in the original container or in a suitable container for this kind of product. Keep container tightly closed and sealed until ready for use. Do not store in unlabelled containers. Containers that have been opened must be carefully resealed and kept upright to prevent leakage. Empty containers may contain harmful, flammable/combustible or explosive residue or vapours. Do not cut, grind, drill, weld, reuse or dispose of containers unless adequate precautions are taken against these hazards. Store locked up. Protect from sunlight.

7.3 Specific end use(s)

Recommendations
Industrial sector specific solutions

Not available.

Not available.

Exposure controls/personal protection

es in Section 1 should be consulted for any available use-specific information provided in the

Exposure limits	Exposure limit values
name	(Air contaminant) Rozporządzenie Ministra Pracy i Polityki Społecznej (Dz.U. 2014 poz. 817) (Poland, 6/2014). TWA: 5 mg/m ³ 8 hours. Form: Inhalable fraction

ing If this product contains ingredients with exposure limits, personal, workplace atmosphere or biological monitoring may be required to determine the effectiveness of the ventilation or other control measures and/or the necessity to use respiratory protective equipment. Reference should be made to appropriate monitoring standards. Reference to national guidance documents for methods for the determination of hazardous substances will also be required.

name	Type	Exposure	Value	Population	Effects
hydro-treated	DNEL	Long term Inhalation	5,4 mg/m ³	Workers	Local
hydro-treated	DNEL	Long term Inhalation	5,4	Workers	Local
solvent-ic	DNEL	Long term Inhalation	5,4 mg/m ³	Workers	Local

The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petronisk model.

Mechanical ventilation and local exhaust will reduce exposure via the air. Use oil resistant material in construction of handling equipment. Store under recommended conditions and if heated, temperature control equipment should be used to avoid overheating.

Wash hands, forearms and face thoroughly after handling chemical products, before eating, smoking and using the lavatory and at the end of the working period. Ensure that eyewash stations and safety showers are close to the workstation location. Wash contaminated clothing before reuse. Recommended: Safety glasses with side shields.

4 - 8 hours (breakthrough time); nitrile rubber
Wear protective clothing if there is a risk of skin contact. Change contaminated clothes at the end of working shift.
Appropriate footwear and any additional skin protection measures should be selected based on the task being performed and the risks involved and should be approved by a specialist before handling this product.
Respirator selection must be based on known or anticipated exposure levels, the hazards of the product and the safe working limits of the selected respirator. Use a properly fitted, particulate filter respirator complying with an approved standard if a risk assessment indicates this is necessary.
Emissions from ventilation or work process equipment should be checked to ensure that

Nyro Libra

SECTION 9: Physical and chemical properties

9.1 Information on basic physical and chemical properties

Appearance	Liquid.
Physical state	Light yellow
Colour	Odourless/Light petroleum.
Odour	Not available.
Odour threshold	Not applicable.
pH	-51 °C
Melting point/freezing point	>250 °C
Initial boiling point and boiling range	Closed cup: >140 °C [Pensky-Martens.]
Flash point	Not available.
Evaporation rate	Not available.
Flammability (solid, gas)	Not available.
Upper/lower flammability or explosive limits	Not available.
Vapour pressure	160 Pa @ 100 °C
Density	0.88 g/cm ³ [15 °C]
Solubility(ies)	Insoluble in water.
Partition coefficient: n-octanol/water	Not available.
Auto-ignition temperature	>270 °C
Decomposition temperature	>280 °C
Viscosity	Kinematic (40 °C): 0.096 cm ² /s (9.6 cSt)
Explosive properties	Not available.
Oxidising properties	Not available.
DMSO extractable compounds for base oil substance(s) according to IP346	< 3%

SECTION 10: Stability and reactivity

10.1 Reactivity
No specific test data related to reactivity available for this product or its ingredients.

10.2 Chemical stability
Stable under normal conditions.

10.3 Possibility of hazardous reactions
Under normal conditions of storage and use, hazardous reactions will not occur.

10.4 Conditions to avoid
Oxidising agent

10.5 Incompatible materials
Keep away from extreme heat and oxidizing agents.

10.6 Hazardous decomposition products
Incomplete combustion is likely to give rise to a complex mixture of airborne solid and liquid particulates, gases, including carbon monoxide, H₂S, SO_x (sulfur oxides) or sulfuric acid and unidentified organic and inorganic compounds.

SECTION 11: Toxicological information

11.1 Information on toxicological effects
Acute toxicity

ecological information				
Result	Species	Dose	Exposure	Remarks
LC50 Inhalation Dusts and mists	Rat - Male, Female	>5.53 mg/l	4 hours	EMBSI 1988a (similar material)
LD50 Dermal	Rabbit	>5000 mg/kg	-	API 1982 (similar material)
LD50 Oral	Rat	>5000 mg/kg	-	API 1986a (similar material)
LC50 Inhalation Dusts and mists	Rat - Male, Female	>5.53 mg/l	4 hours	EMBSI 1988a (similar material)
LD50 Dermal	Rabbit	>5000 mg/kg	-	API 1982 (similar material)
LD50 Oral	Rat	>5000 mg/kg	-	API 1986a (similar material)
LC50 Inhalation Dusts and mists	Rat - Male, Female	>5.53 mg/l	4 hours	EMBSI 1988a (similar material)
LD50 Dermal	Rabbit	>5000 mg/kg	-	API 1982 (similar material)
LD50 Oral	Rat	>5000 mg/kg	-	API 1986a (similar material)
LC50 Inhalation Dusts and mists	Rat - Male, Female	>5.53 mg/l	4 hours	EMBSI 1988a (similar material)
LD50 Dermal	Rabbit	>5000 mg/kg	-	API 1982 (similar material)
LD50 Oral	Rat	>5000 mg/kg	-	API 1986a (similar material)

No known significant effects or critical hazards.

Result	Species	Score	Observation	Remarks
Skin - Non-irritant to skin.	Rabbit	0 to 0.8	24 to 72 hours	UBTL 1984e (similar material)
Eyes - Non-irritating to the eyes.	Rabbit	0.17 to 0.33	24 to 72 hours	UBTL 1984i (similar material)
Eyes - Non-irritating to the eyes.	Rabbit	0.17 to 0.33	24 to 72 hours	UBTL 1984j (similar material)
Skin - Non-irritant to skin.	Rabbit	0 to 0.8	24 to 72 hours	UBTL 1984e (similar material)
Eyes - Non-irritating to the eyes.	Rabbit	0.17 to 0.33	24 to 72 hours	UBTL 1984i (similar material)
Skin - Non-irritant to skin.	Rabbit	0 to 0.8	24 to 72 hours	UBTL 1984e (similar material)
Eyes - Non-irritating to the eyes.	Rabbit	0.17 to 0.33	24 to 72 hours	UBTL 1984i (similar material)

No known significant effects or critical hazards.

No known significant effects or critical hazards.

SECTION 11: Toxicological information

Product/ingredient name	Route of exposure	Species	Result	Remarks
Distillate (petroleum), hydrotreated light naphthenic	skin	Guinea pig	Not sensitizing	UBTL 1984j, k, l (similar material)
Lubricating oils (petroleum), C15-30, hydrotreated neutral oil-based	skin	Guinea pig	Not sensitizing	UBTL 1984j, k, l (similar material)
Distillate (petroleum), hydrotreated light paraffinic	skin	Guinea pig	Not sensitizing	UBTL 1984j, k, l (similar material)
Distillates (petroleum), solvent-refined light naphthenic	skin	Guinea pig	Not sensitizing	UBTL 1984j, k, l (similar material)
Skin			No known significant effects or critical hazards.	
Respiratory			No known significant effects or critical hazards.	
Mutagenicity				
Product/ingredient name	Test	Experiment	Result	Remarks
Distillate (petroleum), hydrotreated light naphthenic	OECD 473 473 In vitro Mammalian Chromosomal Aberration Test	Experiment in vitro	Negative	
Lubricating oils (petroleum), C15-30, hydrotreated neutral oil-based	OECD 473 473 In vitro Mammalian Chromosomal Aberration Test	Subject: Mammalian-Animal Metabolic activation: with and without Experiment in vitro	Negative	
Distillate (petroleum), hydrotreated light paraffinic	OECD 473 473 In vitro Mammalian Chromosomal Aberration Test	Subject: Mammalian-Animal Metabolic activation: with and without Experiment in vitro	Negative	
Distillates (petroleum), solvent-refined light naphthenic	OECD 473 473 In vitro Mammalian Chromosomal Aberration Test	Subject: Mammalian-Animal Metabolic activation: with and without Experiment in vitro	Negative	Reference report 1987 (similar material)

SECTION 11: Toxicological information

Mutagenicity No known significant effects or critical hazards.
 Teratogenicity No known significant effects or critical hazards.
 Developmental effects No known significant effects or critical hazards.
 Fertility effects No known significant effects or critical hazards.
 Other information Not available.
 Specific hazard Not available.

SECTION 12: Ecological information

12.1 Toxicity

Product/ingredient name	Result	Species	Exposure
Distillate (petroleum), hydrotreated light naphthenic	Acute LL50 > 10000 mg/l	Aquatic invertebrates.	96 hours
Lubricating oils (petroleum), C15-30, hydrotreated neutral oil-based	Acute LL50 > 100 mg/l	Fish	96 hours
	Acute NOEL > 100 mg/l	Algae	72 hours
	Chronic NOEL 10 mg/l	Aquatic invertebrates.	21 days
	Acute LL50 > 10000 mg/l	Aquatic invertebrates.	96 hours
Distillates (petroleum), hydrotreated light paraffinic	Acute LL50 > 100 mg/l	Fish	96 hours
	Chronic NOEL 10 mg/l	Algae	72 hours
	Acute IC50 > 100 mg/l	Aquatic invertebrates.	21 days
	Acute LC50 > 100 mg/l	Algae	48 hours
Distillates (petroleum), solvent-refined light naphthenic	Acute LL50 > 100 mg/l	Fish	96 hours
	Acute NOEL > 10000 mg/l	Aquatic invertebrates.	96 hours
	Acute LL50 > 100 mg/l	Fish	96 hours
	Chronic NOEL 10 mg/l	Algae	72 hours
Distillates (petroleum), solvent-refined light naphthenic	Acute LL50 > 10000 mg/l	Aquatic invertebrates.	96 hours
	Acute LL50 > 100 mg/l	Fish	96 hours
Conclusion/Summary		No known significant effects or critical hazards.	

12.2 Persistence and degradability

Product/ingredient name	Aquatic half-life	Photolysis	Biodegradability
Distillate (petroleum), hydrotreated light naphthenic	-	-	Inherent
Lubricating oils (petroleum), C15-30, hydrotreated neutral oil-based	-	-	Inherent
Distillates (petroleum), hydrotreated light paraffinic	-	-	Inherent
Distillates (petroleum), solvent-refined light naphthenic	-	-	Inherent
Conclusion/Summary			Inherently biodegradable.

12.3 Bioaccumulative potential

SECTION 11: Toxicological information

Result	Species	Dose	Exposure	Remarks
Negative - Dermal	Mouse - Female	0.22 to 0.25 ml	78 weeks; Various	Doak, 1983, McKee, 1989 (similar material)
Negative - Dermal	Mouse - Female	0.22 to 0.25 ml	78 weeks; Various	Doak, 1983, McKee, 1989 (similar material)
Negative - Dermal	Mouse - Female	0.22 to 0.25 ml	78 weeks; Various	Doak, 1983, McKee, 1989 (similar material)
Negative - Dermal	Mouse - Female	0.22 to 0.25 ml	78 weeks; Various	Doak 1983, McKee 1989 (similar material)

The base oil(s) in this product is based on an severely hydrotreated distillate. The product should not be regarded as a carcinogen.
 No known significant effects or critical hazards.

Result	Species	Dose	Exposure	Remarks
Negative - Dermal	Rat	0 to 2000 mg/kg mg/kg/day	-	(similar material)
Negative - Dermal	Rat	0 to 2000 mg/kg mg/kg/day	-	-
Negative - Dermal	Rat	0 to 2000 mg/kg mg/kg/day	-	-
Negative - Dermal	Rat	0 to 2000 mg/kg mg/kg/day	-	1987 (similar material)
No known significant effects or critical hazards.				

SECTION 11: Toxicological information

Result	Remarks
Aspiration HAZARD - Category 1	ASPIRATION HAZARD - Category 1
Aspiration HAZARD - Category 1	ASPIRATION HAZARD - Category 1
Aspiration HAZARD - Category 1	ASPIRATION HAZARD - Category 1
Aspiration HAZARD - Category 1	ASPIRATION HAZARD - Category 1
Not available.	

Eye contact may cause redness and transient pain.
 Inhalation of oil mist or vapours at elevated temperatures may cause respiratory irritation.
 No known significant effects or critical hazards.
 May be fatal if swallowed and enters airways.

Nyro Libra

ecological information

name	LogP _{ow}	BCF	Potential
phenic (m),	2 to 6	<500	low
	2 to 6	<500	low
inic	2 to 6	<500	low
	2 to 6	<500	low

The product has a potential to bioaccumulate.

High mobility in soil predicted, based on log Kow > 3.0.

vPvB assessment
Not applicable,
Not applicable.

Insoluble in water. Spills may form a film on water surfaces causing physical damage to organisms. Oxygen transfer could also be impaired.

positional considerations

Section contains generic advice and guidance. The list of Identified Uses in Section 1 should be able use-specific information provided in the Exposure Scenario(s).

methods

Where possible (e.g. in the absence of relevant contamination), recycling of used substance is feasible and recommended. This substance can be burned or incinerated, subject to national/local authorizations, relevant contamination limits, safety regulations and air quality legislation. Contaminated or waste substance (not directly recyclable): Disposal can be carried out directly, or by delivery to qualified waste handlers. National legislation may identify a specific organization, and/or prescribe composition limits and methods for recovery or disposal.

Yes.

Waste designation

mineral-based non-chlorinated insulating and heat transmission oils

The generation of waste should be avoided or minimised wherever possible. Waste packaging should be recycled. Incineration or landfill should only be considered when recycling is not feasible.

transport information

t regulations

SECTION 14: Transport information

	ADR/RID	ADN	IMO/IMDG Classification	ICAO/IATA Classification
14.1 UN number	Not regulated.	Not regulated.	Not regulated.	Not regulated.
14.2 UN proper shipping name	-	-	-	-
14.3 Transport hazard class(es)	-	-	-	-
14.4 Packing group	-	-	-	-
14.5 Environmental hazards	No.	No.	No.	No.
Additional information	-	-	-	-

14.6 Special precautions for user
Transport within user's premises: always transport in closed containers that are upright and secure. Ensure that persons transporting the product know what to do in the event of an accident or spillage.

14.7 Transport in bulk according to Annex I of MARPOL 73/78 and the IBC Code
Oils

SECTION 15: Regulatory information

15.1 Safety, health and environmental regulations/legislation specific for the substance or mixture
EU Regulation (EC) No. 1907/2006 (REACH)
Annex XIV - List of substances subject to authorisation

Annex XIV

None of the components are listed.
Substances of very high concern

None of the components are listed.
Annex XVII - Restrictions on the manufacture, placing on the market and use of certain dangerous substances, mixtures and articles
Other EU regulations
Seveso Directive

This product is not controlled under the Seveso Directive.
National regulations

Product/ingredient name	List name	Name on list	Classification	Notes
Distillates (petroleum), hydrotreated light paraffinic	Poland Carcinogen, Mutagen chemicals	Destylaty lekkie parafinowe, obrablane wodorem (ropa	Carc. - cat.2	-

regulatory information

- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- All components are listed or exempted.
- Complete.

Other information

Not available.

that has changed from previously issued version.

ADN = European Provisions concerning the International Carriage of Dangerous Goods by Inland Waterway
 ADR = The European Agreement concerning the International Carriage of Dangerous Goods by Road
 ATE = Acute Toxicity Estimate
 CLP = Classification, Labelling and Packaging Regulation [Regulation (EC) No. 1272/2008]
 CMR = Carcinogen, Mutagen or Reproductive toxicant
 CSA = Chemical Safety Assessment
 CO₂ = carbon dioxide
 DNEL = Derived No Effect Level
 EC50 = Half maximal effective concentration
 EUH statement = CLP-specific Hazard statement
 IATA = International Air Transport Association
 IC50 = Half maximal inhibitory concentration
 IMDG = International Maritime Dangerous Goods
 LC50 = Median lethal concentration
 LD50 = Median lethal dose
 PNEC = Predicted No Effect Concentration
 PBT = Persistent, Bioaccumulative and Toxic
 RID = The Regulations concerning the International Carriage of Dangerous Goods by Rail
 REACH = Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation [Regulation (EC) No. 1907/2006]
 SCBA = Self-Contained Breathing Apparatus
 SVHC = Substances of Very High Concern

the classification according to Regulation (EC) No. 1272/2008 [CLP/GHS]

Classification	Justification
	Calculation method

H304 May be fatal if swallowed and enters airways.

Asp. Tox. 1, H304 ASPIRATION HAZARD - Category 1

Nyro Lbra

SECTION 16: Other information

Date of previous issue No previous validation
 Version 1

Notice to reader

To the best of our knowledge, the information contained herein is accurate. However, neither the above-named supplier, nor any of its subsidiaries, assumes any liability whatsoever for the accuracy or completeness of the information contained herein.
 Final determination of suitability of any material is the sole responsibility of the user. All materials may present unknown hazards and should be used with caution. Although certain hazards are described herein, we cannot guarantee that these are the only hazards that exist.



Safety Data Sheet (eSDS)

Industrial

Substance or mixture

Mixture
Nytro Libra

Distribution of substance- Industrial (Other Lubricant Base Oils, IP346<3%, H304)

Identified use name: Distribution of substance - Industrial
Process Category: PROC01, PROC02, PROC03, PROC04, PROC08a, PROC08b, PROC09, PROC15
Substance supplied to that use in form of: Substance
Sector of end use: SU03
Subsequent service life relevant for that use: No.
Environmental Release Category: ERC04, ERC05, ERC06a, ERC06b, ERC06c, ERC06d, ERC07, ESW/OC SpERC 1.1b.v1
Market sector by type of chemical product: Not applicable.
Article category related to subsequent service life: Not applicable.

Distribution of substance

Distribution of substance

9.3.1b
Concave
2012
01a
Bulk loading (including marine vessel/barge, railroad car and IBC loading) of substance within closed or contained systems, including incidental exposures during its sampling, storage, unloading, maintenance and associated laboratory activities.
Industrial

Exposure controls

Substance is complex UVCB.. Predominantly hydrophobic
Fraction of EU tonnage used in region 0.1
Regional use tonnage 8.5E+5
Fraction of Regional tonnage used locally 1
Maximum daily site tonnage 1.7E+4
Continuous release
Emission Days (days/year) 100
Local freshwater dilution factor 10
Local marine water dilution factor 100
Release fraction to air from process (initial release prior to RMM) 1.0E-4
Release fraction to wastewater from process (initial release prior to RMM) 1.0E-7
Release fraction to soil from process (initial release prior to RMM) 0.00001
Common practices vary across sites thus conservative process release estimates used.

Risk from environmental exposure is driven by freshwater sediment. Risk from discharging to domestic sewage treatment plant, no onsite wastewater treatment

Distribution of substance- Industrial (Other Lubricant Base Oils, IP346<3%, H304)

Section 2 Exposure controls

Risk management measures - Water
Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 64.4
If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 0
Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.
Estimated substance removal from wastewater via on-site sewage treatment 94.7
Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMIS94.7
Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removal 1.1E+5
Assumed on-site sewage treatment plant flow 2000
External treatment and disposal of waste should comply with applicable local and/or national regulations.
External recovery and recycling of waste should comply with applicable local and/or national regulations.

Contributing scenario controlling worker exposure for 0: Distribution of substance
Product characteristics
Liquid, vapour pressure < 0.5 kPa at STP
Covers percentage substance in the product up to 100% (unless stated differently).
Liquid
Covers daily exposures up to 8 hours (unless stated differently)
Operation
Operation is carried out at elevated temperature (> 20°C above ambient temperature). Assumes a good basic standard of occupational hygiene is implemented
Aspiration hazard
Aspiration hazard if swallowed.
Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.
Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.
This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.
Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.
Do not induce vomiting as there is high risk of aspiration.
IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures
General exposures (closed systems)
No other specific measures identified.
General exposures (open systems)
No other specific measures identified.
Process sampling
No other specific measures identified.
Laboratory activities
No other specific measures identified.
Bulk transfers closed systems
No other specific measures identified.

Organisational measures to prevent/limit release from site
Conditions and measures related to municipal sewage treatment plant
Conditions and measures related to external treatment of waste for disposal
Conditions and measures related to external recovery of waste
Concentration of substance in mixture or article
Physical state
Frequency and duration of use
Other given operational conditions affecting workers exposure

me

Exposure controls

- Drum and small package filling
No other specific measures identified.
- Equipment cleaning and maintenance
Drain down and flush system prior to equipment break-in or maintenance.
- Storage
Store substance within a closed system.
- Measures related to personal protection and hygiene
See Section 8 of the safety data sheet (general health and safety measures).
See Section 8 of the safety data sheet (personal protective equipment).

Exposure estimation and reference to its source

- Not applicable.
- Reference to its source - Environment 2: Distribution of substance
Not available.
- The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrosisk model.
- Reference to its source - Workers: 1: Distribution of substance
Not available.

The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Reference to DU to evaluate whether he works inside the boundaries set

Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using onsite/offsite technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SpERC factsheet. Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet.

The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.

A DNEL (derived no effect levels) cannot be derived.

This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.

However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.

Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.

There are no routine anticipated exposures by ingestion related to any substance-4

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Exposure controls

- Laboratory activities
- No other specific measures identified. Bulk transfers Dedicated facility
- No other specific measures identified.
- Mixing operations (open systems)
- No other specific measures identified.
- Transfer from/into/pouring from containers Manual Non-dedicated facility
- No other specific measures identified.
- Drum/batch transfers Dedicated facility
- No other specific measures identified.
- Production of preparation or articles by tableting, compression, extrusion or pelletisation
- No other specific measures identified.
- Drum and small package filling
- No other specific measures identified.
- Equipment cleaning and maintenance
- Drain down and flush system prior to equipment break-in or maintenance.
- Storage
- Store substance within a closed system.
- Measures related to personal protection and hygiene
- See Section 8 of the safety data sheet (general health and safety measures).
- See Section 8 of the safety data sheet (personal protective equipment).

Exposure estimation and reference to its source

- Not applicable.
- reference to its source - Environment: 2. Formulation and (re)packing of substances and
- Not available.
- The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrosisk model.
- reference to its source - Workers: 1. Formulation and (re)packing of substances and mixtures
- Not available.
- The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Guidance to DU to evaluate whether he works inside the boundaries set

Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using onsite/offsite technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SpEBC factsheet. Scaled to 100%

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

Health

The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to properties (i.e. Kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.

A DNEL (derived no effect levels) cannot be derived.

This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.

However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.

Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.

There are no routine anticipated exposures by ingestion related to any supported uses of the substance. The risk arising from aspiration hazard is solely related to the physico-chemical properties of the substance. The risk can therefore be controlled by implementing risk management measures tailored to this specific risk.

For any substance, classified as H304 (R65), these measures should be communicated via the safety data sheet by use of the following phrase: Do not ingest if swallowed then seek immediate medical assistance.



Safety Data Sheet (eSDS)

Industrial

Substance or mixture
Mixture
Nyro Libra

Manufacturer of substance- Industrial (Other Lubricant Base Oils, IP346<3%, H304)

Identified use name: Manufacture of substance - Industrial
Process Category: PROC01, PROC02, PROC03, PROC04, PROC08a, PROC08b, PROC15
Substance supplied to that use in form of: Substance
Sector of end use: SU03, SU08, SU09
Subsequent service life relevant for that use: No.
Environmental Release Category: ERC04, ESVOC SpERC 1.1.V1
Market sector by type of chemical product: Not applicable.
Article category related to subsequent service life: Not applicable.

Manufacture of substance

Manufacture of substance

9.1.1b
Concawe 2012
01
Manufacture of the substance or use as a process chemical or extraction agent within closed or contained systems. Includes incidental exposures during recycling/recovery, material transfers, storage, sampling, associated laboratory activities, maintenance and loading (including marine vessel/barge, road/rail car and bulk container).
Industrial

Exposure controls

Substance is complex UVCB. Predominantly hydrophobic
Fraction of EU tonnage used in region 0.1
Regional use tonnage 8.5E+5
Fraction of Regional tonnage used locally 1
Annual site tonnage 6.0E+5
Maximum daily site tonnage 2.0E+6
Continuous release
Emission Days (days/year) 300
Local freshwater dilution factor 10
Local marine water dilution factor 100
Release fraction to air from process (initial release prior to RMM) 1.0e-4
Release fraction to wastewater from process (initial release prior to RMM) 1.0e-5
Release fraction to soil from process (initial release prior to RMM) 0.0001
Common practices vary across sites thus conservative process release estimates used.
Risk from environmental exposure is driven by freshwater sediment.

Nyro Libra

Manufacturer of substance- Industrial (Other Lubricant Base Oils, IP346<3%, H304)

Section 2 - Exposure controls

Treat air emission to provide a typical removal efficiency of 90

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 84.8
If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 0
Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Estimated substance removal from wastewater via on-site sewage treatment 94.7
Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs 94.7
Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removals, 7E+6
Assumed on-site sewage treatment plant flow 10000
During manufacturing, no waste of the substance is generated.

During manufacturing, no waste of the substance is generated.

Risk management measures - Air
Risk management measures - Water

Organisational measures to prevent/limit release from site
Conditions and measures related to municipal sewage treatment plant

Conditions and measures related to external treatment of waste for disposal
Conditions and measures related to external recovery of waste

Contributing scenario controlling worker exposure for 0: Manufacture of substance

Product characteristics

Concentration of substance in mixture or article

Physical state

Frequency and duration of use

Other given operational conditions affecting workers exposure

Liquid, vapour pressure < 0.5 kPa at STP
Covers percentage substance in the product up to 100% (unless stated differently).

Liquid With potential for aerosol generation
Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature) Assumes a good basic standard of occupational hygiene is implemented

Aspiration hazard if swallowed.
Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.

Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.
This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.

Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.
Do not induce vomiting as there is high risk of aspiration.
IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures

General exposures (closed systems)
No other specific measures identified.

General exposures (open systems)
No other specific measures identified.

Process sampling
No other specific measures identified.

Laboratory activities
No other specific measures identified.

Bulk transfers (Closed system)

Exposure controls

No other specific measures identified.

Equipment cleaning and maintenance
Drain down and flush system prior to equipment break-in or maintenance.

Bulk product storage
Store substance within a closed system.
Measures related to personal protection and hygiene

See Section 8 of the safety data sheet (general health and safety measures).
See Section 8 of the safety data sheet (personal protective equipment).

Exposure estimation and reference to its source

Not applicable.

Reference to its source - Environment: 2: Manufacture of substance

Not available.

The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petrosisk model.

Reference to its source - Workers: 1: Manufacture of substance
Not available.

The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Guidance to DU to evaluate whether he works inside the boundaries set

Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using onsite/offsite technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SPERC factsheet. (<http://cefic.org/en/reach-for-industries-libraries.html>) Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet.
The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.
A DNEL (derived no effect levels) cannot be derived.

This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.
However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.

Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.

There are no routine anticipated exposures by ingestion related to any supported uses of the substance. The risk arising from aspiration hazard is solely related to the

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

If swallowed then seek immediate medical assistance.

Predicted exposures are not expected to exceed the DN(M)EL when the risk management measures/operational conditions outlined in section 2 are implemented.

Where other risk management measures/operational conditions are adopted, then users should ensure that risks are managed to at least equivalent levels.

Available hazard data do not enable the derivation of a DNEL for dermal irritant effects. Available hazard data do not support the need for a DNEL to be established for other health effects. Risk management measures are based on qualitative risk characterisation.

Industrial

Substance or mixture

Mixture

Nytro Libra

Uses in Functional fluids - Industrial (Other Lubricant Base Oils, IP348-3%, H304)

Identified use name: Functional Fluids - Industrial
 Process Category: PROC01, PROC03, PROC08a, PROC08b, PROC02, PROC04, PROC09

Substance supplied to that use in form of: Substance

Sector of end use: SU03

Subsequent service life relevant for that use: No.

Environmental Release Category: ERC07.

Market sector by type of chemical product: Not applicable.

Article category related to subsequent service life: Not applicable.

Functional Fluids

Functional Fluids

9.37: 1b

Concawe

2012

13a

Use as functional fluids e.g. cable oils, transfer oils, coolants, insulators, refrigerants, hydraulic fluids in industrial equipment including maintenance and related material transfers.

Industrial

Exposure controls

Substance is complex UVCE. Predominantly hydrophobic

Fraction of EU tonnage used in region: 0.1

Regional use tonnage: 1.2E+3

Fraction of Regional tonnage used locally: 1

Annual site tonnage: 1.0E+1

Maximum daily site tonnage: 5.0E+2

Continuous release

Emission Days (days/year): 20

Local freshwater dilution factor: 10

Local marine water dilution factor: 100

Release fraction to air from process (initial release prior to RMM): 5.0E-4

Release fraction to wastewater from process (initial release prior to RMM): 1.0E-6

Release fraction to soil from process (initial release prior to RMM): 0.001

Common practices vary across sites thus conservative process release estimates used.

Risk from environmental exposure is driven by freshwater sediment.

Prevent discharge of undissolved substance to or recover from onsite wastewater.

Nytro Libra

Uses in Functional fluids - Industrial (Other Lubricant Base Oils, IP346-3%, H304)

Section 2 - Exposure controls

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 64.4

If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 0

Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Estimated substance removal from wastewater via on-site sewage treatment: 94.7

Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs: 94.7

Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removal: 3.3E+3

Assumed on-site sewage treatment plant flow: 2000

External treatment and disposal of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

Conditions and measures related to external treatment of waste for disposal

Conditions and measures related to external recovery of waste

Contributing scenario controlling worker exposure for 0: Functional Fluids

Product characteristics

Concentration of substance in mixture or article

Physical state

Frequency and duration of use

Other given operational conditions affecting workers exposure

Liquid, vapour pressure < 0.5 kPa at STP

Covers percentage substance in the product up to 100% (unless stated differently).

Liquid With potential for aerosol generation

Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature)

Assumes a good basic standard of occupational hygiene is implemented

Aspiration hazard: If swallowed.

Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.

Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.

This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.

Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.

Do not induce vomiting as there is high risk of aspiration.

IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures

Bulk transfers - Closed system

No other specific measures identified.

Drum/batch transfers - Dedicated facility

No other specific measures identified.

Filling of articles/equipment - closed systems

No other specific measures identified.

Filling/preparation of equipment from drums or containers - Non-dedicated facility

No other specific measures identified.

General exposures (closed systems)

No other specific measures identified.

Exposure controls

- Remanufacture of reject articles
No other specific measures identified.
- Equipment cleaning and maintenance
Drain down system prior to equipment break-in or maintenance.
- Storage
Store substance within a closed system.
- Measures related to personal protection and hygiene
See Section 8 of the safety data sheet (general health and safety measures).
See Section 8 of the safety data sheet (personal protective equipment).

Exposure estimation and reference to its source

Not applicable.

Exposure estimation and reference to its source - Environment: 2: Functional Fluids

Not available.

The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petronrisk model.

Exposure estimation and reference to its source - Workers: 1: Functional Fluids

Not available.

The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Guidance to DU to evaluate whether he works inside the boundaries set

Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using on-site/off-site technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SpERC factsheet. (<http://cefic.org/en/reach-for-industries-libraries.html>) Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet. The CLP hazard statement H304; May be fatal if swallowed and enters airways (the DPD risk phrase R65; Harmful; may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.

A DNEL (derived no effect levels) cannot be derived. This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance. However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance. Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern. There are no routine cases.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

For any substance, classified as H304 (R65), these measures should be communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Predicted exposures are not expected to exceed the DN(M)EL when the risk management measures/operational conditions outlined in section 2 are implemented.

Where other risk management measures/operational conditions are adopted, then users should ensure that risks are managed to at least equivalent levels.

Available hazard data do not enable the derivation of a DNEL for dermal irritant effects. Available hazard data do not support the need for a DNEL to be established for other health effects. Risk management measures are based on qualitative risk characterisation.



Nyro Libra

Uses in Functional fluids - Professional (Other Lubricant Base Oils, IP346<3%, H304)

afety Data Sheet (eSDS)

Professional

Substance or mixture

Mixture

Nyro Libra

Uses in Functional fluids - Professional (Other Lubricant Base Oils, IP346<3%, H304)

Identified use name: Functional Fluids - Professional

Process Category: PROC01, PROC02, PROC03, PROC08a, PROC08, PROC09, PROC20

Substance supplied to that use in form of: Substance

Sector of end use: SU22

Subsequent service life relevant for that use: No.

Environmental Release Category: ERC08a, ERC08b, ESVOC SpERC 9.13b.v1

Market sector by type of chemical product: Not applicable.

Article category related to subsequent service life: Not applicable.

Functional Fluids

Functional Fluids

9.38, 1b

Concawe

2012

13b

Use as functional fluids e.g. cable oils, transfer oils, coolants, insulators, refrigerants,

hydraulic fluids in professional equipment including maintenance and related

material transfers.

Professional

Substance is complex UVCB. Predominantly hydrophobic

Fraction of EU tonnage used in region 0.1

Regional use tonnage 1.2E+3

Fraction of Regional tonnage used locally 1

Annual site tonnage 6.0E-1

Maximum daily site tonnage 1.6E+0

Continuous release

Emission Days (days/year) 365

Local freshwater dilution factor 10

Local marine water dilution factor 100

Release fraction to air from process (Initial release prior to RMM) 0.05

Release fraction to wastewater from process (Initial release prior to RMM) 0.025

Release fraction to soil from process (Initial release prior to RMM) 0.025

Common practices vary across sites thus conservative process release estimates

used.

Risk from environmental exposure is driven by freshwater sediment.

If discharging to domestic sewage treatment plant, no onsite wastewater treatment

required.

Section 2 - Exposure controls

Risk management

measures - Water

Organisational measures to prevent/limit release from site

Conditions and measures related to municipal sewage treatment plant

Conditions and measures related to external treatment of waste for disposal

Conditions and measures related to external recovery of waste

Treat on-site wastewater (prior to receiving water discharge) to provide the required removal efficiency of 64.9

If discharging to domestic sewage treatment plant, provide the required onsite wastewater removal efficiency of 0

Do not apply industrial sludge to natural soils. Sludge should be incinerated, contained or reclaimed.

Estimated substance removal from wastewater via on-site sewage treatment 94.7

Total efficiency of removal from wastewater after on-site and off-site (domestic treatment plant) RMMs 94.7

Maximum allowable site tonnage (M_{site}) based on release following total wastewater treatment removal 1.1E+1

Assumed on-site sewage treatment plant flow 2000

External treatment and disposal of waste should comply with applicable local and/or national regulations.

External recovery and recycling of waste should comply with applicable local and/or national regulations.

Contributing scenario controlling worker exposure for 0: Functional Fluids

Product characteristics

Concentration of substance in mixture or article

Physical state

Frequency and duration of use

Other given operational conditions affecting workers exposure

Liquid, vapour pressure < 0.5 kPa at STP

Covers percentage substance in the product up to 100% (unless stated differently).

Liquid With potential for aerosol generation

Covers daily exposures up to 8 hours (unless stated differently)

Operation is carried out at elevated temperature (> 20°C above ambient temperature)

Assumes a good basic standard of occupational hygiene is implemented

Aspiration hazard if swallowed.

Aspiration means the entry of a liquid substance directly into the trachea and lower respiratory tract.

Aspiration of hydrocarbon substances can result in severe acute effects such as chemical pneumonitis, varying degree of pulmonary injury or death.

This property relates to the potential for low viscosity material to spread quickly into the deep lung and cause severe pulmonary tissue damage.

Classification of a hydrocarbon substance for aspiration hazard is made on the basis of reliable human evidence or on the basis of physical properties.

Do not induce vomiting as there is high risk of aspiration.

IF SWALLOWED: Immediately call a POISON CENTER or physician.

Contributing scenarios - Operational conditions and risk management measures

Bulk transfers - Closed system

No other specific measures identified.

Drum/batch transfers - Dedicated facility

No other specific measures identified.

Filling of articles/equipment - closed systems

No other specific measures identified.

Filling/preparation of equipment from drums or containers - Non-dedicated facility

No other specific measures identified.

General exposures (closed systems)

No other specific measures identified.

Control measures

- Remanufacture of reject articles
No other specific measures identified.
- Equipment cleaning and maintenance
Drain down system prior to equipment break-in or maintenance.
- Storage
Store substance within a closed system.
Measures related to personal protection and hygiene
See Section 8 of the safety data sheet (general health and safety measures).
See Section 8 of the safety data sheet (personal protective equipment).

Exposure estimation and reference to its source

Not applicable.

Reference to its source - Environment: 2: Functional Fluids

Not available.

The Hydrocarbon Block Method has been used to calculate environmental exposure with the Petronisk model.

Reference to its source - Workers: 1: Functional Fluids

Not available.

The ECETOC TRA tool has been used to estimate workplace exposures unless otherwise indicated.

Guidance to DU to evaluate whether he works inside the boundaries set

Guidance is based on assumed operating conditions which may not be applicable to all sites; thus, scaling may be necessary to define appropriate site-specific risk management measures. Required removal efficiency for wastewater can be achieved using on-site/off-site technologies, either alone or in combination. Required removal efficiency for air can be achieved using on-site technologies, either alone or in combination. Further details on scaling and control technologies are provided in SPERC factsheet. (<http://cefic.org/en/reach-for-industries-libraries.html>) Scaled local assessments for EU refineries have been performed using site-specific data and are attached in PETRORISK file - "Site-Specific Production" worksheet.
The CLP hazard statement H304: May be fatal if swallowed and enters airways (the DPD risk phrase R65: Harmful; may cause lung damage if swallowed) relates to potential for aspiration, a non-quantifiable hazard determined by physico-chemical properties (i.e. kinematic viscosity) that can occur during ingestion and also if it is vomited following ingestion.

A DNEL (derived no effect levels) cannot be derived.
This general qualitative CSA (chemical safety assessment) approach aims to reduce/avoid contact or incidents with the substance.
However, implementation of risk management measures (RMMs) and operational conditions (OCs) need to be proportional to the degree of concern for the health hazard presented by the substance.

Exposures should be controlled to at least the levels that represent an acceptable level of risk such that the implementation of the chosen RMMs will ensure that the likelihood of an event occurring due to the substance hazard is negligible, and the risk is considered to be controlled to a level of no concern.
There are no specific measures to be taken.

Section 4 - Guidance to DU to evaluate whether he works inside the boundaries set by the ES

For any substance, classified as H304 (R65), these measures should be communicated via the safety data sheet by use of the following phrase: Do not ingest. If swallowed then seek immediate medical assistance.

Predicted exposures are not expected to exceed the DN(M)EL when the risk management measures/operational conditions outlined in section 2 are implemented.

Where other risk management measures/operational conditions are adopted, then users should ensure that risks are managed to at least equivalent levels.

Available hazard data do not enable the derivation of a DNEL for dermal irritant effects. Available hazard data do not support the need for a DNEL to be established for other health effects. Risk management measures are based on qualitative risk characterisation.

Handwritten mark

**„Доставка на електрически апарати
110кV“, реф. № РРД 17-064.**

**Обособена позиция 2 – Доставка на
токови измервателни трансформатори
110кV за монтаж на открито – 21бр.**

ПРИЛОЖЕНИЕ 4



INSTITUTE OF POWER ENGINEERING)
Zespół ds. Certyfikacji (Certification Department)

PRODUCT EVALUATION REPORT

Nr DZC/135c/E/2014-1

and symbol: HV current transformer, single-phase,
outdoor, type: PA 123a

Sp. z o.o., Oddział w Przasnyszu, ul. Leszno 59,
00 Przasnysz

INSTYTUT ENERGETYKI
Zespół ds. Certyfikacji

Report
No DZC/135c/E/2014-1

Author: Grażyna Wieczorek M. Sc.

Contents:

- | | |
|-----------------------------------|---|
| 1. Introduction | 3 |
| 2. List of applied documents | 4 |
| 3. Testing laboratory competences | 5 |
| 4. Test result list | 5 |
| 4.1. Type tests | 6 |
| 4.2. Routine tests | 6 |
| 5. Summary | 9 |

APPENDIX – Type test reports, special test reports and Manufacturer’s Statement (pages not numbered)

Non-conformities observed:

None found

General evaluation result:

Positive

Based on the analysis made, herewith I conclude for granting of compliance certificates to the HV current transformers type PA 123a, with composite or ceramic insulator, manufactured by ABB Sp. z o.o., Oddział w Przasnyszu

Introduction

from evaluation of HV overhead, single-phase, current transformer series, types: PA manufactured by ABB Sp. z o.o., Oddział w Przasnyszu, was developed within the process carried out by Zespół ds. Certyfikacji (Certification Team) upon application (Contract No DZC/135c/E/2014 of the 06th October 2014) that concerns the new series of current instrument transformers featuring design and type marked: PA 123a.

123a current transformers are designed for feeding measurement and protection critical power grids with the highest system voltage of 123 kV and frequency of 50 Hz. Transformers consist of a current element located inside an enclosure with a composite configuration: straight and spiral) or with a ceramic insulator filled with epoxy resin.

23a current transformer series tests were carried out on selected representatives at the Institute of Energy (Institute of Power Engineering) in Warsaw and Instytut Elektrotechniczny (Electrotechnical Institute) in Warsaw as well as (within the range of product tests and measurements) at the manufacturer's laboratory. The selection procedure of current transformer representatives included the most severe conditions resulting from the design and occurring during the temperature-rise tests, short-circuit withstand, mechanical tests such as: values of continuous and short-circuit currents, winding wire current main circuits, power of windings for measurement and protection, housing masses, etc. Tests were carried out on eleven selected transformer prototypes. The results of the entire transformer series acc. to the list as suggested for certification. Test results and the transformer features are listed in the reports in cl. 2 of this document. The results are compared against requirements of the following standards:

IEC 60044-1:2009

IEC 60044-2:2003

IEC 60044-3:2011

IEC 60044-4:2003

IEC 60044-5:2003

IEC 60044-6:2003

IEC 60044-7:2003

IEC 60044-8:2003

IEC 60044-9:2003

IEC 60044-10:2003

IEC 60044-11:2003

Customer/manufacturer: ABB Sp. z o.o., Przasnysz holds the complex certificate for the following standards: ISO 9001:2008, ISO 14001:2004 and PN-N-18001:2004 – certificate No 0198/150 01525 issued by TÜV Rheinland Polska Sp. z o.o.

2. List of applied documents

The current transformers design and the test results were evaluated and analysed based on the following documents delivered by the Manufacturer and included in the reports:

- D1. Report No EWP/10/E/2014-1c, Temperature-rise test -PVA 145a (360 A), IEn, High Current Laboratory, Warsaw, January 2014
- D2. Report No EWP/47/E/2014-1e, Temperature-rise test -PA 145a (1800 A), IEn, High Current Laboratory, Warsaw, January 2014 r.
- D3. Report No EWP/35/E/2013-1e, Temperature-rise test -PVA 145a (2400 A), IEn, High Current Laboratory, Warsaw, January 2014 r.
- D4. Report No EWP/35/E/2013-2e, Temperature-rise test -PVA 145a (900 A), IEn, High Current Laboratory, Warsaw, January 2014 r.
- D5. Test Report No 8595/ANZL/NBR/15, Temperature-rise test -PA 145a (3000 A), IEl, Distribution Equipment Test Laboratory Warsaw, January 2015 r.
- D6. Report No EUR/34/E/14-1 E, Mechanical tests, IEn, Distribution Equipment Laboratory Warsaw, September 2014 r.
- D7. Report No EUR/34/E/14-2 E, Mechanical tests, IEn, Distribution Equipment Laboratory Warsaw, September 2013 r.
- D8. Report No EUR/34/E/14-3 E, Mechanical tests, IEn, Distribution Equipment Laboratory Warsaw, September 2014 r.
- D9. Report No EUR/34/E/14-4 E, Mechanical tests, IEn, Distribution Equipment Laboratory Warsaw, September 2014 r.
- D10. Report No EUR/71/E/13-3 E, Short-time current test, Test for composite error, test of strength against short-circuit in the secondary circuit, IEn, Distribution Equipment Laboratory Warsaw, January 2014 r.
- D11. Report No EUR/74/E/13 E, Short-time current test, Test for composite error, IEn, Distribution Equipment Laboratory Warsaw, December 2013 r.
- D12. Test Report No 8596/ANZL/NBR/15, Short-time current test, IEl, Distribution Equipment Test Laboratory Warsaw, January 2015 r.
- D13. Report No EUR/71/E/13-4 E, Short-time current test, Test for composite error, IEn, Distribution Equipment Laboratory Warsaw, January 2014 r.
- D14. Report No EUR/23/E/14 E, Short-time current test, Test for composite error, IEn, Distribution Equipment Laboratory Warsaw, May 2014 r.
- D15. Test Report No EWN/145/E/13 Type tests, special tests and additional tests of combined transformers type PVA123a i PVA145a manufactured by ABB sp. z o.o., IEn, High Voltage Laboratory, Warsaw, January 2014 r.

Report No EWN/11/E/12-1, Type tests, special tests and additional tests of Voltage
PV 123, manufactured by ABB sp. z o.o., IEn, High Voltage Laboratory Warsaw,
h No EWN/11/E/12-2, tests of Current transformer type PA 123 (PA 145) with
L1 650kV/AC 275kV, manufactured by ABB sp. z o.o., IEn, High Voltage
saw, October 2012 r.
EWP/35/E/2013-3e), Sprawdzanie ochrony przed uderzeniem mechanicznym, IEn,
boratory, Warsaw, February 2014 r.
281/A/NZL/NBR/12), IP tests for terminal box, IEl, Distribution Equipment Test
saw, Warsaw, July 2012 r.

al drawings:

- onal drawing Combined instrument transformer PVA 123a-145a
2GKK614122/ABB R&D_TS_KU568/13 (17.12.2013),
- onal drawing Combined instrument transformer PVA 123a-145a
2GKK614123/ABB R&D_TS_KU571/13 (17.12.2013),
- onal drawing Combined instrument transformer PVA 123a-145a
2GKK614123/ABB R&D_TS_KU572/13 (17.12.2013),
- onal drawing Combined instrument transformer PVA 123a-145a
2GKK614120/ABB R&D_TS_KU569/13/A (17.12.2013),
- onal drawing Combined instrument transformer PVA 123a-145a
2GKK614121/ABB R&D_TS_KU569/13 (17.12.2013),
- onal drawing Current transformer PA 145, 2GKA612004 (01.08.2014),
- onal drawing Current transformer PA 145, 2GKA612002 (11.09.2014),
- onal drawing Current transformer PA 145, 2GKA612001 (11.09.2014),
- onal drawing Current transformer PA 145, 2GKA612003 (11.09.2014),
- onal drawing Voltage transformer PV 123, 2GKA614114/ (19.01.2012),
- onal drawing Current transformer PA 123 (PA 145), 2GKA614117 (19.01.2012),
- onal drawing Current transformer PA 145, 2GKA612004 (01.08.2014),
- onal drawing Current transformer PA 145, 2GKA614301 (01.08.2014).

est reports and accuracy check reports – see reports from tests D1+D5, D10+D17
ates – see reports from tests D1+19
diagrams – see reports from tests D1+D5, D10+D17
er's Statement issued on 2nd March 2015 r. –concerns total active power dissipated in
ner windings.

boratory competences

time tests and special tests for PA...a transformers were carried out at the following
a Wysokich Napięć (High Voltage Laboratory), a unit of Instytut Energetyki (Institute
ngineering) in Warsaw, holding the PCA Accreditation Certificate of the Research
CA No AB 272.

- Laboratorium Wielkoprdowe (High Current Laboratory), a unit of Instytut Energetyki (Institute
of Power Engineering) in Warsaw, holding the PCA Accreditation Certificate of the Research
Laboratory PCA.Nr AB 323.

- Laboratorium Fabryczne ABB Sp. z o.o. (ABB Manufacturing Plant Laboratory) in Przasnysz –
Punkt Legalizacyjny OUM Warszawa (OUM Warsaw Verification Unit) – deviation
measurement, and product tests under supervision of Instytut Energetyki (Institute of Power
Engineering), Laboratorium Wysokich Napięć (High Voltage Laboratory).

- Laboratorium Badawcze Aparatury Rozdzielczej (Distribution Equipment Test Laboratory), a unit
of Instytut Elektrotechniki (Electrotechnical Institute) in Warsaw, holding the PCA Accreditation
Certificate of the Research Laboratory PCA.No AB 074.

4. Test result list

4.1. Type tests and additional tests

The tests were made on selected PA ...a, PVA ...a and PV ... transformer designs (various
rated currents for the current elements, various main circuit designs, various design of secondary
circuits, different accuracy classes and various insulation covers, etc.) The tests results are valid for
the entire transformer series acc. to the list as suggested for certification. Table 1 shows produced
by manufacturer's solutions for the main circuits of current transformers. Representative designs
for short-circuit tests and temperature-rise tests were selected from that list.

PVA...a and PA ...a transformers were selected to temperature-rise test based on the most heat-
exposed design solutions.

Dielectric tests were made for two transformers type : PVA 123a, and 145a as well as PA 123
(145) and PV 123.

The short-circuit withstand tests were made for PVA...a and PA ...a transformers.
Representatives designs were selected according to their main circuits exposition to dynamic and
thermal effects.

Table 2 shows performed tests. Their scope meets requirements included in respective standards
for type tests, special tests, routine tests, and some additional requirements. Respective item
numbers in PN-EN 61869 and IEC 61869 as well as report numbers with detailed test results are
listed.

Results of all tests were positive.

type tests

The tests and accuracy class tests were carried out at the manufacturer's laboratory for transformers tested under the IEn supervision.

ded:

ments before filling the instrument transformer,
of markings of terminals,
ency voltage withstand tests on primary terminals,
ency voltage withstand tests on secondary terminals,
arge intensity,
insulation test,
racy,
-efficient determination,
characteristics determination,
of capacitance and dielectric dissipation factor,
ance measurement.

ults were listed in protocols, their numbers being the same as that of the transformer
voltage tests and short circuit tests, additional routine tests and accuracy class tests

sensitive

circuit list:

current circuit assembly drawing number	Drawing title	Max current I _{ch}	Max current I _{th} (I ₁)/105n	Performed positive tests with current I _{ch}	Performed positive tests with current I _{th} (I ₁)/105n
KCK314133A000 1	Main circuit, rod φ40 Cu	3000 A	63/158 kA (60 kA/60)	PA 145a 8596/NZL/NBR/15	PA 145a 8596/NZL/NBR/15
KCK314133A000 1	Main circuit, rod φ40 Al	2400 A	63/158 kA	PVA 145a EUB/23/E/13	PVA 145a EUB/23/E/13
KCK314133A000 1	Main circuit, rod φ40 Al + trns. φ40x4 Al	2400A - 3800A	63-67/158-158 kA φ40x4 Al	PVA 145a EWP/35/E/2013-1 PA 145a EWP/40/E/2014-1	PVA 145a EUB/23/E/13-3 EUB/23/E/13-4
KCK314133A000 1	Main circuit, rod φ40 Al + trns φ40x4 Al + 2 terminals	2400A - 3800A - 900 A	63-67/158-158- 100 kA	PA 145a EWP/40/E/2014-1 PVA 145a EWP/35/E/2013-1 EWP/35/E/2013-2 ⁰	PVA 145a EUB/23/E/13-3 EUB/23/E/13-4
KCK314133A000 1	Main circuit, rod φ40 Al + trns φ40x4 Al	900 A	40/100 kA	PVA 145a EWP/35/E/2013-2 ⁰	PVA 145a EUB/23/E/13-3
KCK314133A000 1	Main circuit, rod φ40 Al + trns φ40x4 Al	900 A	40/100 kA	PVA 145a EWP/35/E/2013-2 ⁰	PVA 145a EUB/23/E/13-3

3 turns of cable 240mm ²	4 turns of cable 240mm ²	5 turns of cable 240mm ²	6 turns of cable 240mm ²	7 turns of cable 240mm ²	8 turns of cable 240mm ²	2 + 2 turns of cable 240mm ²	3 + 3 turns of cable 240mm ²	4 + 4 turns of cable 240mm ²	2 + 2 + 4 turns of cable 240mm ²	3 turns of cable 120mm ²	6 turns of cable 120mm ²	9 turns of cable 120mm ²	12 turns of cable 120mm ²	3 + 3 turns of cable 120mm ²	6 + 6 turns of cable 120mm ²	3 + 3 + 3 turns of cable 120mm ²	Rod φ40 Cu + pipe φ40x4 Al
2GKCK314133A000 3	2GKCK314133A000 4	2GKCK314133A000 5	2GKCK314133A000 6	2GKCK314133A000 7	2GKCK314133A000 8	2GKCK314133A000 1	2GKCK314133A000 2	2GKCK314133A000 3	2GKCK314133A000 1	2GKCK314133A000 2	2GKCK314133A000 3	2GKCK314133A000 4	2GKCK314133A000 5	2GKCK314133A000 6	2GKCK314133A000 7	2GKCK314133A000 8	2GKCK314133A000 1
Main circuit 3 turns of cable 240 mm ²	Main circuit 4 turns of cable 240 mm ²	Main circuit 5 turns of cable 240 mm ²	Main circuit 6 turns of cable 240 mm ²	Main circuit 7 turns of cable 240 mm ²	Main circuit 8 turns of cable 240 mm ²	Main circuit 2+2 turns of cable 240 mm ²	Main circuit 3+3 turns of cable 240 mm ²	Main circuit 4+4 turns of cable 240 mm ²	Main circuit 2+2+4 turns of cable 240 mm ²	Main circuit 3 turns of cable 120 mm ²	Main circuit 6 turns of cable 120 mm ²	Main circuit 9 turns of cable 120 mm ²	Main circuit 12 turns of cable 120 mm ²	Main circuit 3+3 turns of cable 120 mm ²	Main circuit 6+6 turns of cable 120 mm ²	Main circuit 3+3+3 turns of cable 120 mm ²	Main circuit rod φ40 Cu + pipe φ40x4 Al
900 A	900 A	900 A	900 A	900 A	900 A	900 A - 900 A	900 A - 900 A	900 A - 900 A	900 A - 900 A - 900 A	360 A	360 A	360 A	360 A	360 A - 360 A	360 A - 360 A - 360 A	3000 A - 1800 A	PA 145a EWP/35/E/2013-2 ⁰ EUB/23/E/13-3 EUB/23/E/13-4
40/100 kA	40/100 kA	40/100 kA	40/100 kA	40/100 kA	40/100 kA	40-40/100-100 kA	40-40/100-100 kA	40-40/100-100- 100 kA	40-40/100-100- 100 kA	20/20 / 50-50 kA	20/20 / 50-50 kA	20/20 / 50-50 kA	20/20 / 50-50 kA	20-20 / 50-50 kA	20-20/20-50-50-50- 50 kA	63-67/158-158 kA (60 kA/60)	PA 145a EWP/35/E/2013-2 ⁰ EUB/23/E/13-3 EUB/23/E/13-4
PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-3	PVA 145a EUB/23/E/13-4	PVA 145a EUB/23/E/13-4	PVA 145a EUB/23/E/13-4	PVA 145a EUB/23/E/13-4	PVA 145a EUB/23/E/13-4	PVA 145a EUB/23/E/13-4	PVA 145a EUB/23/E/13-4	PA 145a EWP/35/E/2013-2 ⁰ EUB/23/E/13-3 EUB/23/E/13-4

1) See Manufacturer's Statement issued on 02.03.2015 r. concerning limitation of active power of windings resistance to 80 W.

Table 2. List of tests made for type PA...a current transformer

Item	Test type	Requirements	Report numbers
1	Short-time current test	PN EN 61869-2, p.7.2.201	8596/NZL/NBR/15 EUB/23/E/13-3 EUB/23/E/13-4 EUB/23/E/13-4
TYPE TESTS			

			EWP/35/E/2013-2 8995/NZL/NBR/15
age withstand test	PN-EN 61869-1, p.7.2.3 PN-EN 61869-2, p.7.2.3		EWN/145/E/13
outdoor type	PN-EN 61869-1, p.7.2.4 PN-EN 61869-2, p.7.2.4		EWN/11/E/12-1 EWN/11/E/12-2
accuracy	PN-EN 61869-2, p. 7.2.6.201. + 203		EWN/145/E/13 and protocols from manufacturer's laboratory
composite error	PN-EN 61869-1, p. 7.2.5.1		EWN/145/E/13
ox verification of the IP	PN-EN 61869-2, p. 7.2.7.1 PN-EN 60529, p.13.14		EUR/71/E/13-3 EUR/71/E/13-4 EUR/74/E/13 EUR/23/E/14
il impact test (IK)	PN-EN 61869-1, p. 7.2.7.1 PN-EN 60529, p.13.14 PN-EN 61869-1, p. 7.2.7.2 PN-EN 62262		8281/NZL/NBR/12 EWP/35/E/2013-3
SPECIAL TESTS			
pulse voltage withstand test terminals	PN-EN 61869-1, p.7.4.1 PN-EN 61869-2, p.7.4.1		EWN/145/E/13
test	PN-EN 61869-1, p.7.4.5		EUR/34/E/14-1 EUR/34/E/14-2 EUR/34/E/14-3 EUR/34/E/14-4
overvoltage test	PN-EN 61869-1, p.7.4.4		EWN/145/E/13
ent of capacitance and dissipation factor	PN-EN 61869-1, p.7.4.3 PN-EN 61869-2, p.7.4.3		and protocols from manufacturer's laboratory

test results for selected representatives of transformers series type PA 123a and 45a and PV 123. As well as on analysis of the standards, it was found that: formed all tests from the type test range, special tests and additional tests sufficient evaluation of the apparatuses.

transformer errors tests and instrument transformer secondary circuit designs were their metrological properties were confirmed.

instrument transformer main circuit designs were analysed. It was found that the tests and temperature-rise tests as carried out are binding for all design solutions.

ade according to requirements of the 61869 series standard (PN and IEC)

results under consideration, the technical data listed in Table 3 may be referenced to

- This document may be a basis for issuing compliance certificates for PA 123a instrument transformer series manufactured by ABB Sp. z o.o. Oddział w Przasnyszu. The certificate validity date is suggested to be November 2017.

Table 3. List of technical data assigned to PVA 123a

Transformer type PA 123a	
Highest voltage of current transformer [U _{nl}]	≤ 123 kV
Rated frequency [f _z]	50 Hz
Rated insulation level	AC 230 kV / LL 550 kV
Burden class	F _R =3600N
External insulation – minimal creepage distance of insulator:	3640 mm 3800 mm
• ceramic insulator	
• composite insulator	
Degree of protection to mechanical impact of enclosure ¹⁾	IK7
Degree of protection of secondary terminal enclosure	IP55
Current element	
Rated primary current [I _{sp}]	50 A + 3 000 A
Extended current rating	do 200%
Rated continuous thermal current [I _{sp}]	≤ 3000 A
Rated short-time thermal current [I _{sh}] during 1 s	20 kA lub 40 kA lub 63kA
Rated short-time thermal current [I _{sh}] during 3 s	20 kA lub 40kA
Rated dynamic current [I _{dyn}]	50 kA lub 100 kA lub 158 kA
Rated secondary current [I _s]	1 A lub 5 A
Core power to measurements and to protection (S _z)	1VA – 200 VA
Measure core accuracy class (cl.)	0,1; 0,2; 0,2S; 0,5; 0,5S; 1; 3; 5
Protective core accuracy class (cl.)	5P; 10P; 5PR; 10PR; PX; PXK; TPX; TPY; TPZ

REMARKS: ¹⁾ Do not apply to ceramic insulators

APPENDIX

ports, special test reports and manufacturers statements (pages not numbered)

P/10/E/2014-1c, Temperature-rise test - PVA 145a (360 A), IEn, High Current Laboratory, Warsaw,

P/17/E/2014-1c, Temperature-rise test -PA 145a (1800 A), IEn, High Current Laboratory, Warsaw,

P/35/E/2013-1c, Temperature-rise test -PVA 145a (2400 A), IEn, High Current Laboratory, Warsaw,

P/35/E/2013-2c, Temperature-rise test -PVA 145a (900 A), IEn, High Current Laboratory, Warsaw,

8595/ANZLNBR/15, Temperature-rise test -PA 145a (3000 A), IEI, Distribution Equipment Test
Laboratory, January 2015 r.

3/34/E/14-1 E, Mechanical tests, IEn, Distribution Equipment Laboratory, Warsaw, September 2014

3/34/E/14-2 E, Mechanical tests, IEn, Distribution Equipment Laboratory, Warsaw, September 2014

3/34/E/14-3 E, Mechanical tests, IEn, Distribution Equipment Laboratory, Warsaw, September 2014

3/34/E/14-4 E, Mechanical tests, IEn, Distribution Equipment Laboratory, Warsaw, September 2014

R/71/E/13-3 E, Short-time current test, Test for composite error, test of strength against short-
circuit, IEn, Distribution Equipment Laboratory, Warsaw, January 2014 r.

R/74/E/13 E Short-time current test, Test for composite error, IEn, Distribution Equipment
Laboratory, December 2013 r.

8596/ANZLNBR/15, Short-time current test, IEI, Distribution Equipment Test Laboratory,
January 2015 r.

7/1/E/13-4 E, Short-time current test, Test for composite error, IEn, Distribution Equipment
Laboratory, January 2014 r.

7/3/E/14 E, Short-time current test, Test for composite error, IEn, Distribution Equipment
Laboratory, May 2014 r.

EWV/145/E/13, Type tests, special tests and additional tests of combined transformers type
produced by ABB sp. z o.o., IEn, High Voltage Laboratory, Warsaw, January 2014 r.

WVN/11/E/12-1, Type tests, special tests and additional tests of current transformer type PV 123,
3 sp. z o.o., IEn, High Voltage Laboratory, Warsaw, October 2012 r.

WVN/11/E/12-2, Tests of current transformer type PA 123 (PA 145) with dielectric level LI
manufactured by ABB sp. z o.o., IEn, High Voltage Laboratory, Warsaw, October 2012 r.

733/E/2013-3c), Mechanical impact test, IEn, High Current Laboratory, Warsaw, February 2014

AA/NZLNBR/12 IP tests for terminal box, IEI, Distribution Equipment Test Laboratory, Warsaw,

on 2nd March 2015 r. refers to the total active power dissipated in the current transformer



**INSTITUTE OF POWER
ENGINEERING**

DISTRIBUTION EQUIPMENT LABORATORY

01-330 Warsaw, ul Mory 8
tel.fax: +48 22 836-73-35
tel. +48 22 345-13-86
http://www.iem.com.pl/enr

Page 1/9

TEST REPORT No. EUR/34/E/14-3 E

Current transformer type PA 145a with porcelain insulator
Serial No. 2GKF01.4A1287182

ER: ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

ED BY: ABB Sp. z o.o., ul. Żegalska 1, 04-713 Warszawa
order No. 4500574872 dated 22.07.2014

S: Mechanical tests

EDURE: According to IEC 61869-1:2007 p. 7.4.5

S: 22.08.2014

T: Positive for
 $F_R = 3600\text{ N}$

Tests result refers only to the test object

ERE
Y:

ngineer

[Signature]
czmarczyk

HEAD OF LABORATORY

[Signature]
Lidia Gruza



INSTITUTE OF POWER ENGINEERING
DISTRIBUTION EQUIPMENT LABORATORY

Test report No.
EUR/34/E/14-3 E
Page 2/9

Contents

1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	3
4. Tests and theirs detailed results	4
5. Test results evaluation	4
Annexes: 1. Photographs taken during the tests	5
2. Documentations delivered by orderer	8

[Handwritten signature]

Report contents:

numbered pages	9
tables	1
photographs	6

DESCRIPTION

transformer type PA 145a is used for supplying of measuring and protection circuits of maximum operating voltage 145 kV and frequency 50 Hz. The transformer current transformer mounted housing with porcelain insulator immersed with

TECHNICAL DATA

Manufacturer attributed the following construction data to the test object.

Operating voltage 145 kV
Frequency 50 Hz
Rated current 3600 N

REFERENCES

Technical documentation purpose of tests the orderer delivered the following technical documentation:
Drawing current instrument transformer PA 145a, No. 2GK6K612001, 11.09.2014,

transformer electrical diagram
3 Sp. z o.o. (Annex 2).

The test object proceeded the identification of test object on the base of above documentation and

TEST PREPARATION

The test object was prepared for test by factory.

TESTS

The tests, agreed with orderer, comprised the following tests according to requirements

according to IEC 61869-1:2007:
- static tests according to item 7.4.5 of above standard for $F_R = 3600$ N of P1 and P2 150 A

The results of tests of transformer shall be recorded.

MEASURING CIRCUITS

The measuring circuits of the transformer was fixed to the rigid construction of the test stand. The tests were performed applying the load consecutively to the transformer's P1 and P2 as shown on photographs in Annex 1.



4. TESTS AND THEIRS DETAILED RESULTS

Test results presents table 1. The load was increased and released smoothly (30 – 90 s) and was maintained 60 s.

During the tests the following records were made:

- phot. 1 to 6 - current transformer during mechanical tests.
- (Annex 1 presents the photographs)


Table 1. Results of static load withstand tests at $F = 3620$ N

Test No.	Terminal	Load direction	Test time s	Observations
1	P1	longitudinal	60	During the static load deflection was 9,0 mm. Residual deflection was 1,5 mm. After tests no damage nor oil leak was stated.
2	P1	transverse	60	During the static load deflection was 9,7 mm. Residual deflection was 1,6 mm. After tests no damage nor oil leak was stated.
3	P1	vertical	60	During the static load deflection was 3,2 mm. Residual deflection was 0,1 mm. After tests no damage nor oil leak was stated.
4	P2 150 A	longitudinal	60	During the static load deflection was 7,8 mm. Residual deflection was 1,1 mm. After tests no damage nor oil leak was stated.
5	P2 150 A	transverse	60	During the static load deflection was 9,0 mm. Residual deflection was 1,4 mm. After tests no damage nor oil leak was stated.
6	P2 150 A	vertical	60	During the static load deflection was 3,0 mm. Residual deflection was 0,2 mm. After tests no damage nor oil leak was stated.


5. TESTS RESULTS EVALUATION

According to criteria given in IEC 61869-1:2007 p. 7.4.5 the results of tests of tested current transformer is positive for:

$F_R = 3600$ N.




Phot. 3. Vertical load of terminal P1





Phot. 4. Longitudinal load of terminal P2 150 A

Photographs taken during the tests




Phot. 1. Longitudinal load of terminal P1





Phot. 5. Transverse load of terminal P2 150 A




Phot. 6. Vertical load of terminal P2 150 A



ANNEX 2

Documentations delivered by orderer





Instrument Transformer


Standard **PN-EN 61869-2** Type **PA 145a**
 Weight/Oil weight **420 / 120 kg** f_n **50 Hz**
 Temp. range **-40°C → +40°C**

Model **145I275/650 KV**
 Nytro Libra **KP014A1287182**

K_n **150-300/5-1-5-1** A/A
 I_{th}/I_S **20-20** I_{dyn} **60-60** kA
 I_{ctn} **180-360** A

A	VA	Class	FS/ALF	Ext.%
1S1-1S2	5	30	0,2	5
2S1-2S2	1	40	5P	20
3S1-3S2	5	60	5P	20
4S1-4S2	1	60	5P	20
5S1-5S2				
6S1-6S2				

Transportation Vertical / Horizontal



Instrument transformer electrical diagram

ATTENTION!
 1. HIGH VOLTAGE AT OPEN CURRENT SECONDARY TERMINALS XS1 - XS2
 2. DURING INSTRUMENT TRANSFORMER OPERATION TERMINAL Igδ MUST BE EARTHED

Small



TEST REPORT No. EUR/34/E/14-4 E

Current transformer type PA 145a with porcelain insulator
Serial No. 2GKP014A1287181

PREPARED BY: ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

ORDERED BY: ABB Sp. z o.o., ul. Żegalska 1, 04-713 Warszawa
order No. 4500574872 dated 22.07.2014

TEST TYPE: Mechanical tests

REFERENCE: According to IEC 61869-1:2007 p. 7.4.5

DATE: 27.08.2014

TEST RESULT: Positive for
 $F_R = 3600\text{ N}$

Tests result refers only to the test object

Contents

1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	3
4. Tests and theirs detailed results	4
5. Test results evaluation	4
Annexes: 1. Photographs taken during the tests	5
2. Documentations delivered by orderer	8

Report contents:

numbered pages	9
tables	1
photographs	6

HEAD OF LABORATORY

ew f. Klenin
Lidia Gruza

inrer

ymarczyk

SUBJECT

Description

transformer type PA 145a is used for supplying of measuring and protection circuits of maximum operating voltage 145 kV and frequency 50 Hz. The transformer current transformer mounted housing with porcelain insulator immersed with

Initial data

Manufacturer attributed the following construction data to the test object.

145 kV
50 Hz
3600 N

Initial documentation

Purpose of tests the orderer delivered the following technical documentation:
Drawing current instrument transformer PA 145a, No. 2GKK612003, 11.09.2019,
Transformer electrical diagram
Sp. z o.o. (Annex 2).

Preceded the identification of test object on the base of above documentation and

Preparation for tests

Test object was prepared for test by factory.

TESTS

Test program, agreed with orderer, comprised the following tests according to requirements

as acc. to item 7.4.5 of above standard for $F_R = 3600$ N of P1 and P2 600 A

Deflection of the transformer shall be recorded.

MEASURING CIRCUITS

The transformer was fixed to the rigid construction of the test stand. Measurements were performed applying the load consecutively to the transformer's P1 and as shown on photographs in Annex 1.



4. TESTS AND THEIRS DETAILED RESULTS

Test results presents table 1. The load was increased and released smoothly (30 – 90 s) and was maintained 60 s.

During the tests the following records were made:

- phot. 1 to 6 – current transformer during mechanical tests.
(Annex 1 presents the photographs)

Table 1. Results of static load withstand tests at $F = 3620$ N

Test No.	Terminal	Load direction	Test time s	Observations
1	P1	longitudinal	60	During the static load deflection was 7,5 mm. Residual deflection was 0,3 mm. After tests no damage nor oil leak was stated.
2	P1	transverse	60	During the static load deflection was 4,3 mm. Residual deflection was 0,8 mm. After tests no damage nor oil leak was stated.
3	P1	vertical	60	During the static load deflection was 3,1 mm. Residual deflection was 0,2 mm. After tests no damage nor oil leak was stated.
4	P2 600 A	longitudinal	60	During the static load deflection was 8,4 mm. Residual deflection was 0,7 mm. After tests no damage nor oil leak was stated.
5	P2 600 A	transverse	60	During the static load deflection was 9,2 mm. Residual deflection was 0,5 mm. After tests no damage nor oil leak was stated.
6	P2 600 A	vertical	60	During the static load deflection was 2,7 mm. Residual deflection was 0,2 mm. After tests no damage nor oil leak was stated.

5. TESTS RESULTS EVALUATION

According to criteria given in IEC 61869-1:2007 p. 7.4.5 the results of tests of tested current transformer is positive for:

$F_R = 3600$ N.




INSTITUTE OF POWER ENGINEERING
DISTRIBUTION EQUIPMENT LABORATORY


Test report No.
EUR/34/E/14-4 E
Page 6/9

Handwritten signature


Photographs taken during the tests




Phot. 1. Longitudinal load of terminal P1



Phot. 2. Transverse load of terminal P1



Phot. 3. Vertical load of terminal P1



Phot. 4. Longitudinal load of terminal P2 600 A




Instrument Transformer

Model	14S/27S/650 KV	Standard	IEC 61869-2	Type	PA 145a
Material	Nytrö Libra	Weight / Oil weight	420 / 120 kg	fn	50 Hz
Serial No.	SKP014A1287181	Temp. range	-40°C → +40°C		

K_n 300-600/5-5-1 A/A
 $I_{th}/1s$ 40-40 kA I_{dyn} 100-100 kA
 I_{cth} 450-900 A

A	VA	Class	FS/ALF	Ext.%
1S1-1S2	5	40	0,2	5
2S1-2S2	5	60	5P	20
3S1-3S2	1	120	10P	15
4S1-4S2				
5S1-5S2				
6S1-6S2				

Transportation Vertical Horizontal



Instrument transformer electrical diagram

- ATTENTION!**
- HIGH VOLTAGE AT OPEN CURRENT SECONDARY TERMINALS 3S1 - 3S2
 - DURING INSTRUMENT TRANSFORMER OPERATION TERMINAL tpe MUST BE EARTHED

Handwritten signature



TEST REPORT No. EUR/71/E/13-3 E

Combined instrument transformer type PVA 123a with composite insulator
Serial No. ZGKP013K1486138

ORDER: ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

ORDERED BY: Internal order No. EWN/145/E/13 dated 12.12.2013

OBJECT: Short-time current tests
Test for composite error
Short-circuit withstand capability test

REFERENCE: According to IEC 61869-2:2012 and IEC 61869-3:2011

DATE: 16/17.12.2013

TESTS: Positive for
 $I_{dyn} = 158 \text{ kA}$, $I_{th} = 63 \text{ kA}$, $t = 1 \text{ s}$ for 100 A terminal
 $I_{dyn} = 100 \text{ kA}$, $I_{th} = 40 \text{ kA}$, $t = 1 \text{ s}$ for 50 A terminal
63,5 kV at short-circuit in secondary circuits of VT

Tests result refers only to the test object

ENGINEER: M. Tarnowski, Z. Wesolowski – ABB Sp. z o.o.

HEAD OF LABORATORY

Lidia Gruza

Contents

1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	4
4. Tests and theirs detailed results	7
5. Test results evaluation	8
Annexes: 1. Short-circuit test records	9
2. Photographs taken during the tests	10
3. Routine test report before and after short-time current tests	11
4. Documentations delivered by orderer	28

Report contents:

numbered pages	30
records (pages not numbered)	3
tables	2
figures	2
photographs	1

SUBJECT
circuitor

ed instrument transformer type PVA 123a is used for supplying of measuring and its in the network of maximum operating voltage 126 kV and frequency 50 Hz. The consists of current and voltage transformers mounted in common housing with ator immersed with transformer oil.

Technical data

ufacturer attributed the following construction data to the test object.

ing voltage	126 kV
50 Hz	
50 A	100 A
100 A	200 A
40 kA	63 kA
100 kA	158 kA

is thermal current
current for 1 s
current

Technical documentation

e of tests the orderer delivered the following technical documentation:
wing combined transformer PVA 123a-145a, No. 2GKK.614122 (17.12.2013),
ort of combined instrument transformer (12.11.2013),
ort of combined instrument transformer after short-time current test (24.01.2013),

former electrical diagram
Sp. z.o.o (Annex 3 and 4).

ceeded the identification of test object on the base of above documentation and oniformity of manufacturing with constructional documentation is stated
claration, copy of which presents Annex 4.

Justification for tests

was prepared for tests in the factory by the manufacturer.

TESTS

agreed with orderer, comprised the following tests according to requirements of and IEC 61869-3:2011:

ant tests of current transformer acc. to item 7.2.201 of above standard at

$kA, I_{th} = 63 \text{ kA}, t_{th} = 1 \text{ s}, I_{th}^2 \times t_{th} \geq 3969 \text{ kA}^2 \times \text{s}$ for 100 A terminal.
 $kA, I_{th} = 40 \text{ kA}, t_{th} = 1 \text{ s}, I_{th}^2 \times t_{th} \geq 1600 \text{ kA}^2 \times \text{s}$ for 50 A terminal.

error acc. to item 7.2.203 of above standard with current's transformer burden nected to 4S1-4S2 windings at parameters:

$kA, t_{th} = 1 \text{ s}$ for 50 A terminal,
withstand capability test acc. to item 7.2.301 of above standards at parameters:
 $63,5 \text{ kV}, t_p = 1 \text{ s}.$

and after short-time current test made in factory.



3. TEST AND MEASURING CIRCUITS

For the tests the transformer was fixed to the rigid construction of the test stand. Short-time current tests and test for composite error were made in one-phase circuit presented on fig. 1 at dimensions presented on fig.2. Short-circuit withstand capability test were made in one phase circuit presented on fig. 3.

The following quantities were recorded during short-time current tests and test for composite error using digital recorder type HOKI 8842:

- primary current (with short-circuited all secondary terminals) during short-time current tests using laboratory current transformer type Cdc class 0,5 with a ratio 50.000/2 A/A (uncertainty of measurement $\pm 0,018\%$ for $k = 2$),
- secondary currents in -1S2, 3S1-3S2 and 4S1-4S2 windings by means of laboratory toroidal current transformers type IL20a class 0,5 with a ratio 1.000/5 A/A, 2.000/5 A/A and 5.000/5 A/A (uncertainty of measurement $\pm 0,012\%$ for $k = 2$),
- voltage drop (U_0) on test object during short-time current tests by means of a resistance-capacitance voltage divider with a bandwidth from 0 to 100 kHz.

The following quantities were recorded during short-circuit withstand capability tests using digital recorder type HOKI 8842:

- primary voltage and current, secondary current in short-circuited windings: 1a-1n (next 4a-4n and 6a-6n) during short-circuit withstand capability tests of voltage transformer using:
- inductive voltage transformer type U110a class 0,5 with a ratio 110/ $\sqrt{3}$ /0,1/ $\sqrt{3}$ kV/kV for primary voltage measurement,
- laboratory current transformer type GE 4461 class 0,2 with a ratio 5/5 A/A for primary current measurement (uncertainty of measurement $\pm 0,013\%$ for $k = 2$),
- laboratory current transformer type IL 20a class 0,5 with a ratio 2.000/5 A/A for secondary currents measurements (uncertainty of measurement $\pm 0,012\%$ for $k = 2$).






Fig. 1. Configuration of test circuit during tests during short-time current tests



Short-circuit transformer
Back-up circuit-breaker
Make switch
Current transformers
Voltage divider
Test object

Fig. 2. Test and measuring circuits during short-time current tests



WB110 - back-up circuit-breaker
PN - voltage transformer
PP1, PP2 - current transformers

Fig. 3. Test and measuring circuits during short-circuit withstand capability tests

AND THEIR DETAILED RESULTS

results presents tables 1, 2 and 3.
 the tests the following records were made:
 - Nos. 33089, 33090, 33092, 33093 - short-time current tests,
 - No. 33095 - composite error test,
 - No. 33096, 33097, 33098 - short-circuit withstand capability test,
 (Annex 1 presents the copies of short-circuit test records - all records
 are stored in laboratory's archives),
 - phot. 1, 2 - current transformer on the tests stand
 (Annex 2 presents the photograph).

ts of short-time current tests

I_x	t_x	$I_x^2 \times t_x$	I_{SI-1S2}	I_{SI-3S2}	I_{SI-4S2}	U_0	Observations
kA	s	(kA) ² ·s	A	A	A	V	
4,74	0,97	4066 ⁽²⁾	256*	1517*	649	38	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.
4,74	0,06	-	-	-	-	-	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.
0,54	0,08	-	-	-	-	-	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.
0,54	1,02	1676 ⁽⁴⁾	269*	1556*	811	60	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

of test current,
 e of test current (determined from test period without asymmetrical component),
 I_p - r.m.s. value of primary side test current,
 I_{ss} - r.m.s. value of secondary side test current,
 t_x - test duration
 U_0 - test voltage
 I_{ps} - r.m.s. value of primary side test current
 I_{ss} - r.m.s. value of secondary side test current
 t_x - test duration
 U_0 - test voltage
 I_{ps} - r.m.s. value of primary side test current
 I_{ss} - r.m.s. value of secondary side test current
 t_x - test duration
 U_0 - test voltage

During the composite error test current's transformer burden connected to 4S1-4S2 was 2,4 Ω.

Table 2. Results of composite error test for 4S1-4S2 winding

Test No.	I_p	ϵ_c	t_x	Observations
-	kA	%	s	
33095	4,31	0,98	1,02	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

Legend:
 I_p - r.m.s. value of the test current (determined from test period without asymmetrical component),
 t_x - test duration,
 $\epsilon_c = \frac{\sqrt{\frac{1}{T} \int_0^T (k_r \cdot i_s - i_p)^2 dt}}{I_p} \cdot 100\%$
 k_t - rated transformation ratio (30/1 A/A),
 i_p - instantaneous value of the primary current,
 i_s - instantaneous value of the secondary current,
 T - duration of one cycle.

Table 3. Results of short-circuit withstand capability tests

Test No.	Terminals	U_z	I_{ps}	I_{ss}	t_x	Observations
-	-	kV	A	A	s	
33096	1a - 1n	65,0 ⁽¹⁾	0,73	804	1,00	Behaviour of transformer during the tests was correct. After tests no damage nor oil leak was stated.
33097	4a - 4n	65,0 ⁽¹⁾	0,72	796	1,00	Behaviour of transformer during the tests was correct. After tests no damage nor oil leak was stated.
33098	da - dn	65,0 ⁽¹⁾	0,42	795	1,00	Behaviour of transformer during the tests was correct. After tests no damage nor oil leak was stated.

Legend:
 U_z - test voltage
 I_{ps} - r.m.s. value of primary side test current
 I_{ss} - r.m.s. value of secondary side test current
 t_x - test duration
 U_0 - required $U_0 \geq 63,5$ kV

5. TESTS RESULTS EVALUATION

According to criteria given in IEC 61869-2:2012 and IEC 61869-3:2011 the results of tests is positive for:


Test records



is not numbered pages the following copies of records are given:
33089, 33090, 33092, 33093 – short-time current tests,
33095 – composite error test,
33096, 33097, 33098 – short circuit withstand capability test.

is:



- in test object,
- winding current,
- winding current,
- winding current.



ring voltage transformer tests,
n primary side of VT,
test current on secondary side of VT.





23







low




ANNEX 2 Photographs taken during the tests



Phot. 1. PVA 123a after short-time current tests



Phot. 2. PVA 123a after short circuit withstand capability test.



Routine test report before and after short-time current tests

ip. z o.o. Pizaszysz szyno 59		Routine tests report of combined instrument transformer		TYP: PVA123a Nr fabr. 2GKP019K1466138	
Insulation level: 120/230/550 kV		Voltage factor: 1,8/2h		Ith1 [kA] 100-100-100	
Ith1 s [kA] 40-40-40		Ith2 [kA] 180-360-720		IEC 61869-4 50 Hz	
Winding	1a-3n	Uan [kV] 0,15-3	Sn [VA] 25	class 0,1	Sh [VA] 1000
	2a-2n	0,1-3	25	3,0	1000
3a-3n	0,1-3	25	0,1	1000	1000
	0,1-3	25	3,0	1000	1000
4a-4n	0,1-3	25	0,10P	1000	1000
	0,1-3	25	3,0P	1000	1000
5a-5n	0,1-3	25	0,10P	1000	1000
	0,1-3	25	3,0P	1000	1000
6a-6n	0,1-3	100	1	450	450
	0,1-3	300	3P	450	450
Winding	1S1-1S2	Ien [A] 1-5-6	class 0,6FS5	Pz [kVA]	
	2S1-2S2	1-2-5	0,6FS10	50-10-200/5	
3S1-3S2	5-10	5P 10	5P 10	50-10-200/1	
	4S1-4S2	2,5	6P40	50-10-200/5	
5S1-5S2	1	PX	PK	50-10-200/1	
	1	Ek=100V Ien=14,065 V Rct=0,3Ω Rc=3,6 Ω Rc=80 4-2-1200	Ek=100V Ien=14,065 V Rct=0,3Ω Rc=3,6 Ω Rc=80 4-2-1200	50-10-200/1	
6S1-6S2	1	TPX	TPX	50-10-200/1	
	1	Ksep=13 Ktd=14,6 cyl=0,16 T=0,05 Rct=0,3Ω Rb=1 Ω	Ksep=13 Ktd=14,6 cyl=0,16 T=0,05 Rct=0,3Ω Rb=1 Ω	50-10-200/1	
Ratio error <±0,5% 6P10		Ratio error <±0,5% 6P10			

- Tests**
- Parameters check before filling (oil after treatment)
 - 7. Breakdown voltage acc. IEC 60156
 - Thermal
 - Short-circuit test: oil overpressure: 0,8 bar / 24h - no traces of oil withstand on primary windings
 - PT+2VA Up=230 kV / 60 s, I=87 Hz; Ni; Up = 3 kV/60s, f=50 Hz
 - Withstand test on secondary
 - Voltage test for current transformers - lower value - Up = 3 kV/60 s
 - Errors
 - The over current factors FS, ALF
 - Capacitance and dielectric dissipation factor (tgδ)
 - Core magnetization characteristics
 - Winding resistance



Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tgs according to IEC 60247
Tgs = 0,06%; electrical stress = 1 kV/mm, f=50 Hz, Oil temp. = 80°C±1°C
- Measurement of breakdown voltage according to IEC 60156
Mean breakdown voltage = 77,42 kV, Relative standard deviation = 5,64%, f=50 Hz, oil temp. = 28 °C, measurement with the stirrer, type of electrodes used: partially spherical.

Sample	Breakdown voltage [kV]
1	83,2
2	80,1
3	70,8
4	79,2
5	76,4
6	74,8

Partial discharge measurement

- Measurement according to procedure A (PD test voltages were reached while decreasing the voltage after the power-frequency withstand test on primary winding)
- Stress voltage 230 kV / 60 s
- Frequency 87 Hz

Test voltage	1,2 Um = 151 kV	1,2 Um / √3 = 87,5 kV
Level of partial discharge	2 pC	1,5 pC

Remarks: background noise level: 1 (measured after voltage switch off), measuring circuit was calibrated with 5 pC (calibrating charge).

Inter-turn overvoltage test for current transformers

	Peak voltage on secondary winding [kV(peak)]	Current in primary winding [A]
1S1-1S2	0,088	400
2S1-2S2	0,307	400
3S1-3S2	0,205	400
4S1-4S2	1,41	400
5S1-5S2	0,736	400

INSTITUTE OF POWER ENGINEERING
DISTRIBUTION EQUIPMENT LABORATORY

Determination of voltage part errors (± U %) (App U min), $\cos \phi = 0,8$

Uznanje	U _{min} (U)	S _h (VA)	S _h (VA)
1a-1n	0,15	25	1000
2a-2n	0,15-3	25	1000
3a-3n	0,15-3	500	1000
4a-4n	0,15-3	25	1000
5a-5n	0,15-3	300	450

1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	
± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U
Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U
cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ

*) at 1,9 Un winding da-dn is loaded with S_n, cos φ = 0,8 ind.

INSTITUTE OF POWER ENGINEERING
DISTRIBUTION EQUIPMENT LABORATORY

Determination of voltage part errors (± U %) (App U min), $\cos \phi = 0,8$

Uznanje	U _{min} (U)	S _h (VA)	S _h (VA)
1a-1n	0,15	25	1000
2a-2n	0,15-3	25	1000
3a-3n	0,15-3	500	1000
4a-4n	0,15-3	25	1000
5a-5n	0,15-3	300	450

1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	1a-1n 25 VA	2a-2n 25 VA	3a-3n 500 VA	4a-4n 25 VA	
± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U	± U
Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U	Δp U
cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ	cos φ


*) Un winding da-dn is loaded with S_n, cos φ = 0,8 ind.



Handwritten signature


Winding 3S1-3S2

I _m	[mA]
22	2714.7
21.4	1328.1
20.6	814.6
19.2	555.1
17.8	444.8
16.5	388.7
15	348.4
13.8	329.9
12.3	297
10.9	288.9
9.6	243.4
6.7	186.1
4.1	130.9
1.2	51.58
0.2	13.46




ization characteristics:

-1S2	[mA]
5292	2108.3
135.6	55.41
42.87	35
28.78	20.73
12.12	3.25




Winding 4S1-4S2

I _m	[mA]
256.5	5777
251.1	1957.8
248.2	1141.9
241.4	449.8
234	217
229.3	168.1
220.8	123.9
207.3	100.74
184.2	90.53
178.1	81.76
152.6	72.53
109.8	58.59
67.7	43.23
25.2	23
1.8	4.79



-2S2	[mA]
224.3	224.3
13.6	3.1
6.71	3.58
4.58	4.49
2.87	3.93
1.19	1.19
0.66	0.66
1.75	1.75
0.93	0.93
0.23	0.23
0.32	0.32





INSTITUTE OF POWER ENGINEERING
DISTRIBUTION EQUIPMENT LABORATORY

Test report No.
EUR/71/E/13-3 E
Page 20/30

AME Sp. z o.o.

06 - 300 Przasnysz

ul. Leszno 59

Insulation level:
126230/650 kV

A - N

110-√3 kV

Routine tests report
of combined instrument transformer
after short time current test

TYP: PVA123a

Nr fabr. 2GKP013K1488138

10yn [VA]

100-158-153

Ictth [A]

100-200-400

IEC 61868-4

50 Hz

CZŁON NAPIĘCIOWY

Uzwojenie	U _{im} [kV]	S _{im} [VA]	Klasa	S _{th} [VA]
1a-1n	0,1-√3	25	0,1	1000
2a-2n	0,1-√3	25	3,0	1000
3a-3n	0,1-√3	25	0,1	1000
3a-3n	0,1-√3	25	3,0	1000
4a-4n	0,1-√3	25	0,1GP	1000
4a-4n	0,1-√3	25	3,0GP	1000
da-dn	0,1-√3	25	0,1GP	1000
da-dn	0,1-√3	25	3,0GP	1000
	0,1-√3	100	1	450
	0,1-√3	300	3P	450

CZŁON PRĄDOWY


Uzwojenie	I _{im} [A]	S _{im} [VA]	Klasa	Przebieżalność [A/A]
1S1-1S2	5	1-√6	0,5FS5	50-10-200/6
2S1-2S2	1	1-√2,5	0,5FS10	50-10-200/1
3S1-3S2	5	10	SP10	50-10-200/6
	1	2,5	SP80	50-10-200/1
	1		PK	50-10-200/1
			PK = 100V	
			I _{PK} = 0,4/86 V	
			R _{PK} = 0,2 Ω	
			R _{PK} = 3,5 Ω	
			K _{PK} = 50	
			4-2-1/200	
4S1-4S2	1		TPX	50-10-200/1
			K _{TPX} = 13	
			K _{TPX} = 14,6	
			T _{TPX} = 0,18	
			R _{TPX} = 0,05	
			R _{TPX} = 1 Ω	
			Ratio error = 0,5%	
			SP10	50-10-200/1

List of performer tests

- Oil dielectric parameters check before filling (oil after 10s wg IEC 60247, breakdown voltage acc. IEC 60158)
- Verification of terminal
- Pressure and tightness test: oil overpressure: 0,8 bar / 24h - no traces of oil
- Power-frequency withstand on primary windings
- P1+P2/U_p=230 kV / 60 s, f=50 Hz; N; U_p = 3 kV / 80s, f=50 Hz
- Partial discharge
- Power-frequency withstand test on secondary
- P1+P2/U_p=230 kV / 60 s, f=50 Hz; N; U_p = 3 kV / 80s, f=50 Hz
- Inter-turn overvoltage test for current transformers - lower value
(U_{szczyt} = 4,5 kV lub U_{szczyt} / 60s
- U_p = 3 kV / 80 s
- Determination of errors
- Determination of the over current factors: FS, ALF
- Measurement of capacitance and dielectric dissipation factor (tgδ)
- Determination of core magnetization characteristics
- Measurement of windings' resistance

INSTITUTE OF POWER ENGINEERING
DISTRIBUTION EQUIPMENT LABORATORY

Test report No.
EUR/71/E/13-3 E
Page 19/30



Measurement of windings' resistance

resistance of current part:

range	R (23°C)	R.ct (75°C)
range 50 A	266,0 μΩ	320,4 μΩ
range 100 A	100,0 μΩ	120,4 μΩ
range 200 A	47,0 μΩ	56,6 μΩ
1-1S2	0,048 Ω	0,058 Ω
1-2S2	0,527 Ω	0,635 Ω
1-3S2	0,024 Ω	0,028 Ω
4-S2	0,214 Ω	0,257 Ω
5-S2	0,315 Ω	0,380 Ω

resistance of voltage part:

	R (24,9°C)	R.ct (75°C)
-N	17,90 kΩ	20,835 kΩ
-1n	44,120 mΩ	53,138 mΩ
-2n	45,150 mΩ	54,377 mΩ
-3n	48,680 mΩ	56,220 mΩ
-4n	48,050 mΩ	57,689 mΩ
-dn	31,900 mΩ	38,419 mΩ

Przasnysz, 12.11.2013 r.

OG-4
16/406

Parameters check before filling (oil after treatment)

it of oil t₆₈ according to IEC 60247
5%; electrical stress = 1 kV/mm, f=50 Hz, Oil temp. = 90°C±1°C

it of breakdown voltage according to IEC 60156
breakdown voltage = 77.42 kV, Relative standard deviation = 5,84%; f=50 Hz,
°C, measurement with the stirrer, type of electrodes used; partially spherical.

Napiecie przebicia [kV]
83.2
80.1
70.8
79.2
76.4
74.8

Discharge measurement

ment according to procedure B
tage 230 kV / 60 s
y 97 Hz

1,2 Um = 151 kV	1,2 Um / √3 = 87,5 kV
1,2 pC	1,2 pC

background noise level: 1 (measured after voltage switch off),
g circuit was calibrated with 5 pC (calibrating charge).

on overvoltage test for current transformers

Winding	Peak voltage on secondary winding [kV/peak]	Current in primary winding [A]
1S1-1S2	0.09	400
2S1-2S2	0.3	400
3S1-3S2	0.192	400
4S1-4S2	1.31	400
5S1-5S2	0.704	400



Determination of voltage part errors (ε U %), (ε_{ap} U min), ε_{cos φ} = 0,8

Usewoltomierz	U _{min} [kV]	U _{max} [kV]	ε _{cos φ} [%]
1a-1n	0,1-1,3	25	1000
2a-2n	0,1-1,3	25	1000
3a-3n	0,1-1,3	25	1000
4a-4n	0,1-1,3	25	1000
5a-5n	0,1-1,3	25	1000

1a-1n 25 VA;	cos φ = 0,8 ind.	1a-1n 25 VA;	cos φ = 0,8 ind.
2a-2n 25 VA; 3a-3n 25 VA; 4a-4n 25 VA;	cos φ = 0,8 ind.	2a-2n 0 VA; 3a-3n 0 VA; 4a-4n 0 VA;	1,2 U _n
0,8 U _n	1,2 U _n	0,8 U _n	0,038
ε U	-0,034	ε U	0,038
ε U	2,1	ε U	3,5
ε U	2,2	ε U	3,5
1a-1n 6,25 VA;	cos φ = 0,8 ind.	1a-1n 6,25 VA;	cos φ = 0,8 ind.
2a-2n 25 VA; 3a-3n 25 VA; 4a-4n 25 VA;	cos φ = 0,8 ind.	2a-2n 0 VA; 3a-3n 0 VA; 4a-4n 0 VA;	1,2 U _n
0,8 U _n	1,2 U _n	0,8 U _n	0,075
ε U	0,005	ε U	0,075
ε U	2,1	ε U	3,5
ε U	2,1	ε U	3,5
2a-2n 25 VA;	cos φ = 0,8 ind.	2a-2n 25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 3a-3n 25 VA; 4a-4n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 3a-3n 0 VA; 4a-4n 0 VA;	1,2 U _n
0,8 U _n	1,2 U _n	0,8 U _n	0,042
ε U	-0,028	ε U	0,042
ε U	2,3	ε U	3,8
ε U	2,3	ε U	3,8
2a-2n 6,25 VA;	cos φ = 0,8 ind.	2a-2n 6,25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 3a-3n 25 VA; 4a-4n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 3a-3n 0 VA; 4a-4n 0 VA;	1,2 U _n
0,8 U _n	1,2 U _n	0,8 U _n	0,061
ε U	0,009	ε U	0,061
ε U	2,1	ε U	3,5
ε U	2,2	ε U	3,5
3a-3n 25 VA;	cos φ = 0,8 ind.	3a-3n 25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 2a-2n 25 VA; 4a-4n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 2a-2n 0 VA; 4a-4n 0 VA;	1,2 U _n
0,02 U _n	1,2 U _n	0,02 U _n	0,035
ε U	-0,167	ε U	-0,087
ε U	-0,167	ε U	-1,5
ε U	2,4	ε U	3,7
ε U	2,4	ε U	3,7
3a-3n 6,25 VA;	cos φ = 0,8 ind.	3a-3n 6,25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 2a-2n 25 VA; 4a-4n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 2a-2n 0 VA; 4a-4n 0 VA;	1,2 U _n
0,02 U _n	1,2 U _n	0,02 U _n	0,095
ε U	-0,120	ε U	-0,052
ε U	-0,120	ε U	-1,7
ε U	2,2	ε U	3,5
ε U	2,2	ε U	3,5
4a-4n 25 VA;	cos φ = 0,8 ind.	4a-4n 25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 2a-2n 25 VA; 3a-3n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 2a-2n 0 VA; 3a-3n 0 VA;	1,0 U _n
0,02 U _n	1,2 U _n	0,02 U _n	0,035
ε U	-0,178	ε U	-0,111
ε U	-0,178	ε U	-1,3
ε U	2,7	ε U	4,0
ε U	2,7	ε U	4,0
4a-4n 6,25 VA;	cos φ = 0,8 ind.	4a-4n 6,25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 2a-2n 25 VA; 3a-3n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 2a-2n 0 VA; 3a-3n 0 VA;	1,0 U _n
0,02 U _n	1,2 U _n	0,02 U _n	0,05 U _n
ε U	-0,122	ε U	-0,089
ε U	-0,122	ε U	-0,709
ε U	2,3	ε U	3,8
ε U	2,3	ε U	3,8
4a-4n 100 VA; cos φ = 0,8 ind.	4a-4n 25 VA;	4a-4n 25 VA;	cos φ = 0,8 ind.
1a-1n 25 VA; 2a-2n 25 VA; 3a-3n 25 VA;	cos φ = 0,8 ind.	1a-1n 0 VA; 2a-2n 0 VA; 3a-3n 0 VA;	1,0 U _n
0,03 U _n	1,2 U _n	0,03 U _n	0,304
ε U	-0,741	ε U	-0,738
ε U	8,9	ε U	5,2
ε U	8,9	ε U	5,2

*) at 1,8 Un winding 4a-4n is loaded with Sn, cos φ = 0,8 ind.

Measurement of current part errors (e I %), (Δp I min),

In	151-152 5 VA; $\cos\phi = 0.8$			151-152 1 VA; $\cos\phi = 0.8$		
	0.2 In	1.0 In	2.0 In	0.05 In	0.2 In	1.0 In
5	-0.363	-0.232	0.132	0.295	0.300	0.315
6	17.3	7.5	-1.1	13.2	6.8	4.9
7	3.1	3.1	3.1	3.1	3.1	3.1

In	251-252 2.5 VA; $\cos\phi = 1$			251-252 1 VA; $\cos\phi = 1$		
	0.2 In	1.0 In	2.0 In	0.05 In	0.2 In	1.0 In
5	0.035	0.008	0.193	0.254	0.241	0.276
6	32.6	22.0	7.0	18.7	12.7	5.8
7	3.1	3.1	3.1	3.1	3.1	3.1

In	451-452		
	1.0 In	e I	Δp I
5	1.0 In	-0.391	14.5
6	1.0 In	-0.391	14.5

In	151-152 5 VA; $\cos\phi = 0.8$			151-152 1 VA; $\cos\phi = 0.8$		
	0.2 In	1.0 In	2.0 In	0.05 In	0.2 In	1.0 In
5	-0.243	-0.129	0.152	0.305	0.317	0.334
6	17.0	8.3	-0.8	26.3	8.9	4.9
7	3.1	3.1	3.1	3.1	3.1	3.1

In	251-252 2.5 VA; $\cos\phi = 1$			251-252 1 VA; $\cos\phi = 1$		
	0.2 In	1.0 In	2.0 In	0.05 In	0.2 In	1.0 In
5	0.027	0.009	0.137	0.251	0.237	0.272
6	22.5	7.1	4.0	19.0	13.5	6.1
7	3.0	3.0	3.0	3.0	3.0	3.0

In	451-452		
	1.0 In	e I	Δp I
5	1.0 In	-0.391	14.5
6	1.0 In	-0.391	14.5

In	151-152 5 VA; $\cos\phi = 0.8$			151-152 1 VA; $\cos\phi = 0.8$		
	0.2 In	1.0 In	2.0 In	0.05 In	0.2 In	1.0 In
5	-0.316	-0.063	0.068	0.168	0.277	0.280
6	11.4	2.9	-1.4	21.6	12.4	7.8
7	6.3	6.3	6.3	6.3	6.3	6.3

In	251-252 2.5 VA; $\cos\phi = 1$			251-252 1 VA; $\cos\phi = 1$		
	0.2 In	1.0 In	2.0 In	0.05 In	0.2 In	1.0 In
5	0.039	0.143	0.194	0.249	0.251	0.279
6	19.1	6.4	4.0	19.0	12.4	5.7
7	3.3	3.3	3.3	3.3	3.3	3.3

In	451-452		
	1.0 In	e I	Δp I
5	1.0 In	-0.392	14.5
6	1.0 In	-0.392	14.5



Current part: Measurements uncertainty: $\epsilon I = \pm 0.045\%$, $\Delta p I = \pm 2.3$ min
Voltage part: Measurements uncertainty: $\epsilon U = \pm 0.044\%$, $\Delta p U = \pm 2.2$ min
Determination of the over current factors:

- Instrument security factor (FS) of measuring cores

Winding	Ia [A]	U [V]	Ers [V]	Condition	Assessment
1S1-1S2	2.5	4.29	6.22	U < E _{rs}	☑
2S1-2S2	1	9.64	31.28	U < E _{rs}	☑

- accuracy limit factor (ALF) - test for composite error ϵ_a of protective cores

Winding	E _{ALF} [V]	Ia [A]	ϵ_a [%]	Warning	Assessment
3S1-3S2	21.14	1.156	2.31	$\epsilon_a < 5\%$	☑
4S1-4S2	220.32	0.127	0.16	$\epsilon_a < 5\%$	☑
5S1-5S2	53.95	0.129	1.28	$\epsilon_a < 5\%$	☑

Determination of parameters of class PX core 4S1-4S2:


Item (A)	50	100
Factor Kx	54.93	54.94
Turns ratio error [%]	-0.007	-0.003

Determination of parameters of class TPX core 4S1-4S2:

Item (A)	50	100
Factor Ksc	13.91	13.91
Factor Ktd	14.46	14.46
Current ratio error [%]	-0.225	-0.230
Ta [s]	5.438	5.517
e-peak [%]	1.530	1.528


Measurement of capacitance and dielectric dissipation factor (tg δ)
Temperature: 22,3 °C, Frequency: 50 Hz

Primary voltage	Instrument transformer			Current part			Voltage part		
	Tg δ [%]	Capacity [pF]	Leak current [mA]	Tg δ [%]	Capacity [pF]	Leak current [mA]	Tg δ [%]	Capacity [pF]	Leak current [mA]
10 kV	0.23	1378	4.32	0.24	1111	3.459	0.22	266	0.833
63 kV	0.23	1378	27.22	0.24	1112	21.93	0.22	266	5.252
71 kV	0.23	1378	30.77	0.24	1112	24.82	0.22	266	5.939



Winding 3S1-3S2

I _V	[mA]
22.4	4318.6
21.9	2020.1
21.0	1039.6
19.8	697.5
18.2	472.7
16.9	411.5
15.3	366.6
14.0	333.9
12.7	305.3
11.3	276.6
9.7	245.5
7.0	192.1
4.0	128.2
1.3	58.24
0.2	15.55




Winding 4S1-4S2

I _V	[mA]
256.9	6035
252.7	2439.3
248.4	1129.5
243.5	554.3
228.8	165.1
223.8	137.5
215.6	113.2
202.1	97.48
185.6	85.34
171.9	76.69
158.4	73.91
114.0	58.23
70.8	42.85
26.9	23.1
2.7	5.8


Handwritten signature

ization characteristics:



1S2

I _V	[mA]
251.1	1146.5
251.1	291.1
61.75	43.85
35.91	28.93
20.93	12.27
2.41	0.34




2S2

I _V	[mA]
371.9	196.7
17.91	7.12
8.63	1.18
8.3	8.3
7.18	7.18
6.44	6.44
5.79	5.79
4.92	4.92
3.98	3.98
2.9	2.9
1.28	1.28
0.34	0.34



1-552
1mA
044,4
543,8
257,8
883,6
159,5
141,4
21,5
09,27
01,74
8,35
2,18
6,62
8,89
9,35
1,95



Measurement of windings' resistance

resistance of current part

range 50 A	R (23°C)	R ct (75°C)
range 100 A	278,0 µΩ	383,7 µΩ
range 200 A	119,0 µΩ	142,9 µΩ
1-1-7S2	68,0 µΩ	78,2 µΩ
1-1-2S2	0,048 Ω	0,057 Ω
1-1-3S2	0,623 Ω	0,628 Ω
1-1-3S2	0,023 Ω	0,028 Ω
1-4S2	0,212 Ω	0,254 Ω
1-5S2	0,313 Ω	0,376 Ω

resistance of voltage part

range 50 A	R (23°C)	R ct (75°C)
range 100 A	17,30 kΩ	20,787 kΩ
range 200 A	44,080 MΩ	52,891 MΩ
1-1-7S2	44,860 MΩ	53,971 MΩ
1-1-2S2	48,480 MΩ	55,772 MΩ
1-1-3S2	47,940 MΩ	57,569 MΩ
1-4S2	31,500 MΩ	37,954 MΩ



Przasnysz, 24.01.2014 r.

ANNEX 4 Documentations delivered by orderer

ABB ABB Sp. z o.o.	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
DECLARATION OF CONFORMITY No. 001/2014 (EN) (acc. to ISO/IEC 17050-1)		
Manufacturer:	ABB Sp. z o.o. Dept. in Przasnysz	
Address:	Str. Leszno 59 06-300 Przasnysz / POLAND	
Product:	Combined Instrument Transformer PVA 123a	
Above mentioned product conforms with the following standard :		
Standard	Title	Edition/Date
IEC 61869 - 4	Combined Instrument Transformers	2013
Additional information:		
Serial numbers: 2GKP013K1486138;		
Place and date of issue of declaration		
Przasnysz, 13.01.2014		
Referent do: Referencja/Zainteresowany	ABB Sp. z o.o.	ABB Sp. z o.o.
Osoba w Przasnyszu	Osoba w Przasnyszu	Osoba w Przasnyszu
Małgorzata	Małgorzata	Małgorzata
(Name)	(Name)	(Signature)

ABB
ABB Sp. z o.o.
ul. Zagajnikowa 1, 04-713 Warszawa
NIP: 698-030-44-54; PL 6280334484
REGON: 140077188
KRS: 0000438154
ul. Leszno 59, 06-300 Przasnysz
tel. (22) 223 8021, fax (22) 223 8058

Osoba w Przasnyszu
Małgorzata
(Name)

Osoba w Przasnyszu
Małgorzata
(Signature)



TEST REPORT No. EUR/74/E/13 E

Combined instrument transformer type PVA 145a with porcelain insulator
Serial No. 2GKP013K1486140

FR: ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

D BY: Internal order No. EWN/145/E/13 dated 09.12.2013

: Short-time current tests
Test for composite error

URE: According to IEC 61869-2:2012

S: 10/11.12.2013

: Positive for
 $I_{sp} = 158 \text{ kA}$, $I_{th} = 63 \text{ kA}$, $t = 1 \text{ s}$ for 1000 A terminal

Tests result refers only to the test object

RE
Z: M. Tarnowski, Z. Wesołowski – ABB Sp. z o.o.

HEAD OF LABORATORY

Lidia Gruza

ineer

zmarczyk

Contents

1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	3
4. Tests and theirs detailed results	5
5. Test results evaluation	6
Annexes: 1. Short-circuit test records	7
2. Photographs taken during the tests	8
3. Routine test report before and after short-time current tests	9
4. Documentations delivered by orderer	28

Report contents:

numbered pages	30
records (pages not numbered)	3
tables	2
figures	2
photographs	1




Fig. 2. Configuration of test circuit during tests

THEIR DETAILED RESULTS

... presents tables 1 and 2.
 tests the following records were made:
 o. 33059 - calibration of measuring and test circuit,
 o.s. 33061, 33063 - short-time current tests,
 o. 33067 - composite error test,
 (Annex 1 presents the copies of short-circuit test records - all records
 are stored in laboratory's archives).
 phot. 1 - current transformer on short-circuit tests stand
 (Annex 2 presents the photograph).

z	t _z	I _z ² × t _z	I _{1S1-1S2}	I _{4S1-4S2}	I _{5S1-5S2}	U ₀	Observations
A	s	(kA) ² × s	A	A	A	V	
22	0,06	-	-	-	-	-	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.
22	1,00	4124 ⁽²⁾	329	-	64	33	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

of test current,
 of test current (determined from test period without asymmetrical component),
 (determined from test period without asymmetrical component),
 (determined from test period without asymmetrical component),
 (determined from test period without asymmetrical component),
 (determined from test period without asymmetrical component).
 158 kA,

During the composite error test current's transformer burden connected to 6S1-6S2 was 10,3 Ω.

Table 2. Results of composite error test for 6S1-6S2 winding

Test No.	I _p kA	ε _c %	t _z s	Observations
33067	20,34	1,81	1,00	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

Legend:
 I_p - r.m.s. value of the test current (determined from test period without asymmetrical component),
 t_z - test duration,

$$\epsilon_c = \frac{\int_0^T (i_s \cdot i_p - i_p^2) dt}{I_p^2} \cdot 100\%$$

 k_r - rated transformation ratio (10000/1 A/A),
 i_p - instantaneous value of the primary current,
 i_s - instantaneous value of the secondary current,
 T - duration of one cycle.

5. TESTS RESULTS EVALUATION

According to criteria given in IEC 61869-2:2012 the results of tests is positive for:
 I_{dyn} = 158 kA, I_{th} = 63 kA, t = 1 s for 1000 A terminal of tested combined instrument transformer.


(Handwritten signature)

Test records



As not numbered pages the following copies of records are given:
 33061, 33063 – short-time current tests,
 33067 – composite error test.

ZIE:


- on test object,*
- winding current,*
- winding current,*
- winding current,*
- winding current.*



100V



Photographs taken during the tests



Phot. 1. PVA 145a after short-time current tests

ANNEX 3

Routine test report before and after short-time current tests

AMS Sp. z o.o. 06 - 300 Przasnysz ul. Leszno 59		Routine tests report of combined instrument transformer			TYP: PVA145a Nr fabr. 2GXP013K1486140	
A - N 132-√3 kV	Insulation level: 14527/5850 kV	Voltage factor: 1,9 /Rn	Ith 1 s [kA] 63-63	I90m [kA] 159-159	Icth [kA] 1200-2400	IEC 61868-4 50 Hz
VOLTAGE PART						
Winding 1b-1n 2a-2n 3a-3n 4a-4n da-dn	Um [kV] 0,11-0,3 0,11-0,3 0,11-0,3 0,11-0,3 0,11-0,3 0,11-0,3	Sn [VA] 25 25 25 25 25 25	class 0,2 3,0 0,2 3,0 0,2 3,0	I90m [kA] 159-159	Icth [kA] 1200-2400	5th [VA] 1000
						1000
						1000
						1000
						1000
CURRENT PART						
Winding 5S1-5S2 3S1-3S2 4S1-4S2 6S1-6S2	Ith [A] 5 1 6 5 1	Sn [VA] 100 70 35 15 10	class 0,2FS10 0,1FS5 0,1FS5 SF 60 PX EK = 250V Ith = 0,1A / 125 Rct = 7Ω Rb = 1 Ω TTPV K _{max} = 15 K _{th} = 13 C _{th} = 0,1s T _{th} = 0,05 s P _{th} = 2,0 K _s = 10%	Ratio 1000-2000/5 1000-2000/1 1000-2000/5 1000-2000/5 1000-2000/5 1000-2000/1	IEC 61868-4 50 Hz	1000-2000/1
						1000-2000/1
						1000-2000/1
						1000-2000/1
						1000-2000/1

List of performer tests

- Oil dielectric parameters check before filling (oil after 1g8 wg IEC 60247, breakdown voltage acc. IEC 60156)
- Verification of terminals
- Pressure and tightness test: oil overpressure: 0,8 bar / 24h - no traces of oil
- Power-frequency withstand on primary windings
- P1+P2/A; Up=275 kV / 80 s; f=67 Hz; N; Up = 3 kV/60s, f=60 Hz
- Partial discharge
- Power-frequency withstand test on secondary
- Up = 3 kV/80 s

ilt factor (ALF) – test for composite error ϵ_c of protective cores

E_{ALF} [V]	I_e [A]	ϵ_a [%]	Condition	Assessment
	0.02	0.1	$\epsilon_a < 5\%$	<input checked="" type="checkbox"/>
363.35	0.123	0.04	$\epsilon_a < 5\%$	<input checked="" type="checkbox"/>
877.45	1.298	4.33	$\epsilon_a < 5\%$	<input checked="" type="checkbox"/>
	0.227	1.14	$\epsilon_c < 5\%$	<input checked="" type="checkbox"/>

1 of parameters of class PX: core 4S1-4S2

	1000	2000
	38.39	37.18

1 of parameters of class TPY core 5S1-5S2:

	1000	2000
	15.78	15.41
	12.78	12.75
	0	0
er [%]	-0.164	-0.167
	0.4445	0.4358
	9.44	9.67



1 of parameters of class PXR core 6S1-6S2:

	1000	2000
	28.69	28.68
	3	3

of capacitance and dielectric dissipation factor (fig 5)
22,3 °C, Frequency: 50 Hz

s	Instrument transformer			Voltage part		
	Capacity [pF]	Leak current [mA]	Tg δ [%]	Capacity [pF]	Leak current [mA]	Capacity [pF]
1	1418	4.464	0.25	1141	3.587	276
4	1418	27.97	0.24	1141	22.51	276
4	1418	31.67	0.24	1142	25.51	276

Core magnetization characteristics:



z.z.o.o. Przasnysz
z.z.p. 59
145276/650 kV

**Routine tests report
of combined instrument transformer
after short time current test**

TYP: PVA145a
Nr fabr. 2GKP013K1486140

IEC 61869-4
50 Hz

- 5. Partial discharge
- 6. Power-frequency withstand test on secondary
- 7. Inter-turn overvoltage test for current transformers - lower value (U accyt. = 4,5 kV/ub U accyt. Przy lech) / 60a
- 8. Determination of errors
- 9. Determination of the over current factors; FS.
- 10. Measurement of capacitance and dielectric dissipation factor (tgδ)
- 11. Determination of core magnetization characteristics
- 12. Measurement of windings' resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tgδ according to IEC 60247
Tgδ = 0,06%, electrical stress = 1 kV/mm, f=50 Hz, Oil temp. = 90°C±1°C

- Measurement of breakdown voltage according to IEC 60156
Mean breakdown voltage = 77,42 kV, Relative standard deviation = 5,64%, f=50 Hz, oil temp. = 26 °C, measurement with the stirrer, type of electrodes used: partially spherical.

Sample	Breakdown voltage [kV]
1	83,2
2	80,1
3	70,6
4	79,2
5	76,4
6	74,3

Partial discharge measurement

- Measurement according to procedure B
Stress voltage 247,5 kV / 60 s
Frequency 87 Hz

Test voltage	1,2 Um = 174 kV	1,2 Um / √3 = 100,5 kV
Level of partial discharge	1,8 pC	1,2 pC

Remarks: background noise level: 1 (measured after voltage switch off), measuring circuit was calibrated with 5 pC (calibrating charge).

Winding	1S1-1S2	2S1-2S2	3S1-3S2	4S1-4S2
Ratio [A/A]	1000-2000/1	1000-2000/1	1000-2000/1	1000-2000/1

Inter-turn overvoltage test for current transformers

Winding	Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]
1S1-1S2	4,5	2050
2S1-2S2	4,5	400
3S1-3S2	4,5	135
4S1-4S2	4,5	1100
6S1-6S2	1,47	2400
6S1-6S2	4,5	1750

z.z.o.o. Przasnysz
z.z.p. 59
145276/650 kV

**Routine tests report
of combined instrument transformer
after short time current test**

TYP: PVA145a
Nr fabr. 2GKP013K1486140

IEC 61869-4
50 Hz

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tgδ according to IEC 60247
Tgδ = 0,06%, electrical stress = 1 kV/mm, f=50 Hz, Oil temp. = 90°C±1°C

- Measurement of breakdown voltage according to IEC 60156
Mean breakdown voltage = 77,42 kV, Relative standard deviation = 5,64%, f=50 Hz, oil temp. = 26 °C, measurement with the stirrer, type of electrodes used: partially spherical.

Partial discharge measurement

- Measurement according to procedure B
Stress voltage 247,5 kV / 60 s
Frequency 87 Hz

Test voltage	1,2 Um = 174 kV	1,2 Um / √3 = 100,5 kV
Level of partial discharge	1,8 pC	1,2 pC

Remarks: background noise level: 1 (measured after voltage switch off), measuring circuit was calibrated with 5 pC (calibrating charge).

Inter-turn overvoltage test for current transformers

Winding	Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]
1S1-1S2	4,5	2050
2S1-2S2	4,5	400
3S1-3S2	4,5	135
4S1-4S2	4,5	1100
6S1-6S2	1,47	2400
6S1-6S2	4,5	1750

z.z.o.o. Przasnysz
z.z.p. 59
145276/650 kV

**Routine tests report
of combined instrument transformer
after short time current test**

TYP: PVA145a
Nr fabr. 2GKP013K1486140

IEC 61869-4
50 Hz

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tgδ according to IEC 60247
Tgδ = 0,06%, electrical stress = 1 kV/mm, f=50 Hz, Oil temp. = 90°C±1°C

- Measurement of breakdown voltage according to IEC 60156
Mean breakdown voltage = 77,42 kV, Relative standard deviation = 5,64%, f=50 Hz, oil temp. = 26 °C, measurement with the stirrer, type of electrodes used: partially spherical.

Partial discharge measurement

- Measurement according to procedure B
Stress voltage 247,5 kV / 60 s
Frequency 87 Hz

Test voltage	1,2 Um = 174 kV	1,2 Um / √3 = 100,5 kV
Level of partial discharge	1,8 pC	1,2 pC

Remarks: background noise level: 1 (measured after voltage switch off), measuring circuit was calibrated with 5 pC (calibrating charge).

Inter-turn overvoltage test for current transformers

Winding	Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]
1S1-1S2	4,5	2050
2S1-2S2	4,5	400
3S1-3S2	4,5	135
4S1-4S2	4,5	1100
6S1-6S2	1,47	2400
6S1-6S2	4,5	1750



- accuracy limit factor (ALF) – test for composite error ϵ_c of protective cores

of current part errors (ϵ %), ($\Delta\phi$ I min),

100 VA:	cos ϕ = 0,8		1S1-1S2: 25 VA:		1,0 In		cos ϕ = 0,8
0,2 In	1,2 In	0,05 In	0,2 In	1,0 In	1,0 In	1,2 In	0,152
-0,135	-0,014	-0,011	0,068	0,148	0,148	0,152	1,5
4,9	1,9	1,7	3,1	1,6	1,6	1,5	
70 VA:	cos ϕ = 0,8		2S1-2S2: 17,50 VA:		1,0 In		cos ϕ = 0,8
0,2 In	1,0 In	1,2 In	0,05 In	0,2 In	1,0 In	1,2 In	0,027
-0,053	-0,008	-0,013	0,019	0,010	0,023	0,027	0,0
0,4	-0,6	-0,2	0,6	0,7	0,1	0,0	
A	cos ϕ = 0,8		4S1-4S2: 16 VA		1,0 In		cos ϕ = 0,8
	ϵ I	-0,034					
	$\Delta\phi$ I	0,6					
A	cos ϕ = 0,8		6S1-6S2: 15 VA		1,0 In		cos ϕ = 0,8
	ϵ I	-0,015					
	$\Delta\phi$ I	14,9					

100 VA:	cos ϕ = 0,8		1S1-1S2: 25 VA:		1,0 In		cos ϕ = 0,8
0,2 In	1,0 In	1,2 In	0,05 In	0,2 In	1,0 In	1,2 In	0,151
-0,136	-0,018	-0,005	0,068	0,147	0,147	0,151	1,5
4,9	1,8	1,6	3,1	1,6	1,6	1,5	
70 VA:	cos ϕ = 0,8		2S1-2S2: 17,50 VA:		1,0 In		cos ϕ = 0,8
0,2 In	1,0 In	1,2 In	0,05 In	0,2 In	1,0 In	1,2 In	0,027
-0,053	-0,008	-0,004	0,021	0,012	0,024	0,027	-0,1
0,4	-0,6	-0,7	0,5	0,5	-0,1	-0,1	
A	cos ϕ = 0,8		4S1-4S2: 15 VA		1,0 In		cos ϕ = 0,8
	ϵ I	-0,035					
	$\Delta\phi$ I	0,6					
A	cos ϕ = 0,8		6S1-6S2: 15 VA		1,0 In		cos ϕ = 0,8
	ϵ I	-0,020					
	$\Delta\phi$ I	14,9					

Measurements uncertainty: ϵ I = $\pm 0,045$ %, $\Delta\phi$ I = $\pm 2,3$ min
Measurements uncertainty: ϵ U = $\pm 0,044$ %, $\Delta\phi$ U = $\pm 2,2$ min

of the over current factors:

security factor (FS) of measuring cores

I_0	U	E_{FS}	E_{FS}	Condition	Assessment
[A]	[M]	[M]	[M]	U < E _{FS}	<input checked="" type="checkbox"/>
5	153,46	422,08	422,08	U < E _{FS}	<input checked="" type="checkbox"/>
0,5	157,29	530,14	530,14	U < E _{FS}	<input checked="" type="checkbox"/>

5020

Uzwojenia	E _{ALF} [M]	I ₀ [A]	ϵ_c [%]	Condition	Assessment
3S1-3S2	363,63	0,123	0,1	ϵ_c < 5%	<input checked="" type="checkbox"/>
4S1-4S2	1,296	0,087	0,04	ϵ_c < 5%	<input checked="" type="checkbox"/>
5S1-5S2	876,63	0,087	0,49	ϵ_c < 5%	<input checked="" type="checkbox"/>
6S1-6S2				ϵ_c < 5%	<input checked="" type="checkbox"/>

Determination of parameters of class PX core 4S1-4S2:

4S1-4S2	1000	2000
Ion (A)	1000	38,67
factor Kx		38,64

Determination of parameters of class TPY core 5S1-5S2:


Ion (A)	1000	2000
factor Kssc	15,81	15,81
factor Ksd	12,78	12,78
factor Kd	0	0
factor Kr [%]	-0,124	-0,127
Blad przekadni [pradowe] [%]	0,4452	0,4453
Ts [s]	9,423	9,421
r-piek [%]		

Determination of parameters of class PXR core 6S1-6S2:

Ion (A)	1000	2000
factor Kx	28,84	26,64
factor Kr [%]	3	3

Measurement of capacitance and dielectric dissipation factor (tg δ)
Temperature: 22,3 °C, Frequency: 50 Hz

Primary voltage	Instrument transformer			Current part			Voltage part		
	Tg δ [%]	Capacity [pF]	Leak current [mA]	Tg δ [%]	Capacity [pF]	Leak current [mA]	Tg δ [%]	Capacity [pF]	Leak current [mA]
10 kV	0,23	1417	4,448	0,24	1140	3,585	0,22	276	0,868
63 kV	0,23	1417	28,01	0,24	1141	22,57	0,22	276	5,468
71 kV	0,23	1417	31,75	0,24	1141	25,54	0,22	276	6,195



Measurement of windings' resistance

Windings' resistance of current part:


	R (23°C)	R ct (75°C)
P1-P2 zakres 1000 A	145.0 μΩ	173.5 μΩ
P1-P2 zakres 2000 A	77.0 μΩ	92.1 μΩ
1S1-1S2	0.455 Ω	0.544 Ω
2S1-2S2	8.200 Ω	7.418 Ω
3S1-3S2	3.352 Ω	4.011 Ω
4S1-4S2	0.395 Ω	0.473 Ω
5S1-5S2	3.710 Ω	4.439 Ω
6S1-6S2	3.909 Ω	4.677 Ω

Windings' resistance of voltage part:

	R (24.9°C)	R ct (75°C)
A-N	21.60 kΩ	25.944 kΩ
1a-1n	48.940 mΩ	56.164 mΩ
2a-2n	48.610 mΩ	56.162 mΩ
3a-3n	49.980 mΩ	58.741 mΩ
4a-4n	51.500 mΩ	61.620 mΩ
Da-dn	113.700 mΩ	136.042 mΩ

Przasnysz. 20.12.2013 r.

Checked by: *[Signature]*
 OGA
 KJ-006



2	
---	--

Documentations delivered by orderer

ABB ABB Sp. z o.o.	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
------------------------------	---------------------------	--

DECLARATION OF CONFORMITY No. 093/2013 (EN)
 (acc. to ISO/IEC 17050-1)

Manufacturer: **ABB Sp. z o.o. Dept. in Przasnysz**

Address: **Str. Leszno 59
 06-300 Przasnysz / POLAND**

Product: **Combined Instrument Transformer PVA 145a**

The mentioned product conforms with the following standard :

Standard: **61869 - 4 Combined Instrument Transformers** Edition/Date **2013**

Additional information:
 Serial numbers: **26KFP013K1486140;**


Signature and date of issue of declaration

Przasnysz 13.01.2014

ABB
 ul. Zagajnikowa 11, 06-300 Przasnysz
 NIP: 525-024-11-74, REGON: 141303044-4
 Region 010017168
ODDZIAŁ W PRZASNYSZU
 ul. Leszno 59, 06-300 Przasnysz
 tel. (22) 225 0021, fax.(22) 323 0056

Wzrost: ...
 Data: ...
 Podpis: ...
 Imię: ...

(Name) (Signature)



BB

ded Instrument Transformer | Type **PVA 145a**

el **145/275/650 kV** | Standard **IEC 61869-4** | In **50 Hz**

Nyro Libra | Weight / Oil weight **620 / 150 kg** | Temp. range **-50°C → +40°C**

2013K1486140 | Voltage factor **1.9U_N/8h** | U₀ **0.2 mV/kA**

CURRENT PART | **VOLTAGE PART**

0-2000 / 5-1-1-5-1-1 | A/A | A-N | 132:√3 | kV

- 63 | kA | I_{dyn} | 158 - 158 | kA

- 2400 | A

VVA	Kclass	FSALF	Ext. %
100	0.2	10	120
70	0.1	5	120
35	5P	20	-
15	6P	60	-


Rb=10, Minia PX, E₀=250V, I₀=0.1 A, R_{ct}=7Ω
 Rb=20, Minia PXY 15x13, R_{ct}=7Ω, T_p=650 ms,
 cycle 100 ms, T_p=50 ms

10 VA, Minia SFR20, R_{ct}= 8 Ω
 Rb=20Ω, Minia PXR, 2-1/2000, E₀=500 V,
 I₀=0.1 A / 250 V, R_{ct}= 5Ω, K₀=20

1a-1n	2a-2n	3a-3n	4a-4n	da-dn
V	110:√3	110:√3	110:√3	110
VA	25	25	25	150
Kclass	0.2	0.2	0.2	3.6P
VA	(25)	(25)	(500)	(400)
V _{lim}	(3)	(3)	(3.6P)	(3P)
	1000	1000	1000	450

Transportation | Vertical/Horizontal

Handwritten signature



Instrument transformer electrical diagram



Instytut Elektrotechniki Electrotechnical Institute



BIURO INSTYTUTU ELEKTROTECHNIKI
APARATURY ROZDZIELCZEJ
03 WARSZAWA

+48 22 812 04 07

It is accredited by Polish Centre of Accreditation,
signature of EA ML.A. No. AB 074

Table of contents

1	List of applicable standards.....	3
2	Range of tests performed.....	3
3	Ratings assigned by the manufacturer.....	4
4	Short-time current test.....	5
5	Photographs.....	15
6	Drawings.....	16
7	Uncertainty electrical and non electrical quantities in laboratory.....	18
8	Annex A – Routine test report of current instrument transformer before short-time current test.....	19
9	Annex B – Routine test report of current instrument transformer after short-time current test.....	24

TEST REPORT No. 8596/ANZL/NBR/15

Current transformer
PA 145a

ABB Sp. z o.o.
ul. Leszno 59, 06-300 Przasnysz

ABB Sp. z o.o.
ul. Leszno 59, 06-300 Przasnysz

Short-time current tests

PN-EN 61869-2:2013-06

504-021300/038

23 January 2015 r.

POSITIVE

Handwritten signature

Head of Laboratories of the
Electrotechnical Institute

Handwritten signature

Robert Franaszek, M.Sc.

WARSAW, 11.02.2015

to the apparatus tested. The responsibility for conformity of any apparatus having the same designators
Manufacturer,
of this Test Report is permitted without written permission from Laboratory.

prints in total.



able standards

- 9-1:2009 Instrument transformers – Part 1: General requirements
- 59-2:2013-06 Instrument transformers – Part 2: Additional requirements for current
- 2001 Current transformers. General specifications¹

performed

urrent test by PN-EN 61869-2:2013-06 clause 7.2.201

3 Ratings assigned by the manufacturer

Test object: Current transformer
 Type: PA 145a
 Manufacturer: ABB Sp. z o.o., ul. Leszno 59, 06-500 Przasnysz
 Serial No.: 2GKFP014A1287155
 Year of manufacture: 2014
 Rating plate: Figure 1, page 16
 Design documentation:
 1. Dimensional drawing No. 2GKA612004
 2. Drawing of current circuit No. 2GKK314159A0001
 3. Routine test report of current instrument transformer before short-time current test – type: PA 145a, No. 2GKFP014A1287155; ABB Sp. z o.o., Przasnysz, 17.12.2014
 4. Routine test report of current instrument transformer after short-time current test – type: PA 145a, No. 2GKFP014A1287155; ABB Sp. z o.o., Przasnysz, 30.01.2015

Rated primary current..... I_N1500 – 3000 A
 Rated continuous thermal current..... I_{ca}1800 – 3000 A
 Rated frequency..... f50 Hz
 Highest system voltage..... U_m145 kV
 Rated power-frequency withstand voltage.....275 kV
 Rated lightning-impulse withstand voltage.....650 kV
 Rated short-time thermal current..... I_{th}63 – 63 kA
 Rated dynamic current..... I_{dyn}158 – 158 kA
 Rated duration of short circuit..... t_k1 s

Detailed list of components specified in technical project:

1. Dimensional drawing No. 2GKA612004
2. Drawing of current circuit No. 2GKK314159A0001



Dynamic test at dynamic current 158 kA

Test objectCurrent transformer PA 145a
 Primary current range:1500 A
 Condition of test object before test:.....New
 Date of test:.....23 January 2015 r.
 Ambient temperature:.....2°C

Expected current parameters:

- Test peak current I_p158 kA
 - Duration of short-circuit t_k0.06 s
- Phot. 1, page 15

Test object on testing stand:Table 1, page 6, Osc. 90065, page 10
 Test results:.....
 Scaling oscillogram:Osc. 90064, str. 9

Table 1 Test results

Oscillogram No.	90065
Symmetrical current (r.m.s)	76,6 kA
Peak value of current	161,3 kA
Duration	61,8 ms

Condition of tested object after the test:


No deterioration and failure was noted.

Test result: Object passed the test

mas

Current test

ing to PN-EN 61869-2:2013-06 clause. 7.2.201.



Sch. 1 Test circuit

MB	Master Breaker	MS	Making Switch
R	Resistor	PT	Power Transformer
Uz	Voltage Measurement	TO	Tested Object

-283 MVA
-4,5 kV
-63 kA
-71 mΩ
-50 Hz

dition:Earthed by 700 Ω
 erator:.....Insulated
 t-circuit point:.....

dynamic current 100 kA

Test object: Current transformer PA 145a
 Primary current range:1500 A
 Condition of test object before test:After dynamic test
 Date of test:23 January 2015 r.
 Ambient temperature:2°C
 Expected current parameters:
 • Test current: I_k100 kA
 • Duration of short-circuit: t_k0,06 s
 Test object on testing stand:Phot. 1, page 15
 Test results:Table 2, page 7, Osc. 90066, page 11
 Scaling oscillogram:Table 3, page 7, Osc. 90067, page 12
Table 4, page 7, Osc. 90069, page 13
Osc. 90064, page 9

Table 2 Test results 1

Oscillogram No.	90066
Symmetrical current (r.m.s)	48,0 kA
Peak value of current	101,2 kA
Duration	61,8 ms

Table 3 Test results 2

Oscillogram No.	90067
Symmetrical current (r.m.s)	48,1 kA
Peak value of current	101,3 kA
Duration	61,3 ms

Table 4 Test results 3

Oscillogram No.	90069
Symmetrical current (r.m.s)	47,6 kA
Peak value of current	101,39 kA
Duration	81,7 ms

Condition of tested object after the test:
 No deterioration and failure was noted.

Test result: Object passed the test



Thermal test at thermal current 63 kA

Test object: Current transformer PA 145a
 Primary current range:1500 A
 Condition of test object before test:After dynamic tests
 Date of test:23 January 2015 r.
 Ambient temperature:2°C
 Expected current parameters:
 • Test current: I_k63 kA
 • Duration of short-circuit: t_k1 s
 Test object on testing stand:Phot. 1, page 15
 Test results:Table 5, page 8, Osc. 90071, page 14
 Scaling oscillogram:Osc. 90064, page 9

Table 5 Test results

Oscillogram No.	90071
Symmetrical current (r.m.s)	63,2 kA
Peak value of current	124,1 kA
Voltage on primary terminals P1-P2	24,54 V
Duration	1,23 s
Integral $\int i dt$	4,93 GA's

Condition of tested object after the test:
 No deterioration and failure was noted.


Test result: Object passed the test

Current transformer complies with the requirements of:


- short-time current test at thermal current 63 kA/1 s and at dynamic current 158 kA
- short-time current test at thermal current 40 kA/3 s and 3 dynamic tests at dynamic current 100 kA.



Handwritten signature

Current transformer PA 14Sa - dynamic test




Current transformer PA 14Sa - calibration






W

Current transformer PA 145a - thermal test




Current transformer PA 145a - dynamic test






6 Drawings



Phot. 1 Test object on short-time current testing stand



ABB

Current Transformer

Insulation level	145/275/650 kV	Standard	PN-EN 61869-2
Oil type	Nyto Libra	Weight/Oil weight	360 / 120 kg
S/N	2SKP014A1287155	Temp. range	-40°C → +40°C

Type	PA 145a
K_n	1500-3000/5-1-5-1-1 A/A
$I_{br}/1s$	63-63 kA
I_{dyn}	156-158 kA
I_{th}	1800-3000 A

A	VA	Class	FS/ALF	Ext. %
5S1-4S2	5	200	0,2	10
2S1-2S2	1	100	0,1	5
5S1-3S2	5	20	5P	60
4S1-4S2	1	35	10P	40
5S1-5S2				
6S1-6S2				

Transportation Vertical / Horizontal

Figure 1 Rating plate

Routine test report of current instrument transformer before short-time current test

Op. z o.o. Pracownia Przemysłowa Pracownia 59	Routine test report of current instrument transformer		TYPE: PA145a
	Serial no: 2GKP014A1287155		
Idyn [A]: 158-158	Idch [A]: 1800-3600	PN-EN 61869-2	50 Hz
Isn [A]	Sn [VA]	class	Ratio [A/A]
5	200	0,2FS 10	1500-3000/5
1	100	0,1FS 5	1500-3000/1
5	20	5P 60	1500-3000/5
1	35	10P 40	1500-3000/1

Notes:
 - random check before filling (oil after treatment):
 80247, breakdown voltage acc. IEC 60758
 - minimal markings
 - physical test of overpressure: 0,8 bar / 24h - no traces of oil leakage
 - withstand test
 - measurement
 - P1+P2: Up = 230kV / 60s, f = 50Hz
 - Up = 3 kV/60s, f=50Hz
 - lower value (U peak=4,5kV or U peak for Icb) /
 - the over current factors: FS, ALF
 - core magnetization characteristics
 - windings' resistance
 - core check before filling (oil after treatment)
 - according to IEC
 - electrical stress = 1kV/mm, f = 50Hz, oil temp. = 80C
 - breakdown voltage according to IEC 60158
 - voltage = 76.27 kV, Relative standard deviation = 5.37
 - 25.4 °C, measurement without the slirer, type of electrodes used: partially spherical.

77.7	
77.9	
72.7	
83.2	
70.4	
75.7	



Partial discharge measurement

- Measurement according to procedure A (PD test voltages were reached while decreasing the voltage after the power-frequency withstand test on primary winding)
 Stress voltage: 275 kV / 60 s
 Frequency: 50 Hz

Test voltage	1,2 Um = 174 kV	1,2 Um / √3 = 100,5 k
Level of partial discharge	1 pC	0,9 pC

Remarks: background noise level: 0,7 (measured after voltage switch off), measuring circuit was calibrated with 5 pC (calibrating)

Inter-turn overvoltage test

Winding	Peak voltage on secondary winding [kV/peak]	Current in primary winding [A]
1S1-1S2	4,5	1450
2S1-2S2	4,5	350
3S1-3S2	4,5	1000
4S1-4S2	3,24	3600

Determination of errors ϵ (%), $\Delta\phi$ (min)

Ipn (A): 1500			1S1-1S2: 60 VA			1S1-1S2: 60 VA		
ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.
0,05	1,0	0,8	0,05	1,2	0,8	0,2	1,0	1,2
-0,313	-0,147	-0,032	-0,056	0,046	0,082	0,058	0,046	0,082
6,3	3,1	1,0	0,7	3,9	1,8	0,9	0,9	0,8
Ipn (A): 3000			2S1-2S2: 25 VA			2S1-2S2: 25 VA		
ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.
0,05	1,0	0,8	0,05	1,2	0,8	0,2	1,0	1,2
-0,058	-0,003	-0,003	0,015	0,014	0,018	0,015	0,014	0,018
1,3	0,3	-0,4	0,3	0,2	0,0	0,2	0,2	0,0
Ipn (A): 1500			3S1-3S2: 20 VA			3S1-3S2: 20 VA		
ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.
1,0	1,0	0,8	1,0	1,0	0,8	1,0	1,0	0,8
-0,016	-0,016	-0,016	-1,323	-1,323	-1,323	63,5	63,5	63,5
0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3
Ipn (A): 3000			4S1-4S2: 35 VA			4S1-4S2: 35 VA		
ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.	ϵ (%)	$\Delta\phi$ (min)	p.f.
1,0	1,0	0,8	1,0	1,0	0,8	1,0	1,0	0,8
-0,016	-0,016	-0,016	-1,323	-1,323	-1,323	63,5	63,5	63,5
0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3	0,3

Measurements uncertainty: ϵ (%) = ± 0,045 %, $\Delta\phi$ (min) = ± 2,3 min

Determination of the over current factors:

- instrument security factor (FS) of measuring cores

Winding	I ₀ [A]	U [V]	EPS [V]	Condition	Assessment
1S1-1S2	5	233,67	422,08	U < EPS	☑
2S1-2S2	0,5	227	528,03	U < EPS	☑


factor (ALF) - test for composite error ϵ_c of protective cores

EALF [V]	I ₀ [A]	ϵ_c [%]	Condition	Assessment
430.12	0.047	0.02	$\epsilon_c \leq 5\%$	<input checked="" type="checkbox"/>
1825.88	0.889	2.25	$\epsilon_c \leq 10\%$	<input checked="" type="checkbox"/>
	0.242		$\epsilon_c \leq$	

capacitance and dielectric dissipation factor - tg δ


Tg δ [%]	Capacitance [pF]	Leak current [mA]
0.24	1124	3.575
0.24	1125	28.87
0.24	1125	28.73

Characteristics:



Winding 2S1-2S2

[V]	[mA]
228.5	645.1
205.2	3.9
191.8	2.07
186.3	1.89
183	1.77
179.4	1.63
178	1.43
172.8	1.35
169.3	1.21
162.7	1.55
133.6	0.77
102.3	0.44
87.3	0.33
32	0.21
5	0.08




Winding 3S1-3S2

[V]	[mA]
525.1	9728
523.8	8209
520.3	4890.4
518.7	3801.5
506.4	1070.4
474.3	140.39
459.1	78.03
442.6	53.68
404.7	34.65
368	28.14
330.8	24.88
293.8	21.8
182.3	14.74
69.5	7.21
5.8	1.01

Handwritten signature

[mA]	
612.2	
715	
869.8	
821.3	
958.3	
1207	
88.8	
832	
32.1	
48	
80	
8.28	
9.83	
1.7	
23	



*) Average rectifier effective value.

Windings' resistance	R (23 °C)	Ret (75 °C)
A	63.0 μΩ	75.9 μΩ
A	26.0 μΩ	31.3 μΩ
	0.452 Ω	0.545 Ω
	5.330 Ω	6.419 Ω
	0.560 Ω	0.711 Ω
	5.650 Ω	6.805 Ω

Przasnysz

OG-1
K-21

9 Annex B - Routine test report of current instrument transformer after short-time current test

ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 59		Routine test report of current instrument transformer After short time current test		TYPE: PA145a Serial no: 2GKP014A1287155	
Ith 1s [kA]: 63-63	IcIn [kA]: 158-158	IcIn [A]: 1800-3600	PN-EN 61869-2	50 Hz	
Winding	Icn [A]	Sn [VA]	class	Ratio [kVA]	
1S1-1S2	5	200	0.2FS 10	1500-3000/5	
2S1-2S2	1	100	0.1FS 5	1500-3000/1	
3S1-3S2	5	20	5P 60	1500-3000/5	
4S1-4S2	1	35	10P 40	1500-3000/1	

List of performed tests:

- Oil dielectric parameters check before filling (oil after treatment):
to 8 acc. IEC 60247, breakdown voltage acc. IEC 60168
- Verification of terminal
- Pressure and tightness test: oil overpressure: 0.8 bar/ 24h - no traces of oil leakage
- Power-frequency withstand on primary winding
- Partial discharge
- Power-frequency withstand test on secondary
- Intra-turn overvoltage
- Determination of errors
- Determination of the over current factors: FS, ALF
- Measurement of capacitance and dielectric dissipation factor - tgδ
- Determination of core magnetization characteristics
- Measurement of windings' resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tg δ according to IEC
Tg δ = 0.1983 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C
- Measurement of breakdown voltage according to IEC 60156
Mean breakdown voltage = 76.27 kV, Relative standard deviation = 5.37
f = 50Hz, oil temp. = 25.4 °C, measurement without the stirrer, type of electrodes used: partially spherical.

Sample	Breakdown voltage [kV]
1	77.7
2	77.8
3	72.7
4	83.2
5	70.4
6	75.7



- accuracy limit factor (ALF) - test for composite error ϵ_c of protective cores

Winding	EALF [V]	Ic [A]	ϵ_c [%]	Condition	Assessment
3S1-3S2	430.4	0.047	0.02	$\epsilon_c \leq 5\%$	<input checked="" type="checkbox"/>
4S1-4S2	1626.33	0.898	2.24	$\epsilon_c \leq 10\%$	<input checked="" type="checkbox"/>

Measurement of capacitance and dielectric dissipation factor - Iq, δ


Temperature: 22.6 °C, Frequency: 50

Primary voltage	Iq, δ [%]	Capacitance [pF]	Leak current [mA]
10 kV	0.24	1127	3.592
76 kV	0.24	1128	28.0
84 kV	0.24	1128	28.78

Core magnetization characteristics:

Winding 1S1-1S2

[V]	[mA]
234.6	6267
233.4	4553
231.2	2625.9
227.9	1811.7
218.5	321.59
208.8	133.29
203.6	90.28
184.7	44.86
166	33.81
147.4	28.87
128.7	25.04
91	18.62
53.6	12.97
16	5.53
2.4	1.5



Measurement

according to procedure B

7.5 kV / 60 s

Winding	1.2 Um / 174 kV	1.2 Um / $\sqrt{3}$ = 100.5 k	1 pC
1st discharge	1.1 pC	1 pC	1 pC

Mid noise level: 0.7 (measured after voltage switch off), is calibrated with 5 pC (calibrating)

Peak voltage on secondary winding [kV/peak]	Current in primary winding [A]
4.5	1450
4.5	350
4.5	890
3.18	3600

errors ϵ (%), $\Delta\phi$ (mIn)

Winding	1S1-1S2: 50 VA	2S1-2S2: 25 VA	4S1-4S2: 35 VA
ϵ	0.05 in	0.2 in	1.0 in
$\Delta\phi$	0.041	0.045	0.088
$\Delta\phi$	0.7	1.7	0.8
ϵ	0.05 in	0.2 in	1.0 in
$\Delta\phi$	0.014	0.011	0.012
$\Delta\phi$	0.3	0.3	0.2
ϵ	0.05 in	0.2 in	1.2 in
$\Delta\phi$	0.014	0.011	0.010
$\Delta\phi$	0.3	0.3	0.3
ϵ	1.0 in	1.0 in	1.0 in
$\Delta\phi$	69.2	69.2	69.2

Winding	1S1-1S2	2S1-2S2	4S1-4S2
ϵ	0.05 in	0.2 in	1.0 in
$\Delta\phi$	0.041	0.045	0.088
$\Delta\phi$	0.7	1.7	0.8

Winding	1S1-1S2	2S1-2S2	4S1-4S2
ϵ	0.05 in	0.2 in	1.0 in
$\Delta\phi$	0.014	0.011	0.010
$\Delta\phi$	0.3	0.3	0.3

Uncertainty: $\epsilon_1 = \pm 0.045\%$, $\Delta\phi_1 = \pm 2.3$ mIn


over current factors:

uncertainty factor (FS) of measuring cores


Ic [A]	U [V]	Eps [V]	Condition	Assessment
5	233.75	422.57	U < Eps	<input checked="" type="checkbox"/>
0.5	227	526.81	U < Eps	<input checked="" type="checkbox"/>



[mA]
810.7
3.78
2.08
2
1.84
1.89
1.55
1.47
1.31
1.63
1.73
1.42
1.32
2.2
.04



[A]
98.7
19.7
11.3
7.7
0.8
8.2
2.7
1.3
1.7
1.1
.8
35
81
17
2



*) Average rectifier effective value.

Diodes' resistance

R (22 °C)	R _{eff} (75 °C)
63.0 μΩ	76.1 μΩ
26.0 μΩ	31.4 μΩ

1S1-1S2	0.460 Ω	0.555 Ω
2S1-2S2	5.470 Ω	6.609 Ω
3S1-3S2	0.689 Ω	0.712 Ω
4S1-4S2	5.640 Ω	6.815 Ω
5S1-5S2	6.120 Ω	7.395 Ω

Checked by: *GASIN*

Przasnysz, 2016-01-30

TEST REPORT No. EUR/71/E/13-4 E

Object: Combined instrument transformer type PVA 145a with composite insulator
 Serial No. 2GKFP013K1486145/13

ORDERER: ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

DATE: Internal order No. EWN/145/E/13 dated 12.12.2013

TESTS: Short-time current tests
 Test for composite error


REFERENCE: According to IEC 61869-2:2012

DATE: 18/19.12.2013


TEST: Positive for
 $I_{dyn} = 50 \text{ kA}$, $I_{th} = 20 \text{ kA}$, $t = 1 \text{ s}$ for 150 A terminal

Tests result refers only to the test object

ENGINEER: Z. Wesolowski – ABB Sp. z o.o.

Engineer

 Licia Gruza

HEAD OF LABORATORY



Licia Gruza

Warsaw 15.01.2014

Contents	Page
1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	3
4. Tests and theirs detailed results	5
5. Test results evaluation	6
Annexes: 1. Short-circuit test records	7
2. Photographs taken during the tests	8
3. Routine test report before and after short-time current tests	9
4. Documentations delivered by orderer	21



Report contents:

numbered pages	23
records (pages not numbered)	3
tables	2
figures	2
photographs	1

OBJECT

Description

ned instrument transformer type PVA 145a is used for supplying of measuring and units in the network of maximum operating voltage 145 kV and frequency 50 Hz. The consists of current and voltage transformers mounted in common housing with alator immersed with transformer oil.

Technical data

manufacturer attributed the following construction data to the test object.

rating voltage	145 kV
frequency	50 Hz
nominal current	180 A, 360 A
short-circuit current for 1 s	20 kA
short-circuit current	50 kA

Technical documentation

list of tests the orderer delivered the following technical documentation:
drawing combined transformer PVA 123a-145a, No. 20RKK614123 (17.12.2013),
report of combined instrument transformer (04.12.2013),
report of combined instrument transformer after short-time current test (03.01.2014),

Transformer electrical diagram

BB Sp. z o.o (Annex 3 and 4).
proceeded the identification of test object on the base of above documentation and
Conformity of manufacturing with constructional documentation is stated
's declaration, copy of which presents Annex 4.

Preparation for tests

test was prepared for tests in the factory by the manufacturer.

TESTS

agreed with orderer, comprised the following tests according to requirements of 12.2:

short-circuit tests of current transformer acc. to item 7.2.201 of above standard at 0 kA, $I_{sc} = 20 \text{ kA}$, $t_{sc} = 1 \text{ s}$, $I_{sc}^2 \times t_{sc} \geq 400 \text{ kA}^2\text{-s}$ for 150 A terminal.

Short-circuit error acc. to item 7.2.6.203 of above standard with current's transformer burden connected to 3S1-3S2 windings at parameters:

$I_{sc} = 20 \text{ kA}$, $t_{sc} = 1 \text{ s}$ for 150 A terminal,


before and after short-time current test made in factory.



3. TEST AND MEASURING CIRCUITS

For the tests the transformer was fixed to the rigid construction of the test stand. Short-time current tests and test for composite error were made in one-phase circuit presented on fig. 1 at dimensions presented on fig.2.

- primary current (with short-circuited all secondary terminals) during short-time current tests using laboratory current transformer type CdC class 0,5 with a ratio 50.000/2 A/A (uncertainty of measurement $\pm 0,018\%$ for $k = 2$),
- secondary currents in 1S1-1S2, 3S1-3S2, 4S1-4S2 windings by means of laboratory toroidal current transformers type IL20a class 0,5 with a ratio 1.000/5 A/A and 2.000/5 A/A (uncertainty of measurement $\pm 0,012\%$ for $k = 2$),
- voltage drop (U_0) on test object during short-time current tests by means of a resistance-capacitance voltage divider with a bandwidth from 0 to 100 kHz.






Fig. 2. Configuration of test circuit during tests

THEIR DETAILED RESULTS

... presents tables 1 and 2.
 ... tests the following records were made:
 Nos. 33101, 33104 - calibration of measuring and test circuit,
 Nos. 33102, 33103 - short-time current tests,
 No. 33105 - composite error test.
 (Annex 1 presents the copies of short-circuit test records - all records
 are stored in laboratory's archives).
 Phot. 1 - current transformer on short-circuit tests stand
 (Annex 2 presents the photograph).

t_z	t_e	$I_z^2 \times t_z$	I_{S1-S2}	I_{S1-S2}	I_{S1-S2}	U_0	Observations
A	s	(kA) ² xs	A	A	A	V	-
31	0,06	-	-	-	-	-	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.
31	1,02	420,7 ²	232*	618	127	201	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

of test current,
 of test current (determined from test period without asymmetrical component),
 I_p
 I_e (determined from test period without asymmetrical component),
 I_e (determined from test period without asymmetrical component),
 I_e (determined from test period without asymmetrical component),
 I_e (determined from test period without asymmetrical component).
 > 50 kA,

During the composite error test current's transformer burden connected to 3S1-3S2 was 2,4 Ω.

Table 2. Results of composite error test for 3S1-3S2 winding

Test No.	I_p	ϵ_c	t_z	Observations
-	kA	%	s	-
33105	3,02	0,71	1,00	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

Legend:
 I_p - r.m.s. value of the test current (determined from test period without asymmetrical component),
 t_z - test duration,

$$\epsilon_c = \frac{\int_0^T (k_e \cdot i_e - i_p)^2 dt}{\int_0^T i_p^2 dt} \cdot 100\%$$

 k_e - rated transformation ratio (150/5 A/A),
 i_p - instantaneous value of the primary current,
 i_e - instantaneous value of the secondary current,
 T - duration of one cycle.

5. TESTS RESULTS EVALUATION

According to criteria given in IEC 61869-2:2012 the results of tests is positive for:

$I_{S1-S2} = 50$ kA, $I_{S1} = 20$ kA, $t = 1$ s for 150 A terminal of tested combined instrument transformer.

Handwritten signature

Test records

As not numbered pages the following copies of records are given:



- 33102, 33103 – short-time current tests,
- 33105 – composite error test.

ions:

- p on test object,
- 2 winding current,
- 2 winding current,
- 2 winding current.




Max





Photographs taken during the tests



Phot. I. PVA 145a after short-time current tests

ANNEX 3

Routine test report before and after short-time current tests

ABB Sp. z o.o. 06-300 Przasnysz ul. Leśna 59		Routine tests report of combined instrument transformer		TYPE: PVA145a
A-N	Insulation level: 132-16 kV / 145/275/650 kV	10yn [kV]: 20-20	10yn [kV]: 50-50	Serial no: 26KPO13K1486145
	1,9/8h	Voltage factor: 20-20	10yn [kV]: 50-50	10yn [kV]: 225-450
VOLTAGE PART				
	Winding	U _{1n} [kV]	S _n [VA]	class
	1a - 1n	0,11-√3	100	1,0
	2a - 2n	0,11-√3	100	1,0
	3a - 3n	0,11-√3	100	1,0
	4a - 4n	0,11-√3	100	1,0
	da - dn	0,11-√3	100	1,0
	da - dn	0,11-√3	200	3,0
	da - dn	0,11-√3	400	4,0
CURRENT PART				
	Winding	I _{1n} [A]	S _n [VA]	class
	1S1-1S2	5	30	0,2FS 5
	2S1-2S2	1	40	5P 20
	3S1-3S2	5	60	5P 20
	4S1-4S2	1	60	5P 20
				Ratio [kVA]
				150-300/5
				150-300/1
				150-300/5
				150-300/1

List of performed tests:

- Oil dielectric parameters check before filling (oil after treatment):
to § acc. IEC 60247; breakdown voltage acc. IEC 60166
- Verification of terminal
- Pressure and tightness test; oil overpressure: 0,8 bar / 24h; - no traces of oil
- Power-frequency withstand on primary windings
- P1+P2/Δ; U_p = 275kV / 60s, f = 50Hz; N: U_p = 3kV / 60s, f = 60Hz
- Partial discharge
- Power-frequency withstand test on secondary
- Inter-turn overvoltage test for current transformers
- Determination of errors
- Determination of the core current factors: FS
- Measurement of capacitance and dielectric dissipation factor - to §
- Determination of core magnetization characteristics
- Measurement of winding resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil to § 6 according to IEC
- T₀ § = 0,08 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C

- Measurement of breakdown voltage according to IEC 60158
- Mean breakdown voltage = 78,15 kV, Relative standard deviation = 5,89
- f = 50Hz, oil temp. = 25 °C, measurement with the oilmer; type of electrodes used: partially

Sample	Breakdown voltage [kV]
1	73,7
2	84,3
3	82,8
4	78,4
5	76,9
6	72,5



Frequency measurement

According to procedure A, (PD test voltages were reached while decreasing the on-frequency withstand test on primary

ing: 275 kV / 80 s

Test voltage	1,2 Un = 174 kV	1,2 Un f ₀ = 108,5
of partial discharge	2 pC	1,2 pC

background noise level: 1 (measured after voltage switch off), result was calibrated with 5 pC (combining

rvoltage test for current transformers

A	Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]	on of voltage part errors (c U%), Δp U min)	
			p.f. = 0,8 lag.	p.f. = 0,8 lag.
1	0,368	450	± 1,0 Un	± 1,0 Un
2	4,28	450	± 1,0 Un	± 1,0 Un
3	1,09	450	± 1,0 Un	± 1,0 Un
4	4,5	310	± 1,0 Un	± 1,0 Un

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2	0,283	0,285	0,285	0,285
3	-1,3	-1,3	5,1	5,2
4	-0,162	-0,162	0,118	0,118
5	-1,3	-1,3	5,1	5,2

1	1,0 Un	1,2 Un	1,0 Un	1,2 Un
2				

352	278.66	0.097	0.1	$\pm 5.5\%$	<input checked="" type="checkbox"/>
452	1308.83	0.015	0.08	$\pm 5.5\%$	<input checked="" type="checkbox"/>

ent of capacitance and dielectric dissipation factor - δ
 at: 24.2 °C, Frequency: 60

Insulating transformer				Current part				Voltage part			
Tg δ	Capacity [pF]	Leak.current [mA]	Tg δ [%]	Capacity [pF]	Leak.current [mA]	Tg δ [%]	Capacity [pF]	Leak.current [mA]	Tg δ [%]	Capacity [pF]	Leak.current [mA]
0.23	1404	4.389	0.24	1129	3.672	0.23	275	0.862	0.23	278	5.46
0.23	1404	27.03	0.24	1129	22.34	0.22	278	5.46	0.22	278	6.106

ization characteristics:









ABB Sp. z o.o. 06-300 Przasnysz ul. Leżnisko 59 132-13 kV / 146275/660 kV 1.910h		Routine tests report of combined instrument transformer After short time current test		TYPE: PVA/145a Serial no: 26KFP03K1486145 IEC 61869-4 50 Hz	
A-N	Insulation level: 132-13 kV / 146275/660 kV 1.910h	Voltage factor: 20-20	I _{th} I _s [kA]: 20-20	I ₀ [mA]: 50-50	IEC 61869-4 50 Hz
VOLTAGE PART					
Winding	U _{res} [kV]	S _n [VA]	class	S _{th} [VA]	
1s - 1n	0,11-√3	100	1,0	1000	
2a - 2n	0,11-√3	100	1,0	1000	
3a - 3n	0,11-√3	100	1,0P	1000	
4a - 4n	0,11-√3	100	3/3P	1000	
dn - dn	0,11-3	200	3,0	450	
CURRENT PART					
Winding	I _{th} [A]	S _n [VA]	class	Ratio [A/A]	
1S1-1S2	5	30	0,2FS 6	150-300/6	
2S1-2S2	1	40	5P 20	150-300/1	
3S1-3S2	5	60	5P 20	150-300/5	
4S1-4S2	1	80	5P 20	150-300/1	


List of performed tests:

- Oil dielectric parameters check before filling (oil after treatment):
to § acc. IEC 60247, breakdown voltage acc. IEC 60158
 - Verification of terminal
 - Pressure and tightness test; oil overpressure: 0.8 bar / 24h - no traces of oil
 - Power-frequency withstand
on primary windings
 - Partial discharge
 - Power-frequency withstand test on secondary
 - Inter-turn overvoltage test for current
 - Determination of errors
 - Determination of the over current factors: FS, ALF
 - Measurement of capacitance and dielectric dissipation factor - to § transformer
 - Determination of core magnetization characteristics
 - Measurement of windings' resistance
- 1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
- P1+P2/A: U_p = 247,5 kV / 60s, f = 97Hz; U_n = 3kV / 60s, f = 50Hz
 - U_p = 3 kV/60s
 - lower value (U_{peak} = 0,5kV or U_{peak} for I_{th}) /
 - U_p = 3 kV/60s

Oil dielectric parameters check before filling (oil after

- Measurement of oil to § according to IEC
Tg § = 0,06 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C
- Measurement of breakdown voltage according to IEC 60166
Mean breakdown voltage = 78,15 kV, Relative standard deviation = 4,93
f = 50Hz, oil temp. = 25 °C, measurement with the silicon, type of electrodes used; partially

Sample	Breakdown voltage [kV]
1	73,7
2	84,3
3	82,8
4	78,4
5	76,0
6	72,8



of windings' resistance

Imax	R (23 °C)	R _{ed} (75 °C)
150A	1883,0 μΩ	2267,8 μΩ
300A	970,0 μΩ	1168,2 μΩ
S2	0,298 Ω	0,287 Ω
S2	7,990 Ω	9,623 Ω
S2	0,369 Ω	0,468 Ω
S2	9,460 Ω	11,381 Ω

of voltage part

R (23 °C)	R _{ed} (75 °C)
21,30 kΩ	25,653 kΩ
47,010 mΩ	56,617 mΩ
48,480 mΩ	58,397 mΩ
50,000 mΩ	60,218 mΩ
51,700 mΩ	62,285 mΩ
34,090 mΩ	41,045 mΩ

Przasnysz, 2019-12-04






Wipe


Winding 2S1-2S2

[V]	[mA]
1134.6	1823
1130.8	1194.6
1113.7	432.2
1047	40.78
1018.8	21.84
880	16.73
887	15.44
801	13.44
847	12.71
794	12.26
621	9.81
448	7.46
277	5.5
105	2.85
10.7	0.7



Winding 3S1-3S2

[V]	[mA]
377	10440
335	258.5
314	170.6
305	148.6
300	136.7
283	106.74
270	89.86
267	77.84
242	66.66
200	53.43
156	43.17
113	34.76
70.1	26.63
26.4	13.48
2.5	2.82




278.51	0.1	0.1	εc ± 5%	<input checked="" type="checkbox"/>
1385.12	0.015	0.08	εs ± 5%	<input checked="" type="checkbox"/>


capacitance and dielectric dissipation factor - 3

Instrument transformer				Current part				Voltage part			
Cap	Leak	Tg	Cap	Leak	Tg	Cap	Leak	Cap	Leak	Tg	Cap
[pF]	[mA]	[%]	[pF]	[mA]	[%]	[pF]	[mA]	[pF]	[mA]	[%]	[pF]
1891	4.392	0.24	1115	3.53	0.23	275	0.671	275	0.671	0.23	275
1391	27.54	0.23	1115	22.08	0.23	275	5.663	275	5.663	0.23	275
1391	30.81	0.23	1115	24.79	0.23	275	6.122	275	6.122	0.23	275

Winding characteristics:

[mA]
3519.3
136.8
57.25
31.73
17.13
11.25
9.58
8.2
7.37
4.94
3.25
1.88
0.24





of windings' resistance
 distance of current port

	R (23 °C)	Rect (76 °C)
to 150A	1708.0 μΩ	2054.9 μΩ
to 300A	881.0 μΩ	1061.0 μΩ
52	0.236 Ω	0.284 Ω
52	7.950 Ω	9.575 Ω
52	0.385 Ω	0.464 Ω
52	9.270 Ω	11.164 Ω

ance of voltage part

	R (23 °C)	Rect (76 °C)
20.90	4.Ω	25.171 kΩ
46.820	mΩ	56.388 mΩ
48.340	mΩ	56.219 mΩ
49.840	mΩ	60.025 mΩ
51.400	mΩ	61.804 mΩ
34.070	mΩ	40.990 mΩ

Przasnysz, 2014-01-03



ANNEX 4 Documentations delivered by orderer

<p>ABB Sp. z o.o.</p>	<p>Declaration of conformity</p> <p>ABB Sp. z o.o. Dept. in Przasnysz POLAND</p>
<p>DECLARATION OF CONFORMITY No. 092/2013 (EN) (acc. to ISO/IEC 17050-1)</p> <p>Manufacturer: ABB Sp. z o.o. Dept. in Przasnysz</p> <p>Address: Str. Leszno 59 06-300 Przasnysz / POLAND</p> <p>Product: Combined Instrument Transformer PVA 145a</p> <p>Above mentioned product conforms with the following standard :</p> <p>Standard IEC 61869 - 4 Title Combined Instrument Transformers Edition/Date 2013</p> <p>Additional information: Serial numbers: ZGKP013K1486145;</p>	
<p>Place and date of issue of declaration Przasnysz 13.01.2014</p> <p>ABB Sp. z o.o. Oddział w Przasnyszu Kalderska 10 06-300 Przasnysz, tel. (22) 223 8821, fax (22) 223 8859</p>	<p>ABB ABB Sp. z o.o. ul. Zesławicka 1, 04-713 Warszawa NIP: 523-030-44-84; PL 5250304494 Regon 010017168 ODDZIAŁ W PRZASNYSZU ul. Kalderska 10 06-300 Przasnysz, tel. (22) 223 8859</p>
<p>..... (Name)</p> <p>..... (Signature)</p>	<p>..... (Name)</p> <p>..... (Signature)</p>



TEST REPORT No. EUR/23/E/14 E

Combined instrument transformer type PVA 145a with composite insulator
Serial No. 2GKFP013K1486144/13

ER: ABB Sp. z o.o. Division in Przasnysz, ul. Leszno 59, 06-300 Przasnysz

ED BY: ABB Sp. z o.o., ul. Żegaińska 1, 04-713 Warszawa
Order No. 4500554112 z dnia 25.04.2014

S: Short-time current tests
Test for composite error

URE: According to IEC 61869-2:2012

S: 12/13.05.2014

C: Positive for
 $I_{dyn} = 100 \text{ kA}$, $I_{th} = 40 \text{ kA}$, $t = 1 \text{ s}$ for 300 A terminal

Tests result refers only to the test object

ERE
Y: Z. Wesolowski – ABB Sp. z o.o.

ineer

HEAD OF LABORATORY

Lidia Gruza

zmarczyk

Contents

1. Test object	3
1.1. Description	3
1.2. Technical data	3
1.3. Technical documentation	3
1.4. Preparation for tests	3
2. Scope of tests	3
3. Test and measuring circuits	4
4. Tests and theirs detailed results	5
5. Test results evaluation	6
Annexes: I. Short-circuit test records	7
2. Photographs taken during the tests	8
3. Routine test report before and after short-time current tests	9
4. Documentations delivered by orderer	21

Report contents:

numbered pages	23
records (pages not numbered)	3
tables	2
figures	2
photographs	1

OBJECT

definition

Standard instrument transformer type PVA 145a is used for supplying of measuring and tests in the network of maximum operating voltage 145 kV and frequency 50 Hz. The consists of current and voltage transformers mounted in common housing with and immersed with transformer oil.

Standard instrument transformer delivered for the tests wasn't equipped with voltage current transformer wasn't equipped with 2S1-2S2 winding.

technical data

Manufacturer attributed the following construction data to the test object.
Operating voltage
145 kV
50 Hz

- Thermal current 360 A, 720 A
- Current for 1 s 40 kA
- 100 kA

technical documentation

One of tests the orderer delivered the following technical documentation:
Certificate of combined instrument transformer before short-time current test (29.04.2014)
Certificate of combined instrument transformer after short-time current test (16.05.2014),
Certificate of combined transformer PVA 123a-145a, No. 2GK614123 (17.12.2013),

former electrical diagram

Sp. z o.o (Annex 3 and 4).

Proceeded the identification of test object on the base of above documentation and uniformity of manufacturing with constructional documentation is stated declaration, copy of which presents Annex 4.

ration for tests

was prepared for tests in the factory by the manufacturer.

TESTS

Agreed with orderer, comprised the following tests according to requirements of :

Tests of current transformer acc. to item 7.2.201 of above standard at

$I_{th} = 40 \text{ kA}$, $t_{th} = 1 \text{ s}$, $I_{th}^2 \times t_{th} \geq 1600 \text{ kA}^2 \cdot \text{s}$ for 300 A terminal.

Proceeded the error acc. to item 7.2.6.203 of above standard with current's transformer burden 5% connected to 3S1-3S2 windings at parameters:

$I_{th} = 40 \text{ kA}$, $t_{th} = 1 \text{ s}$ for 300 A terminal,


and after short-time current test made in factory.



3. TEST AND MEASURING CIRCUITS

For the tests the transformer was fixed to the rigid construction of the test stand. Short-time current tests and test for composite error were made in single-phase circuit presented on fig. 1 at dimensions presented on fig.2.

- primary current (with short-circuited all secondary terminals) using laboratory current transformer type C4C class 0,5 with a ratio 50,000/2 A/A (uncertainty of measurement $\pm 0,018\%$ for $k = 2$),
- secondary currents in 1S1-1S2, 3S1-3S2, 4S1-4S2 windings by means of laboratory toroidal current transformers type IL20a class 0,5 with a ratio 500/5 A/A, 1.000/5 A/A and 2.000/5 A/A (uncertainty of measurement $\pm 0,012\%$ for $k = 2$),
- voltage drop (U_0) on test object during short-time current tests by means of a resistance-capacitance voltage divider with a bandwidth from 0 to 100 kHz.



- T - short-circuit transformer
- CB - back-up circuit-breaker
- R - reactor
- MS - make switch
- CT - current transformers
- VD - voltage divider
- TO - test object




Fig. 2. Configuration of test circuit during tests

THEIR DETAILED RESULTS

Results presents tables 1. and 2. During the tests the following records were made:
 Nos. 33757, 33758, 33762 – calibration of measuring and test circuit,
 No. 33759 – composite error test,
 Nos. 33763, 33764 – short-time current tests,

(Annex 1 presents the copies of short-circuit test records - all records are stored in laboratory's archives),
 phot. 1 – current transformer on short-circuit tests stand
 (Annex 2 presents the photograph).
 composite error test current's transformer burden connected to 3S1-3S2 was

of composite error test for 3S1-3S2 winding

I_p	ε_c	t_s	Observations
kA	%	s	
3,32	4,04	0,99	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

r.m.s. value of the test current (determined from test period without asymmetrical component),
 test duration,

$$\frac{\int_0^t (k_r \cdot i_r - i_p)^2 dt}{I_p^2} \cdot 100\%$$

rated transformation ratio (300/5 A/A),
 instantaneous value of the primary current,
 instantaneous value of the secondary current,

Table 2. Results of short-time current tests

Test No.	i_{peak} kA	I_t kA	t_t s	$I_t^2 \times t_t$ (kA) ² × s	I_{S1-3S2} A	I_{S1-3S2} A	I_{S1-4S2} A	I_{S1-4S2} A	U_0 V	Observations
33763	100,24 ¹⁾	40,12	0,08	-	-	-	-	-	-	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.
33764	71,71	40,12	1,00	1610 ²⁾	239*	611	126	176	-	Behaviour of transformer during the test was correct. After test no damage nor oil leak was stated.

Legend:
 i_{peak} – peak value of test current,
 I_t – r.m.s. value of test current (determined from test period without asymmetrical component),
 t_t – test duration,
 I_{S1-3S2} – r.m.s. value (determined from test period without asymmetrical component),
 I_{S1-4S2} – r.m.s. value (determined from test period without asymmetrical component),
 U_0 – r.m.s. value of voltage drop (determined from test period without asymmetrical component).
 Required: 1) $i_{peak} \geq 100$ kA,
 2) $I_t^2 \times t_t \geq 1600$ (kA)² × s,
 * – deformed waveform.

5. TESTS RESULTS EVALUATION

According to criteria given in IEC 61869-2:2012 the results of tests is positive for:

$I_{G95} = 100$ kA, $I_{th} = 40$ kA, $t = 1$ s for 300 A terminal of tested combined instrument transformer.


Test records

As not numbered pages the following copies of records are given:



- 33759 – composite error test,
- 33763, 33764 – short-time current tests.

cons:


- o on test object,
- o winding current,
- o winding current,
- o winding current,
- o secondary current in 3S1-3S2 winding (including ratio) minus primary current.



500



Photographs taken during the tests



Phot. 1. PVA 145a after short-time current tests



ANNEX 3 Routine test report before and after short-time current tests

ABB Sp. z o.o. 06-300 Przasnysz ul. Leszno 58		Routine tests report of combined instrument transformer before short time current test		TYPE: PVA145a	
A+N	Insulation level: 132-3 kV 145278/650 kV 1,9/8h	Voltage factor: 1/1h Ts (kA): 40-40	Iq (kA): 100-100	Iqth (A): 450-900	Serial no: 2GKPO13K1486144 IEC 61968-4 50 Hz
VOLTAGE PART *)					
Winding	Uen [kV]	Sn [VA]	class	SIn [VA]	
1a - 1n	0,11:√3	0-10	0,1	1000	
2a - 2n	0,11:√3	25	0,1	1000	
3a - 3n	0,11:√3	25	0,1/3P	1000	
4a - 4n	0,11:√3	40	1/3P	1000	
da - dn	0,11	100	1,0	450	
CURRENT PART					
Winding	Ien [A]	SIn [VA]	class	Ratio [VA]	
1S1-1S2	5	40	0,2FS 5	300-600/5	
2S1-2S2	1	30	0,5FS 10	300-600/1	
3S1-3S2	5	60	5P 20	300-600/5	
4S1-4S2	1	120	10P 15	300-600/1	

List of performed tests:

1. Oil dielectric strength check before filling (oil after treatment):
2. Ug 8 acc. IEC 60247, breakdown voltage acc. IEC 60150
3. Verification of terminal markings
4. Pressure and tightness test: oil overpressure: 0,8 bar/24h - no traces of oil leakage
5. Power-frequency withstand test on primary windings
6. Partial discharge measurement
7. Power-frequency withstand test on secondary windings
8. Intra-turn overvoltage test for current transformers
9. Determination of errors
10. Determination of the over current factor: FS, ALF
11. Measurement of capacitance and dielectric dissipation factor - tgδ
12. Determination of core magnetization characteristics
13. Measurement of windings' resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tg δ according to IEC 60247
Tg δ = 0,05 %, electrical stress = 1kV/mm, t = 50Hz, oil temp. = 90C ±1C.

- Measurement of breakdown voltage according to IEC 60156
Mean breakdown voltage = 73,62 kV, Relative standard deviation = 6,88 %;
t = 50Hz, oil temp. = 23 °C, measurement with the stirrer, type of electrodes used: partially spherical.

Sample	Breakdown voltage [kV]
1	71,3
2	72,8
3	69,9
4	83,6
5	71,7
6	72,4

*) In the combined instrument transformer lack of the voltage part in the current part back of the core 2S1-2S2

Measurement

According to procedure A (PD test voltages were reached while decreasing the voltage after the withstand test on primary winding)

Hz

test voltage	1,2 Um = 174 kV	1,2 Um / √3 = 100,5 kV
partial discharge	5 pC	5 pC

ground noise level: 2,5 (measured after voltage switch on),
It was calibrated with 5 pC (charging charge).

Charge test for current transformers

Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]
1,27	800
1,32	800
4,5	100

the combined instrument transformer lack of the voltage

Attention: IN the combined instrument transformer lack of the voltage part

Determination of current part errors (e %), Δp (min)

Ipri (A): 300

1S1-1S2: 40 VA		p.f. = 0,8 lag.		1S1-1S2: 10 VA		p.f. = 0,8 lag.	
e 1	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δp 1	-0,058	-0,048	-0,032	-0,028	-0,017	-0,018	-0,015
Δp 1	4,1	0,2	-0,3	-0,3	0,4	0,1	0,1
2S1-2S2: 30 VA		p.f. = 0,8 lag.		2S1-2S2: 7,50 VA		p.f. = 0,8 lag.	
e 1	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δp 1	-0,058	-0,050	-0,017	-0,027	0,009	0,014	0,018
Δp 1	2,9	1,2	-0,4	0,5	1,3	0,8	0,2
3S1-3S2: 60 VA		p.f. = 0,8 lag.		4S1-4S2: 120 VA		p.f. = 0,8 lag.	
e 1	1,0 in			4,0 in			
Δp 1	-0,127			-0,171			
Δp 1	0,6			1,0			

Ipri (A): 600

1S1-1S2: 40 VA		p.f. = 0,8 lag.		1S1-1S2: 10 VA		p.f. = 0,8 lag.	
e 1	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δp 1	-0,058	-0,050	-0,032	-0,028	-0,017	-0,018	-0,015
Δp 1	1,0	0,4	-0,2	-0,1	0,1	0,0	-0,1
2S1-2S2: 30 VA		p.f. = 0,8 lag.		2S1-2S2: 7,50 VA		p.f. = 0,8 lag.	
e 1	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δp 1	-0,077	-0,060	-0,018	-0,038	0,017	0,013	0,018
Δp 1	2,7	1,3	-0,3	1,1	1,1	0,8	0,2
3S1-3S2: 60 VA		p.f. = 0,8 lag.		4S1-4S2: 120 VA		p.f. = 0,8 lag.	
e 1	1,0 in			4,0 in			
Δp 1	-0,124			-0,167			
Δp 1	0,6			1,0			

Current part: Measurements uncertainty: e I = ± 0,045 %, Δp I = ± 2,3 min
Voltage part: Measurements uncertainty: e U = ± 0,044 %, Δp U = ± 2,2 min

Determination of the over current factors:

- Instrument security factor (FS) of measuring cores

Winding	Io		U		Ers	M	Ers	Condition	Assessment
	[A]	[V]	[V]	[V]					
1S1-1S2	2,6	2,6	31,1,4	31,1,4	50,12	M	50,12	U < Ers	☑
2S1-2S2	1	1	87,04	87,04	360,23	M	360,23	U < Ers	☑

- accuracy limit factor (ALF) - test for composite error e c of protective cores

Winding	EALF		Io		Ers	M	Ers	Condition	Assessment
	[V]	[V]	[A]	[V]					
1S1-1S2									
2S1-2S2									


22	284.18	0.185	0.19	$\delta_c \leq 5\%$	<input type="checkbox"/>
22	1940	0.022	0.15	$\delta_a \leq 10\%$	<input checked="" type="checkbox"/>

Factor of capacitance and dielectric dissipation factor - tg δ
22.5 °C, Frequency: 50 Hz

Instrument transformer				Current part				Voltage part			
Tg δ [%]	Capacity [pF]	Leak-current [mA]	Tg δ [%]	Capacity [pF]	Leak-current [mA]	Tg δ [%]	Capacity [pF]	Leak-current [mA]	Tg δ [%]	Capacity [pF]	Leak-current [mA]
0.24	1387	4.405	0.25	1110	3.524	0.22	277	0.079	0.25	1387	37.05
0.25	1387	27.46	0.25	1110	21.87	0.22	277	5.681	0.25	1111	24.79
											277


ization characteristics:

[mA]	[mA]
4558.2	7.33
2318.3	6.01
41.64	5.09
26.04	4.35
11.05	3.47
2.26	2.9
1.73	2.26
0.93	1.73
0.12	0.93




Winding 4S1-4S2

[V]	[mA]
303.5	8136
305.2	2080.3
302.2	1928.8
298.3	679.5
284.4	181.04
276.8	95.13
269.5	65.11
265.4	61.8
244.6	52.54
225.7	47.91
208.8	43.39
190	34.55
92.4	25.35
54.3	13.79
2.6	2.76



Winding 4S1-4S2

[V]	[mA]
2478.1	891.2
2472.2	758.1
2440.5	368.77
2383.9	127.27
2299.8	55.65
2195.4	43.02
2010.7	26.03
1823.9	17.24
1647.4	12.78
1483.9	10.05
1273	8.35
868.2	6.07
517.8	4.32
148.8	2.02
25.3	0.7



*) Average rectifier effective value.

Measurement of windings' resistance
Windings' resistance of current part:

PI-P2 range 300A	R (25 °C)	ReI (75 °C)
PI-P2 range 600A	617.0 $\mu\Omega$	738.2 $\mu\Omega$
4S1-4S2	311.0 $\mu\Omega$	372.1 $\mu\Omega$
2S1-2S2	0.401 Ω	0.478 Ω
3S1-3S2	0.443 Ω	0.530 Ω
4S1-4S2	8.580 Ω	11.438 Ω

Resistance of voltage part:

R (24 °C)	R ₆₅ (75 °C)
K Ω	K Ω
M Ω	M Ω
m Ω	m Ω
m Ω	m Ω
m Ω	m Ω



Przasnysz, 2014-04-20

ABB Sp. z o.o. 06-300 Przasnysz ul. Łoszczy 59		Routine tests report of combined instrument transformer After short time current test		TYPE: PVA145a
A-N	Insulation level: 132-0 kV / 145275/860 kV	Voltage factor: 1.8/2h	1th 1s [kA]: 40-40	Serial no: 2GKP013K1486144
VOLTAGE PART *)		100-100		IEC 61868-4 50 Hz
Winding		Uen [kV]	Sn [VA]	class
1a - 1n		0,11; $\sqrt{3}$	0-210	0,1
2a - 2n		0,11; $\sqrt{3}$	25	0,1
3a - 3n		0,11; $\sqrt{3}$	25	0,1/3P
4a - 4n		0,11; $\sqrt{3}$	40	1/3P
6a - 6n		0,11	100	1,0
CURRENT PART		len [A]	Sn [VA]	class
Winding		5	40	300-600/5
1S1-1S2		1	30	0,5FS 10
2S1-2S2		5	60	5P 20
4S1-4S2		1	120	10P 15
				Ratio [A/A]
				300-600/5
				300-600/1
				300-600/5
				300-600/1

List of performed tests:

1. Oil dielectric structures check before filling (oil after treatment):
 1g § acc. IEC 60247, breakdown voltage acc. IEC 60150
2. Verification of terminal markings
3. Pressure and tightness test: oil overpressure: 0,8 bar / 24h - no traces of oil leakage
4. Power-frequency withstand test
 - P1+P2/A: Up = 247,5 kV / 60s, f = 67,5 Hz; N: Up = 3kV / 60s, f = 60Hz
5. Partial discharge measurement
 - Up = 3 kV/60s
6. Power-frequency withstand test on secondary windings
 - lower value (U peak=4,5kV or U peak for tabs) / 60s
7. Inter-turn overvoltage test for current transformers
8. Determination of errors
9. Determination of the over current factors: FS, ALF
10. Measurement of capacitance and dielectric dissipation factor - tg δ
11. Determination of core magnetization characteristics
12. Measurement of windings' resistance

Oil dielectric parameters check before filling (oil after treatment)

- Measurement of oil tg δ according to IEC 60247
 Tg δ = 0,06 %; electrical stress = 1kV/mm, f = 50Hz, oil temp. = 90C \pm 1C.
- Measurement of breakdown voltage according to IEC 60156
 Mean breakdown voltage = 73,62 kV, Relative standard deviation = 6,88 %;
 f = 60Hz, oil temp. = 28 °C, measurement with the stirrer, type of electrodes used; partially spheroidal.

Sample	Breakdown voltage [kV]
1	71,3
2	73,8
3	68,9
4	83,8
5	71,7
6	72,4

*) In the combined instrument transformer lack of the voltage part
 *) In the current part lack of the core 2S1-2S2.

Large measurement

Test according to procedure B

Age: 247,5 kV / 60 s
f: 97 Hz

Test voltage	1,2 Un = 174 kV	1,2 Un / √3 = 100,5 kV
U of partial discharge	1,2 pC	1,2 pC

background noise level: 1,2 (measured after voltage switch off).
test was calibrated with 5 pC (calibrating charge).

voltage test for current transformers

Peak voltage on secondary winding [kVpeak]	Current in primary winding [A]
1,31	800
2	800
4,5	100

the combined instrument transformer lack of the voltage



Attention: IN the combined instrument transformer lack of the voltage part

Determination of current part errors (± 1%), Δφ 1 min

Ip (A): 300

1S1-1S2: 40 VA		p.f. = 0,8 lag.		1S1-4S2: 10 VA		p.f. = 0,8 lag.	
ε I	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δφ I	-0,061	-0,02	-0,033	-0,015	-0,015	-0,014	-0,013
Δφ II	0,9	0,3	-0,2	0,3	0,1	0,0	0,0
2S1-2S2: 30 VA		p.f. = 0,8 lag.		2S1-2S2: 7,50 VA		p.f. = 0,8 lag.	
ε I	0,06 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δφ I	-0,085	-0,060	-0,017	-0,027	0,009	0,011	0,014
Δφ II	2,9	1,2	-0,4	0,5	1,3	0,8	0,3
3S1-3S2: 60 VA		p.f. = 0,8 lag.		4S1-4S2: 120 VA		p.f. = 0,8 lag.	
ε I	1,0 in	1,0 in	1,0 in	1,0 in	1,0 in	1,0 in	1,0 in
Δφ I	-0,125	0,6	0,6	-0,170	1,0	1,0	1,0
Δφ II	0,6	0,6	0,6	1,0	1,0	1,0	1,0

Ip (A): 800

1S1-1S2: 40 VA		p.f. = 0,8 lag.		1S1-1S2: 10 VA		p.f. = 0,8 lag.	
ε I	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δφ I	-0,063	-0,024	-0,032	-0,013	-0,017	-0,015	-0,013
Δφ II	1,0	0,4	-0,2	0,2	0,2	0,1	0,0
2S1-2S2: 30 VA		p.f. = 0,8 lag.		2S1-2S2: 7,50 VA		p.f. = 0,8 lag.	
ε I	0,05 in	0,2 in	1,0 in	0,05 in	0,2 in	1,0 in	1,5 in
Δφ I	-0,077	-0,060	-0,018	-0,039	0,017	0,013	0,018
Δφ II	2,7	1,3	-0,3	1,1	0,8	0,2	0,1
3S1-3S2: 60 VA		p.f. = 0,8 lag.		4S1-4S2: 120 VA		p.f. = 0,8 lag.	
ε I	1,0 in	1,0 in	1,0 in	1,0 in	1,0 in	1,0 in	1,0 in
Δφ I	-0,123	0,6	0,6	-0,168	1,0	1,0	1,0
Δφ II	0,6	0,6	0,6	1,0	1,0	1,0	1,0

Current part: Measurements uncertainty: ε I = ± 0,045 %, Δφ I = ± 2,3 min
Voltage part: Measurements uncertainty: ε U = ± 0,044 %, Δφ U = ± 2,2 min

Determination of the over current factors:

- Instrument security factor (FS) of measuring cores

Winding	I ₀ [A]	U [V]	E _{FS} [%]	Condition	Assessment
1S1-1S2	2,5	31,39	48,88	U < E _{FS}	2
2S1-2S2	1	97,04	360,43	U < E _{FS}	2

- accuracy limit factor (ALF) - test for composite error ε c of protective cores

Winding	E _{ALF} [V]	I _n [A]	ε c [%]	Condition	Assessment




282.28	0.143	0.14	$\epsilon_c \leq 5\%$	<input checked="" type="checkbox"/>
1984.49	0.022	0.16	$\epsilon_c \leq 10\%$	<input checked="" type="checkbox"/>

Capacitance and dielectric dissipation factor - tg δ
5 °C, frequency: 50 Hz

Instrument transformer			Current part			Voltage part		
Ig [A]	Capacity [pF]	Leak.current [mA]	Tg δ [%]	Capacity [pF]	Leak.current [mA]	Tg δ [%]	Capacity [pF]	Leak.current [mA]
0.24	1387	4.405	0.25	1110	3.624	0.22	277	0.879
0.26	1387	27.46	0.25	1110	21.97	0.22	277	6.481
0.25	1387	31.05	0.25	1111	24.79	0.22	277	6.184


Winding characteristics:

[mV]	[mA]
4658.2	861.2
2318.3	758.1
41.64	368.77
28.84	127.27
11.05	55.85
7.28	43.02
6.01	28.05
5.09	17.24
4.35	10.06
3.47	8.35
2.9	6.07
2.36	4.32
1.73	2.02
0.93	0.7
0.12	




Winding 3S1-3S2

[V]	[mA]
308.5	8138
305.2	2980.3
302.2	1628.8
296.3	879.5
282.4	181.04
276.5	95.13
266.5	68.11
263.4	61.8
244.6	52.54
225.7	47.61
206.8	43.39
160	34.98
92.4	25.35
34.3	13.79
2.6	2.78



Winding 4S1-4S2

[V]	[mA]
2479.1	861.2
2472.2	758.1
2440.5	368.77
2368.8	127.27
2289.8	55.85
2195.4	43.02
2010.7	28.05
1823.9	17.24
1647.4	10.06
1463.9	8.35
1278	6.07
886.2	4.32
517.8	2.02
148.9	0.7
25.3	



*) Average rectifier effective value.

Measurement of windings' resistance

Windings' resistance of current part:

	R (24 °C)	Rct (75 °C)
P1-P2 range 300A	696.0 $\mu\Omega$	745.5 $\mu\Omega$
P1-P2 range 800A	313.0 $\mu\Omega$	376.7 $\mu\Omega$
1S1-1S2	0.583 Ω	0.459 Ω
2S1-2S2	Ω	0.909 Ω
3S1-3S2	9.160 Ω	10.996 Ω
4S1-4S2		

Balance of voltage part

R (24 °C)	Ref (76 °C)
kΩ	kΩ
mΩ	mΩ
mΩ	mΩ
mΩ	mΩ
mΩ	mΩ



Przasnysz, 2014-05-16



ANNEX 4 Documentations delivered by orderer

ABB ABB Sp. z o.o.	Declaration of conformity	ABB Sp. z o.o. Dept. in Przasnysz POLAND
DECLARATION OF CONFORMITY No. 091/2013 (EN) (acc. to ISO/IEC 17050-1)		
Manufacturer: ABB Sp. z o.o. Dept. in Przasnysz		
Address: Str. Leszno 59 06-300 Przasnysz / POLAND		
Product: Combined Instrument Transformer PVA 145a		
Above mentioned product conforms with the following standard :		
Standard IEC 61869 - 4	Title Combined Instrument Transformers	Edition/Date 2013
Additional information: Serial numbers: 2GKP013K1486144;		
Place and date of issue of declaration Przasnysz 13.01.2014		
Referent do: Realizacji Zamówień ABB Sp. z o.o. Oddział Przasnysz ul. Leszno 59, 06-300 Przasnysz tel. (22) 223 052 1, fax (22) 220 0550 (9)		
Jeronimik os. Zarechnienia w/w ABB Sp. z o.o. Oddział w Przasnyszu Krzysztof Lubnicki		
		(Name)
		(Signature)

HIGH VOLTAGE LABORATORY



INSTYTUT ENERGETYKI




LABORATORY ACCREDITED
BY THE POLISH CENTRE FOR ACCREDITATION
Accreditation Certificate of Testing Laboratory
No AB 272

AB 272

TEST REPORT

No. EWN/145/E/13

Type test, special tests and additional tests
of combined transformers type PVA123a and PVA145a
manufactured by ABB sp. z o.o.

	HIGH VOLTAGE LABORATORY INSTYTUT ENERGETYKI POLAND 01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 836-80-48, fax (+48 22) 836-80-48 e-mail: ewn@ten.com.pl	EWN/145/E/13 Page 2/29
	TESTS REPORTS No EWN/145/E/13	

TEST OBJECT: Combined transformers type
PVA123a and PVA145a

TEST ORDERED BY: ABB Sp. z o.o.
04-713 Warszawa, ul. Żegalska 1

ORDER NO: 4500513518 - 21.10.2013

SCOPE OF TEST: Type test, special tests and additional tests
in accordance with standards:
PN-EN/IEC 61869-1, PN-EN/IEC 61869-2,
PN-EN/IEC 61869-3, IEC 61869-4

PROCEDURA OF TESTS: November - December 2013

DATE OF TESTS: Positive - details are presented in following parts of
TESTS RESULTS: report
Test results refer to tested objects only.

TEST PERFORMERS:

Michał MOLAS,
M.Sc.E.E.





Jan SZOKALSKI,
M.Sc.E.E.

AUTHORIZATION:

Jerzy MIKOŁAJCZYK
M.Sc.E.E.

HEAD OF HIGH VOLTAGE
DEPARTMENT:

January L. MIKULSKI,
Prof., Dr. hab. E. E.

	SIGNATURE
	SIGNATURE
	SIGNATURE
	SIGNATURE

Warsaw, January 2014

HIGH VOLTAGE LABORATORY
INSTYTUT ENERGETYKI

POLAND 01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 836-80-48,
fax (+48 22) 836-80-48 e-mail: ewn@ten.com.pl

EMN/145/E/13

Page 3/29



HIGH VOLTAGE LABORATORY
INSTYTUT ENERGETYKI

POLAND 01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 836-80-48,
fax (+48 22) 836-80-48 e-mail: ewn@ten.com.pl

EMN/145/E/13

Page 4/29

CONTENTS

4	4
5	5
6	6
7	7
7	7
9	9
11	11
11	11
15	15
22	22
24	24
25	25
26	26
28	28

STATEMENT OF LABORATORY
DESCRIPTION OF TEST OBJECT
SCOPE OF TESTS
TESTS
Lightning impulse test
at test
Termination of mutual influence
Checking influence of the current transformer on the voltage transformer
Checking influence of the voltage transformer on the current transformer
Radio interference voltage measurement
Capped impulse test on the primary winding
Unswitched overvoltage measurement
Charge capacitor test
OF ANNEXES

main:
29 numbered pages
presented:

- 5 drawings
 - 1 photography
 - 7 numbered tables
 - 4 annexes
- and non numbered diagrams and tables

1. COMPETENCE OF THE LABORATORY

The High Voltage Laboratory of Institute of Power Engineering (IEIn) in Warsaw is in possession of accreditation issued by the Polish Centre for Accreditation (Accreditation Certificate of Testing Laboratory No AB 272) concerning following tests:

- Insulators and insulator strings
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Distribution substations
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Circuit breakers, disconnectors
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Insulators
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Current and voltage transformers
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Power transformers
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Lightning arresters and limiters
 - lightning and switching impulse tests
 - power-frequency voltage 50 Hz tests
 - radio interference measurements
- Cables and cable fittings
 - lightning and switching impulse tests

Note! Tests described in sub-clauses 4.3, 4.6, 4.7 of this Report don't comply with the scope of Laboratory accreditation.

This Report concerns test results obtained in other competent laboratories - (see Annex 2):

- Factory Laboratory of ABB sp. z o.o. in Przyszysz - calibration unit in cooperation with Central and Regional Office of Measures in Warsaw - determination of errors and test in range of type tests at supervision of representative of High Voltage Laboratory of Institute of Power Engineering in Warsaw.

DESCRIPTION OF TEST OBJECT

and objects were two types of combined transformers PVA123a and PVA145a
ABB sp. z o.o. 04-713 Warszawa, Żegaska 1 St. (Fabryka Aparatury Wysokich i
36-300 Przasnysz, Leszno 59 St.), with the following parameters:

PVA123a
GKPO13K1486138
rated primary voltage 110/ $\sqrt{3}$ kV
rated primary current 50-100-200 A
rated frequency 50 Hz
rated insulation level 126/230/550 kV
rated short-time thermal current 40-63-63 kA
rated dynamic current 100-158-158 kA
minimum creepage distance 3800 mm (composite insulator)

PVA145a
GKPO13K1486145
rated primary voltage 132/ $\sqrt{3}$ kV
rated primary current 150-300 A
rated frequency 50 Hz
rated insulation level 145/275/650 kV
rated short-time thermal current 20-20 kA
rated dynamic current 50-50 kA
minimum creepage distance 4495 mm (composite insulator)

PVA145a
GKPO13K1486144
rated primary voltage 132/ $\sqrt{3}$ kV
rated primary current 300-600 A
rated frequency 50 Hz
rated insulation level 145/275/650 kV
rated short-time thermal current 40-40 kA



The identification of the objects was made on the basis of the following documents attached to this report:

- Manufacturer Conformity Declaration (applies only for objects for electrical tests: prototype 1 - 2GKPO13K1486138, prototype 6 - 2GKPO13K1486144, prototype 7 - 2GKPO13K1486145) - annex 1,
- Dimension drawings, rating plates, electrical diagrams - annex 1,
- Routine test reports of combined instrument transformers - annex 2.

3. AGREED SCOPE OF TESTS

According to ordered tests the type test and selected special test were performed according to the following standards:

- IEC 61869-1:2007 „Instrument transformers - Part 1: General requirements” (equiv. with: PN-EN 61869-1:2007 “Przeładunki -- Część 1: Wymagania ogólne”)
- IEC 61869-2:2012 „Instrument transformers - Part 2: Additional requirements for current transformers” (equiv. with: PN-EN 61869-2:2013 “Przeładunki -- Część 2: Wymagania szczegółowe dotyczące przeładunków prądowych”)
- IEC 61869-3:2011 „Instrument transformers - Part 3: Additional requirements for inductive voltage transformers” (equiv. with: PN-EN 61869-3:2011 “Przeładunki -- Część 3: Wymagania szczegółowe dotyczące przeładunków napięciowych indukcyjnych”)
- IEC 61869-4:2013 „Instrument transformers - Part 4: Additional requirements for combined transformers”

On request of ordering party the additional special test were performed. List of the performed tests are contained in Table 1.


During the tests mentioned above at Factory Laboratory of ABB sp. z o.o. in Przasnysz Leszno 59 Street, determination of errors of transformer was performed to prove the positive results of consecutive tests. The complete tests were performed according to mentioned above standards. The tests were supervised by representatives of High Voltage Laboratory of Institute of Power Engineering in Warsaw in purpose to prove results of tests (Annex 2).

registered during the tests of the prototypes 1(2GKP013K1486138) and 6
 1486144) don't indicate any failures of the transformers' insulation.
 of the accuracy verification before and after the lightning impulse test of the
 (annex 2) don't indicate significant changes of the transformers'
 characteristics.
 positive.

scillograms of all applied impulses are shown in Annex No. 3 of this Report.



outdoor transformers

was performed in arrangement of test transformer type TuR 700kV, 0,5A.
 diagram is presented in the Figure 2.



at circuit diagram for power frequency voltage 50 Hz: C = 200 pF (C' in series with C').
 measurement uncertainty: 1,5 % of the measured value (confidence interval 95%, k=2).

was performed on transformers prototypes with disassembled winding (prototypes 3-
 86142/12; presented in the photography 1). All external elements of transformers,
 hence test results were identical to the complete transformer. The purpose of the
 withstanding of porcelain housing (prototype 3) and composite housing (prototype
 posed to the artificial rain conditions.



Phot. 1: Wet test of prototypes 3 (86143/13) and 4 (86142/13) at power frequency voltage 50 Hz.

In each case the test voltage U=275 kV (corresponding to the equipment with Um=145 kV)
 was applied for 1 minute.

During wet test for outdoor transformers the transformer was wetting by artificial rain at
 parameters:

- vertical component of precipitation $H_v = 1,4 \text{ mm/min}$
- horizontal component of precipitation $H_h = 1,4 \text{ mm/min}$
- water electrical resistivity $\rho = 101 \div 103 \Omega \text{m}$

The test voltage was corrected according to density of air.

During the tests no flashover or failure of insulation could be observed.

Test result - positive.

Electric strength of the inner insulation does not depend on atmospheric conditions and it was tested
 during routine test at ABB's Factory Laboratory (Annex 2).

Influence of the current transformer on the voltage transformer

Measurements were performed by exciting in primary current winding with range current part of combined transformer 50 Hz current at value:

$$2 \cdot I_n = 400 \text{ A}$$

Current transformer had the shape of a horizontal rectangular loop with approximately 3500 x 1100mm. Secondary windings of current transformer and of voltage of transformer were short-circuited. On all windings of voltage part of transformer which are burdened by 15 VA were measured in turn interference voltage KEITHLEY type 2001.

1a-1n	2a-2n	3a-3n	4a-4n	da-dn
15	15	15	15	15
0,150	0,139	0,118	0,111	0,089

Parameters were calculated:

(0,8 U_{SN}) change of voltage error (at 80% voltage of secondary winding for measurement)

(0,02 U_{SN}) change of voltage error (at 2% voltage of secondary winding for protection)

change of phase displacement (in min.)

induced voltage [V]

Table 3: Calculated voltage errors and phase displacements - prototype 1.

Bg	1a-1n	2a-2n	3a-3n	4a-4n	da-dn
n	80%	80%	2%	2%	2%
ε	0,00032	0,00030	0,01022	0,00961	0,01335
Δn	0,0112	0,0104	0,3515	0,3307	0,4592


Linearity between induced voltage (interfere) and current in current transformer (in

150 mV / 0,400 kA ≈ 0,375 mV/kA



The maximal error of voltage transformer was evaluated by summarize mentioned above errors originated from influence of current path on voltage path together with extreme values of errors measured during routine test at U = 0,8 · U_n ± 1,2 · U_n (Report No. 2GKPO13K1486138 - 12.11.2013, Annex No. 2 of hereby Report)


Below are presented chosen results of calculation in analytic and graphic form (for maximal errors).



Maximal possibly voltage error of measurement winding 1a-1n (U = 0,8 · U_n)

$$\pm \epsilon'_1 = |\epsilon_1| + |\Delta \epsilon_1| = 0,517\% + 0,00032\% = 0,517\%$$


$$\pm \delta'_1 = |\delta_1| + |\Delta \delta_1| = 0,075\% + 0,00032\% = 0,075\%$$



Maximal possibly phase displacement of measurement winding 3a-3n (U = 0,8 · U_n)

$$\pm \delta'_3 = |\delta_3| + |\Delta \delta_3| = 7,1 \text{ min} + 0,0112 \text{ min} = 7,1 \text{ min}$$


$$\pm \delta'_1 = |\delta_1| + |\Delta \delta_1| = 3,5 \text{ min} + 0,0112 \text{ min} = 3,5 \text{ min}$$



Maximal possibly voltage error of winding for protection 1a-1n (U = 0,02 · U_n)

$$\pm \epsilon'_1 = |\epsilon_1| + |\Delta \epsilon_1| = 1,451\% + 0,01022\% = 1,461\%$$

$$\pm \delta'_1 = |\delta_1| + |\Delta \delta_1| = 0,305\% + 0,01022\% = 0,315\%$$



phase displacement of winding
 $3n (U=0,02 \cdot U_n)$
 $1,151\% + 0,01022\% = 1,161\%$
 $0,305\% + 0,01022\% = 0,315\%$

that errors derived from influence of current path on voltage path of transformer PVA123a (prototype 1- 2GKPO13K1486138) don't cause loss of properties (loss of accuracy class) for all secondary voltage windings. positive.

7 - 2GKPO13K1486145

measurements were performed by exciting in primary current winding with range part of combined transformer 50 Hz current at value:

$1,5 \cdot I_n = 450 \text{ A}$

to current transformer had the shape of a horizontal rectangular loop with approximately 3500 x 1100mm. Secondary windings of current transformer and of voltage of transformer were short-circuited. On all windings of voltage part of transformer which are burdened by rated burden (winding da-dn were burdened by 15 mV) in turn interference voltage using instrument KEITHLEY type 2001.

1a-1n	2a-2n	3a-3n	4a-4n	da-dn
100	100	100	100	15
0,336	0,388	0,405	0,462	0,611

parameters were calculated:
 change of voltage error (at 80% voltage of secondary winding for
 measurement)
 change of voltage error (at 2% voltage of secondary winding for
 protection)



where:

U_{SN} - secondary rated voltage [V]

Table 4: Calculated voltage errors and phase displacements - prototype 1.

Winding	1a-1n	2a-2n	3a-3n	4a-4n	da-dn
$x U_{SN}$	80%	80%	2%	2%	2%
$\Delta S_V [\%]$	0,00066	0,00076	0,03189	0,03637	0,00208
$\Delta \delta_V [\text{min}]$	0,0227	0,0263	1,0969	1,2512	0,0717

Factor of proportionality between induced voltage (interfere) and current in current transformer (in mV/kA)



$p < U_V / (1,5 \cdot I_n) = 1,2512 \text{ mV} / 0,450 \text{ kA} \approx 2,78 \text{ mV/kA}$

The maximal error of voltage transformer was evaluated by summarize mentioned above errors originated from influence of current path on voltage path together with extreme values of errors measured during routine test at $U = 0,8 \cdot U_n \pm 1,2 \cdot U_n$ (Report No. 2GKPO13K1486145 - 04.12.2013, Annex No. 2 of hereby Report)

Below are presented chosen results of calculation in analytic and graphic form (for maximal errors).

Maximal possibly voltage error of measurement winding
 2a-2n ($U = 0,8 \cdot U_n \pm 1,2 \cdot U_n$)

$\pm \delta_V' = |\delta_V| + |\Delta S_V| = 0,163\% + 0,00076\% = 0,163\%$
 $\pm \delta_V' = |\delta_V| + |\Delta S_V| = 0,266\% + 0,00076\% = 0,266\%$



Maximal possibly phase displacement of measurement winding 2a-2n ($U = 0,8 \cdot U_n$)

$\pm \delta_V'' = |\delta_V| + |\Delta \delta_V| = 1,1 \text{ min} + 0,0263 \text{ min} = 1,1 \text{ min}$
 $\pm \delta_V'' = |\delta_V| + |\Delta \delta_V| = 5,2 \text{ min} + 0,0263 \text{ min} = 5,2 \text{ min}$

ply voltage error of winding for

$$\alpha(U=0,02 \cdot U_n)$$

$$= 0,261\% + 0,03637\% = 0,297\%$$


$$= 0,179\% + 0,03637\% = 0,215\%$$

ly phase displacement of winding

$$-4\theta(U=0,02 \cdot U_n)$$

$$= 1,0 \text{ min} + 1,2512 \text{ min} = 2,25 \text{ min}$$

$$= 4,6 \text{ min} + 1,2512 \text{ min} = 5,85 \text{ min}$$



that errors derived from influence of current path on voltage path of transformers PVA145a (prototype 7-2GKP013K1486145) don't cause loss of properties (loss of accuracy class) for all secondary voltage windings. positive.

Influence of the voltage transformer on the current transformer

was performed by applying two value of voltage of power frequency 50 Hz to the primary winding of combined transformer:

Prototype 1 - PVA123a

$$1,9 \cdot 110/\sqrt{3} \text{ kV} = 121 \text{ kV}$$

$$1,2 \cdot 110/\sqrt{3} \text{ kV} = 76 \text{ kV}$$

Prototype 7 - PVA145a

$$U = 1,9 \cdot 132/\sqrt{3} \text{ kV} = 145 \text{ kV}$$

$$U = 1,2 \cdot 132/\sqrt{3} \text{ kV} = 91 \text{ kV}$$

secondary windings of current transformer were measured interfere voltages U_i , current $I_n = 5 \text{ A}$ were burdened by resistor $R = 4 \Omega$ and winding with rated



current $I_n = 1 \text{ A}$ were burdened by resistor $R = 100 \Omega$. Measurements were performed using instrument KEITHLEY type 2001 was $1 \mu\text{V}$.

For each of windings were done two measurements of interfere voltage U_i , with earthed input terminal or input terminal. The calculation were performed:

- value of interfere current $I=U_i/R$
- change of measured current error (at 5% of rated current) $\Delta\epsilon_i=(U_i \cdot 100)/(R \cdot 0,05 I_n)$
- change of measured current error (at 100% of rated current) $\Delta\epsilon_i=(U_i \cdot 100)/(R \cdot I_n)$
- change of phase displacement (in minutes) $\Delta\delta_i=\Delta\epsilon_i \cdot 34,4$

Prototype 1 - 2GKP013K1486138

Test results and calculated values are present in tables below.

Tested winding 1s1-1s2

earthed 1s1

x	U_N	U_i (R=4 Ω)	$I=U_i/R$	$\Delta\epsilon_i$	$\Delta\delta_i$
[-]	[mV]	[mV]	[mA]	[%]	[min]
1,9	1,960	0,490	0,196	0,196	6,74
1,2	1,030	0,258	0,103	0,103	3,54

Tested winding 1s1-1s2

earthed 1s2

x	U_N	U_i (R=4 Ω)	$I=U_i/R$	$\Delta\epsilon_i$	$\Delta\delta_i$
[-]	[mV]	[mV]	[mA]	[%]	[min]
1,9	1,870	0,468	0,187	0,187	6,43
1,2	1,070	0,268	0,107	0,107	3,68

Tested winding 2s1-2s2

earthed 2s1

x	U_N	U_i (R=100 Ω)	$I=U_i/R$	$\Delta\epsilon_i$	$\Delta\delta_i$
[-]	[mV]	[mV]	[mA]	[%]	[min]
1,9	10,830	0,108	0,217	0,217	7,45
1,2	5,440	0,054	0,109	0,109	3,74

2s1-2s2

earthed 2s2

U_i (R=100 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
8,810	0,088	0,176	6,06
5,580	0,056	0,112	3,84

3s1-3s2

earthed 3s1

U_i (R=4 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
0,690	0,173	0,003	0,12
0,070	0,018	0,000	0,01

3s1-3s2

earthed 3s2

U_i (R=4 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
0,480	0,120	0,002	0,08
0,100	0,025	0,001	0,02

4s1-4s2

earthed 4s1

U_i (R=100 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
1,540	0,015	0,002	0,05
0,890	0,009	0,001	0,03

4s1-4s2

earthed 4s2

U_i (R=100 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
1,590	0,016	0,002	0,05
0,940	0,009	0,001	0,03

5s1-5s2

earthed 5s1

U_i (R=100 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
0,710	0,007	0,001	0,02



Tested winding 5s1-5s2

earthed 5s2

x U _N [V]	U _i (R=100 Ω) [mV]	I=U _i /R [mA]	Δε _i [%]	Δδ _i [min]
1,9	0,490	0,005	0,000	0,02
1,2	0,120	0,001	0,000	0,00

Current transformer maximal error of combined transformer was evaluated by summarize mentioned above errors originated from influence voltage path on current path together with extreme values of errors measured during routine test at I = 0,05 · I_n; ±2 · I_n (Report No. 2GKFP013K1486138 – 12.11.2013, Annex No. 2 of hereby Report).

Below are presented chosen results of calculation in analytic and graphic form (for maximal errors).

Maximal possibly current error of winding for measurement 2S1-2S2 (I = 0,05 · I_n; ±2 · I_n)



$$\pm \epsilon_1' = |\epsilon_1| + |\Delta \epsilon_1| = 0,024\% + 0,217\% = 0,241\%$$

$$\pm \epsilon_1'' = |\epsilon_1| + |\Delta \epsilon_1| = 0,252\% + 0,217\% = 0,469\%$$

Maximal possibly phase displacement of for measurement 2S1-2S2 (I = 0,05 · I_n; ±2 · I_n)

$$\pm \delta_1' = |\delta_1| + |\Delta \delta_1| = 33,2 \text{ min} + 7,45 \text{ min} = 40,65 \text{ min}$$

$$\pm \delta_1'' = |\delta_1| + |\Delta \delta_1| = 19,3 \text{ min} + 7,45 \text{ min} = 26,75 \text{ min}$$




[Handwritten signature]

HIGH VOLTAGE LABORATORY INSTYTUT ENERGETYKI

POLAND 01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 836-30-48,
fax (+48 22) 836-60-48 e-mail: ewn@len.com.pl

EWN/145/E/13


Page 19/29



Relative current error of winding for

1-3S2 ($I = 0.05 \cdot I_n = 2 \cdot I_0$)

$I = 0.896\% + 0.003\% = 0.899\%$



Phase displacement of winding

1-3S2 ($I = 0.05 \cdot I_n = 2 \cdot I_0$)

$\delta = 8.3 \text{ min} + 0.12 \text{ min} = 8.42 \text{ min}$

Errors derived from influence of voltage path on current path of combined A 123a (prototype 1-2GKP013K1486138) not cause loss of metrological (of accuracy class) for all secondary voltage windings.

diver.

- 2GKP013K1486145

and calculated values are present in tables below.

1s1-1s2 earthed 1s1

U_1 [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
0.540	0.135	0.054	1.86
0.136	0.034	0.014	0.47



HIGH VOLTAGE LABORATORY INSTYTUT ENERGETYKI

POLAND 01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 836-30-48,
fax (+48 22) 836-30-48 e-mail: ewn@len.com.pl

EWN/145/E/13

Page 20/29

Tested winding 1s1-1s2

earthed 1s2

$x \cdot \bar{U}_N$ [-]	U_1 (R=4 Ω) [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
1.9	0.599	0.150	0.060	2.06
1.2	0.346	0.087	0.035	1.19

Tested winding 2s1-2s2

earthed 2s1

$x \cdot \bar{U}_N$ [-]	U_1 (R=100 Ω) [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
1.9	0.766	0.008	0.001	0.03
1.2	0.410	0.004	0.000	0.01

Tested winding 2s1-2s2

earthed 2s2

$x \cdot \bar{U}_N$ [-]	U_1 (R=100 Ω) [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
1.9	2.990	0.030	0.003	0.10
1.2	1.970	0.020	0.002	0.07

Tested winding 3s1-3s2

earthed 3s1

$x \cdot \bar{U}_N$ [-]	U_1 (R=4 Ω) [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
1.9	1.366	0.342	0.007	0.23
1.2	0.173	0.043	0.001	0.03

Tested winding 3s1-3s2

earthed 3s2

$x \cdot \bar{U}_N$ [-]	U_1 (R=4 Ω) [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
1.9	0.564	0.141	0.003	0.10
1.2	0.364	0.091	0.002	0.06

Tested winding 4s1-4s2

earthed 4s1

$x \cdot \bar{U}_N$ [-]	U_1 (R=100 Ω) [mV]	$I=U_1/R$ [mA]	$\Delta \epsilon_i$ [%]	$\Delta \delta_i$ [min]
1.9	1.930	0.019	0.002	0.03

1s1-4s2 earthed 4s2

U_1 (R=100 Ω) [mV]	$I = U_1/R$ [mA]	$\Delta \varepsilon_i$ [%]	$\Delta \delta_i$ [min]
2,860	0,029	0,003	0,10
1,880	0,019	0,002	0,06

transformer maximal error of combined transformer was evaluated by summarize errors originated from influence voltage path on current path together with errors measured during routine test at $I = 0,05 \cdot I_n \pm 2 \cdot I_n$

P013K1486145 - 04.12.2013, Annex No. 2 of hereby Report).

chosen results of calculation in analytic and graphic form

current error of winding for

1-1S2 ($I = 0,05 \cdot I_n \pm 2 \cdot I_n$)

= 0,441% + 0,060% = 0,501%

= 0,043% + 0,060% = 0,103%

Y phase displacement of for

1-1S2 ($I = 0,05 \cdot I_n \pm 2 \cdot I_n$)

= 17,7 min + 2,06 min = 19,76 min

= 3,1 min + 2,06 min = 5,16 min





Maximal possibly current error of winding for protection 3S1-3S2 ($I = 0,05 \cdot I_n \pm 2 \cdot I_n$)

$\pm \varepsilon_i^* = |\varepsilon_i| + |\Delta \varepsilon_i| = 0,148\% + 0,007\% = 0,155\%$

Maximal possibly phase displacement of winding for protection 3S1-3S2 ($I = 0,05 \cdot I_n \pm 2 \cdot I_n$)

$\pm \delta_i^* = |\delta_i| + |\Delta \delta_i| = 1,7 \text{ min} + 0,23 \text{ min} = 1,93 \text{ min}$



It was found that errors derived from influence of voltage path on current path of combined transformers PVA145a (prototype 7 - 2GKP013K1486145) don't cause loss of metrological properties (loss of accuracy class) for all secondary voltage windings.

Test result - positive.

4.4 Radio interference voltage measurement

According to the IEC 61869-1 RIV measurement was performed in a test circuit shown in the figure 3 (IEC/CISPR 18-2). Voltage value was measured on the resistance 300 Ω for the frequency 0,5 MHz. Before the measurement the test setup was calibrated using a stable signal generator, what resulted in estimation of the RIV correction value +24 dB. Measuring was done with a RIV meter LMZ-5. „Background noise level” was measured within the range of test voltage values 0 - 100 kV. Level of the radio interference voltage caused by the test setup, radio stations, etc. was less than

overvoltage measurement
 the test of transformers prototypes 1 (2GKP013K1486138) and 6 (44) impulse voltage was applied to the HV terminal. Maximal value of recorded which came in each secondary windings - both current and voltage requirement of Standard for impulse 0,5/50 μs and value $U_m/\sqrt{3}$ the values of transmitted overvoltages can not exceed 1,6 kV. During all the transformer were applied lightning impulses at value ten times less, that is forming linear of phenomenon, registered overvoltages should have values less than absolute peak value). Wave shapes of impulses and transmitted overvoltage were pulse voltage measuring system Dr Strauss TR-AS 200-14.

if test are presented in the table below.

Table 6: Transmitted overvoltage measurement results.

Overvoltage value $U_{pp}/2$ [V]	Prototype 1 (2GKP013K1486138)		Prototype 6 (2GKP013K1486144)	
	$U_F=160$ kV ; $U_T=16$ kV	$U_F=190$ kV ; $U_T=19$ kV	$U_F=160$ kV ; $U_T=16$ kV	$U_F=190$ kV ; $U_T=19$ kV
33,50	20,9	20,9	47,66	29,8
33,01	20,6	20,6	44,63	27,9
35,87	22,4	22,4	55,98	35,0
42,21	26,4	26,4	66,13	41,3
57,63	36,0	36,0	40,02	25,0
82,71	51,7	51,7	93,96	58,7
35,68	22,3	22,3	103,30	64,6
95,93	60,0	60,0	101,50	63,4
58,59	36,6	36,6	86,20	53,9
43,54	27,2	27,2		

at for each of secondary winding of tested transformers (prototype 1 - 15138 and 6- 2GKP013K1486144) transmitted overvoltages don't exceed value is maximum permissible value.



4.7 Discharge capacitor test

Prototype 1 - 2GKP013K1486138

Discharge capacitor test consists of ten time discharged capacitor with capacitance $C = 6 \mu V$ charged through combined transformer to voltage of value $U = 1,1 \cdot \sqrt{2} \cdot 110 / \sqrt{3} \text{ kV} \approx 100 \text{ kV}$. Before tests and before each discharge the resistance of winding was measured and temperature rise were calculated. The discharges was performed after 3 minutes, that is short as possibly time because charging capacitor and performing measurements. Additionally in purpose of checking transformer cooling the measurements of resistance of winding were performed and measurement value were used to calculation decrease of temperature during 15 minutes. Ambient temperature (initial temperature of transformer) was $T_0 = 5,8^\circ C$.

Rise of temperature was calculated according to formula:

$$\Delta T = \frac{\Delta R}{R_0 \cdot \alpha}$$

where: ΔR - increase of resistance of winding;

R_0 - resistance of winding before test;

α - temperature coefficient of resistance for copper (assumed $\alpha = 0,004$)

Results of performed test are presented in the table 7 and diagram in the figure 5.

Table 7: Rise of the temperature during discharging test results.

t [min]	R [Ω]	ΔR [Ω]	ΔT [K]
0	16310	0	0,0
3	16450	140	2,1
6	16570	260	4,0
9	16700	390	6,0
12	16820	510	7,8
15	16920	610	9,4
18	17040	730	11,2
21	17170	860	13,2
24	17290	980	15,0
27	17410	1100	16,9
30	17540	1230	18,9
33	17400	1090	16,7
36	17270	960	14,7
39	17150	840	12,9



5. LIST OF ANNEXES

Annex No. 1

Documents provided by ABB Sp. z o.o. used as base of identification of test object:

- Manufacturer Conformity Declaration No. 001/2014 (13.01.2014),
- Manufacturer Conformity Declaration No. 091/2013 (13.01.2014),
- Manufacturer Conformity Declaration No. 092/2013 (13.01.2014),
- Dimension drawing 2GKK614122/ABB R&D_TS_KU568/13 (17.12.2013),
- Dimension drawing 2GKK614123/ABB R&D_TS_KU570/13 (17.12.2013),
- Dimension drawing 2GKK614121/ABB R&D_TS_KU570/13 (17.12.2013),
- Dimension drawing 2GKK614123/ABB R&D_TS_KU571/13 (17.12.2013),
- Dimension drawing 2GKK614123/ABB R&D_TS_KU572/13 (17.12.2013),
- Rating plate of transformer SN 2GKP013K1486138
- Rating plate of transformer SN 86142/13
- Rating plate of transformer SN 86143/13
- Rating plate of transformer SN 2GKP013K1486144
- Rating plate of transformer SN 2GKP013K1486145
- Electrical diagram of transformer SN 2GKP013K1486138
- Electrical diagram of transformer SN 86142/13
- Electrical diagram of transformer SN 86143/13
- Electrical diagram of transformer SN 2GKP013K1486144
- Electrical diagram of transformer SN 2GKP013K1486145

Annex No. 2

Reports of routine test and determination of errors of combined transformers type PVA123a and PVA145a performed in Factory Laboratory of ABB sp. z o.o.

- Tests before type test and special test (Measurements before type test and special tests)
 - Report No. 2GKP013K1486138 - 12.11.2013,
- Tests before type test and special test (Measurements before type test and special tests)
 - Report No. 2GKP013K1486144 - 18.11.2013,
- Tests before type test and special test (Measurements before type test and special tests)
 - Report No. 2GKP013K1486145 - 04.12.2013,
- Tests after lightning impulse test
 - Report No. 2GKP013K1486138 - 09.12.2013,
- Tests after lightning impulse test




Fig. 5: Rise of the temperature of the transformer during discharging test
 C=60F, U=100kV.

rise of temperature $\Delta T=18,9$ K is not dangerous for insulation of combined
 Maximal permissible rise of temperature in temperature-rise test is 65 K
 51869-1, p. 6.4.1). This criterion can be applied to capacitor discharge test
 of the combined transformer during test was proper. After the test any
 leakage could be observed. It was found that metrological properties of
 transformer are comply assigned accuracy classes for separate windings and
 after tests are virtually identical to values measured before tests (No.
 6138 - 20.12.2013 - Annex No. 2).

stive.

**HIGH VOLTAGE LABORATORY
INSTYTUT ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 836-80-48,
fax (+48 22) 836-80-48 e-mail: ewn@ten.com.pl

EWN/145/E/13

Page 29/29

test. Impulse 1,2/50 μ s, full and chopped;
test voltages and detection currents.

/145/E/13-1a - 20.11.2013.
/145/E/13-1b - 09.11.2013.

oltage measurement;

f measured overvoltages transmitted to the secondary windings.
/145/E/13-2a - 21.11.2013.
/145/E/13-2b - 13.11.2013.



**LABORATORIUM WYSOKICH NAPIĘĆ
INSTYTUTU ENERGETYKI**

01-330 WARSZAWA, ul. Mory 8, tel. (+48 22) 3451242
tel. fax. (+48 22) 836-80-48, e-mail: ewn@ten.com.pl

EWN/145/E/13

ANNEX 1

ANNEX 1 for test report EWN/145/E/13

Documents provided by ABB Sp. z o.o. used as base of identification of test object:

- Manufacturer Conformity Declaration No. 001/2014 (13.01.2014),
- Manufacturer Conformity Declaration No. 091/2013 (13.01.2014),
- Manufacturer Conformity Declaration No. 092/2013 (13.01.2014),
- Dimension drawing 2GKK614122/ABB R&D_TS_KU568/13 (17.12.2013),
- Dimension drawing 2GKK614123/ABB R&D_TS_KU570/13 (17.12.2013),
- Dimension drawing 2GKK614121/ABB R&D_TS_KU570/13 (17.12.2013),
- Dimension drawing 2GKK614123/ABB R&D_TS_KU571/13 (17.12.2013),
- Dimension drawing 2GKK614123/ABB R&D_TS_KU572/13 (17.12.2013),
- Rating plate of transformer SN 2GKP013K1486138
- Rating plate of transformer SN 86142/13
- Rating plate of transformer SN 86143/13
- Rating plate of transformer SN 2GKP013K1486144
- Rating plate of transformer SN 2GKP013K1486145
- Electrical diagram of transformer SN 2GKP013K1486138
- Electrical diagram of transformer SN 86142/13
- Electrical diagram of transformer SN 86143/13
- Electrical diagram of transformer SN 2GKP013K1486144
- Electrical diagram of transformer SN 2GKP013K1486145



ABB Sp. z o.o.

Declaration of conformity

ABB Sp. z o.o.
Dept. in Przasnysz
POLAND

DECLARATION OF CONFORMITY No. 001/2014 (EN)
(acc. to ISO/IEC 17050-1)

Manufacturer: ABB Sp. z o.o. Dept. in Przasnysz

Address: Str. Leszno 59
06-300 Przasnysz / POLAND

Product: Combined Instrument Transformer PVA 123A

Above mentioned product conforms with the following standard:

Standard	Title	Edition/Date
IEC 61869 - 4	Combined Instrument Transformers	2013

Additional information:
Serial numbers: 2GKFP013K1486138;

Place and date of issue of declaration

Przasnysz 13.01.2014

ABB
ABB Sp. z o.o.
ul. Zagańska 1, 04-713 Warszawa
NIP: 526-030-44-84, PL 5260304484
Region 010017169
ODZIAŁ W PRZASNYSZU
ul. Leszno 59, 06-300 Przasnysz
tel. (22) 223 8621, fax (22) 223 8658
(8)

Biuro ds. Rozliczeń Zamówień
ABB Sp. z o.o.
ul. w Przasnyszu
Przasnysz

Biuro ds. Zapewnienia Jakości
ABB Sp. z o.o.
Oddział w Przasnyszu
Przasnysz
Krzysztof Lubnicki
(Signature)



ABB Sp. z o.o.

Declaration of conformity

ABB Sp. z o.o.
Dept. in Przasnysz
POLAND

DECLARATION OF CONFORMITY No. 091/2013 (EN)
(acc. to ISO/IEC 17050-1)

Manufacturer: ABB Sp. z o.o. Dept. in Przasnysz

Address: Str. Leszno 59
06-300 Przasnysz / POLAND

Product: Combined Instrument Transformer PVA 145A

Above mentioned product conforms with the following standard:

Standard	Title	Edition/Date
IEC 61869 - 4	Combined Instrument Transformers	2013

Additional information:
Serial numbers: 2GKFP013K1486144;


Place and date of issue of declaration

Przasnysz 13.01.2014

ABB
ABB Sp. z o.o.
ul. Zagańska 1, 04-713 Warszawa
NIP: 526-030-44-84, PL 5260304484
Region 010017169
ODZIAŁ W PRZASNYSZU
ul. Leszno 59, 06-300 Przasnysz
tel. (22) 223 8621, fax (22) 223 8658
(8)

Biuro ds. Rozliczeń Zamówień
ABB Sp. z o.o.
ul. w Przasnyszu
Przasnysz

Biuro ds. Zapewnienia Jakości
ABB Sp. z o.o.
Oddział w Przasnyszu
Przasnysz
Krzysztof Lubnicki
(Signature)



A scale 1:10

P2/A

Primary terminals: 1, 2

B scale 1:3

Flat terminals - Aluminium alloy DIN 462

C scale 1:3

Earthing terminals

Mechanical load

Maximum operating voltage	(kV)	126
Total weight	(kg)	540
Insulating oil amount	(kg)	150
Wind pressure surface	(m ²)	1,03
Creepage distance	(mm)	3800
Mechanical load		
FR - Static load	(kN)	3,6
FR - Dynamic load	(kN)	5,0

Standard IEC 61869-4

Prepared by	Date	Replacement of	Scale
P. Grysztor	17.12.2013		
Checked by	Date	Responsible department	Title
Z. Wesolowski	17.12.2013	PPHV	Dimensional drawing
Approved by	Date	Take over department	Combined instrument transformer
M. Tarnowski	17.12.2013		PVA 123a-145a
Revision			
A			

ABB ABB Sp. z o.o. Power Products Document no. 2002114122/ABB_R40_TS_MUS8/13

ABB Sp. z o.o.
 Declaration of conformity
 ABB Sp. z o.o.
 Dept. in Przasnysz
 POLAND

DECLARATION OF CONFORMITY No. 092/2013 (EN)
 (acc. to ISO/IEC 17050-1)

Manufacturer: **ABB Sp. z o.o. Dept. in Przasnysz**

Str. Leszno 59
 06-300 Przasnysz / POLAND

Combined Instrument Transformer PVA 145a

mentioned product conforms with the following standard :

Title: **Combined Instrument Transformers**
 Edition/Date: **2013**

Standard: **IEC 61869-4**

Additional information:
 Numbers: **ZGKP013K1436145;**

ABB Sp. z o.o.
 ul. Zagajnikowa 59, 04-713 Warszawa
 NIP: 525-050444-68, KRS: PL 5269004494
 REGON: 1410017168
 PVA 145 W. P. R. Z. A. S. N. Y. S. Z. U.
 ul. Leszno 59, 06-300 Przasnysz
 tel. (22) 223 8921, fax (22) 223 8950


in-tytuł: Realizacja Zamówienia
 ABB Sp. z o.o.
 Oddział w Przasnysz
 Osiedle w Przasnysz
 ul. Leszno 59

in-tytuł: Zapięcie wzdłuż
 ABB Sp. z o.o.
 Oddział w Przasnysz
 Osiedle w Przasnysz

(Signature)

Name

Issue date of declaration: **13.01.2014**



A
scale 1:10

B
scale 1:5

C
scale 1:3

D
scale 1:4

Primary terminals: 1, 2

Flat terminals - Aluminium alloy

Earthing terminals

Mechanical load


Maximum operating voltage	(kV)	1
Total weight	(kg)	6
Insulating oil amount	(kg)	1
Wind pressure surface	(m ²)	1
Creepage distance	(mm)	44
Mechanical load:		
F _R - Static load	(kN)	3
F _R - Dynamic load	(kN)	5

Standard IEC 61869-4

Prepared by	Date	Place/area of	Scale
P.Grysztar	17.12.2013		
Modified by	Date	Responsible department	Title
Z.Wesołowski	17.12.2013	PPHV	
Approved by	Date	Task over department	
M.Farnowski	17.12.2013		
Revision			
A			

ABB ABB Sp. z o.o. Power Products Document no. P000514121/ABB P40_75_M1870/1

Dimensional drawing
Combined instrument transformer
PVA 123a-145



A
scale 1:10

B
scale 1:3

C
scale 1:3

D
scale 1:4

Primary terminals: 1, 2

Flat terminals - Aluminium alloy

Earthing terminals

Mechanical load


Maximum operating voltage	(kV)	145
Total weight	(kg)	520
Insulating oil amount	(kg)	150
Wind pressure surface	(m ²)	1,03
Creepage distance	(mm)	440

Standard IEC 61869-4

Prepared by	Date	Place/area of	Scale
P.Grysztar	17.12.2013		
Modified by	Date	Responsible department	Title
Z.Wesołowski	17.12.2013	PPHV	
Approved by	Date	Task over department	
M.Farnowski	17.12.2013		
Revision			
A			

ABB ABB Sp. z o.o. Power Products Document no. P000514121/ABB P40_75_M1870/1

Dimensional drawing
Combined instrument transformer
PVA 123a-150



A
scale 1:10

P2/A
300 A 150 A
Primary terminals
1 2

Flat terminals - Aluminium alloy
DIN 462

B
scale 1:3

Earthing terminals
C
scale 1:3


Mechanical load

Maximum operating voltage	(kV)	145
Total weight	(kg)	540
Insulating oil amount	(kg)	150
Wind pressure surface	(m ²)	1,03
Creepage distance	(mm)	4495
Mechanical load:		
FR - Static load	(kN)	3,6
FR' - Dynamic load	(kN)	5,0

Standard IEC 61869-4

Prepared by P.Grysztar	Date 17.12.2013	Replacement of	Scale 1:1
Modified by Z.Wesołowski	Date 17.12.2013	Responsible department PPHV	Dimensional drawing Combined instrument transformer PVA 12.3a-145a
Approved by M.Tarnowski	Date 17.12.2013	Take over department	
Revision A			Document no. 2200514123/ABB PAV_TL_KU572/13

ABB ABB Sp. z o.o. Power Products



A
scale 1:10

P2/A
600 A 300 A
Primary terminals
1 2

Flat terminals - Aluminium alloy
DIN 462

B
scale 1:3

Earthing terminals
C
scale 1:3

Mechanical load

Maximum operating voltage	(kV)	145
Total weight	(kg)	540
Insulating oil amount	(kg)	150
Wind pressure surface	(m ²)	1,03
Creepage distance	(mm)	4495



Combined Instrument Transformer

Type **PVA 145a**

Insulation level **145/275/650kV** Standard **IEC 61869-4** fn **50 Hz**
 Oil type **Nytro Libra** Weight / Oil weight **520 / 150 kg** Temp. range **-40°C → +40°C**
 S/N **86142 / 13** Voltage factor **1,9Un/8h** Ue **0,2 mV/kA**

CURRENT PART

VOLTAGE PART

K_n **150-300-600/5-5** A/A

A-N **132:√3** kV

I_{th}/1s **40-40-40 kA** I_{dyn} **100-100-100 kA**

I_{cth} **180-360-720 A**

	1S1-1S2	2S1-2S2	3S1-3S2	4S1-4S2	5S1-5S2	6S1-6S2
A	5	5				
VA	30	30				
Class	5P	5P				
FS/ALF	20	20				
Ext.%						

	1a-1n	2a-2n	3a-3n	4a-4n	da-dn
V	110:√3	110:√3			
VA	25	25			
Class	0,5	0,5/3P			
VA _{sn}	1000	1000			

Transportation **Vertical / Horizontal**



Combined Instrument Transformer

Type **PVA 123a**

Insulation level **126/230/550 kV** Standard **IEC 61869-4** fn **50 Hz**
 Oil type **Nytro Libra** Weight / Oil weight **540 / 150 kg** Temp. range **-50°C → +40°C**
 S/N **2GKP013K1486138** Voltage factor **1,9Un/8h** Ue **0,2 mV/kA**

CURRENT PART

VOLTAGE PART

K_n **50-100-200 / 5-1-5-1-1** A/A

A-N **110:√3** kV

I_{th}/1s **40 - 63 - 63 kA** I_{dyn} **100 - 158 - 158 kA**

I_{cth} **100 - 200 - 400 A**

	A	VA	class	FS/ALF	Ext.%
1S1-1S2	5	1 → 5	0,5	5	200
2S1-2S2	1	1 → 2,5	0,5	10	200
3S1-3S2	5	10	5P	10	-
		2,5	5P	80	-
4S1-4S2	1	Rb=3,5Ω, class PX, 4-2-1/200, Ek=190 V, Ie<=0.1 A / 95 V, Rct<=0.3Ω, Kv=50			

	1a-1n	2a-2n	3a-3n	4a-4n	da-dn
V	100:√3	100:√3	100:√3	100:√3	100:3
VA	25	25	25	25	100
Klasa	0,1	0,1	0,1/3P	0,1/3P	1,0
VA	(25)	(25)	(500)	(25)	300)
Klasa	(3)	(3)	(3/3P)	(3/3P)	(3P)