





Copy of marking plate and product

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBS that own these marks.



ВЯРНО С
ОРИГИНАЛА



242

<p>Test item particulars:</p> <p>Classification of installation and use:, Fuses for use by authorized persons</p> <p>Supply Connection:, At both sides</p>
<p>Possible test case verdicts:</p> <p>- test case does not apply to the test object: N/A</p> <p>- test object does meet the requirement: P (Pass)</p> <p>- test object does not meet the requirement: F (Fail)</p>
<p>Testing:</p> <p>Date of receipt of test item: 10.03.2015</p> <p>Date (s) of performance of tests: 13.03.2015 – 15.03.2015</p>
<p>General remarks:</p> <p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the issuing testing laboratory.</p> <p>"(see Enclosure #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p>
<p>Manufacturer's Declaration per sub-clause 6.2.5 of IEC60362-2:</p> <p>The application for obtaining a CB Test Certificate <input type="checkbox"/> Yes includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided:</p> <p>When differences exist, they shall be identified in the General product information section.</p> <p>Name and address of factory (ies):</p>


Clause	Requirement + Test	Result - Remark	Verdict
CHARACTERISTICS OF FUSES			
5.2	Rated voltage (V) as specified	500 V	P
5.3.1	Rated current (A) of the fuse-link in accordance with specified values	63, 80, 100, 125, 160, 200, 250, 315, 400 A	P
5.3.2	Rated current (A) of the fuse-holder	400 A	P
5.4	Rated frequency (Hz)	50 Hz	P
5.5	Max. rated power dissipation (VA) of fuse-link	34 W	P
	Rated acceptable power dissipation (VA) of fuse-holder	45 W	P
5.6	Limits of time-current characteristics based on reference ambient air temperature T_a of +20°C	+20°C	P
5.6.1	Time-current zones deviated from standardized, or available in manufacturers documentation (with tolerances)		N/A
5.6.2	Conventional times and currents see Table 2		P
5.6.3	Gates		P
5.7	Breaking range and breaking capacity		
5.7.1	Breaking range and utilization category	gL/gG	P
5.7.2	Rated breaking capacity (A) of fuse-link corresponds to the rated voltage (V), and is equal or higher than given minimum (A) in subsequent part of this standard	100 kA/500 V	P
5.8	Cut-off current and I^2t characteristics are referred to the values of voltage, frequency and power factor		P
5.8.1	Cut-off current characteristics. If required, given by the manufacturer according to Figure 4		P
5.8.2	Pre-arcing I^2t characteristics for pre-arcing times of less than 0,1 s down to a time corresponding to the rated breaking capacity given by the manufacturer		P
	The operating I^2t characteristics with specified voltages as parameter for pre-arcing times less than 0,1 s given by the manufacturer		P

Clause	Requirement + Test	Result - Remark	Verdict
MARKINGS			
	Markings are durable and easily legible		P
6.1	Fuse-holders marked by: - name of manufacturer or trade mark which enable identification of fuse-holder - manufacturer's identification reference enabling to find all characteristics listed in 5.1.1 - rated voltage (V) - rated current (A) - kind of current and rated frequency (Hz)	FEDERAL NH2-FA 690 V 400 A ~	P P P P P
6.2	Fuse-link(s) except small fuse-link(s) marked by: - name of manufacturer or trade mark which enable identification of fuse-links - manufacturer's identification reference enabling to find all characteristics listed in 5.1.2 - rated voltage (V) - rated current (A) - breaking range and utilization category (if applicable) (5.7.1) - kind of current - rated frequency (Hz), if applicable (5.4)	FEDERAL NH2-FB 500 V 63, 80, 100, 125, 160, 200, 250, 315, 400 A gL/gG ~	P P P P P N/A
	Small fuse-links marked by: - trademark - list reference of manufacturer - rated voltage (V) - rated current (A)		N/A N/A N/A N/A
6.3	Symbols for the kind of current and frequency in accordance with IEC 60417		P

Handwritten signature

Handwritten signature


**ВЕРНО С
ОПРЕДЕЛЕНИЕМ**



Clause	Requirement + Test	Result - Remark	Verdict
STANDARD CONDITIONS FOR CONSTRUCTION			
7.1	Mechanical design		P
7.1.1	Replacement of fuse-links easily and safely		P
7.1.2	Connections, including terminals		P
	Contact force is not transmitted through insulating material other than ceramic or other material with characteristics not less suitable, unless there is sufficient resilience in the metallic parts to compensate any possible shrinkage or other deformation of the insulating material		P
	Terminals cannot turn or be displaced when the connecting screws are tightened		P
	Terminals shall be such, that the conductors cannot be displaced		P
	Parts gripping the conductors are of metal		P
	Gripping parts cannot unduly damage conductors		P
	Terminals readily accessible under the intended conditions of installation		P
7.1.3	Fuse-contacts		P
	Fuse-contacts are such that necessary contact force is maintained under the conditions of service and operation		P
	Contact is such that electromagnetic forces occurring during operation under conditions in accordance with 7.5 not impair electrical connections between		N/A
	a) fuse-base and fuse-carrier		N/A
	b) fuse-carrier and fuse-link		P
	c) fuse-link and fuse-base		P
	Fuse contacts are so constructed and of such material that, when fuse is properly installed and service conditions are normal, adequate contact is maintained		P
	a) after repeated engagement and disengagement		P
	b) after being left undisturbed in service for long period		P
7.1.4	Construction of a gauge-piece		N/A
	Gauge-piece is so designed that it withstands normal stresses occurring during use		N/A
7.1.5	Mechanical strength of fuse-link		P
	Fuse-link have adequate mechanical strength and its contacts are securely fixed		P
7.2	Insulating properties and suitability for isolation		P

Report No: 0315.15-5

ВЕРНО С
ОРИГИНАЛОМ



244


Clause	Requirement + Test	Result - Remark	Verdict
	Fuses are such that they do not lose insulating properties at voltages to which they are subjected in normal service		P
	Fuse passes the tests for verification of insulating properties and suitability for isolation in accordance with 8.2		P
7.3	Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of the fuse-tripster		P
	See Table 5		P
7.4	Operation		P
	Fuse-link is so designed and proportioned that, when tested in its appropriate test arrangement at rated frequency and ambient air temperature of (20±5)°C		P
	- is able to carry continuously any current not exceeding its rated current		P
	- is able to withstand overload conditions as they may occur in normal service (see 8.4.3.4)		P
	Fuse-link satisfy these conditions if it passes the tests prescribed in 8.4		P
7.5	Breaking capacity		P
	Fuse is capable of breaking, at rated frequency and at voltage not exceeding the recovery voltage specified in 8.5, any circuit having prospective current between		P
	- current I _b (for "g" fuse-links)		N/A
	- current I _{gh} (for "a" fuse-links)		N/A
	- for a.c. rated breaking capacity at power factors not lower than those in Table 20	100 kA	P
	- for d.c. rated breaking capacity at time constants not greater than those limits in Table 21		N/A
	Arc voltage not exceed values given in Table 6		P
	Fuse satisfy these conditions if it passes the tests prescribed in 8.5		P
7.6	Cut-off current characteristic		P

Report No: 0315.15-5

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	Values of cut-off current measured as specified in 8.6 are less than, or equal to, the values corresponding to cut-off current characteristics assigned by the manufacturer		P
7.7	I_A characteristics		
	Pre-arcing I_A values verified according to 8.7 (Table 7)		P
	Operating I_A values verified according to 8.7		P
7.8	Overcurrent discrimination of fuse-links		P
7.9	Protection against electric shock		
	The degree of protection when the fuse is under normal service conditions: IP		N/A
	The degree of protection when replacing the fuse-link: IP		N/A
	The degree of protection when the fuse-link and fuse-carrier is removed: IP		N/A
7.9.1	Clearances and creepage distances		
	Clearances are not less than the values given in Table 9	See Clause 8.2.3	P
	Creepage distances correspond to material group, as defined in 2.7.1.3 of IEC 60664-1, corresponding with rated voltage given in Table 10	See Clause 8.2.3	P
7.9.2	Leakage currents of fuses suitable for isolation		
	Value of leakage current (mA) not exceed		
	- 0.5 mA per pole for fuses in new conditions	< 0.05 mA	P
	- 2 mA per pole for fuses having been submitted to test according to 8.5		-
7.9.3	Additional constructional requirements for fuses for linked fuse-carriers, suitable for isolation		
	Fuse-holder are marked with the symbol IEC 60617-S00369		N/A
	When fuse is in open position, with fuse-link remaining inside the fuse-carrier, isolating distance between the fuse contacts in accordance with the isolating function are provided		N/A
	Indication of this position is provided by the position of the fuse-carrier		N/A
	There exists a locking means in order to lock the fuses in the isolated position, locking is possible only in this position		N/A

ВЕРНО С
ОРИГИНАЛОМ



245

[Handwritten signature]


Clause	Requirement + Test	Result - Remark	Verdict
	Fuses are designed so that the fuse-carrier remains attached to the fuse-base giving correct indication of the open position, and of locking		N/A
7.10	Resistance to heat		
	All components are sufficiently resistant to heat which may occur in normal use (see 8.9 and 8.10)		P
7.11	Mechanical strength		
	All components of fuse are sufficiently resistant to mechanical stresses which may occur in normal use (see 8.3 to 8.5 and 8.11.1)		P
7.12	Resistance to corrosion		
	All metallic components of fuse are resistant to corrosive influences which may occur in normal use		P
7.12.1	Resistance to rusting		
	Ferrous components are so protected that they meet relevant tests (see 8.2.2.3.2 and 8.11.2.3)		P
7.12.2	Resistance to season cracking		
	Current-carrying parts are sufficiently resistant to season cracking (see 8.2.2.3.2 and 8.11.2.1)		P
7.13	Resistance to abnormal heat and fire		
	All components of fuse are sufficiently resistant to abnormal heat and fire (see 8.11.2.2)		P
7.14	Electromagnetic compatibility		
	Fuses within the scope of this standard are not sensitive to normal electromagnetic disturbances		N/A
	No immunity tests are required		N/A

Clause	Requirement + Test	Result - Remark	Verdict
8.1.2	At the beginning of each test, the fuse is approximately at the ambient temperature		P
8.1.3	Tests made on fuses in clean and dry condition		P
8.1.4	Arrangement of the fuse and dimensions		P
	Except for degree of protection test (see 8.8), fuse are mounted in free air in draught-free surroundings in the normal operation position and on insulating material of sufficient rigidity		P
	Before tests are started, specified external dimensions are measured and results compared with dimensions specified in the relevant data sheet of the manufacturer or specified in subsequent parts	Part 2, Figure 101	P
8.1.5	Testing of fuse-links		
	Fuse-links tested with the kind(s) of current for which they are rated	AC	P
	Fuse-links tested for a.c. with frequency for which they are rated	50 Hz	P
8.1.5.1	Complete tests		
	Internal resistance R measured by a current $\leq 0,1$ in		P
	Measuring current (A) : 0,3		P
	Ambient air temperature in range of 20 ± 5 °C		P
	The values of resistance	(see appended table)	P
8.1.5.2	Testing of fuse-links of a homogeneous series		P
	Fuse-links tested like a homogeneous series	Yes/No	P
	If yes: (fuse-links have identical enclosures in form and construction (except of fuse-elements and contacts)		P
	- the same arc-extinguishing medium and same completeness of filling		P
	- fuse-elements of identical materials		P
	- their cross-section of fuse-elements not exceed the cross-section of fuse-links having the highest rated current		P
	- number of fuse-elements do not exceed number of fuse-elements of fuse-links with the highest rated current		P
	- minimum distances between adjacent fuse-elements and between the fuse-elements and the inner surface of the cartridge is not less than those in the fuse-link with the highest rated current		P

Clause	Requirement + Test	Result - Remark	Verdict
	- fuse-links used with a given fuse-holder, or		P
	- fuse-links intended to be used in an arrangement identical for all rated currents of the homogeneous series		P
	- value of $R_{i,32}$ does not exceed the value for the fuse-link with largest rated current of the homogeneous series (R measured as indicated in 8.1.5.1)		P
	the rated breaking capacity of fuse-links not greater than that of the fuse-link with the largest rated current within the homogeneous series		P
	- if not, the fuse-links with greater breaking capacity subjected to tests no. 1 and no. 2		N/A
	The fuse-link having the largest rated current tested completely according to Table 11	400 A	P
	The fuse-link having the smallest rated current tested only according to Table 12	63 A	P
	The fuse-links between the largest and smallest rated current tested according to Table 13	80 A, 100 A, 125 A, 160 A, 200, 250, 315 A	P
8.1.6	Testing of fuse-holders		
	The fuse-holders are subjected to the tests according to Table 14		P
8.2	Verification of the insulating properties and of the suitability for isolation		P
8.2.1	Arrangement of the fuse-holder		
	The fuse-holder fitted with a fuse-links of the largest dimensions for the type of fuse-holder concerned		P
	The fuse-base fixed to a metal plate, unless otherwise specified		P
	Fuse-link is replaced while five - surfaces of fuse-link, of device for replacing it or of fuse-carrier, if of insulating material, are provided with metal coverings connected during tests to the frame of the apparatus; if of metal, they are connected direct to the frame		P
8.2.2	Verification of the insulating properties		
	Points of application of the test voltage	1890 V	P
	The test voltage is applied between:		
	a) live parts and the frame with the fuse-link and the device for replacing it, or		P
	the fuse-carrier, if any, in position		N/A
	no breakdown of insulation or flashover during 1 min of the applying test voltage		P

[Handwritten signature]


ВЕРНО С
ОРИГИНАЛА



9/18

Clause	Requirement + Test	Result - Remark	Verdict
	b) the terminals without fuse-link, device for replacing on the fuse-carrier		P
	no breakdown of insulation or flashover during 1 min of the applying test voltage		P
	c) live parts of different polarity in the case of multipole fuse-holder with fuse-links, fuse-carrier(s) or device(s) for replacing the fuse-links		N/A
	no breakdown of insulation or flashover during 1 min of the applying test voltage		N/A
	d) live parts which in the case of a multipole fuse-holder reach different potential after the fuse-link operates (equipped by fuse-carrier or device for replacing without fuse-link)		N/A
	no breakdown of insulation or flashover during 1 min of the applying test voltage		N/A
	The values of test voltage (V) as specified in Table 15	1850 V	P
8.2.2.3.2	Fuse-holder is subjected to humid atmospheric conditions		P
	Relative humidity of ambient air (%)	%95	P
	Ambient air temperature (°C)	25 °C	P
	Duration of treatment (h)	48 h	P
	Insulation resistance is measured between the points prescribed in 8.2.2.1 by applying d.c. voltage of approximately 500 V		P
	Points of measuring:		
	a) min. measured value (MΩ)	> 1 MΩ	P
	b) min. measured value (MΩ)	> 1 MΩ	P
	c) min. measured value (MΩ)		N/A
	d) min. measured value (MΩ)		N/A
	The insulation resistance not less than 1 MΩ		P
8.2.3	Verification of the suitability for isolation		
	Clearances and creepage distances are verified by dimensional measurement and by voltage test		
	Points of application of the test voltage		N/A
	The test voltage is applied between:		
	terminals when the fuse-link and device for replacing it, are removed		N/A
	Test voltage (kV) for verification of the rated impulse withstand voltage is given in Table 16		N/A

ВЕРНО С
ОРИГИНАЛА



Report No: 0315.15-5


244

Clause	Requirement + Test	Result - Remark	Verdict
	The 1,2/50 μs impulse voltage applied 5 times for each polarity at intervals of 1 s minimum		N/A
	no breakdown of insulation or flashover during of the applying test voltage		N/A
	no disruptive discharge during the test		N/A
8.2.4.2	Fuse-holder is subjected to humid atmospheric conditions		N/A
	Relative humidity of ambient air (%)	%95	P
	Ambient air temperature (°C)	25 °C	P
	Duration of treatment (h)	48 h	P
	Insulation resistance is measured between the points prescribed in 8.2.2.1 by applying d.c. voltage of approximately 500 V		P
	Points of measuring:		
	a) min. measured value (MΩ)	> 1 MΩ	P
	b) min. measured value (MΩ)	> 1 MΩ	P
	c) min. measured value (MΩ)		N/A
	d) min. measured value (MΩ)		N/A
	The insulation resistance not less than 1 MΩ		P
8.3	Verification of temperature rise and power dissipation		
8.3.1	One fuse used for test (unless otherwise stated by the manufacturer) mounted in free air		P
	Test performed at an ambient air temperature of (20±5) °C	20°C	P
	Ambient air temperature during the test (°C)		P
	Cross-sectional area (see Table 17) (mm ² or mm x mm)	240 mm ²	P
	Tightened by torque; torque (Nm)	32 Nm	P
8.3.2	The temperature of the fuse measured by method of measuring	Thermocouples	P
8.3.3	Measurement of the power dissipation of the fuse-link		
	One fuse used for test (unless otherwise stated by the manufacturer) mounted in free air		P
	Test performed at an ambient air temperature of (20±5) °C		P
	Ambient air temperature during the test (°C)	22°C	P
	Cross-sectional area (see Table 17) (mm ² or mm x mm)	240 mm ²	P
	Tightened by torque; torque (Nm)	32 Nm	P
8.3.4.1	Temperature rise of the fuse-holder		

[Handwritten signature]

Report No: 0315.15-5

Clause	Requirement + Test	Result - Remark	Verdict
	Applied a.c. current (A) for test equal to the rated current of the fuse-holder	400 A	P
	Test made with fuse-link (A), or with a dummy fuse-link specified in subsequent parts	Part 2 Figure 105	P
	Temperature rise limits T for contacts and terminals (Table 5): spring loaded contacts (silver plated; limited only by the necessity of not causing any damage to adjacent parts)	unenclosed / enclosed 47K	P
	bolted contacts, limit (K)	unenclosed / enclosed	N/A
	terminals; (silver plated) limits 70 K	unenclosed / enclosed 40K	P
8.3.4.2	Power dissipation of a fuse-link The test made with a.c. at the current (A) equal to the rated current of the fuse-link	400 A	P
	The points of measuring	Part 2 Figure 106, S points	P
	Measured value of power (W) dissipation in limits (W) specified in subsequent parts	24,8 W	P
8.3.5	The acceptable power dissipation (W) of fuse-holder not less than the rated power dissipation of the corresponding fuse-links After the tests prescribed in 8.3, the insulating parts of the fuse-holders cooled down to ambient temperature withstood the test voltage according to 8.2	45 W	P
	No deformation after tests of 8.3		P
8.4	Verification of operation		P
8.4.1	The test arrangement as specified in 8.1.4 Length (m) of conductors (see 8.3.1) as specified in their cross-sectional area (mm ²) as specified in table 17	2 m 16 mm ² (63 fuse-links) 25 mm ² (80A fuse-link) 35 mm ² (100A fuse-link) 50 mm ² (125A fuse-link) 70 mm ² (160A fuse-link) 95 mm ² (200A fuse-link) 120 mm ² (250A fuse-link) 185 mm ² (315A fuse-links) 240 mm ² (400A fuse-links)	P
8.4.2	Ambient air temperature during test within (20±5) °C	20-22 °C	P
8.4.3.1	Verification of conventional non-fusing and fusing current		P




248

Clause	Requirement + Test	Result - Remark	Verdict
	a) the fuse-link subjected to the conventional non-fusing current (I _n) (see Table 2)	1,25 I _n	P
	the fuse-link did not operate within the conventional time of (t) (Table 2)	1 h (63A) 2 h (80A, 100A, 125A, 160A) 3 h (200A, 250A, 315A, 400A)	P
	b) the same fuse-link, after cooled down to ambient temperature, subjected to the conventional fusing current (I _f) (see Table 2)	1,6 I _n	P
	the fuse-link operated within the conventional time of (minutes) (Table 2)	35 min (63A fuse-link) 27 min (80A fuse-link) 33 min (100A fuse-link) 44 min (125A fuse-link) 39 min (160A fuse-link) 50 min (200A fuse-link) 41 min (250A fuse-link) 58 min (315A fuse-link) 43 min (400A fuse-link)	P
8.4.3.2	Verification of rated current of "g" fuse-links One fuse-link submitted to a pulse test for 100 h	100h	P
	On-period equal to conventional time (t)	1 h (63A) 2 h (80A, 100A, 125A, 160A) 3 h (200A, 250A, 315A, 400A)	P
	Off-period of 0,1 of the conventional time	0,1 h (63A) 0,2 h (80A, 100A, 125A, 160A) 0,3 h (200A, 250A, 315A, 400A)	P
	Test current (A) equal to 1,05 of the rated current	1,05 I _n	P
	After the test, the fuse-link not have changed its characteristics		P
8.4.3.1	a) the fuse-link subjected to the conventional non-fusing current (I _n) (see Table 2)	1,25 I _n	P
	the fuse-link did not operate within the conventional time of (t) (Table 2)	1 h (63A) 2 h (80A, 100A, 125A, 160A) 3 h (200A, 250A, 315A, 400A)	P
8.4.3.3	Verification of time-current characteristics and gaites		P
8.4.3.3.1	The time-current characteristics verified on the basis of the test according to 8.5 Values of pre-arcing and operating times within the time-current zones: - indicated by the manufacturer - specified in subsequent parts		P
	Verification for smaller current ratings, if only one largest rated current fuse-link is subjected to the test according to 8.5 (in case of homogeneous series): "g" fuse-links (except "gD", "gS" and "gM")		N/A

Emilio

Clause	Requirement + Test	Result - Remark	Verdict
	Tests made in connection with verification of the gates (see 8.4.3.3.2)		N/A
	Ambient air temperature within (20±5) °C		N/A
	rated current I _n (A) of the fuse-link		
	test performed at voltage (V)		
	test 3a) prospective current (A) equal to I _n (10 ≤ k ≤ 20)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max./min.		N/A
	test 4a) prospective current (A) equal to I _n (5 ≤ k ≤ 8)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max./min.		N/A
	test 5a) prospective current (A) equal to I _n (2.5 ≤ k ≤ 4)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max./min.		N/A
	Verification for smaller current ratings, if only one largest rated current fuse-link is subjected to the test according to 8.5 (in case of homogeneous series):		
	"a" fuse-links		N/A
	Ambient air temperature within (20±5) °C		N/A
	rated current I _n (A) of the fuse-link		
	test performed at voltage (V)		
	test 3a) prospective current (A) equal to nI _n (5 ≤ n ≤ 8)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max./min.		N/A
	test 4a) prospective current (A) equal to nI _n (2 ≤ n ≤ 3)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max./min.		N/A
	test 5a) prospective current (A) equal to nI _n (1.5 ≤ n ≤ 1.5)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max./min.		N/A
8.4.3.3.2	Verification of gates "g1" and "g1f" fuse-links		N/A
			P
			P

Report No: 0315.15-5



ВЕРНО С
ОПРЕДЕЛЕНАТА

5/18


Clause	Requirement + Test	Result - Remark	Verdict
	rated current of the fuse-link (A)	63, 80, 100, 125, 160, 200, 250, 315, 400 A	
	test performed at voltage (V)	10-15 V	
	a) testing current (A); pre-arcing time (s) higher than 10 s	160A; >10 s (63A fuse-link) 220A; >10 s (80A fuse-link) 298A; >10 s (100A fuse-link) 365A; >10 s (125A fuse-link) 470A; >10 s (160A fuse-link) 618A; >10 s (200A fuse-link) 761A; >10 s (250A fuse-link) 1058A; >10 s (315A fuse-link) 1433A; >10 s (400A fuse-link)	P
	b) testing current (A); pre-arcing time (s) less than 5 s	320A; 2,9 s (63A fuse-link) 428A; 2,8 s (80A fuse-link) 582A; 2,8 s (100A fuse-link) 716A; 3,2 s (125A fuse-link) 952A; 3,0 s (160A fuse-link) 1254A; 3,3 s (200A fuse-link) 1655A; 2,4 s (250A fuse-link) 2205A; 3,0 s (200A fuse-link) 2844A; 2,9 s (250A fuse-link)	P
	c) testing current (A); pre-arcing time (s) higher than 0,1 s	450A; 0,43 s (63A fuse-link) 612A; 0,48 s (80A fuse-link) 828A; 0,60 s (100A fuse-link) 1114A; 0,47 s (125A fuse-link) 1452A; 0,35 s (160A fuse-link) 1921A; 0,44 s (200A fuse-link) 2601A; 0,34 s (250A fuse-link) 3421A; 0,35 s (315A fuse-link) 4555A; 0,44 s (400A fuse-link)	P
	d) testing current (A); pre-arcing time (s) less than 0,1 s	820A; 35 ms (63A fuse-link) 1115A; 35 ms (80A fuse-link) 1453A; 47 ms (100A fuse-link) 1921A; 45 ms (125A fuse-link) 2597A; 30 ms (160A fuse-link) 3428A; 16 ms (200A fuse-link) 4510A; 18 ms (250A fuse-link) 6018A; 18 ms (315A fuse-link) 8077A; 20 ms (400A fuse-link)	P
	"g1f" fuse-links		N/A
	rated current of the fuse-link (A)		
	test performed at voltage (V)		

Report No: 0315.15-5

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	Cross-sectional area (see Table 18) (mm ² or mm x mm)		
	e) testing current (A); pre-arcing time (s) higher than 60 s		N/A
	f) testing current (A); pre-arcing time (s) less than 60 s		N/A
	g) testing current (A); pre-arcing time (s) higher than 0,2 s		N/A
	h) testing current (A); pre-arcing time (s) less than 0,10 s		N/A
8.4.3.4	Overload The test arrangement is same as that for the temperature rise test (see 8.3.1) Three fuse-links submitted to 50 pulses having the same duration and test current test performed at voltage (V) *g* fuse-links:	50 pulses 10-15 V	P
	(test current (A) equal to 0,8 times the current stated for a pre-arcing time of 5 s)	224A (63A fuse-links) 464A (125A fuse-links) 2000A (400A fuse-links)	P
	duration of each pulse 5 s	5 s	P
	time (s) interval between pulses equal to 20 % of the conventional time (s) specified in Table 2	12 min (63A fuse-links) 24 min (125A fuse-links) 36 min (400A fuse-links)	P
	a fuse-links: rated current (A) of fuse-link test current (A) equal to $k_{1n} \pm 2\%$ the pulse duration (s) corresponds to that indicated on the overload curve for k_{1n} stated by manufacturer time (s) intervals between pulses equal to 30 times the pulse duration fuse-links having ambient air temperature subjected to a current (A) equal to current for the overload test		N/A N/A N/A N/A N/A P

ВЯРНО С
ОРИГИНАЛА




250

Clause	Requirement + Test	Result - Remark	Verdict
	pre-arcing time (s) of sample lies within the manufacturers time-current zone	1) 15 s 2) 15 s (63A fuse-links) 3) 14 s 1) 14 s 2) 14 s (125A fuse-links) 3) 15 s 1) 12 s 2) 13 s (400A fuse-links) 3) 13 s	P
8.4.3.5	Conventional cable overload protection test (for "g" fuse-links only) fuse-link mounted as specified in 8.4.1 provided with PVC insulated copper conductors of cross-sectional area (mm ²) (see Table 19)	10 mm ² (63A fuse-links) 18 mm ² (80A fuse-link) 25 mm ² (100A fuse-link) 35 mm ² (125A fuse-link) 50 mm ² (160A fuse-link) 70 mm ² (200A fuse-link) 120 mm ² (250A fuse-link) 185 mm ² (315A fuse-link) 240 mm ² (400A fuse-link)	P
	fuse and conductor connected to it, preheated with rated current (A) of fuse-link for a time (h) equal to the conventional time	In 1 h (63A) 2 h (80A, 100A, 125A, 160A) 3 h (200A, 250A, 315A, 400A)	P
	test current increased to 1,45 I _n (A) (I _n specified in Table 19) NOTE: It is not necessary to perform this test if the product 1,45 I _n is greater than the conventional fusing current.	63A (63A fuse-link) 124A (80A fuse-link) 163A > 160A (100A fuse-link) 200,1A > 200A (125A fuse-link) 244A; (160A fuse-link) 309A; (200A fuse-link) 433A > 400A (250A fuse-link) 568A > 504A (315A fuse-link) 668A > 640A (400A fuse-link)	P N/A N/A P N/A N/A
	the fuse-link operated in time (s) less than the conventional time (s)	50 min (63A fuse-link) 44 min (80A fuse-link) 42 min (160A fuse-link) 31 min (200A fuse-link)	P
8.4.3.6	Operation of indicating devices and strikers, if any Operation of indicating device verified in combination with the verification of breaking capacity (see 8.5.5) The verification of striker operation:		P N/A

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	"g" fuse-link tested at current (A) equal to current I _g (see Table 20 and 21)		N/A
	recovery voltage (V)		N/A
	stated recovery voltage (V)		N/A
	"a" fuse-link tested at current (A) equal to current 2I _{ka} (A) (see Figure 2)		N/A
	recovery voltage (V)		N/A
	stated recovery voltage (V)		N/A
	Striker operate during all tests made at recovery voltage of at least 20 V		N/A
	No failure of indicating device or striker		N/A
8.5	Verification of the breaking capacity	BUSTYAL Report No R.0106-15	P
8.5.1	The test arrangements as specified in 8.1.4		P
8.5.2	Characteristics of the test circuit as specified		P
	Scheme of test circuit (see Figure 5)		P
	Deviations from specified characteristics of test circuit		N/A
8.5.3	Measuring Instruments		P
8.5.4	Calibration of test circuit		P
	Calibration oscillograms and their evaluation		P
8.5.6	The breaking-capacity tests made at an ambient air temperature of (20 ± 5) °C		P
	Breaking-capacity tests on a.c. fuses		P
8.5.5.1	Table 20, test No. 1 for "g" and "a" fuse-links		N/A
	Rated breaking capacity of the fuse-links (kA), at voltage (V)	100 kA, at 500 V	
	Rated current (A) of the fuse-links	63 A, 400 A	P
	Prospective current I _p (kA) equal to rated breaking capacity within a tolerance of + 10%, - 0%	103,1 kA	P
	Power factor	0,12	P
	Initiation of arcing after voltage zero: within 40° - 65° for sample 1 and within 65° - 90° for sample 2 and 3, or for sample 1) arcing after voltage zero within 10° + 10° - 0°	1) 2) 3)	N/A
			P

ВЯРНО С
ОРИГИНАЛА




251

Clause	Requirement + Test	Result - Remark	Verdict
	Power-frequency recovery voltage: voltage (V) i.e. (%) of rated voltage within + 5%, - 0% of the rated voltage or + 110% + 5%, - 0% of the rated voltage	1) 555,7 V 2) 551,6 V (400A fuse-link) 3) 548,6 V	P
		1) 549,4 V 2) 543,7 V (63A fuse-link) 3) 549,4 V	
	Cut-off current (A)	1) 36,62 kA 2) 37,23 kA (400A fuse-link) 3) 37,11 kA	P
		1) 6,226 kA 2) 6,348 kA (63A fuse-link) 3) 6,226 kA	
8.5.8	Acceptability of No. 1 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		P
	b) fuse-links operated without external effects or damage to the components of the complete fuse		P
	c) no permanent arcing, flashover or ejection of dangerous flames		P
	d) no damage of fuse components hindering from their further use		P
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		P
	f) fuse-link remains in one piece before its removal from the fuse-carrier		P
	g) resistance (mΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases		P
8.5.5.1	Table 20, test No. 2 for "g" and "a" fuse-links		P
	Prospective current I _p (kA)	27,10 kA	P
	Test made under conditions which approximate those giving maximum arc energy		P
	Power factor	0,16	P
	Making angle after voltage zero: within tolerance 0° + 20° - 0°		P
	Power-frequency recovery voltage: voltage (V) i.e. (%) of rated voltage within + 5%, - 0% of the rated voltage or + 110% + 5%, - 0% of the rated voltage	1) 2) 3)	P
	Recovery voltage maintained at a value (V); duration (s) for sample (No.)	550 V, 15 s for sample 3	P
	For other samples duration 15 s (8.5.5.2)		N/A

Clause	Requirement + Test	Result - Remark	Verdict
8.5.8	Acceptability of No. 2 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) b) fuse-links operated without external effects or damage to the components of the complete fuse c) no permanent arcing, flashover or ejection of dangerous flames d) no damage of fuse components hindering from their further use e) no damage of fuse-link such, that it is difficult or dangerous to replace them f) fuse-link remains in one piece before its removal from the fuse-carrier g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) : 2) : 3) :		P
8.5.5.1	Table 20, test No. 2* for "g" and "a" fuse-links, for I ₂ 2 I ₁ Prospective current I ₂ (kA) for test No. 2 greater than the rated breaking capacity (kA) Test made on six samples replacing tests of Nos. 1 and 2. 1 test made with current I ₁ (kA) Making angles differ approximately 30° between each test Power factor Acceptability of No. 2 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) b) fuse-links operated without external effects or damage to the components of the complete fuse c) no permanent arcing, flashover or ejection of dangerous flames d) no damage of fuse components hindering from their further use e) no damage of fuse-link such, that it is difficult or dangerous to replace them f) fuse-link remains in one piece before its removal from the fuse-carrier g) prospective current for "g" fuse-link I ₂ (A) equal to 3.2 I ₁	(see appended table)	N/A
8.5.8	Prospective current for "a" fuse-link I ₂ (A) equal to 2.0 I ₁ Prospective current for "g" fuse-link I ₂ (A) equal to 1.6 I ₁ Power factor Tolerance on current + 20%, - 0% Recovery voltage (V) maintained for 15 s (8.5.5.2) Acceptability of No. 4 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) b) fuse-links operated without external effects or damage to the components of the complete fuse c) no permanent arcing, flashover or ejection of dangerous flames d) no damage of fuse components hindering from their further use e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A

Report No: 0315.15-5



252

Clause	Requirement + Test	Result - Remark	Verdict
8.5.8	Prospective current for "a" fuse-link I ₂ (A) equal to 2.0 I ₁ Prospective current for "g" fuse-link I ₂ (A) equal to 1.6 I ₁ Power factor Tolerance on current + 20% Recovery voltage (V) maintained for 15 s (8.5.5.2) Acceptability of No. 3 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) b) fuse-links operated without external effects or damage to the components of the complete fuse c) no permanent arcing, flashover or ejection of dangerous flames d) no damage of fuse components hindering from their further use e) no damage of fuse-link such, that it is difficult or dangerous to replace them f) fuse-link remains in one piece before its removal from the fuse-carrier g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) : 2) : 3) :		N/A
8.5.5.1	Table 20, test No. 4 for "g" and "a" fuse-links Prospective current for "g" fuse-link I ₂ (A) equal to 2.0 I ₁ Prospective current for "a" fuse-link I ₂ (A) equal to 1.6 I ₁ Power factor Tolerance on current + 20%, - 0% Recovery voltage (V) maintained for 15 s (8.5.5.2) Acceptability of No. 4 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) b) fuse-links operated without external effects or damage to the components of the complete fuse c) no permanent arcing, flashover or ejection of dangerous flames d) no damage of fuse components hindering from their further use e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A

SWMA

Report No: 0315.15-5


Clause	Requirement + Test	Result - Remark	Verdict
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (mΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 20, test No. 5 for "g" and "ar" fuse-links		
	Prospective current for "g" fuse-link I _g (A) equal to 1,25 I _n		N/A
	Prospective current for "ar" fuse-link I _{ar} (A) equal to k ₂ I _n		N/A
	Power factor		N/A
	Tolerance on current + 20%, - 0%		N/A
	Recovery voltage (V) maintained for 15 s (8.5.5.2) :		N/A
8.5.8	Acceptability of No. 5 test results		
	a) max. arc voltage (V) did not exceed stated values of 7,5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (mΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
	Breaking-capacity tests on d.c. fuses		
8.5.5.1	Table 21, d.c.test No. 1 for "g" and "ar" fuse-links		
	Rated breaking d.c. capacity of the fuse-links (kA), at voltage (V)		N/A
	Rated current (A) of the fuse-links		N/A
	Rated voltage (V) of the fuse-links		N/A
	Prospective current I _p (kA) equal to rated breaking capacity within a tolerance of + 10%, - 0%		N/A
	Time constant		N/A

Clause	Requirement + Test	Result - Remark	Verdict
	Arching commences at current (A)	1) 2) 3)	
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 1 test results		
	a) max. arc voltage (V) did not exceed stated values of 7,5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (mΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c.test No. 2 for "g" and "ar" fuse-links		
	a) During test No. 1 arcing commences at a current $\geq 0,5 I_n$, test No. 2 was not performed		N/A
	b) Prospective current I _p (A). Test made under conditions which approximate those giving maximum arc energy		N/A
	Time constant		N/A
	Arching commences at current (A)	1) 2) 3)	
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 2 test results		
	a) max. arc voltage (V) did not exceed stated values of 7,5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A

Handwritten signature


Handwritten signature

**ВЯРНО С
ОРИГИНАЛА**



Clause	Requirement + Test	Result - Remark	Verdict
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one place before its removal from the fuse-carrier		N/A
	g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c.test No. 3 for "g" and "a" fuse-links Conventional fusing current (A) : Prospective current I _s (A) equal to 3.2 I _n : Tolerance on current (%) ± 20% : Time constant : Arcing commences at current (A) : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A
8.5.8	Acceptability of No. 3 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) : b) fuse-links operated without external effects or damage to the components of the complete fuse : c) no permanent arcing, flashover or ejection of dangerous flames : d) no damage of fuse components hindering from their further use : e) no damage of fuse-link such, that it is difficult or dangerous to replace them : f) fuse-link remains in one place before its removal from the fuse-carrier : g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A
8.5.5.1	Table 21, d.c.test No. 4 for "g" and "a" fuse-links Conventional fusing current (A) : Prospective current I _s (A) equal to 1.25 I _n : Tolerance on current (%) ± 20%, - 0% : Time constant : Arcing commences at current (A) : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A
8.5.8	Acceptability of No. 4 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) : b) fuse-links operated without external effects or damage to the components of the complete fuse : c) no permanent arcing, flashover or ejection of dangerous flames : d) no damage of fuse components hindering from their further use : e) no damage of fuse-link such, that it is difficult or dangerous to replace them : f) fuse-link remains in one place before its removal from the fuse-carrier : g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A

ВЕРНО С
ОРИГИНАЛА




254

Clause	Requirement + Test	Result - Remark	Verdict
	Prospective current I _s (A) equal to 2.0 I _n : Tolerance on current (%) ± 20%, - 0% : Time constant : Arcing commences at current (A) : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A
8.5.8	Acceptability of No. 4 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) : b) fuse-links operated without external effects or damage to the components of the complete fuse : c) no permanent arcing, flashover or ejection of dangerous flames : d) no damage of fuse components hindering from their further use : e) no damage of fuse-link such, that it is difficult or dangerous to replace them : f) fuse-link remains in one place before its removal from the fuse-carrier : g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A
8.5.5.1	Table 21, d.c.test No. 5 for "g" and "a" fuse-links Conventional fusing current (A) : Prospective current I _s (A) equal to 1.25 I _n : Tolerance on current (%) ± 20%, - 0% : Time constant : Arcing commences at current (A) : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A
8.5.8	Acceptability of No. 5 test results a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6) : b) fuse-links operated without external effects or damage to the components of the complete fuse : c) no permanent arcing, flashover or ejection of dangerous flames : d) no damage of fuse components hindering from their further use : e) no damage of fuse-link such, that it is difficult or dangerous to replace them : f) fuse-link remains in one place before its removal from the fuse-carrier : g) resistance (MΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) 2) 3)		N/A
	Value of recovery voltage, voltage (V) within tolerances 115 ± 5%, - 9% of the rated voltage : 1) 2) 3)		N/A

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (MO) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases : 1) 2) 3)		N/A
8.6	Verification of the cut-off current characteristics		
8.6.2	The values measured did not exceed cut-off characteristics indicated by the manufacturer (see 5.8.1)		P
8.7	Verification of I _t characteristics and overcurrent discrimination		
8.7.2	The operating I _t values measured not exceed the values indicated by the manufacturer, or those specified in subsequent parts	I ₁ - 1810 kA ² I ₂ - 2544 kA ²	N/A
	The pre-arcing I _{pa} values not less than minimum pre-arcing values given by the manufacturer, or they lie within the limits indicated in Table 7	I ₁ - 718 kA ² I ₂ - 837 kA ²	P
8.7.3	Verification of compliance for fuse-links at 0,01 s "gG" and "gR" fuse-links at 0,01 s comply with Table 7	I _{0,01} - 1039 kA ² I _{0,01} - 965 kA ² (Annex B1)	P
8.7.4	Verification of overcurrent discrimination		
	The discrimination of the fuse-links verified by means of the time-current characteristics and the pre-arcing and operating I _t values		P
8.8	Verification of the degree of protection of enclosures		
	Degree of protection IP	IP	N/A
	Verification by test under conditions specified in IEC 60529		N/A
8.9	Verification of resistance to heat		



255

Clause	Requirement + Test	Result - Remark	Verdict
	No damage impaired by heat during the previous tests (in particular with respect to 8.3, 8.4, 8.5 and 8.10)		P
8.10	Verification of non-deterioration of contacts		
8.10.1	Three samples provided with standardized dummy fuse-links of the highest current rating (A) intended to be used in the fuse-holder (see subsequent parts) :	400 A dummy fuse-links	P
8.10.2	Test current (A) for load period	500 A	P
	Duration (s) of load period	45 min	P
	Duration (s) of no-load period	18 min	P
	a) Test of 250 cycles, measured values not exceed the limits given in subsequent parts		P
	b) Test of 750 cycles, measured values not exceed the limits given in subsequent parts		N/A
8.11	Mechanical and miscellaneous tests		
8.11.1	Mechanical strength		
	Mechanical characteristics of fuse and its parts judged in the context of normal handling and mounting as well as with results shown after breaking-capacity test (see 8.5), if not otherwise specified in the subsequent parts		P
8.11.2	Miscellaneous tests		
8.11.2.1	Verification of freedom from seasion cracking		
	Current-carrying parts made of rolled copper alloy with less than 83% copper content and with all grease removed, placed for 4 h in test cabinet having temperature of (30 ± 10) °C		N/A
	After this, samples placed for 8 h in test cabinet, on the bottom of which is ammonium chloride solution having pH value 10 - 11		N/A
	After test no cracks visible to the unaided eye		N/A
8.11.2.2	Verification of resistance to abnormal heat and fire		N/A
8.11.2.2.1	Parts of insulating material, except ceramic, have a limited duration of burning without spreading fire by flames or burning droplets or glowing particles falling from the specimen		N/A
8.11.2.2.5	Glow-wire test: (650 ± 10) °C		
	Parts of insulating materials not necessary to retain current-carrying parts in position even though they are in contact with them, made the glow-wire test (650 ± 10) °C		P

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	No visible flame, or burning or glowing of the specimen extinguish within max. (s) after removal of the glow-wire. Limit (30 ± 1) s		P
	No burning of the tissue paper		P
	No scorching of the pinewood board		P
	Glow-wire test: (960 ± 10) °C		
	Parts of insulating materials necessary to retain current-carrying parts and parts of the earthing circuit, if any, in position, made the glow-wire test (960 ± 10) °C		P
	No visible flame, or burning or glowing of the specimen extinguish within max. (s) after removal of the glow-wire. Limit (30 ± 1) s		P
	No burning of the tissue paper		P
	No scorching of the pinewood board		P
8.11.2.3	Verification of resistance to rusting		
	Tested parts after degreasing (10 min in specified solution) placed for 10 min in air saturated with moisture and after that dried 10 min in an ambient temperature (100 ± 5) °C	10 min. - 10 % solution of ammonium chloride in water	P
	Surface of tested parts show no signs of rust		P

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

APPENDIX 1

8.1.5.1 TABLE: Internal resistance of the fuse-links

a) rated current (A) of the fuse-link : 400 A

measuring current (A) : 400 A

ambient air temperature (°C) : 21 °C

Internal resistance	sample No.
	1 2 3 4 5 6 7 8 9 10 11 12
R (mΩ)	0.136 0.128 0.132 0.140 0.136 0.140 0.138 0.132 0.136 0.140 0.138 0.136
Internal resistance	sample No.
	13 14 15 16 17 18 19 20 21 22 23 24
R (mΩ)	0.140 0.132 0.136 0.142 0.138 0.136 0.133 0.132 0.136 0.134 0.142 0.136

b) rated current (A) of the fuse-link : 315 A

measuring current (A) : 315 A

ambient air temperature (°C) : 21 °C

Internal resistance	sample No.
	1 2 3 4 5 6 7 8 9 10 11 12
R (mΩ)	0.198 0.196 0.198 0.192 0.194 0.196 0.192 0.198 0.190 0.194 0.192 0.196
Internal resistance	sample No.
	13 14 15 16 17 18 19 20 21 22 23 24
R (mΩ)	0.194 0.198 0.196 0.192 0.192 0.192 0.192 0.192 0.192 0.192 0.192 0.192

TABLE: Internal resistance of the fuse-links

a) rated current (A) of the fuse-link : 250 A

measuring current (A) : 250 A

ambient air temperature (°C) : 21 °C


Internal resistance	sample No.
	1 2 3 4 5 6 7 8 9 10 11 12
R (mΩ)	0.240 0.232 0.242 0.234 0.238 0.242 0.234 0.232 0.228 0.230 0.236 0.242
Internal resistance	sample No.
	13 14 15 16 17 18 19 20 21 22 23 24
R (mΩ)	0.238 0.236 0.238 0.240 0.240 0.240 0.240 0.240 0.240 0.240 0.240 0.240

b) rated current (A) of the fuse-link : 200 A

measuring current (A) : 200 A

ambient air temperature (°C) : 21 °C

Internal resistance	sample No.
	1 2 3 4 5 6 7 8 9 10 11 12
R (mΩ)	0.292 0.304 0.298 0.302 0.292 0.296 0.298 0.296 0.304 0.292 0.298 0.296
Internal resistance	sample No.
	13 14 15 16 17 18 19 20 21 22 23 24
R (mΩ)	0.298 0.292 0.296 0.292 0.292 0.292 0.292 0.292 0.292 0.292 0.292 0.292



ВЯРНО С
ОРИГИНАЛА

Clause	Requirement + Test	Result - Remark	Verdict
	a) rated current (A) of the fuse-link measuring current (A) : 160 A		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No. : 1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.368 0.358 0.364 0.362 0.368 0.364 0.363 0.366 0.362 0.368 0.372		
Internal resistance	sample No. : 13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.368 0.364 0.364 0.362		

	a) rated current (A) of the fuse-link measuring current (A) : 125 A		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No. : 1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.558 0.562 0.556 0.564 0.568 0.558 0.562 0.564 0.568 0.564 0.558		
Internal resistance	sample No. : 13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.560 0.564 0.558 0.562		

	a) rated current (A) of the fuse-link measuring current (A) : 100 A		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No. : 1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.752 0.746 0.748 0.752 0.748 0.752 0.752 0.748 0.754 0.740 0.746 0.752		
Internal resistance	sample No. : 13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.746 0.748 0.748 0.744		


	a) rated current (A) of the fuse-link measuring current (A) : 80 A		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No. : 1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.968 0.972 0.964 0.962 0.968 0.966 0.962 0.970 0.968 0.972 0.966 0.970		
Internal resistance	sample No. : 13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.968 0.964 0.962 0.968		

Clause	Requirement + Test	Result - Remark	Verdict
	a) rated current (A) of the fuse-link measuring current (A) : 63 A		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No. : 1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	1.218 1.222 1.220 1.226 1.220 1.218 1.232 1.224 1.226 1.222 1.228 1.230		
Internal resistance	sample No. : 13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	1.226 1.228 1.224 1.226		

Handwritten signature

Handwritten signature

ВАРНО С
ОРИГИНАЛА



257

TEST REPORT
IEC 60269-2
Low-voltage fuses

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) - Examples of standardized systems of fuses A to K

List of Attachments (including a total number of pages in each attachment):

Summary of testing:	Testing location:
Tests performed (name of test and test clause): 7.1 Mechanical design 8.1.4 Arrangement of fuse and dimensions 8.1.6 Testing of fuse holders 8.2.5 Resistance to tracking 8.3 Verification of temperature rise and power dissipation 8.7.4 Verification of overcurrent discrimination 8.9 Verification of resistance to heat 8.10 Verification of non-deterioration of contacts 8.11 Mechanical strength and miscellaneous tests	IHP Test Laboratory / SAKARYA / TURKEY

Summary of compliance with National Differences
List of countries addressed:


The product fulfils the requirements of IEC 60269-2

Test item particulars.....

Classification of installation and use.....: For use by authorized persons

Supply Connection.....: At both sides

Fuse system.....: ABC/DEF/GHIJK



Report No: 0315.15-5

Report No: 0315.15-5

Clause	Requirement + Test	Result - Remark	Verdict
Requirements IEC 60269-2			
Requirements IEC 60269-1			
FUSE SYSTEM A - FUSES WITH FUSE-LINKS WITH BLADE CONTACTS (NH FUSE SYSTEM)			
5. CHARACTERISTICS OF FUSES			
5.2	Rated voltage (V) as specified.....	500 V	P
5.3.1	Rated current (A) of the fuse-link in accordance with specified values.....	63, 80, 100, 125, 160, 200, 250, 315, 400 A	P
5.3.2	Rated current (A) of the fuse-holder and the size of the fuse-link.....	400 A	P
5.5	Rated power (W) dissipation of fuse-link see Figure 101.....	34 W	P
5.6	Rated acceptable power (VA) dissipation of fuse-bases given in Figure 102.....	45 W	P
5.6	Limits of time-current characteristics		P
5.6.1	Time-current characteristics, time-current zones and overload curves.....		P
5.6.2	Conventional times and current see Table 101.....		P
5.6.3	Gates.....		P
5.7.2	Rated breaking capacity (A).....	100 kA	P
6. MARKING			
Markings are legible			
Fuse-holders marked by:			
6.1	- IEC 60269-2.....		P
	- size.....	NH2	P
	Marking of rated current and rated voltage are discernible from the front	400 A, 690 V	P
Fuse-links marked by:			
6.2	- IEC 60269-2.....		P
	- size or reference.....	NH2	P
	- rated breaking capacity.....	100 kA	P
	Marking of rated current and rated voltage are discernible from the front	63, 80, 100, 125, 160, 200, 250, 315, 400 A	P
	Fuse-links are marked as described in Table 104.....		P

EMH


ВЪРНО С
ОРИГИНАЛА

258

Clause	Requirement + Test	Result - Remark	Verdict
7.1	STANDARD CONDITIONS FOR CONSTRUCTION Mechanical design		P
	The dimensions of the fuse-links given in Figure 101		P
	Dimensions:		
	dimension marking a ₁ : prescribed (mm); measured (mm)	150 ± 2,5 ; 150	P
	dimension marking a ₂ : prescribed (mm); measured (mm)	75 - 10; 72	P
	dimension marking a ₃ : prescribed (mm); measured (mm)	62 ± 2,5 ; 62	P
	dimension marking a ₄ : prescribed (mm); measured (mm)	68 ± 2,5 ; 68	P
	dimension marking b ₁ : min; prescribed (mm); measured (mm)	25 ; 25	P
	dimension marking b ₂ : min; prescribed (mm); measured (mm)	8 ;	N/A
	dimension marking b ₃ : max; prescribed (mm); measured (mm)	6 ; 5	P
	dimension marking b ₄ : min; prescribed (mm); measured (mm)	22 ; 25	P
	dimension marking c ₁ : prescribed (mm); measured (mm)	48 ± 0,8 ; 48,5	P
	dimension marking c ₂ : prescribed (mm); measured (mm)	11 - 2; 10,5	P
	dimension marking d: prescribed (mm); measured (mm)	2,5 _{±0,5} *1,5 ; 2	P
	dimension marking e ₁ : max; prescribed (mm); measured (mm)	61 ; 59,5	P
	dimension marking e ₂ : max; prescribed (mm); measured (mm)	60 ; 58,5	P
	dimension marking e ₃ : prescribed (mm); measured (mm)	20 ± 2,5 ; 22,5	P
	dimension marking e ₄ : prescribed (mm); measured (mm)	6 ± 0,2 ; 6	P
	dimension marking f ₁ : max; prescribed (mm); measured (mm)	15 ; 13	P
	dimension marking z ₁ : max; prescribed (mm); measured (mm)	5 ;	N/A

Report No: 0315.15-5

ВЯРНО С
ОРИГИНАЛА



259

Clause	Requirement + Test	Result - Remark	Verdict
	The dimensions of the fuse-base given in Figure 102		P
	Dimensions:		
	dimension marking g: prescribed (mm); measured (mm)	61 ± 1 ;	N/A
	dimension marking h: prescribed (mm); measured (mm)	200 ± 1; 200	P
	dimension marking n ₁ : max; prescribed (mm); measured (mm)	60 ;	N/A
	dimension marking n ₂ : max; prescribed (mm); measured (mm)	68 ; 48	P
	dimension marking p ₁ : max; prescribed (mm); measured (mm)	60 ; 55	P
	dimension marking p ₂ : prescribed (mm); measured (mm)	35 ± 1,5 ;	N/A
	dimension marking r ₁ : min; prescribed (mm); measured (mm)	17 ; 31	P
	dimension marking s ₁ : max; prescribed (mm); measured (mm)	46 ; 34	P
	dimension marking t ₁ : min; prescribed (mm); measured (mm)	27 ; 28	P
	dimension marking v: prescribed (mm); measured (mm)	80 ± 3 ; 80	P
	dimension marking w ₁ : prescribed (mm); measured (mm)	30 ± 0,7 ; 30	P
	dimension marking w ₂ : prescribed (mm); measured (mm)	25 ± 0,7 ; 25	P
	dimension marking x ₁ : min; prescribed (mm); measured (mm)	20 ; 21	P
	dimension marking y: prescribed (mm); measured (mm)	10,5 ± 0,5 ; 11	P
	dimension marking z ₁ : max; prescribed (mm); measured (mm)	5 ; 3	P
	dimension marking a ₁ : min; prescribed (mm); measured (mm)	28 ; 55	P
	dimension marking b ₁ : min; prescribed (mm); measured (mm)	25 ; 35	P
	dimension marking c ₁ : min; prescribed (mm); measured (mm)	4 ; 2,7 (see note 11 of Figure 102)	P
	dimension marking d ₁ : prescribed (mm); measured (mm)	11 ± 0,25 ; 11	P

Report No: 0315.15-5

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
	increased by means of partition walls and covers of fuse-contacts		N/A
	operation by authorized persons, instructed in electrical matters, using replacement handles according to this fuse system		N/A
8	TESTS		
	IEC 60269-1 applies with the following supplementary requirements		
8.1.4	Arrangement of fuse and dimensions	Part 2 Figure 101	P
	Requirements of 7.2 verified on fuse-bases		P
	Creepage distances and clearances of fuse-links according to 7.2 are verified		P
	Clearances verified on fuse-link inserted into model fuse-base according to Figure 111		N/A
8.1.6	Testing of fuse-holders		
	In addition to test given in IEC 60269-1 tested according to Table 109		P
8.2.2.1	Points of application of test voltage		
	In addition to IEC 60269-1		N/A
	e) between isolated metal gripping-lugs and terminals of test fuse-bases		
8.2.3.2	Value of test voltage		
	rated impulse withstand voltage in Table 110	6 kV	N/A
8.2.3.3	Test method		
	5 Impulses of both polarities and of shape 1,2/50 µs and rated withstand voltage level according to Table 110	7.3 kV 5 times - period of 5 s	P
	minimum period between impulses are 1 s		
8.2.4	Acceptability of test results		P
8.2.4.3	No flash-over or puncture shall occur during test		
8.2.5	Resistance to tracking		
	insulating parts supporting live parts of fuse-links and fuse-bases tested according to IEC 60112 (test solution A)		N/A
	Five specimens tested and passed at PTI 400		N/A
8.3	Verification of temperature rise and power dissipation		
8.3.1	Arrangement of the fuse		P
	Tightened by torque (Nm)	32 Nm	
8.3.2	Measurement of the temperature rise		


Report No: 0315.15-5

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
7.1.2	dimension marking e, prescribed (mm); measured (mm)	12,5 ± 0,5; 12,5	P
	Connections, including terminals cross-sectional ranges (Table 105)	50 - 240 mm ²	P
	torques to be applied (Table 111) (lug terminal)	32 Nm	
7.1.3	Contact surfaces should be silver plated	Yes / No	P
	If no test according to 8.10 are passed with dummies described in 8.10.1		P
7.1.6	Dynamic short-circuit withstand shall meet cut-off currents (Table 112)		N/A
7.1.7	Construction of fuse-link		
	Blade contacts made of solid material		P
	If any other construction, manufacturer demonstrate that construction adequate		N/A
	Endplates not permitted to protrude radially from insulation body		P
	preferable to insulate the gripping lugs from live parts		N/A
	Fuse-links has an indicator		P
	Electrically conductive parts of indicator not ejected from the fuse-link during operation		P
7.2	Insulating properties and suitability for insulation		
	Creepage distances and clearances of fuses and fuse-accessories meet requirements of IEC 60964-1 for overvoltage category III and pollution degree 3		P
	Insulating parts of fuse-base supporting live parts meet the test at PTI 400 according to IEC 60112 (test solution A)		P
7.7	I _t characteristics		
	maximum pre-arcing I _t (Table 7 of IEC 60269-1)		P
	rated currents lower than 16 A and for 224 A (Table 106)		N/A
	maximum operating I _t for "aM" fuse-links (Table 107)		N/A
	Test No. 2 of the largest rated current of each homogeneous series (Table 20 of IEC 60269-1)		
7.8	Other current discrimination of "gG" fuse-links (see 8.7.4, Table 108)		
7.9	Protection against electric shock		P

Report No: 0315.15-5


BRNO UNIVERSITY OF TECHNOLOGY



260

Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Protective covers and fuse-carriers as provided by manufacturer mounted Temperature rise of the fuse-holder	51 K	N/A
	Dummy (Figure 105) Point at which temperature rise is measured (Figure 106)	45W dummy link Point marked with "E"	P
8.3.4.2	Power dissipation of a fuse-link (Figure 106)		N/A
8.4.3.1	Verification of conventional non-fusing and fusing current non-fusing current test - second test specimen are used for b)		P
8.4.3.5	Conventional cable overload protection test (or "gG" fuse-links only)		P
Annex AA	Details of special test are given in Annex AA Special test for cable overload protection		N/A
AA.1	For fuses with $I_n > 16$ A of the sizes 000, 00, 0, 1 and 2 Arrangement of the fuse		N/A
	Three fuse-links in fuse-bases mounted in a box ... Ambient air temperature outside the fuse box shall be (30 ± 0.5) °C		N/A
AA.2	Test method and acceptability of test results 1,13 I_n flowed through the fuse-links for conventional time (see Table 2 of IEC 60269-1) None of fuse-links operated	A for s	N/A
	Test current raised without interruption within 5 s to 1,45 I_n One fuse-link operated within conventional time ...	A	N/A
8.5.5.1	Verification of the peak withstand current of a fuse-base not be carried out, if this has already been verified during the breaking capacity test of fuse-links with the highest rating of the size		N/A
8.5.5.1.1	Arrangement of the fuse single-phase type, 8.5.1 of IEC 60269-1 peak values of the test currents (Table 112) maximum values (see 8.5.5.1.3) dummy fuse-link (Figure 101)		N/A

WARRANTY
SPECIAL SERVICE
C O P Y R I G H T




106

Clause	Requirement + Test	Result - Remark	Verdict
8.5.5.1.2	Test method fuse-base 1 (Figure 107) resilient spring travel is limited to elastic range contacts opened up three times fuse-base 2 (see 8.11.1.2) F_{max} according to Table 118		N/A
8.5.5.1.3	Acceptability of test results fuse-links not be ejected no signs of arcing or welding or other damage		N/A
8.5.8	Acceptability of test results Fuse or circuit-breaker not operate during this test		N/A
8.7.4	Verification of overcurrent discrimination verified by I_{t1} values evaluated from the recorded test results Arrangement of the samples as for the breaking capacity test		N/A
	two samples tested at the r.m.s. prospective test current I_t , corresponding to minimum pre-arcing I_{t1}	1,5 kA (63A fuse-links) 3 kA (125A fuse-links) 11,8 kA (400A fuse-links)	P
	The values of I_{t1} lie within corresponding limits specified in Table 113 For 63A: Min pre-arcing > 9 kA's For 125A: Min pre-arcing > 36 kA's For 400A: Min pre-arcing > 557 kA's	1) 9,8 kA's (63A fuse-links) 2) 10,2 kA's 1) 45 kA's (125A fuse-links) 2) 40 kA's 1) 750 kA's (400A fuse-links) 2) 830 kA's	P
	the other samples tested at the r.m.s. prospective test current I_t , corresponding to operating I_{t1}	2,3 kA (63A fuse-links) 5,1 kA (125A fuse-links) 20 kA (400A fuse-links)	P
	test voltage (V)	400 V	
	The test voltage for 690 V fuses is 1,05xUn/3		N/A
	The test voltage for all other fuses is 1,1xUn/3	400V (Measured values were calculated for 318V according to Annex B3)	P

Handwritten signature

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
	The values of I_{t1} lie within corresponding limits specified in Table 113..... For 63A: Max operating < 21,2 kA's For 125A: Max operating < 104 kA's For 400A: Max operating < 1600 kA's	1) 19,2 kA's (63A fuse-links) 2) 19,1 kA's 1) 72 kA's (125 A fuse-links) 2) 73 kA's 1) 1585 kA's (400A fuse-links) 2) 1528 kA's	P
8.9	Verification of resistance to heat		
	Tests apply to fuse-link and fuse-base		P
	Fuse-holder with fuse-links having maximum power dissipation are cyclically loaded as pre-treatment.....		P
	After cooling to normal temperature breaking capacity tested at I_1 (see 8.5).....	$I_1 = 100 \text{ kA}$	P
	Fuse-links with organic material Fuse-holder with fuse-links having maximum power dissipation are cyclically loaded as pre-treatment.....		N/A
	After cooling to normal temperature breaking capacity tested at I_1 and I_2 (see 8.5).....	$I_1 =$ $I_2 =$	N/A
8.9.1	Fuse-base test below apply if it is not obvious that components are not affected adversely by given temperature and withdrawal forces		
8.9.1.1	Test arrangement Figure 105 and 108	Figure 105	P
	Test set-up in heating chamber		
8.9.1.2	Test method Temperature of $(80 \pm 2)^\circ\text{C}$ for 2 h 160% rated current for 2 h..... Test voltage	$80^\circ\text{C}, 2 \text{ h}$ (Stealtite, bmc) $160\% I_n = 640\text{A}, 2 \text{ h}$ $10-12 \text{ V}$	P P
	3 min after switching off tensile force F_{max} (see Table 118) exerted for 15 s	$F_{max} = 400 \text{ N}, 15 \text{ s}$	P
8.9.1.3	Acceptability of test results Contact pieces not have moved to affect the further use		P
	Dimensions of Figure 102 are considered Insulating mounting part no broken and no show any signs of cracks		P
8.9.2	Fuse-links with gripping lugs of moulded material or of metal fixed in moulded material		N/A




262

Clause	Requirement + Test	Result - Remark	Verdict
8.9.2.1	Test arrangement Figure 108		N/A
8.9.2.2	Test method Temperature of $(80 \pm 2)^\circ\text{C}$ for 2 h 150% rated current for conventional time..... Test voltage	A for h V	N/A N/A N/A
	3 min after fuse-link operated or conventional time expired tensile force F_{max} (see Table 118) exerted for 15 s	$F_{max} =$	N/A
8.9.2.3	Acceptability of test results		
	Gripping lugs remain fully operational		N/A
	Dimensions of Figure 101 (d and c_2) not be exceeded by more than 2 mm		N/A
8.10	Verification of non-deterioration of contacts		
8.10.1	Arrangement of the fuse Figure 105 for lug terminals, torque in Table 111	400A, dummy fuse-link 32 Nm	P P
	Insulation of conductors removed over the whole length	2 m	P
8.10.1.2	All covers of contacts and terminals are removed Direct terminal clamps		P
	Test performed on 10 direct terminal clamps of five fuse-bases		N/A
	Distances between fuse-base centres of at least three lugs c_2 (see Figure 101)		N/A
	Torque of tightened of screws	Nm	
	Conductor cross-section	mm ²	
8.10.2	Test method Test current (A) for load period	$1,25 I_n = 500 \text{ A}$	P
	Duration (s) of load period	$0,25 \times 180 = 45 \text{ min}$	P
	Duration (s) of no-load period	$0,1 \times 180 = 18 \text{ min}$	P
	Test voltage (V)	10-12 V	
	a) Test of 50 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	b) Test of 250 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P

Emerson

BC

Clause	Requirement + Test	Result - Remark	Verdict
	c) Test of 500 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	d) Test of 750 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
8.10.2.1	Contacts Points between voltage drop is measured (A and B in Figure 106)		P
	Withdrawal force (Table 118); measured force after 250 cycles (N)	1) 250 N 2) 270 N 3) 300 N	P
	Withdrawal force (Table 118); measured force after 750 cycles (N)	1) 2) 3)	N/A
	If measured values too low, test of 8.5.5.1	Table 118 (150 N - 400 N)	P
8.10.2.2	Direct terminal clamps Points between voltage drop is measured (Figure 110)		N/A
	Test sequence for all types conductors (see Table 116)	(see appended table)	N/A
	Verification of temperature rise (see 8.3.4.1) (see figure 110)		N/A
8.10.3	Acceptability of test results		
8.10.3.1	Contacts Limit value after 250 th cycle ≤ 15% Limit value after 500 th cycle ≤ 30% Limit value after 750 th cycle ≤ 40% Difference between last and first measurement of temperature rise less than 20 K	See Table 1 Max 3K	P N/A N/A P
8.10.3.2	Direct terminal clamps Permissible tolerance for resistance R _{ep} for Al conductors : R _{ep max} ≤ 2 R _{at 0 min} Permissible changes of the resistance from R _{ep} to R _{ep 750} : see Table 117 Copper or cleaned aluminium conductors Uncleaned aluminium conductors		N/A N/A N/A N/A N/A



BRPHOC
OPINTANATA


Clause	Requirement + Test	Result - Remark	Verdict
	Change from 50 th to 250 th cycle		N/A
	Change after 250 th to 500 th cycle		N/A
	Change after 500 th to 750 th cycle		N/A
	Change between 50 th to 750 th cycle		N/A
	Temperature rise at test spot F < 75K		N/A
8.11	Mechanical and miscellaneous tests		
8.11.1.1	Mechanical strength of fuse-holders Test set-up subjected to temperature rise test at rated current	400A, dummy fuse-link 46K	P
	fuse-link or fuse-carrier are withdrawn and inserted into fuse-base 100 times	100 times	
	All parts are intact and function normally		P
	Test set-up subjected to further temperature rise test at rated current (values obtained are not more than 5 K or 15 % above the values from temperature-rise test prior)	47K Difference < 5K	P
8.11.1.2	Mechanical strength of the fuse-base Test-link inserted three times in the fuse-base	1) 250 N 2) 260 N 3) 280 N	P
	(Dimensions of blade contacts see Figure 101) (Withdrawal force F lied within limits in Table 118)		
	Stool screws are fastened three times at the terminals, torque of 1.2 times value specified by manufacturer or value of Table 111	38.4 Nm	P
	Contact pieces not have moved to affect the further use		P
	Insulating mounting part no broken and no show any signs of cracks		P
8.11.1.8	Impact resistance of gripping-lugs of moulded material or of metal fixed in moulded material		
8.11.1.8.1	Test arrangement		N/A
8.11.1.8.2	Facility is given in Figure 109		N/A
	One fuse-link ... (150±5)°C for 168 h		
	Another one ... 15°C for 72 h		
	One impact on each of gripping-lugs		N/A
8.11.1.8.3	Acceptability of test results		
	No damage capable of hindering their further use		N/A
	No bent out by more than 3 mm		N/A

Handwritten signature

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
8.11.2.3	Coupling with a handle (Figure 103) not are hindered		N/A
8.11.2.3.1	Verification of resistance to rusting According to ISO 6888 cyclic moist atmosphere containing 0,2% SO2 (SFV 0,2 S) for 1 cycle		P
8.11.2.3.2	Optional test (severe environmental conditions) Fuse-links and fuse-bases for used in environment of pollution degree 3 tested with SFV 2,0 S for 5 cycles		N/A
8.11.2.4	They marked accordingly		P
8.11.2.4.1	Non-deterioration of insulating parts of fuse-link and fuse-base Test method Period 168 h for equipment comprising moulded elements to support live parts (150±5)°C for covers (100±5)°C Period greater than 1 h for sealing compounds; stability of marking (150±5)°C After cooling to ambient temperature the following are tested. Fuse-links: breaking capacity with I ₁ and I ₂ Fuse-base: mechanical strength in accordance with 8.11.1.2	168 h 150 °C 3 h 150°C	P P N/A P P P P P
8.11.1.2	Mechanical strength of the fuse-base Test-link inserted three times in the fuse-base (Dimensions of blade contacts see Figure 101) (Withdrawal force F ₁ lied within limits in Table 118)	Figure 101 1) 250 N 2) 270 N 3) 290 N	P
8.11.2.4.2	Steel screws are fastened three times at the terminals, torque of 1,2 times value specified by manufacturer or value of Table 111 Contact pieces not have moved to affect the further use Insulating mounting part no broken and no show any signs of cracks Acceptability of test results	38,4 Nm	P P P

ВЯРНО С
ОРГАНИЗАЦИЯТА



264

Clause	Requirement + Test	Result - Remark	Verdict
	Not have changed of positions of fuse-base contacts to correct functioning		P
	No fracture nor any signs of fracture on insulating body with terminals		P
	Mechanical strength of connected joints not impaired		P
	Sealing compounds not shifted to extent permitting live parts to be exposed		P
	Fuse-links operate correctly		P
	Marking are durable and easily legible		P


APPENDIX 1

8.10.2		TABLE 1: Direct terminal clamps ambient air temperature (°C) : 20°C - 22°C Sample No. (contacts)									
		1	2	3	4	5	6	7	8	9	10
T 1 (K)	44K	45K	45K	45K							
ΔU initial	1,33 Vdc	1,54 Vdc	1,48 Vdc								
Rcl 0	66,5 mΩ	77 mΩ	74 mΩ								
ΔU 50	1,34 Vdc	1,56 Vdc	1,48 Vdc								
Rcl 50	67 mΩ	78 mΩ	74 mΩ								
ΔU 250	1,44 Vdc	1,62 Vdc	1,50 Vdc								
Rcl 250	72 mΩ	81 mΩ	75 mΩ								
T 2 (K)	47K	47K	45K								
ΔU 500											
Rcl 500											
ΔU 750											
Rcl 750											
T 3 (K)											

T 1: Initial temperature rise / T 2: temperature rise after 250 cycles / T 3: final temperature rise

[Handwritten signature]

[Handwritten signature]



Handwritten signature or initials at the top of the page.

List of test equipment used:

Equipment Name - No	Manufacturer - Type	Features	Traceability
Test transformer (TT01)	Best	440 V 65 kA, 660 V 5 kA	-
Resistive load (RY01-03)	Hilbert	38 ohm, 1300 A / 4t	-
Inductive load (EY01-12)	BEST	128 ohm	-
Resistive and inductive load (AY01)	FEDERAL	2,3 ohm, 6 mH	-
Resistive and inductive load (AY03)	IHP	50 mohm, 390 uH	-
Current measuring system (A001-03)	DIMES L 500 TC	143,29 kA / 2,8703 V	IHP 1014.01
Voltage measuring system (G001-03)	DIMES L 500 TV	± 1024 V	IHP 1014.02
Rogowski coil (RG05-07)	HEBEMUS 150 K	150 kA / 2 Volt	IHP 1114.03
Fliuke current coil (F101-03)	Fluke 2000 flex	200 A / 2000 A	IHP 0814.02
Voltmeter (V01-03)	Federal FV - 72	0-500 V	IHP 1014.03
Making breaker (KK01-03)	Prusaieg NVL 82DA	12 kV, 1250 A, Icp=80 kA	-
Making breaker (KK04)	Federal F112E	2500 A, 400 V	-
Making breaker (KK06)	Federal F121E	2000 A, 400 V	-
Current supply (TT04)	Mersan	300 A	-
Current supply (TT05)	Mersan	8000 A	-
Current supply (TT07)	Alnal	2000 A, 5 V	-
Current-voltage supply (AGK 01)	Alnal	220 Vdc, 500 Vac, 10 A	-
Current-voltage supply (AGK 02)	GW Instak	30 Vdc, 3 A	-
Transformer-Ammeter (A001-03)	Federal FAT100-FYA96	3000 / 5 A	IHP 0814.05
Clamp meter (F03)	CIE	1000 A RMS	IHP 1014.07
Isolation test equipment (IT04)	GW Instak GFI 825	5 kV AC, 1000 VDC Megar	IHP 1014.04
Oscilloscope (O02)	Teotronic TDS 469 A	400 MHz, 4 canal	IHP 0713.02
Dynamometer (K001)	Lutron FS 5100	100 Kg	IHP 0114.02
Thermometer (G001)	CIE 306	200 °C	IHP 1114.02
Temperature measuring eq. (S004)	Agilent 34970A	60 canal, T type termokupl	UMS S5315
Multimeter (M01)	HP 3444001A	1000 V, 3 A	IHP 0914.01
Multimeter (M02)	Fluke 87	10 A, 1000 V	IHP 0914.02
Calliper (KLU03)	Mitutoyo	0.01 mm	IHP 0315.01
Torque meter (TO 01)	Torque meter	6-80 Nm	IHP 0215.01
Temperometer (TO03)	Tronic AT 1502 LDIN	0-18 Nm	IHP 0215.02
Impulse test device (DT01)	HILLO PG1012C	0-10 kV, 1,2/50 ms	IHP 0312.03
Climatic chamber (D001)	Anguamoni CH 600 C	-40+180 °C, 10 - 98 %RH	-
Calibrator (K01)	Wavetek	1050 V, 20A	046690 FLUKE
Red-hot wire test device (KT01)	Federal	960 °C	-
Temperature cabinet (S001)	Federal	60 °C, 170x225x220 cm	-
High Voltage Probe (Z001)	Teotronic P8018A	40 kV, x 1000 prob	IHP 0313.23

ВРЯНО С
ОРИГИНАЛА

EM ELECTRIC LTD
Report No: 0315.15-5
265

Управление 3.3

[Handwritten signature]



TURKISH ACCREDITATION AGENCY

COPY OF THE ACCREDITATION CERTIFICATE

As a Testing Laboratory,

IHP ULUSLARARASI YÜKSEK GÜÇ TEST LABORATUVARI LTD.
ŞTİ. Yüksek Güç Test Laboratuvarı

1. organize sanayi bölgesi 2. yol no:13 Hanlı 54580 SAKARYA /
 TURKEY

Is accredited in accordance with TS EN ISO/IEC 17025:2012 standard within the scope given in Annex following the assessment conducted by TURKAK.

Accreditation Number : AB-0989-T
 Accreditation Date : 04 April 2016

This certificate shall remain in force until 03 April 2020, subject to continuing compliance with the standard TS EN ISO/IEC 17025:2012, related regulations and requirements.




на основании чл. 2 от 33ЛД

Dr. H. İbrahim ÇETİN
Secretary General

Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Agreement (MRA) in the scope of ISO/IEC 17025.

ОРИГИНАЛ





EMI ЕЛЕКТРИК ЕООД

9000 гр. Варна, бул. Сливница №26, ет.9. Тел. 052/803 528, email: office@emielectric.bg

Приложение 3.4.

Списък на провежданите рутинни /контролни/ изпитвания


1. Маркировка;
2. Проверка на размерите;
3. Проверка на омическото съпротивление;
4. Проверка на задействане на ВПНН;
 - Проверка на максимален нестайящ ток;
 - Проверка на минимален стояващ ток;
5. Проверка границите на загряване;
6. Проверка на разсейваната мощност;

Дата: 10.03.2018 г.


Декларат

на основание чл. 2 от ЗЗЛД

Алексей Родин



ВЯРНО С
ОРИГИНАЛА



264



EMI ЕЛЕКТРИК ЕООД

9000 гр. Варна, бул. Сливница №26, ет.9 Тел. 052/803 528, email: office@emilectric.bg

Приложение
3.5

Инструкция за поставяне в основата, обслужване и поддържане на предпазители

I. МОНТАЖ И ЕКСПЛОАТАЦИЯ

Монтажът на Предпазители със стопяема вложка NH, високомощни, ножови, характеристика система А (NH система) се извършва от квалифициран персонал, при спазване на всички изисквания по техника на безопасност и на техническата документация, в следния ред:

1. Отваря се блокът с носачите на Вертикалния предпазител-разеденител и се монтират предпазители с определени номинални характеристики.

2. Разеденителят се затваря с рязко движение, до пълното му затваряне.

3. Проверете с указател за напрежение наличието на напрежение по трите фази.

4. Подмяната на изгорял предпазител се извършва, като се провери с указател за напрежение фазата, на която е монтиран изгорелия предпазител, като при проверката не се измерва наличие на напрежение на изгорелия предпазител от страната към консуматора.

5. Отваря се блокът с носачите на Вертикалния предпазител-разеденител и се демонтира изгорелия предпазител, като на негово място се монтира нов-изправен предпазител.

6. Разеденителят се затваря с рязко движение, до пълното му затваряне.

9. Проверете с указател за напрежение наличието на напрежение по трите фази.


10. За да се осигури безопасна работа, блокът с предпазителите се заключва в извадено положение, като за тази цел е осигурен механизъм за заключване.

Дата: 16.03.2018 г.


Управител

на основание чл. 2 от ЗЗЛД

ВЯРНО С
ОРИГИНАЛА



268



INSTITUT „PRÜFFELD FÜR ELEKTRISCHE HOCHLEISTUNGSTECHNIK“ GMBH
 Independent, accredited test laboratory - Registration with STLA and LOVAG

TEST REPORT

NO. 1211.0251.1.194

Federal Elektrik Yatirim ve Ticaret AS.
 1. OSB, Hamitbeldesi
 Adapazarı / Turkey

Federal Elektrik Yatirim ve Ticaret AS.

LV HRC fuse-links

NIH3 - 315 A
 NIH3 - 630 A

Test sample

Rated voltage 400 V
 Rated current 315 A
 Rated frequency 50 Hz
 Utilization category 9C

IEC 60269-1:1988
 IEC 60269-2-1:1996, modified

- Verification of the breaking capacity, tests II to IV (630 A)
 - Verification of the breaking capacity, test II (315 A)

18 and 20 June 2001

на основании чл. 2 от 33ЛД

на основании чл. 2 от 33ЛД


se test laboratory

accredited by Deutsche A
 for any power table of

is located at the site of the apparatus
 and intelligence, insulation equipment and DAT - P - 019/82

IPI - LANDSBERGER ALLEE 376 - D-12681 BERLIN - TEL. 030/54 95 00 30 - FAX 030/54 96 02 22

ВЕРНО С
 ОРИГИНАЛА



Die IPI GmbH, Berlin, als unabhängiges akkreditiertes Prüflabor, hat in Übereinstimmung mit DIN EN ISO/IEC 17025 folgende Prüfverfahrensweise:

Typfall-Zertifizierung

Ein Typfall-Zertifikat, das für einen oder mehrere bestimmter Typenfallprüfungen erteilt, die nach einer gültigen Norm und unter Berücksichtigung der einschlägigen STI-Guides, LOVAG Test Reports oder anderer internationaler Standards ausgestellt wurden, ist ein Zeugnis dafür, dass die Prüfungen unter den durch die Normen oder Standards festgelegten Bedingungen in einem akkreditierten Prüflabor durchgeführt wurden. Es dokumentiert die wesentlichen Verfahren und Prüfungen in Höhe der spezifizierten Prüfungsleistung und stellt die Ergebnisse der dokumentierten Prüfungen dar.

Typfall-Zertifikat

Ein Typfall-Zertifikat wird für einen oder mehrere bestimmter Typenfallprüfungen erteilt, die nach einer gültigen Norm und unter Berücksichtigung der einschlägigen STI-Guides, LOVAG Test Reports oder anderer internationaler Standards ausgestellt wurden. Das Zertifikat dokumentiert die wesentlichen Verfahren und Prüfungen in Höhe der spezifizierten Prüfungsleistung und stellt die Ergebnisse der dokumentierten Prüfungen dar.

Prüfverfahren

Ein Prüfverfahren ist ein Prozess, mittels des eines bestimmten oder mehrerer bestimmter Typenfallprüfungen durchgeführt werden. Der Prüfbericht enthält Angaben zur Identifizierung des Prüfobjekts, zur Beschreibung der Prüfungen, die durchgeführt wurden, sowie die Ergebnisse der Prüfungen. Ein Prüfverfahren kann auch die Verfahren zur Identifizierung der Prüfmuster und zur Bewertung der Prüfergebnisse umfassen.

Prüfverfahrensbeschreibung

Die Prüfverfahrensbeschreibung dokumentiert die wesentlichen Prüfungen, die im Zusammenhang mit dem Typfall-Zertifikat durchgeführt wurden. Sie enthält die wesentlichen Informationen, die für die Durchführung der Prüfungen erforderlich sind.

IPI GmbH, ist ein unabhängiges akkreditiertes Prüflabor, das die Anforderungen an ein Prüflabor nach DIN EN ISO/IEC 17025 erfüllt.

Typfall-Test-Overviews

Das Typfall-Test-Overview ist ein Dokument, das die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, enthält. Es enthält die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, sowie die Ergebnisse der Prüfungen. Ein Typfall-Test-Overview kann auch die Verfahren zur Identifizierung der Prüfmuster und zur Bewertung der Prüfergebnisse umfassen.

Typfall-Test-Report

Das Typfall-Test-Report ist ein Dokument, das die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, enthält. Es enthält die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, sowie die Ergebnisse der Prüfungen. Ein Typfall-Test-Report kann auch die Verfahren zur Identifizierung der Prüfmuster und zur Bewertung der Prüfergebnisse umfassen.

Typfall-Test-Report

Das Typfall-Test-Report ist ein Dokument, das die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, enthält. Es enthält die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, sowie die Ergebnisse der Prüfungen. Ein Typfall-Test-Report kann auch die Verfahren zur Identifizierung der Prüfmuster und zur Bewertung der Prüfergebnisse umfassen.

Typfall-Test-Report

Das Typfall-Test-Report ist ein Dokument, das die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, enthält. Es enthält die wesentlichen Informationen über die Prüfungen, die durchgeführt wurden, sowie die Ergebnisse der Prüfungen. Ein Typfall-Test-Report kann auch die Verfahren zur Identifizierung der Prüfmuster und zur Bewertung der Prüfergebnisse umfassen.

Handwritten signatures and notes at the top of the page.


Contents	Sheet
1. Participants in the test	3
2. Test performed	3
3. Identification of test object	4
3.1 Technical data and characteristics	4
3.2 Identity documents	4
4. Verification of the breaking capacity, tests I1 to I5, AC	5
4.1 Test laboratory	5
4.2 Normative document	5
4.3 Required test parameters	5
4.4 Test arrangement	5
4.5 Test and measuring circuits	6
4.6 Test results	8
5. Appendices	11
5.1 Oscillograms	11
5.2 Drawings	20

1. Participants in the test	
Mr. Rainer Borchert	IPH test engineer in charge
Mrs. Hauschild	IPH test engineer
Mr. Stultz	IPH test engineer
Mr. Georgias	IPH test engineer

2. Test performed	
-	Verification of the breaking capacity, tests I1 to I5 at 630 A type
-	Verification of the breaking capacity, test I1 at 315 A type

[Handwritten signature]

ВЯРНО С
ОРИГИНАЛА



Copy No: 3

Federal Elektrik Yatirim ve Ticaret A.S.

This document is confidential. Its transfer to third parties as well as its reproduction in any form require the consent of the client.

270

TEST REPORT NO. 1211.02511.194

3. Identification of test object

3.1 Technical data and characteristics

Rating assigned by the manufacturer

Test object LV HRC fuse-links

Type NH3

Manufacturer Federal Elektrik Yatirim ve Ticaret AS

Year of manufacture 2001

Rated characteristics

400 V

50 Hz

315 A

630 A

120 kA

gG

Rated voltage

Rated frequency

Rated current

Breaking capacity I1

Utilization category


3.2 Identify documents

The identity of the test object is fixed by the following drawings and data submitted by the client

Name of drawing	Drawing No.	Date of drawing	Author	Notes
Fuse body	14.06.01	23.03.2000	Federal Elektrik Yatirim ve Ticaret AS.	Sheet 20
Etyen Şerit Tel	14.06.04	08.01.2001	Federal Elektrik Yatirim ve Ticaret AS.	Sheet 21
Etyen Şerit Tel	13.06.044	25.04.1996	Federal Elektrik Yatirim ve Ticaret AS.	Sheet 22

Entry of test object at IPH: April 2001

The tests were carried out on the samples chosen by TSE



TEST REPORT NO. 1211.02511.194

4. Verification of the breaking capacity, tests I1 to I5, AC

4.1 Test laboratory

High-power test laboratory, high-current test bay

Low-voltage test laboratory, test room 4

4.2 Normative document

IEC 60269-1: 1988, Sub-clause 8.5

4.3 Required test parameters

Test voltage 440 V AC, 50 Hz

Test current I1: 120 kA

Test currents I2 to I5: To IEC 60269-1: 1988, Sub-clause 8.5, Table 12A


4.4 Test arrangement

To IEC 60269-1: 1988, Sub-clauses 8.5.1 and 8.1.4

Handwritten signature

121

1.5 Test and measuring circuits



- E Supply
- Dr Making switch
- Z Test circuit impedance
- U1 Test voltage measurement
- U2 Switching voltage measurement
- I Current measurement
- 1-3 Measuring points

Figure 1: Test circuit for the verification of breaking capacity

Technical data of measuring circuits

Serial No.	Measuring point	Measured quantity	Measuring sensor/device	Technical parameters
1	1	Current	Shunt	19.387 kA/V
2	2	Switching voltage	RC divider	Ratio 499
3	3	Test voltage	Voltage transformer	Ratio 100

Recording instruments:
BE 256 transient recorder with optical links

Handwritten signature

ВЕРНО С
ОРИГИНАЛА


6.5 Test results

Test requirements
 Type of test circuit: Direct
 Condition of test object before test: New
 Ambient temperature: 19 °C

Test results (continued)
 Test duty I2: Direct
 Condition of test object before test: New
 Ambient temperature: 21 °C

Test No.	101 2455	101 2456	101 2457	101 2461	101 2462	101 2463
Test duty	II	II	II	II	II	II
Series	NH3	NH3	NH3	NH3	NH3	NH3
No. of test object	14	15	16	14	15	16
Rated current of fuse-link	A	630	630	315	315	315
Test voltage	V	550	550	550	550	550
Prospective peak short-circuit current	KA	273	273	273	273	273
Prospective symmetrical rms short-circuit current I _s	KA	121	121	121	121	121
Power factor cos φ		0.16	0.16	0.16	0.16	0.16
Arising angle	°el	27.3	41.0	58.6	29.7	57.6
Arising angle	°el	55.0	66.9	79.2	46.4	70.6
Rising current I _r	KA	50.3	53.3	57.0	30.2	36.2
Cutoff current	KA	55.8	59.1	61.1	32.0	38.4
Arising time	ms	1.54	1.33	1.14	0.926	0.678
Arising time	ms	4.58	4.30	3.79	4.12	4.01
Peak time	ms	6.12	5.53	4.94	5.05	4.74
Peak integral 10°	A ² s	1109	1127	1224	263	297
Arising integral 10°	A ² s	2249	2792	2804	601	1038
Breaking integral 10°	A ² s	3354	3913	4022	862	1328
Arc energy	KVAe	64.3	79.0	73.1	28.5	41.2
Switching voltage	V	1788	1184	1213	947	1081
Recovery voltage	V	555	554	555	557	556
Volume resistivity	MΩ	> 0.1	> 0.1	> 0.1	> 0.1	> 0.1
Notes		ok	ok	ok	ok	ok
Evaluation		ok	ok	ok	ok	ok

Notes:
 ok: The test object was able to properly break
 no permanent arcing
 no flashover
 no section of fuses which may be dangerous to the surroundings.
 Condition of test object after test
 The test object did not show any damage. The indicator responded.



273

Test No.	101 2479	101 2480	101 2481
Test duty	II	II	II
Series	NH3	NH3	NH3
No. of test object	4	5	6
Rated current of fuse-link	A	630	630
Test voltage	V	550	550
Prospective peak short-circuit current	KA	108	108
Prospective symmetrical rms short-circuit current I _s	KA	47.1	47.1
Power factor cos φ		0.16	0.16
Arising angle	°el	13.1	12.7
Arising angle	°el	71.5	70.7
Rising current I _r	KA	40.4	39.9
Cutoff current	KA	43.8	43.1
Arising time	ms	0.858	0.85
Arising time	ms	3.24	3.19
Peak time	ms	3.64	3.82
Peak time	ms	6.88	7.05
Peak integral 10°	A ² s	1374	1308
Arising integral 10°	A ² s	2862	2569
Breaking integral 10°	A ² s	4233	3873
Arc energy	KVAe	84.6	84.2
Switching voltage	V	1201	1239
Recovery voltage	V	553	550
Volume resistivity	MΩ	> 0.1	> 0.1
Notes		ok	ok
Evaluation		ok	ok

Notes:
 ok: The test object was able to properly break
 no permanent arcing
 no flashover
 no section of fuses which may be dangerous to the surroundings.
 Condition of test object after test
 The test object did not show any damage. The indicator responded.

Handwritten signature

Test results (continued)


Type of test circuit: Direct
 Test duties: B, 14, 15
 Test equipment: New
 Condition of test object before test: New
 Ambient temperature: 21 °C

Test parameter	B	14	15
Capacity	NH3	NH3	NH3
Size	20	21	22
No. of test object	630	630	630
Rated current of fuse-link	A	440	440
Test voltage	V	2750	2750
Rated symmetrical fault-circuit current I _{sc}	A	0.47	0.39
Power factor cos φ	1	34	77
Break time	ms	> 0.1	> 0.1
Shunt resistance	Ω	1	1
Indicator	ok	ok	ok

Notes

- ok: The test object was able to properly break
- no permanent arcing
- no flashover
- no ejection of flames which may be dangerous to the surroundings.
- Condition of test object after test
- The test object did not show any damage with exception.
- 1) Cracking in ceramic cartridge.
- The indicator responded.


ВЯРНО &
ОРИГИНАЛ



1211

Appendices

5.1 Oscillograms



Handwritten signature

Handwritten signature



INSTITUT „PRÜFFELD FÜR ELEKTRISCHE HOCHLEISTUNGSTECHNIK“ GMBH

TEST REPORT NO. 1211.0251.1.194



SHEET 13

Ord.-Nr.
Osc.-No. 1012457





INSTITUT „PRÜFFELD FÜR ELEKTRISCHE HOCHLEISTUNGSTECHNIK“ GMBH

TEST REPORT NO. 1211.0251.1.194




SHEET 12


Ord.-Nr.
Osc.-No. 1012456




ВЯРНО С
ОРИГИНАЛА



275






Handwritten signature




Handwritten signature

ВЯРНО С
 ОПИСАНИЕТА







[Handwritten signature]



ВЕРНО С
ОРИГИНАЛОМ



[Handwritten initials]

[Handwritten signature]







Handwritten signature

Orz.-Nr. 1012481
Osc.-No.




Orz.-Nr. 1012480
Osc.-No.





ВАРНО С
ОРИГИНАЛА



Report No:0315-15-1


282

<p>Test item particulars.....</p> <p>Classification of installation and use.....: Fusos for use by authorized persons</p> <p>Supply Connection.....: At both sides</p>
<p>Possible test case verdicts:</p> <p>- test case does not apply to the test object.....: N/A</p> <p>- test object does meet the requirement.....: P (Pass)</p> <p>- test object does not meet the requirement.....: F (Fail)</p>
<p>Testing.....:</p> <p>Date of receipt of test item.....: 01.05.2016</p> <p>Date (s) of performance of tests.....: 01.05.2016 – 20.12.2016</p>
<p>General remarks:</p> <p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(See Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report. Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p>
<p>Manufacturer's Declaration per sub-clause 6.2.5 of IEC60385-1:</p> <p>The application for obtaining a CB Test Certificate <input type="checkbox"/> Yes includes more than one factory location and a <input type="checkbox"/> Not applicable declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided.....:</p>
<p>When differences exist, they shall be identified in the General product information section. Name and address of factory (ies).....:</p>

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
CHARACTERISTICS OF FUSES			
5.2	Rated voltage (V) as specified	: 500 V	P
5.3.1	Rated current (A) of the fuse-link in accordance with specified values	125, 160, 200, 250, 315, 355, 400, 500, 630A	P
5.3.2	Rated current (A) of the fuse-holder	: 630 A	P
5.4	Rated frequency (Hz)	: 50 Hz	P
5.5	Max. rated power dissipation (VA) of fuse-link	: 48 W	P
	Rated acceptable power dissipation (VA) of fuse-holder	: 60 W	P
5.6	Limits of time-current characteristics based on reference ambient air temperature Ta of +20°C	: +20°C	P
5.6.1	Time-current zones deviated from standardized, or available in manufacturers documentation (with tolerances)		N/A
5.6.2	Conventional times and currents	see Table 2	P
5.6.3	Gates		P
5.7	Breaking range and breaking capacity		
5.7.1	Breaking range and utilization category	: gL/gS	P
5.7.2	Rated breaking capacity (A) of fuse-link corresponds to the rated voltage (V), and is equal or higher than given minimum (A) in subsequent part of this standard	100 kA/500 V	P
5.8	Cut-off current and I ² t characteristics are referred to the values of voltage, frequency and power factor		P
5.8.1	Cut-off current characteristics, if required, given by the manufacturer according to Figure 4		P
5.8.2	Pre-arcing I ² t characteristics for pre-arcing times of less than 0.1 s down to a time corresponding to the rated breaking capacity given by the manufacturer		P
	The operating I ² t characteristics with specified voltage as parameter for pre-arcing times less than 0.1 s given by the manufacturer		P

ВЪРХО С
ОРИГИНАЛА



Report No:0315.15-1

283

Clause	Requirement + Test	Result - Remark	Verdict
MARKINGS			
Markings are durable and easily legible			
6.1	Fuse-holders marked by:		P
	- name of manufacturer or trade mark which enable identification of fuse-holder	: FEDERAL	P
	- manufacturer's identification reference enabling to find all characteristics listed in 5.1.1	: NH3-FA	P
	- rated voltage (V)	: 690 V	P
	- rated current (A)	: 630 A	P
	- kind of current and rated frequency (Hz)	: -	P
6.2	Fuse-link(s) except small fuse-link(s) marked by:		
	- name of manufacturer or trade mark which enable identification of fuse-links	: FEDERAL	P
	- manufacturer's identification reference enabling to find all characteristics listed in 5.1.2	: NH3-FB	P
	- rated voltage (V)	: 500 V	P
	- rated current (A)	: 125, 160, 200, 250, 315, 355, 400, 500, 630 A	P
	- breaking range and utilization category (if applicable) (5.7.1)	: gL/gS	P
	- kind of current	: -	P
	- rated frequency (Hz), if applicable (5.4)	: -	N/A
	Small fuse-links marked by:		
	- trademark		N/A
	- list reference of manufacturer		N/A
	- rated voltage (V)		N/A
	- rated current (A)		N/A
6.3	Symbols for the kind of current and frequency in accordance with IEC 60417		P


Report No:0315.15-1

(Handwritten signature)

Clause	Requirement + Test	Result - Remark	Verdict
STANDARD CONDITIONS FOR CONSTRUCTION			
7.1	Mechanical design		
7.1.1	Replacement of fuse-links easily and safely		P
7.1.2	Connections, including terminals		
	Contact force is not transmitted through insulating material other than ceramic or other material with characteristics not less suitable, unless there is sufficient resilience in the metallic parts to compensate any possible shrinkage or other deformation of the insulating material		P
	Terminals cannot turn or be displaced when the connecting screws are tightened		P
	Terminals shall be such, that the conductors cannot be displaced		P
	Parts gripping the conductors are of metal		P
	Gripping parts cannot unduly damage conductors		P
	Terminals readily accessible under the intended conditions of installation		P
7.1.3	Fuse-contacts		
	Fuse-contacts are such that necessary contact force is maintained under the conditions of service and operation		P
	Contact is such that electromagnetic forces occurring during operation under conditions in accordance with 7.5 not impair electrical connections between		
	a) fuse-base and fuse-carrier		N/A
	b) fuse-carrier and fuse-link		N/A
	c) fuse-link and fuse-base		P
	Fuse contacts are so constructed and of such material that, when fuse is properly installed and service conditions are normal, adequate contact is maintained		
	a) after repeated engagement and disengagement		P
	b) after being left undisturbed in service for long period		P
7.1.4	Construction of a gauge-piece		
	Gauge-piece is so designed that it withstands normal stresses occurring during use		N/A
7.1.5	Mechanical strength of fuse-link		
	Fuse-link have adequate mechanical strength and its contacts are securely fixed		P
7.2	Insulating properties and suitability for isolation		

Clause	Requirement + Test	Result - Remark	Verdict
	Fuses are such that they do not lose insulating properties at voltages to which they are subjected in normal service		P
	Fuse passes the tests for verification of insulating properties and suitability for isolation in accordance with 8.2		P
7.3	Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of the fuse-holder		
	See Table 5		P
	Requirements are verified by tests according to 8.3		P
7.4	Operation		
	Fuse-link is so designed and proportioned that, when tested in its appropriate test arrangement at rated frequency and ambient air temperature of (20±5)°C		
	- is able to carry continuously any current not exceeding its rated current		P
	- is able to withstand overload conditions as they may occur in normal service (see 8.4.3.4)		P
	Fuse-link satisfy these conditions if it passes the tests prescribed in 8.4		P
7.5	Breaking capacity		
	Fuse is capable of breaking, at rated frequency and at voltage not exceeding the recovery voltage specified in 8.5, any circuit having prospective current between		
	- current I_k (for "g" fuse-links)		P
	- current k_{A_n} (for "a" fuse-links)		N/A
	- for a.c., rated breaking capacity at power factors not lower than those in Table 20	100 kA	P
	- for d.c., rated breaking capacity at time constants not greater than those limits in Table 21		N/A
	Arc voltage not exceed values given in Table 6		P
	Fuse satisfy these conditions if it passes the tests prescribed in 8.5		P
7.6	Cut-off current characteristic		

BARRACUDA CONSULTING




884

Clause	Requirement + Test	Result - Remark	Verdict
	Values of cut-off current measured as specified in 8.6 are less than, or equal to, the values corresponding to cut-off current characteristics assigned by the manufacturer		P
7.7	I_t characteristics		
	Pre-arcing I_t values verified according to 8.7 (Table 7)		P
	Operating I_t values verified according to 8.7		P
7.8	Overcurrent discrimination of fuse-links		P
7.9	Protection against electric shock		
	The degree of protection when the fuse is under normal service conditions	IP	N/A
	The degree of protection when replacing the fuse-link	IP	N/A
	The degree of protection when the fuse-link and fuse-carrier is removed	IP	N/A
7.9.1	Clearances and creepage distances		
	Clearances are not less than the values given in Table 9	See Clause 8.2.3	P
	Creepage distances correspond to material group, as defined in 2.7.1.3 of IEC 60664-1, corresponding with rated voltage given in Table 10	See Clause 8.2.3	P
7.9.2	Leakage currents of fuses suitable for isolation		
	Value of leakage current (mA) not exceed		
	- 0.5 mA per pole for fuses in new conditions	< 0,05 mA	P
	- 2 mA per pole for fuses having been submitted to test according to 8.5		-
7.9.3	Additional constructional requirements for fuses for linked fuse-carriers, suitable for isolation		
	Fuse-holder are marked with the symbol IEC 60617-S00369		N/A
	When fuse is in open position, with fuse-link remaining inside the fuse-carrier, isolating distance between the fuse contacts in accordance with the isolating function are provided		N/A
	Indication of this position is provided by the position of the fuse-carrier		N/A
	There exists a locking means in order to lock the fuses in the isolated position, locking is possible only in this position		N/A

Clause	Requirement + Test	Result - Remark	Verdict
	Fuses are designed so that the fuse-carrier remains attached to the fuse-base giving correct indication of the open position, and of locking		N/A
7.10	Resistance to heat		
	All components are sufficiently resistant to heat which may occur in normal use (see 8.9 and 8.10)		P
7.11	Mechanical strength		
	All components of fuse are sufficiently resistant to mechanical stresses which may occur in normal use (see 8.3 to 8.5 and 8.11.1)		P
7.12	Resistance to corrosion		
	All metallic components of fuse are resistant to corrosive influences which may occur in normal use		P
7.12.1	Resistance to rusting		
	Ferrous components are so protected that they meet relevant tests (see 8.2.2.3.2 and 8.11.2.3)		P
7.12.2	Resistance to season cracking		
	Current-carrying parts are sufficiently resistant to season cracking (see 8.2.2.3.2 and 8.11.2.1)		P
7.13	Resistance to abnormal heat and fire		
	All components of fuse are sufficiently resistant to abnormal heat and fire (see 8.11.2.2)		P
7.14	Electromagnetic compatibility		
	Fuses within the scope of this standard are not sensitive to normal electromagnetic disturbances		N/A
	No immunity tests are required		N/A


Handwritten signature

EMERIC INC. LTD
CORPORATE




Clause	Requirement + Test	Result - Remark	Verdict
TESTS			
8.1.2	At the beginning of each test, the fuse is approximately at the ambient temperature		P
8.1.3	Tests made on fuses in clean and dry condition		P
8.1.4	Arrangement of the fuse and dimensions		
	Except for degree of protection test (see 8.8), fuses are mounted in free air in draught-free surroundings in the normal operation position and on insulating material of sufficient rigidity		P
	Before tests are started, specified external dimensions are measured and results compared with dimensions specified in the relevant data sheet of the manufacturer or specified in subsequent parts	Part 2, Figure 101	P
8.1.5	Testing of fuse-links		
	Fuse-links tested with the kind(s) of current for which they are rated	AC	P
	Fuse-links tested for a.c. with frequency for which they are rated	50 Hz	P
8.1.5.1	Complete tests		
	Internal resistance R measured by a current $\leq 0,1$ In		P
	Measuring current (A) : 0,3		P
	Ambient air temperature in range of 20 ± 5 °C		P
	The values of resistance (see appended table)		P
8.1.5.2	Testing of fuse-links of a homogeneous series		
	Fuse-links tested like a homogeneous series : Yes/No		P
	If yes: fuse-links have identical enclosures in form and construction (except of fuse-elements and contacts)		P
	- the same arc-extinguishing medium and same completeness of filling		P
	- fuse-elements of identical materials		P
	- their cross-section of fuse-elements not exceed the cross-section of fuse-links having the highest rated current		P
	- number of fuse-elements do not exceed number of fuse-elements of fuse-links with the highest rated current		P
	- minimum distances between adjacent fuse-elements and between the fuse-elements and the inner surface of the cartridge is not less than those in the fuse-link with the highest rated current		P
	- fuse-links used with a given fuse-holder, or		P

Clause	Requirement + Test	Result - Remark	Verdict
	- fuse-links intended to be used in an arrangement identical for all rated currents of the homogeneous series		P
	- value of $R_{i,30}$ does not exceed the value for the fuse-link with largest rated current of the homogeneous series (R measured as indicated in 8.1.5.1)		P
	the rated breaking capacity of fuse-links not greater than that of the fuse-link with the largest rated current within the homogeneous series		P
	- if not, the fuse-links with greater breaking capacity subjected to tests no. 1 and no. 2		N/A
	The fuse-link having the largest rated current tested completely according to Table 11	630 A	P
	The fuse-link having the smallest rated current tested only according to Table 12	125 A	P
	The fuse-links between the largest and smallest rated current tested according to Table 13	160, 200, 250, 315, 400, 500 A	P
8.1.6	Testing of fuse-holders		
	The fuse-holders are subjected to the tests according to Table 14		P
8.2	Verification of the insulating properties and of the suitability for isolation		P
8.2.1	Arrangement of the fuse-holder		
	The fuse-holder fitted with a fuse-links of the largest dimensions for the type of fuse-holder concerned		P
	The fuse-base fixed to a metal plate, unless otherwise specified		P
	Fuse-link is replaced a while live - surfaces of fuse-link, of device for replacing it or of fuse-carrier, if of insulating material, are provided with metal coverings connected during tests to the frame of the apparatus; if of metal, they are connected direct to the frame		P
8.2.2	Verification of the insulating properties		
	Points of application of the test voltage	1890 V	P
	The test voltage is applied between:		
	a) live parts and the frame with the fuse-link and the device for replacing it, or		P
	the fuse-carrier, if any, in position		N/A
	no breakdown of insulation or flashover during 1 min of the applying test voltage		P
	b) the terminals without fuse-link, device for replacing or the fuse-carrier		P



Clause	Requirement + Test	Result - Remark	Verdict
	no breakdown of insulation or flashover during 1 min of the applying test voltage		P
	c) live parts of different polarity in the case of multipole fuse-holder with fuse-links, fuse-carrier(s) or device(s) for replacing the fuse-links		N/A
	no breakdown of insulation or flashover during 1 min of the applying test voltage		N/A
	d) live parts which in the case of a multipole fuse-holder reach different potential after the fuse-link operates (equipped by fuse-carrier or device for replacing without fuse-link)		N/A
	no breakdown of insulation or flashover during 1 min of the applying test voltage		N/A
	The values of test voltage (V) as specified in Table 15	1880 V	P
8.2.2.3.2	Fuse-holder is subjected to humid atmospheric conditions		P
	Relative humidity of ambient air (%)	: %95	P
	Ambient air temperature (°C)	: 25 °C	P
	Duration of treatment (h)	: 48 h	P
	Insulation resistance is measured between the points prescribed in 8.2.2.1 by applying d.c. voltage of approximately 500 V		P
	Points of measuring:		
	a) min. measured value (MΩ)	: > 1 MΩ	P
	b) min. measured value (MΩ)	: > 1 MΩ	P
	c) min. measured value (MΩ)		N/A
	d) min. measured value (MΩ)		N/A
	The insulation resistance not less than 1 MΩ	: > 1 MΩ	P
8.3	Verification of temperature rise and power dissipation		P
8.3.1	One fuse used for test (unless otherwise stated by the manufacturer) mounted in free air		P
	Test performed at an ambient air temperature of (20±5) °C	20°C	P
	Points of measuring:		
	a) Ambient air temperature during the test (°C)		P
	b) Cross-sectional area (see Table 17) (mm ² or mm x mm)	: 2 x 185 mm ²	P
	c) Tightened by torque; torque (Nm)	: 32 Nm	P
8.3.2	The temperature of the fuse measured by method of measuring	Thermocouples	P
8.3.3	Measurement of the power dissipation of the fuse-link		
	One fuse used for test (unless otherwise stated by the manufacturer) mounted in free air		P
	Test performed at an ambient air temperature of (20±5) °C		P
	Ambient air temperature during the test (°C)	: 22°C	P
	Cross-sectional area (see Table 17) (mm ² or mm x mm)	: 2 x 185 mm ²	P
	Tightened by torque; torque (Nm)	: 32 Nm	P
8.3.4.1	Temperature rise of the fuse-holder		
	Applied a.c. current (A) for test equal to the rated current of the fuse-holder	: 630 A	P
	Test made with fuse-link (A), or		N/A

ВРПНО С
ОПРИМАНА



287


Clause	Requirement + Test	Result - Remark	Verdict
	no disruptive discharge during the test		N/A
8.2.4.2	Fuse-holder is subjected to humid atmospheric conditions		N/A
	Relative humidity of ambient air (%)	: %95	P
	Ambient air temperature (°C)	: 25 °C	P
	Duration of treatment (h)	: 48 h	P
	Insulation resistance is measured between the points prescribed in 8.2.2.1 by applying d.c. voltage of approximately 500 V	500 Vdc	P
	Points of measuring:		
	a) min. measured value (MΩ)	: > 1 MΩ	P
	b) min. measured value (MΩ)	: > 1 MΩ	P
	c) min. measured value (MΩ)		N/A
	d) min. measured value (MΩ)		N/A
	The insulation resistance not less than 1 MΩ	: > 1 MΩ	P
8.3	Verification of temperature rise and power dissipation		
8.3.1	One fuse used for test (unless otherwise stated by the manufacturer) mounted in free air		P
	Test performed at an ambient air temperature of (20±5) °C	20°C	P
	Points of measuring:		
	a) Ambient air temperature during the test (°C)		P
	b) Cross-sectional area (see Table 17) (mm ² or mm x mm)	: 2 x 185 mm ²	P
	c) Tightened by torque; torque (Nm)	: 32 Nm	P
8.3.2	The temperature of the fuse measured by method of measuring	Thermocouples	P
8.3.3	Measurement of the power dissipation of the fuse-link		
	One fuse used for test (unless otherwise stated by the manufacturer) mounted in free air		P
	Test performed at an ambient air temperature of (20±5) °C		P
	Ambient air temperature during the test (°C)	: 22°C	P
	Cross-sectional area (see Table 17) (mm ² or mm x mm)	: 2 x 185 mm ²	P
	Tightened by torque; torque (Nm)	: 32 Nm	P
8.3.4.1	Temperature rise of the fuse-holder		
	Applied a.c. current (A) for test equal to the rated current of the fuse-holder	: 630 A	P
	Test made with fuse-link (A), or		N/A

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	with a dummy fuse-link specified in subsequent parts	Part 2 Figure 105	P
	Temperature rise limits T for contacts and terminals (Table 5):		
	spring loaded contacts (silver plated; limited only by the necessity of not causing any damage to adjacent parts)	unenclosed / enclosed 52 K	P
	bolted contacts; limit (K)	unenclosed / enclosed	N/A
	terminals; (silver plated) limits 70 K	unenclosed / enclosed 43 K	P
8.3.4.2	Power dissipation of a fuse-link		
	The test made with a.c. at the current (A) equal to the rated current of the fuse-link	630 A	P
	The points of measuring	Part 2 Figure 106, S points	P
	Measured value of power (W) dissipation in limits (W) specified in subsequent parts	43,5 W	P
8.3.5	The acceptable power dissipation (W) of fuse-holder not less than the rated power dissipation of the corresponding fuse-links	60 W	P
	After the tests prescribed in 8.3, the insulating parts of the fuse-holders cooled down to ambient temperature withstood the test voltage according to 8.2.		P
	No deformation after tests of 8.3		P
8.4	Verification of operation		
8.4.1	The test arrangement as specified in 8.1.4		P
	Length (m) of conductors (see 8.3.1)	2 m	P
	Their cross-sectional area (mm ²) as specified in Table 17	50 mm ² (125A fuse-link) 70 mm ² (160A fuse-link) 95 mm ² (200 A fuse-link) 120 mm ² (250A fuse-links) 185 mm ² (315A fuse-link) 185 mm ² (355A fuse-link) 240 mm ² (400A fuse-link) 2x150 mm ² (500A fuse-link) 2x185 mm ² (630A fuse-link)	P
8.4.2	Ambient air temperature during test within (20±5) °C	20-22 °C	P
8.4.3.1	Verification of conventional non-fusing and fusing current		
	(a) the fuse-link subjected to the conventional non-fusing current (I _{nf}) (see Table 2)	1,25 In	P
	the fuse-link did not operate within the conventional time of (t) (Table 2)	2 h (125A, 160A) 3 h (200, 250, 315, 400A) 4 h (500, 630)	P


Clause	Requirement + Test	Result - Remark	Verdict
	b) the same fuse-link, after cooled down to ambient temperature, subjected to the conventional fusing current (I _f) (see Table 2)	1,6 In	P
	the fuse-link operated within the conventional time of (minutes) (Table 2)	31 min (125A fuse-link) 38 min (160A fuse-link) 42 min (200A fuse-link) 33 min (250A fuse-link) 39 min (315A fuse-link) 48 min (355A fuse-link) 41 min (400A fuse-link) 48 min (500A fuse-link) 45 min (630A fuse-link)	P
8.4.3.2	Verification of rated current of "g" fuse-links		
	One fuse-link submitted to a pulse test for 100 h	100h	P
	On-period equal to conventional time (t)	2 h (125A, 160A) 3 h (200, 250, 315, 400A) 4 h (500, 630)	P
	Off-period of 0,1 of the conventional time	0,2 h (125A, 160A) 0,3 h (200, 250, 315, 400A) 0,4 h (500, 630)	P
	Test current (A) equal to 1,05 of the rated current	1,05 In	P
	After the test, the fuse-link not have changed its characteristics		P
8.4.3.1	a) the fuse-link subjected to the conventional non-fusing current (I _{nf}) (see Table 2)	1,25 In	P
	the fuse-link did not operate within the conventional time of (t) (Table 2)	2 h (125A, 160A) 3 h (200, 250, 315, 400A) 4 h (500, 630)	P
8.4.3.3	Verification of time-current characteristics and gates		
8.4.3.3.1	The time-current characteristics verified on the basis of the test according to 8.5		P
	Values of pre-arcing and operating times within the time-current zones:		
	- indicated by the manufacturer		P
	- specified in subsequent parts		N/A
	Verification for smaller current ratings, if only one largest rated current fuse-link is subjected to the test according to 8.5 (in case of homogeneous series):		
	"g" fuse-links (except "gD", "gS" and "gM")		N/A
	Tests made in connection with verification of the gates (see 8.4.3.2)		N/A
	Ambient air temperature within (20±5) °C		N/A
	rated current In (A) of the fuse-link		
	test performed at voltage (V)		
	test 3a) prospective current (A) equal to I _{in} (10 ≤ k ≤ 20)		N/A
	pre-arcing time (s)		
	specified pre-arcing time (s) max/min		N/A

БРПНО С
ОПРАВИЛАТА



Clause	Requirement + Test	Result - Remark	Verdict
	test 4a) prospective current (A) equal to kIn ($5 \leq k \leq 8$)		N/A
	pre-arcing time (s)		N/A
	specified pre-arcing time (s) max/min.		N/A
	test 5a) prospective current (A) equal to kIn ($2.5 \leq k \leq 4$)		N/A
	pre-arcing time (s)		N/A
	specified pre-arcing time (s) max/min.		N/A
	Verification for smaller current ratings, if only one largest rated current fuse-link is subjected to the test according to 8.5 (in case of homogeneous series):		
	"a" fuse-links		N/A
	Ambient air temperature within (20±5) °C		N/A
	rated current In (A) of the fuse-link		N/A
	test performed at voltage (V)		
	test 3a) prospective current (A) equal to $nk_2 In$ ($5 \leq n \leq 8$)		N/A
	pre-arcing time (s)		N/A
	specified pre-arcing time (s) max/min.		N/A
	test 4a) prospective current (A) equal to $nk_2 In$ ($2.5 \leq n \leq 3$)		N/A
	pre-arcing time (s)		N/A
	specified pre-arcing time (s) max/min.		N/A
	test 5a) prospective current (A) equal to $nk_2 In$ ($1.5 \leq n \leq 1.5$)		N/A
	pre-arcing time (s)		N/A
	specified pre-arcing time (s) max/min.		N/A
8.4.3.2	Verification of gages		P
	"g" and "m" fuse-links		
	rated current of the fuse-link (A)	125, 160, 200, 250, 315, 355, 400, 500, 630 A	
	test performed at voltage (V)	10-15 V	
	a) testing current (A); pre-arcing time (s) higher than 10 s	368A; >10 s (125A fuse-link) 474A; >10 s (160A fuse-link) 617A; >10 s (200A fuse-link) 752A; >10 s (250A fuse-link) 1057A; >10 s (315A fuse-link) 1427A; >10 s (400A fuse-link) 1791A; >10 s (500A fuse-link) 2214A; >10 s (630A fuse-link)	P

ВЯРНО С
ОПТИМАТА



289


Clause	Requirement + Test	Result - Remark	Verdict
	b) testing current (A); pre-arcing time (s) less than 5 s	715A; 3,4 s (125A fuse-link) 950A; 3,1 s (160A fuse-link) 1250A; 2,8 s (200A fuse-link) 1650A; 3,2 s (250A fuse-link) 2200A; 2,8 s (315A fuse-link) 2840A; 3,0 s (400A fuse-link) 3800A; 3,7 s (500A fuse-link) 5100A; 3,4 s (630A fuse-link)	P
	c) testing current (A); pre-arcing time (s) higher than 0,1 s	1110A; 0,24 s (125A fuse-link) 1453A; 0,31 s (160A fuse-link) 1922A; 0,28 s (200A fuse-link) 2601A; 0,33 s (250A fuse-link) 3434A; 0,41 s (315A fuse-link) 4527A; 0,30 s (400A fuse-link) 6026A; 0,27 s (500A fuse-link) 8089A; 0,25 s (630A fuse-link)	P
	d) testing current (A); pre-arcing time (s) less than 0,1 s	1910A; 32ms (125A fuse-link) 2590A; 31ms (160A fuse-link) 3420A; 20ms (200A fuse-link) 4500A; 38ms (250A fuse-link) 6000A; 38 ms (315A fuse-link) 8060A; 23 ms (400A fuse-link) 10600A; 31 ms (500A fuse-link) 14140A; 24 ms (630A fuse-link)	P
	"m" fuse-links		N/A
	rated current of the fuse-link (A)		
	test performed at voltage (V)		
	Cross-sectional area (see Table B) (mm ² or mm x mm)		
	e) testing current (A); pre-arcing time (s) higher than 60 s		N/A
	f) testing current (A); pre-arcing time (s) less than 60 s		N/A
	g) testing current (A); pre-arcing time (s) higher than 0,2 s		N/A
	h) testing current (A); pre-arcing time (s) less than 0,10 s		N/A
8.4.3.4	Overload		
	The test arrangement is same as that for the temperature rise test (see 8.3.1)		P
	Three fuse-links submitted to 50 pulses having the same duration and test current	50 pulses	P
	test performed at voltage (V)	10-15 V	
	"g" fuse-links:		
	test current (A) equal to 0,8 times the current stated for a pre-arcing time of 5 s	572A (125A fuse-links) 4080A (630A fuse-links)	P

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	duration of each pulse 5 s	5 s	P
	time (s) interval between pulses equal to 20 % of the conventional time (s) specified in Table 2	24 min (125A fuse-links) 48 min (630A fuse-links)	P
	"g" fuse-links:		N/A
	rated current (A) of fuse-link		N/A
	test current (A) equal to $k_{1n} \pm 2\%$		N/A
	the pulse duration (s) corresponds to that indicated on the overload curve for k_{1n} , stated by manufacturer		N/A
	time (s) intervals between pulses equal to 30 times the pulse duration		N/A
	fuse-links having ambient air temperature subjected to a current (A) equal to current for the overload test	572A (125A fuse-links) 4080A (630A fuse-links)	P
	pre-arcing time (s) of sample lies within the manufacturers time-current zone	1) 9 s 2) 10 s (125A fuse-links) 3) 9 s 4) 10 s (630A fuse-links) 5) 11 s	P
8.4.3.5	Conventional cable overload protection test (for "g" fuse-links only)		P
	fuse-link mounted as specified in 8.4.1		
	provided with PVC insulated copper conductors of cross-sectional area (mm ²) (see Table 19)	35 mm ² (125A fuse-link) 50 mm ² (160A fuse-link) 70 mm ² (200A fuse-link) 120 mm ² (250A fuse-link) 165 mm ² (315A fuse-link) 240 mm ² (400A fuse-link)	P
	fuse and conductor connected to it, preheated with rated current (A) of fuse-link	In	P
	for a time (h) equal to the conventional time	2 h (125A, 160A) 3 h (200A, 250A, 315A, 400A)	P
	test current increased to 1,45 I _n (A) (I _n specified in Table 19)	200,1A > 200A (125A fuse-link) 244A; (160A fuse-link) 309A; (200A fuse-link) 434A > 400A (250A fuse-link) 568A > 504A (315A fuse-link) 668A > 640A (400A fuse-link)	N/A P P N/A N/A N/A
	NOTE: It is not necessary to perform this test if the product I _n I _t is greater than the conventional fusing current.		
	the fuse-link operated in time (s) less than the conventional time (s)	28 min (160A fuse-link) 42 min (200A fuse-link)	P
8.4.3.6	Operation of indicating devices and strikers, if any		
	Operation of indicating device verified in combination with the verification of breaking capacity (see 8.5.5)		
	The verification of striker operation:		
	"g" fuse-link tested at current (A) equal to current I _n (see Table 20 and 21)		
	recovery voltage (V)		

Clause	Requirement + Test	Result - Remark	Verdict
	stated recovery voltage (V)		N/A
	"a" fuse-link tested at current (A) equal to current 2I _n (A) (see Figure 2)		N/A
	recovery voltage (V)		N/A
	stated recovery voltage (V)		N/A
	Striker operates during all tests made at recovery voltage or at least 20 V		N/A
	No failure of indicating device or striker		N/A
8.5	Verification of the breaking capacity	BUSTYAL Report No R.0107-15	P
8.5.1	The test arrangements as specified in 8.1.4		P
8.5.2	Characteristics of the test circuit as specified		P
	Scheme of test circuit (see Figure 5)		P
	Deviations from specified characteristics of test circuit		N/A
8.5.3	Measuring instruments		P
8.5.4	Calibration of test circuit		P
	Calibration oscillograms and their evaluation		P
8.5.6	The breaking-capacity tests made at an ambient air temperature of (20 ± 5) °C		P
	Breaking-capacity tests on a.c. fuses		P
8.5.5.1	Table 20, test No. 1 for "g" and "a" fuse-links		
	Rated breaking capacity of the fuse-links (kA), at voltage (V)	100 kA, at 500 V	
	Rated current (A) of the fuse-links	125 A, 630 A	
	Prospective current I _p (kA) equal to rated breaking capacity within a tolerance of + 10% - 0%	103,1 kA	P
	Power factor	0,12	P
	Initiation of arcing after voltage zero: within 40° - 65° for sample 1 and within 65° - 90° for sample 2 and 3, 2) or	1) 2) 3)	N/A
	for sample 1) arcing after voltage zero within 0° + 10° - 0°		P
	Power-frequency recovery voltage: voltage (V) (ie (% of rated voltage within 105% + 5% - 0% of the rated voltage or 110% + 5% - 0% of the rated voltage	1) 546,7 V 2) 548,4 V (630A fuse-link) 3) 547,6 V 1) 549,1 V 2) 549,0 V (125A fuse-link) 3) 549,8 V	P


OPSI
KEMENTERIAN
BERSEKUTU
KEMENTERIAN
BERSEKUTU



Clause	Requirement + Test	Result - Remark	Verdict
	Cut-off current (A) :	1) 54,59 kA 2) 49,80 kA (630A fuse-link) 3) 52,05 kA 1) 12,11 kA 2) 12,21 kA (125A fuse-link) 3) 12,70 kA	P
8.5.8	Acceptability of No. 1 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		P
	b) fuse-links operated without external effects or damage to the components of the complete fuse		P
	c) no permanent arcing, flashover or ejection of dangerous flames		P
	d) no damage of fuse components hindering from their further use		P
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		P
	f) fuse-link remains in one piece before its removal from the fuse-carrier		P
	g) resistance (mΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	P
8.5.5.1	Table 20, test No. 2 for "g" and "a" fuse-links		P
	Prospective current I _p (kA)	45,09 kA	P
	Test made under conditions which approximate those giving maximum arc energy		P
	Power factor	0,16	P
	Making angle after voltage zero: within tolerance 0° + 20°, - 0°		P
	Power-frequency recovery voltage (V) i.e. (% of rated voltage within 105% + 5%, - 0% of the rated voltage or 110% + 5%, - 0% of the rated voltage	1) 2) 3)	P
	Recovery voltage maintained at a value (V); duration (s) for sample (No.)	550 V, 15 s for sample 3	P
8.5.8	Acceptability of No. 2 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A

Report No:0315.15-1

ВРФНО С
ОПРАТНИЦА




291

Clause	Requirement + Test	Result - Remark	Verdict
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (mΩ) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 20, test No. 2 for "g" and "a" fuse-links, for I _p ≥ I _n	(see appended table)	N/A
	Prospective current I _p (kA) for test No. 2 greater than the rated breaking capacity (kA)		N/A
	Test made on six samples replacing tests of Nos. 1 and 2. Test made with current I _p (kA)		N/A
	Making angle differ approximately 30° between each test		N/A
	Power factor		N/A
8.5.8	Acceptability of No. 2 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
8.5.5.1	Table 20, test No. 3 for "g" and "a" fuse-links		
	Prospective current for "g" fuse-link I _p (A) equal to 3.2 I _n		N/A
	Prospective current for "a" fuse-link I _p (A) equal to 2.5 I _n		N/A
	Power factor		N/A
	Tolerance on current ± 20%		N/A
	Recovery voltage (V) maintained for 15 s (8.5.5.2)		N/A
8.5.8	Acceptability of No. 3 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A

Handwritten signature

Report No:0315.15-1

Clause	Requirement + Test	Result - Remark	Verdict
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (MD) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases:	1) 2) 3)	N/A
8.5.5.1	Table 20, test No. 4 for "g" and "a" fuse-links		
	Prospective current for "g" fuse-link I _g (A) equal to 2.0 I _n		N/A
	Prospective current for "a" fuse-link I _a (A) equal to 1.6 I _n		N/A
	Power factor		N/A
	Tolerance on current + 20%, - 0%		N/A
	Recovery voltage (V) maintained for 15 s (8.5.5.2):		N/A
8.5.8	Acceptability of No. 4 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (MD) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases:	1) 2) 3)	N/A
8.5.5.1	Table 20, test No. 5 for "g" and "a" fuse-links		
	Prospective current for "g" fuse-link I _g (A) equal to 1.25 I _n		N/A
	Prospective current for "a" fuse-link I _a (A) equal to 1.6 I _n		N/A




Clause	Requirement + Test	Result - Remark	Verdict
	Power factor		N/A
	Tolerance on current + 20%, - 0%		N/A
	Recovery voltage (V) maintained for 15 s (8.5.5.2):		N/A
8.5.8	Acceptability of No. 5 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (MD) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases:	1) 2) 3)	N/A
	Breaking-capacity tests on d.c. fuses		N/A
8.5.5.1	Table 21, d.c. test No. 1 for "g" and "a" fuse-links		
	Rated breaking d.c. capacity of the fuse-links (kA), at voltage (V)		N/A
	Rated current (A) of the fuse-links		N/A
	Rated voltage (V) of the fuse-links		N/A
	Prospective current I _p (kA) equal to rated breaking capacity within a tolerance of + 10%, - 0%		N/A
	Time constant		N/A
	Arcing commences at current (A)	1) 2) 3)	N/A
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 1 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (M Ω) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c.test No. 2 for "g" and "a" fuse-links		
	a) During test No. 1 arcing commences at a current $\geq 0.5 I_n$, test No. 2 was not performed		N/A
	b) Prospective current I_p (A). Test made under conditions which approximate those giving maximum arc energy		N/A
	Time constant		N/A
	Arcing commences at current (A)	1) 2) 3)	
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 2 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (M Ω) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c.test No. 3 for "g" and "a" fuse-links		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (M Ω) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c.test No. 3 for "g" and "a" fuse-links		
	Conventional fusing current (A)		N/A
	Prospective current I_p (A) equal to 3.2 I_n		N/A
	Tolerance on current (%) $\pm 20\%$		N/A

Report No.0815.15-1



293


Clause	Requirement + Test	Result - Remark	Verdict
	Time constant		N/A
	Arcing commences at current (A)	1) 2) 3)	
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 3 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (M Ω) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases :	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c.test No. 4 for "g" and "a" fuse-links		
	Conventional fusing current (A)		N/A
	Prospective current I_p (A) equal to 2.0 I_n		N/A
	Tolerance on current (%) $\pm 20\%$		N/A
	Time constant		N/A
	Arcing commences at current (A)	1) 2) 3)	
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 4 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A

Report No.0815.15-1

[Handwritten signature]


Clause	Requirement + Test	Result - Remark	Verdict
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (MO) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases:	1) 2) 3)	N/A
8.5.5.1	Table 21, d.c. test No. 5 for "g" and "a" fuse-links		
	Conventional fusing current (A)		
	Prospective current I _s (A) equal to 1,25 I _n		N/A
	Tolerance on current (%) + 20%, - 0%		N/A
	Time constant		N/A
	Arcing commences at current (A)	1) 2) 3)	
	Value of recovery voltage: voltage (V) within tolerances 115 + 5%, - 9% of the rated voltage	1) 2) 3)	N/A
8.5.8	Acceptability of No. 5 test results		
	a) max. arc voltage (V) did not exceed stated values of 7.5 (Table 6)		N/A
	b) fuse-links operated without external effects or damage to the components of the complete fuse		N/A
	c) no permanent arcing, flashover or ejection of dangerous flames		N/A
	d) no damage of fuse components hindering from their further use		N/A
	e) no damage of fuse-link such, that it is difficult or dangerous to replace them		N/A
	f) fuse-link remains in one piece before its removal from the fuse-carrier		N/A
	g) resistance (MO) between contacts of fuse-links after test not less than 50 000 Ω for the rated voltage of fuse-links to 250 V, 100 000 Ω in all other cases:	1) 2) 3)	N/A
8.6	Verification of the cut-off current characteristics		
8.6.2	The values measured did not exceed cut-off characteristics indicated by the manufacturer (see 5.8.1)		P
8.7	Verification of I ² t characteristics and overcurrent discrimination		

Clause	Requirement + Test	Result - Remark	Verdict
8.7.2	The operating I ² t values measured not exceed the values indicated by the manufacturer, or those specified in subsequent parts	I ₁ - 4074 kA ² s I ₂ - 4708 kA ² s	N/A
	The pre-arcing I ² t values not less than minimum pre-arcing values given by the manufacturer, or they lie within the limits indicated in Table 7	I ₁ - 1659 kA ² s I ₂ - 2135 kA ² s	P
8.7.3	Verification of compliance for fuse-links at 0,01 s		
	"gG" and "gR" fuse-links at 0,01 s comply with Table 7	I _{0,01g} - 13225 kA ² s I _{0,01gR} - 3720 kA ² s (Annex B1)	P
8.7.4	Verification of overcurrent discrimination		
	The discrimination of the fuse-links verified by means of the time-current characteristics and the pre-arcing and operating I ² t values		P
8.8	Verification of the degree of protection of enclosures		
	Degree of protection IP	IP	N/A
	Verification by test under conditions specified in IEC 60529		N/A
8.9	Verification of resistance to heat		
	No damage impaired by heat during the previous tests (in particular with respect to 8.3, 8.4, 8.5 and 8.10)		P
8.10	Verification of non-deterioration of contacts		
8.10.1	Three samples provided with standardized dummy fuse-links of the highest current rating (A) intended to be used in the fuse-holder (see subsequent parts):	630 A dummy fuse-links	P
8.10.2	Test current (A) for load period	788 A	P
	Duration (s) of load period	60 min	P
	Duration (s) of no-load period	24 min	P
	a) Test of 250 cycles, measured values not exceed the limits given in subsequent parts		P
	b) Test of 750 cycles, measured values not exceed the limits given in subsequent parts		N/A
8.11	Mechanical and miscellaneous tests		
8.11.1	Mechanical strength		
	Mechanical characteristics of fuse and its parts judged in the context of normal handling and mounting as well as with results shown after breaking-capacity test (see 8.5), if not otherwise specified in the subsequent parts		P



Clause	Requirement + Test	Result - Remark	Verdict
8.11.2	Miscellaneous tests		
8.11.2.1	Verification of freedom from season cracking Current-carrying parts made of rolled copper alloy with less than 83% copper content and with all grease removed, placed for 4 h in test cabinet having temperature of (30 ± 10) °C After this, samples placed for 8 h in test cabinet, on the bottom of which is ammonium chloride solution having pH value 10 - 11 After test no cracks visible to the unaided eye	N/A NA NA	N/A NA NA
8.11.2.2	Verification of resistance to abnormal heat and fire		NA
8.11.2.2.1	Parts of insulating material, except ceramic, have a limited duration of burning without spreading fire by flames or burning droplets or glowing particles falling from the specimen Glow-wire test: (650 ± 10) °C Parts of insulating materials not necessary to retain current-carrying parts in position even though they are in contact with them, made the glow-wire test (650 ± 10) °C No visible flame, or burning or glowing of the specimen extinguish within max. (s) after removal of the glow-wire. Limit (30 ± 1) s No burning of the tissue paper No scorching of the pinewood board Glow-wire test: (960 ± 10) °C		P P P P
8.11.2.3	Parts of insulating materials necessary to retain current-carrying parts and parts of the earthing circuit, if any, in position, made the glow-wire test (960 ± 10) °C No visible flame, or burning or glowing of the specimen extinguish within max. (s) after removal of the glow-wire. Limit (30 ± 1) s No burning of the tissue paper No scorching of the pinewood board Verification of resistance to rusting Tested parts after degreasing (10 min in specified solution) placed for 10 min in air saturated with moisture and after that dried 10 min in an ambient temperature (100 ± 5) °C Surface of tested parts show no signs of rust		P P P P

Report No:0315.15-1



295

Clause	Requirement + Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

APPENDIX 1

8.1.5.1 TABLE: Internal resistance of the fuse-links												
a) rated current (A) of the fuse-link : 630 A												
measuring current (A) :												
ambient air temperature (°C) : 21 °C												
Internal resistance	1	2	3	4	5	6	7	8	9	10	11	12
R (mΩ)	0.072	0.075	0.076	0.069	0.074	0.072	0.076	0.075	0.074	0.076	0.076	0.072
sample No.:												
Internal resistance	13	14	15	16	17	18	19	20	21	22	23	24
R (mΩ)	0.073	0.075	0.075	0.076	0.077	0.076	0.074	0.072	0.073	0.076	0.074	0.072
measuring current (A) of the fuse-link : 500 A												
ambient air temperature (°C) : 21 °C												
Internal resistance	1	2	3	4	5	6	7	8	9	10	11	12
R (mΩ)	0.115	0.114	0.110	0.113	0.115	0.112	0.114	0.113	0.115	0.115	0.115	0.112
sample No.:												
Internal resistance	13	14	15	16	17	18	19	20	21	22	23	24
R (mΩ)	0.112	0.115	0.116	0.114								
measuring current (A) of the fuse-link : 400 A												
ambient air temperature (°C) : 21 °C												
Internal resistance	1	2	3	4	5	6	7	8	9	10	11	12
R (mΩ)	0.127	0.130	0.128	0.131	0.127	0.128	0.132	0.129	0.130	0.128	0.129	0.130
sample No.:												
Internal resistance	13	14	15	16	17	18	19	20	21	22	23	24
R (mΩ)	0.128	0.129	0.127	0.131								
measuring current (A) of the fuse-link : 315 A												
ambient air temperature (°C) : 21 °C												
Internal resistance	1	2	3	4	5	6	7	8	9	10	11	12
R (mΩ)	0.151	0.155	0.152	0.160	0.157	0.161	0.157	0.152	0.154	0.155	0.155	0.156
sample No.:												
Internal resistance	13	14	15	16	17	18	19	20	21	22	23	24
R (mΩ)	0.162	0.158	0.153	0.158								

Report No:0315.15-1

Clause	Requirement + Test	Result - Remark	Verdict
	a) rated current (A) of the fuse-link : 250 A		
	measuring current (A) :		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No.		
	1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.212 0.208 0.204 0.218 0.222 0.208 0.212 0.220 0.208 0.214 0.222 0.216		
Internal resistance	sample No.		
	13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.212 0.222 0.206 0.204		

	a) rated current (A) of the fuse-link : 200 A		
	measuring current (A) :		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No.		
	1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.272 0.268 0.256 0.270 0.282 0.254 0.266 0.274 0.258 0.278 0.264 0.268		
Internal resistance	sample No.		
	13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.288 0.278 0.272 0.284		


	a) rated current (A) of the fuse-link : 160 A		
	measuring current (A) :		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No.		
	1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.368 0.380 0.372 0.394 0.376 0.388 0.390 0.366 0.384 0.376 0.368 0.388		
Internal resistance	sample No.		
	13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.378 0.392 0.380 0.378		

	a) rated current (A) of the fuse-link : 125 A		
	measuring current (A) :		
	ambient air temperature (°C) : 21 °C		
Internal resistance	sample No.		
	1 2 3 4 5 6 7 8 9 10 11 12		
R (mΩ)	0.582 0.558 0.564 0.574 0.570 0.582 0.590 0.562 0.578 0.586 0.564 0.580		
Internal resistance	sample No.		
	13 14 15 16 17 18 19 20 21 22 23 24		
R (mΩ)	0.588 0.592 0.576 0.580		

TEST REPORT IEC 60269-2 Low-voltage fuses Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) - Examples of standardized systems of fuses A to K List of Attachments (including a total number of pages in each attachment):	
Summary of testing:	Testing location:
Tests performed (name of test and test clause):	IHP Laboratory/Sakarya/TURKEY
7.1 Mechanical design	
8.1.4 Arrangement of fuse and dimensions	
8.1.6 Testing of fuse holders	
8.2.5 Resistance to tracking	
8.3 Verification of temperature rise and power dissipation	
8.7.4 Verification of overcurrent discrimination	
8.9 Verification of resistance to heat	
8.10 Verification of non-deterioration of contacts	
8.11 Mechanical strength and miscellaneous tests	
Summary of compliance with National Differences List of countries addressed:	
The product fulfils the requirements of IEC 60269-2	

Handwritten signature

**ВАРНО С
ОРИГИНАЛА**




Clause	Requirement + Test	Result - Remark	Verdict
	Requirements IEC 60269-1		

FUSE SYSTEM A - FUSES WITH FUSE LINKS WITH BLADE CONTACTS (NH FUSE SYSTEM)

CHARACTERISTICS OF FUSES			
5.2	Rated voltage (V) as specified	500 V	P
5.3.1	Rated current (A) of the fuse-link in accordance with specified values	125, 160, 200, 250, 315, 400, 500, 630 A	P
5.3.2	Rated current (A) of the fuse-holder and the size of the fuse-link	630 A	P
5.5	Rated power (W) dissipation of fuse-link see Figure 101	48 W	P
	Rated acceptable power (VA) dissipation of fuse-bases given in Figure 102	60 W	P
5.6	Limits of time-current characteristics		P
5.6.1	Time-current characteristics, time-current zones and overload curves		P
5.6.2	Conventional times and current see Table 101		P
5.6.3	Gates		P
5.7.2	Rated breaking capacity (A)	100 kA	P

MARKING			
6.1	Markings are legible		P
	Fuse-holders marked by:		
	- IEC 60269-2		P
	- size	NH3	P
6.2	Marking of rated current and rated voltage are discernible from the front	630 A, 690 V	P
	Fuse-links marked by:		
	- IEC 60269-2		P
	- size or reference	NH3	P
	- rated breaking capacity	100 kA	P
	Marking of rated current and rated voltage are discernible from the front	125, 160, 200, 250, 315, 400, 500, 630 A	P
	Fuse-links are marked as described in Table 104		P

ВЯРНО С
ОРИГИНАЛА



299

Clause	Requirement + Test	Result - Remark	Verdict
	Requirements IEC 60269-2		

STANDARD CONDITIONS FOR CONSTRUCTION


MECHANICAL DESIGN			
7.1	The dimensions of the fuse-links given in Figure 101		P
	Dimensions:		
	dimension marking a ₁ ; prescribed (mm); measured (mm)	150 ± 2,5 ; 150	P
	dimension marking a ₂ ; prescribed (mm); measured (mm)	75 - 10 ; 73,5	P
	dimension marking a ₃ ; prescribed (mm); measured (mm)	62 ± 2,5 ; 62	P
	dimension marking a ₄ ; prescribed (mm); measured (mm)	68 ± 2,5 ; 68	P
	dimension marking b ₁ ; prescribed (mm); measured (mm)	Min 32 ; 32	P
	dimension marking b ₂ ; prescribed (mm); measured (mm)	Min 11 ;	N/A
	dimension marking b ₃ ; prescribed (mm); measured (mm)	Max 6 ; 5	P
	dimension marking b ₄ ; prescribed (mm); measured (mm)	Min 29 ; 31	P
	dimension marking c ₁ ; prescribed (mm); measured (mm)	80 ± 0,8 ; 59	P
	dimension marking c ₂ ; prescribed (mm); measured (mm)	11 - 2 ; 10	P
	dimension marking d ₁ ; prescribed (mm); measured (mm)	2,5 ^{+0,15} ; 2,7	P
	dimension marking e ₁ ; prescribed (mm); measured (mm)	Max 76 ; 68,5	P
	dimension marking e ₂ ; prescribed (mm); measured (mm)	Max 75 ; 68,5	P
	dimension marking e ₃ ; prescribed (mm); measured (mm)	20 ^{-0,5} ;	N/A
	dimension marking e ₄ ; prescribed (mm); measured (mm)	6 ± 0,2 ; 6	P
	dimension marking f ₁ ; prescribed (mm); measured (mm)	Max 18 ; 16,5	P
	dimension marking z ₁ ; prescribed (mm); measured (mm)	5 ;	N/A

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	The dimensions of the fuse-base given in Figure 102		P
	Dimensions:		
	dimension marking g: prescribed (mm); measured (mm)	73 ± 1;	N/A
	dimension marking h: prescribed (mm); measured (mm)	210 ± 1,5; 209	P
	dimension marking n: max: prescribed (mm); measured (mm)	Max 75 ; 34	P
	dimension marking n _{max} : prescribed (mm); measured (mm)	Max 83 ; 48 (bmc)	P
	dimension marking p: max: prescribed (mm); measured (mm)	51 (steelite)	P
	dimension marking p ₂ : prescribed (mm); measured (mm)	Max 68 ; 52,5 (bmc)	P
	dimension marking p ₃ : prescribed (mm); measured (mm)	49 (steelite)	P
	dimension marking r: min: prescribed (mm); measured (mm)	35 ± 1,5;	N/A
	dimension marking r: min: prescribed (mm); measured (mm)	Min 20 ; 28 (bmc)	P
	dimension marking r: min: prescribed (mm); measured (mm)	42 (steelite)	P
	dimension marking s: max: prescribed (mm); measured (mm)	Max 58 ; 44	P
	dimension marking t: min: prescribed (mm); measured (mm)	Min 33 ; 37	P
	dimension marking v: prescribed (mm); measured (mm)	80 ± 3 ; 78	P
	dimension marking w: prescribed (mm); measured (mm)	30 ± 0,7 ; 30	P
	dimension marking w ₂ : prescribed (mm); measured (mm)	25 ± 0,7 ; 25	P
	dimension marking x: min: prescribed (mm); measured (mm)	Min 20 ; 21	P
	dimension marking y: prescribed (mm); measured (mm)	10,5 ± 0,5 ; 11	P
	dimension marking z: max: prescribed (mm); measured (mm)	Max 5 ;	N/A
	dimension marking a: min: prescribed (mm); measured (mm)	Min 35 ; 60	P
	dimension marking b: min: prescribed (mm); measured (mm)	Min 30 ; 35	P
	dimension marking c: min: prescribed (mm); measured (mm)	Min 5 ; 5	P
	dimension marking d : prescribed (mm); measured (mm)	11 ± 0,25 ; 14 (see-note 10 of Figure 102)	P

Report No:0315.15-1

ВЕРНО С
ОРИГИНАЛОМ



298


Clause	Requirement + Test	Result - Remark	Verdict
	IEC 60269-2		
7.1.2	dimension marking e : prescribed (mm); measured (mm) Connections, including terminals cross-sectional ranges (Table 105) torques to be applied (Table 111) (lug terminal)	15 ± 0,5 ; 15 32 Nm	P
7.1.3	Contact surfaces should be silver plated If no test according to 8.10 are passed with dummites described in 8.10.1	Yes / No	P
7.1.6	Dynamic short-circuit withstand shall meet cut-off currents (Table 112)		N/A
7.1.7	Construction of fuse-link Blade contacts made of solid material If any other construction, manufacturer demonstrate that construction adequate Endplates not permitted to protrude radially from insulation body Preferable to insulate the gripping lugs from live parts Fuse-links has an indicator Electrically conductive parts of indicator not ejected from the fuse-link during operation Insulating properties and suitability for insulation		P
7.2	Creepage distances and clearances of fuses and fuse-accessories meet requirements of IEC 60684-1 for overvoltage category III and pollution degree 3. ; Insulating parts of fuse-bases supporting live parts meet the test at PTT 400 according to IEC 60112 (test solution A) f ₁ characteristics maximum pre-arcing f ₁ (Table 7 of IEC 60269-1) rated currents lower than 16 A and for 224 A (Table 106) maximum operating f ₁ for "allV" fuse-links (Table 107) test No. 2. of the largest rated current of each homogeneous series (Table 20 of IEC 60269-1) ... ; Overcurrent discrimination of "gG" fuse-links (see 8.7.4, Table 108)		P
7.7	Protection against electric shock Increased by means of partition walls and covers of fuse-contacts		N/A
7.8			P
7.9			N/A

Report No:0315.15-1

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
	operation by authorized persons, instructed in electrical matters, using replacement handles according to this fuse system		N/A
TESTS:			
8.2.2.1	IEC 60269-1 applies with the following supplementary requirements		
8.1.4	Arrangement of fuse and dimensions Part 2, Figure 101		P
	Requirements of 7.2 verified on fuse-bases		P
	Creepage distances and clearances of fuse-links according to 7.2 are verified Clearance: 28 mm Creepage distance: 27 mm		P
	Clearances verified on fuse-link inserted into model fuse-base according to Figure 111		N/A
8.1.6	Testing of fuse-holders		
	In addition to test given in IEC 60269-1 tested according to Table 109		P
8.2.2.1	Points of application of test voltage		
	In addition to IEC 60269-1 e) between isolated metal gripping-lugs and terminals of test fuse-bases		N/A
8.2.3.2	Value of test voltage		
	rated impulse withstand voltage in Table 110	8 kV	P
8.2.3.3	Test method		
	5 impulses of both polarities and of shape 1,2/50 µs and rated withstand voltage level according to Table 110	9,8 kV 5 times - period of 5 s	P
8.2.4	Acceptability of test results		
8.2.4.3	No flash-over or puncture shall occur during test		P
8.2.5	Resistance to tracking		
	insulating parts supporting live parts of fuse-links and fuse-bases tested according to IEC 60112 (test solution A)		N/A
8.3	Five specimens tested and passed at PTI 400		N/A
8.3.1	Verification of temperature rise and power dissipation		
	Arrangement of the fuse		
	Tightened by torque (Nm)	32 Nm	P
8.3.2	Measurement of the temperature rise		
	Protective covers and fuse-carriers as provided by manufacturer mounted		N/A

ВЯРНО С
ОРИГИНАЛА



Clause	Requirement + Test	Result - Remark	Verdict
IEC 60269-2			
8.3.4.1	Temperature rise of the fuse-holder Dummy (Figure 105) Point at which temperature rise is measured (Figure 106)	43 K 60W dummy link Point marked with 'E'	P
8.3.4.2	Power dissipation of a fuse-link (Figure 105)		N/A
8.4.3.1	Verification of conventional non-fusing and fusing current non-fusing current test - second test specimen are used for I)		P
8.4.3.5	Conventional cable overload protection test (for "gS" fuse-links only)		P
	Details of special test are given in Annex AA		N/A
Annex AA	Special test for cable overload protection		
	For fuses with $I_n > 16$ A of the sizes 000, 00, 0, 1 and 2		N/A
AA.1	Arrangement of the fuse		
	Three fuse-links in fuse-bases mounted in a box		N/A
	Ambient air temperature outside the fuse box shall be (30 ± 0.5) °C	°C	N/A
AA.2	Test method and acceptability of test results		
	1,13 I_n flowed through the fuse-links for conventional time (see Table 2 of IEC 60269-1)	A for s	N/A
	None of fuse-links operated		N/A
	Test current raised without interruption within 5 s to 1,45 I_n	A	NA
	One fuse-link operated within conventional time		NA
8.5.5.1	Verification of the peak withstand current of a fuse-base not be carried out, if this has already been verified during the breaking capacity test of fuse-links with the highest rating of the size		N/A
8.5.5.1.1	Arrangement of the fuse		
	single-phase type, 8.5.1 of IEC 60269-1		
	peak values of the test currents (Table 112)		
	maximum values (see 8.5.5.1.3)		
	dummy fuse-link (Figure 101)		
8.5.5.1.2	Test method		

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
	fuse-base 1 (Figure 107) resilient spring travel is limited to elastic range..... contacts opened up three times..... F _{max} according to Table 118		N/A
	fuse-base 2 (see 8.11.1.2) Acceptability of test results		N/A
8.5.5.1.3	Acceptability of test results fuse-links not be ejected no signs of arcing or welding or other damage		N/A
8.5.8	Acceptability of test results Fuse or circuit-breaker not operate during this test		N/A
8.7.4	Verification of overcurrent discrimination verified by I _t values evaluated from the recorded test results		N/A
	Arrangement of the samples as for the breaking capacity test		P
	two samples tested at the r.m.s. prospective current I _p corresponding to minimum pre-arcing I _p	3 kA (125A fuse-links) 20 kA (630A fuse-links)	P
	The values of I _p lie within corresponding limits specified in Table 113..... For 125A: Min pre-arcing > 36 kA's For 630A: Min pre-arcing > 1600 kA's	1) 45 kA's (125A fuse-links) 2) 40 kA's 1) 1640 kA's (630A fuse-links) 2) 1650 kA's	P
	the other samples tested at the r.m.s. prospective test current I _p corresponding to operating I _p	5,1 kA (125A fuse-links) 37 kA (630A fuse-links)	P
	test voltage (V).....	400 V	
	The test voltage for 690 V fuses is 1,05xUn/3		N/A
	The test voltage for all other fuses is 1,1xUn/3	400V (Measured values were calculated for 318V according to Annex B3)	P
	The values of I _p lie within corresponding limits specified in Table 113..... For 125A: Max operating < 104 kA's For 630A: Max operating < 5470 kA's	1) 94 kA's (125A fuse-links) 2) 82 kA's 1) 3149 kA's (630A fuse-links) 2) 3168 kA's	
8.9	Verification of resistance to heat Tests apply to fuse-link and fuse-base		
	Fuse-holder with fuse-links having maximum power dissipation are cyclically loaded as pre-treatment... After cooling to normal temperature breaking capacity tested at I _p (see 8.5).....	I _p = 100 kA	P




Clause	Requirement + Test	Result - Remark	Verdict
	Fuse-links with organic material Fuse-holder with fuse-links having maximum power dissipation are cyclically loaded as pre-treatment..... After cooling to normal temperature breaking capacity tested at I ₁ and I ₂ (see 8.5).....	I ₁ = I ₂ =	N/A
8.9.1	Fuse-base test below apply if it is not obvious that components are not affected adversely by given temperature and withdrawal forces		P
8.9.1.1	Test arrangement Figure 105 and 108 Test set-up in heating chamber	Figure 105	P
8.9.1.2	Test method Temperature of (80±5)°C for 2 h..... 160% rated current for 2 h..... Test voltage..... 3 min after switching off tensile force F _{max} (see Table 118) exerted for 15 s Acceptability of test results	80°C, 2 h 160% I _p = 1008 A, 2 h 10-12 V F _{max} = 400 N, 15 s	P
8.9.1.3	Contact pieces not have moved to affect the further use Dimensions of Figure 102 are considered insulating mounting part no broken and no show any signs of cracks		P
8.9.2	Fuse-links with gripping lugs of moulded material or of metal fixed in moulded material		N/A
8.9.2.1	Test arrangement Figure 108		N/A
8.9.2.2	Test method Temperature of (80±5)°C for 2 h..... 150% rated current for conventional time..... Test voltage..... 3 min after fuse-link operated or conventional time expired tensile force F _{max} (see Table 118) exerted for 15 s Acceptability of test results	A for h V F _{max} =	N/A
8.9.2.3	Gripping lugs remain fully operational Dimensions of Figure 101 (d and c ₂) not be exceeded by more than 2 mm		N/A

Handwritten signature

Clause	Requirement + Test	Result - Remark	Verdict
8.10	Verification of non-deterioration of contacts		
8.10.1	Arrangement of the fuse		P
	Figure 105	630A, dummy fuse-link	P
	for lug terminals, torque in Table 111	32 Nm	
	Insulation of conductors removed over the whole length	2 m	P
	All covers of contacts and terminals are removed		P
8.10.1.2	Direct terminal clamps		
	Test performed on 10 direct terminal clamps of five fuse-bases		N/A
	Distance between fuse-base centres of at least three times s_x (see Figure 101)		N/A
	Torque of tightened of screws	Nm	
	Conductor cross-section	mm ²	
8.10.2	Test method		
	Test current (A) for load period	1,25 x I _{nl} = 788 A	P
	Duration (s) of load period	0,25 x 240 = 60 min	P
	Duration (s) of no-load period	0,1 x 240 = 24 min	P
	Test voltage (V)	10-12 V	
	a) Test of 50 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	b) Test of 250 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	c) Test of 500 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
	d) Test of 750 cycles, measured values did not exceed the limits given in subsequent parts of IEC 60269	(see appended table)	P
8.10.2.1	Contacts		
	Points between voltage drop is measured (A and B in Figure 106)		P
	Withdrawal force (Table 118); measured force after 250 cycles (N)	1) 270 N 2) 310 N 3) 280 N	P
	Withdrawal force (Table 118); measured force after 750 cycles (N)	1) 2) 3)	N/A

ВЕРНО С
ОРИГИНАЛА




Clause	Requirement + Test	Result - Remark	Verdict
	If measured values too low, test of 8.5.5.1	Table 118 (210 N - 400 N)	P
8.10.2.2	Direct terminal clamps		N/A
	Points between voltage drop is measured (Figure 110)		N/A
	Test sequence for all types conductors (see Table 116)	(see appended table)	N/A
	Verification of temperature rise (see 8.3.4.1) (see figure 110)		N/A
8.10.3	Acceptability of test results		
8.10.3.1	Contacts		
	Limit value after 250 th cycle \leq 15%	See Table 1	P
	Limit value after 500 th cycle \leq 30%		N/A
	Limit value after 750 th cycle \leq 40%		N/A
	Difference between last and first measurement of temperature rise less than 20 K	3 K	P
8.10.3.2	Direct terminal clamps		
	Permissible tolerance for resistance R _{sp} for Al conductors : R _{sp} max. \leq 2 R _{sp} min.		N/A
	Permissible changes of the resistance from R _{sp} to R _{sp} : see Table 117		N/A
	Copper or cleaned aluminium conductors		N/A
	Uncleaned aluminium conductors		N/A
	Change after 50 th to 250 th cycle		N/A
	Change after 250 th to 500 th cycle		N/A
	Change after 500 th to 750 th cycle		N/A
	Change between 50 th to 750 th cycle		N/A
	Temperature rise at test spot F < 75K		N/A
8.11	Mechanical and miscellaneous tests		
8.11.1.1	Mechanical strength of fuse-holders		
	Test set-up subjected to temperature rise test at rated current	630A, dummy fuse-link 41K	P
	fuse-link or fuse-carrier are withdrawn and inserted into fuse-base 100 times	100 times	
	All parts are intact and function normally		P
	Test set-up subjected to further temperature rise test at rated current (values obtained are not more than 5 K or 15 % above the values from temperature-rise test prior)	44K Difference < 3K	P

[Handwritten signature]

Clause	Requirement + Test	Result - Remark	Verdict
8.11.1.2	Mechanical strength of the fuse-base Test-link inserted three times in the fuse-base (Dimensions of blade contacts see Figure 101) (Withdrawal force F liod within limits in Table 118)	Figure 101 1) 270 N 2) 280 N 3) 280 N	P
	Steel screws are fastened three times at the terminals, torque of 1,2 times value specified by manufacturer or value of Table 111	38,2 Nm	P
	Contact pieces not have moved to affect the further use		P
	Insulating mounting part no broken and no show any signs of cracks		P
8.11.1.8	Impact resistance of gripping-lugs of moulded material or of metal fixed in moulded material		
8.11.1.8.1	Test arrangement		N/A
8.11.1.8.2	Facility is given in Figure 109		N/A
	One fuse-link ... (150±5)°C for 168 h		
	Another one ... -15°C for 72 h		N/A
8.11.1.8.3	Acceptability of test results		N/A
	No damage capable of hindering their further use		N/A
	No bent out by more than 3 mm		N/A
	Coupling with a handle (Figure 103) not are hindered		N/A
8.11.2.3	Verification of resistance to rusting		
8.11.2.3.1	According to ISO 6988 cyclic moist atmosphere containing 0,2% SO2 (SFW 0,2 S) for 1 cycle		P
8.11.2.3.2	Optional test (severe environmental conditions)		N/A
	Fuse-links and fuse-bases for used in environment of pollution degree 3 tested with SFW 2,0 S for 5 cycles		N/A
	They marked accordingly		P
8.11.2.4	Non-deterioration of insulating parts of fuse-link and fuse-base		
8.11.2.4.1	Test method		
	Period 168 h	168 h	P
	for equipment comprising moulded elements to support live parts (150±5)°C	150 °C	P
	for covers (100±5)°C		N/A

Report No:0315.15-1



ВРНО С
СРНИМАЈА

302

Clause	Requirement + Test	Result - Remark	Verdict
	Period greater than 1 h	3 h	P
	for sealing compounds: stability of marking (150±5)°C	150°C	P
	After cooling to ambient temperature the following are tested.		P
	Fuse-links: breaking capacity with I ₁ and I ₂		P
	Fuse-base: mechanical strength in accordance with 8.11.1.2		P
8.11.1.2	Mechanical strength of the fuse-base		
	Test-link inserted three times in the fuse-base (Dimensions of blade contacts see Figure 101) (Withdrawal force F liod within limits in Table 118)	Figure 101 1) 280 N 2) 290 N 3) 300 N	P
	Steel screws are fastened three times at the terminals, torque of 1,2 times value specified by manufacturer or value of Table 111	38,2 Nm	P
	Contact pieces not have moved to affect the further use		P
	Insulating mounting part no broken and no show any signs of cracks		P
8.11.2.4.2	Acceptability of test results		
	Not have changed of positions of fuse-base contacts to correct functioning		P
	No fracture nor any signs of fracture on insulating body with terminals		P
	Mechanical strength of cemented joints not impaired		P
	Sealing compounds not shifted to extent permitting live parts to be exposed		P
	Fuse-links operate correctly		P
	Marking are durable and easily legible		P

APPENDIX 1

Report No:0315.15-1

Handwritten signature


Clause	Requirement + Test	Result - Remark	Verdict
8.10.2	TABLE 1: Direct terminal clamps ambient air temperature (°C) : 20°C - 22°C		
	Sample No. (contacts)		
		1 2 3 4 5 6 7 8 9 10	
T 1 (K)	42K 41K 42K		
ΔU initial	1.35 Vdc 1.30 Vdc		
Rd 0	27.0 mΩ 26.0 mΩ		
ΔU 50	1.38 Vdc 1.35 Vdc		
Rel 50	27.8 mΩ 27.0 mΩ		
ΔU 250	1.38 Vdc 1.36 Vdc		
Rel 250	27.8 mΩ 27.2 mΩ		
T 2 (K)	43K 44K		
ΔU 500			
Rel 500			
ΔU 750			
Rel 750			
T 3 (K)			

T 1: initial temperature rise / T 2: temperature rise after 250 cycles / T 3: final temperature rise

List of test equipment used:

Test Equipment	Equipment Name - No	Manufacturer - Type	Features	Traceability
Test transformer (TT01)	Best	440 V 65 kA, 660 V 5 kA		
Resistive load (RY01-03)	Hilker	38 ohm, 1300 A / sn		
Inductive load (EY01-12)	BEST	128 ohm		
Resistive and inductive load (AY01)	FEDERAL	2.5 ohm, 6 mH		
Resistive and inductive load (AY03)	IHP	60 mhm, 380 μH		
Current measuring system (AO01-03)	DIMES L 500 TC	143.28 kA / 2.8763 V		IHP 1014.01
Voltage measuring system (GO01-03)	DIMES L 500 TV	± 102k V		IHP 1014.02
Regowatt coil (RG05-07)	HEBENLUS 150 K	150 kA / 2 Volt		IHP 1114.03
Filko current coil (FL01-03)	Filko 2000 flex	200 A / 2000 A		IHP 0814.02
Voltmeter (V01-03)	Federal FV1-72	0-500 V		IHP 1014.03
Making breaker (KK01-03)	Preussag NVI 32DA	12 kV, 1250 A Ipn=80 kA		
Making breaker (KK04)	Federal F112E	2500 A, 400 V		
Making breaker (KK05)	Federal F121E	2000 A, 400 V		
Current supply (TT04)	Mitsan	300 A		
Current supply (TT05)	Mitsan	5000 A		
Current supply (TT07)	Ahal	2000 A, 5 V		
Current-voltage supply (AGK 01)	Ahal	220 Vdc, 500 Vdc, 10 A		
Current-voltage supply (AGK 02)	GW Instek	30 Vdc, 3 A		
Transformer-ammeter (A-A01-03)	Federal FAT100-FYA86	3000 / 5 A		IHP 0814.05
Clamp meter (P03)	CIE	1000 A RMS		IHP 1014.07
Isolation test equipment (IT04)	GW Instek GPI 825	5 kV AC, 1000 VDC Megger		IHP 1014.04
Oscilloscope (O02)	Tedronik TDS 460 A	400 MHz, 4 canal		IHP 0713.02
Dynamometer (K001)	Lutron FG 5100	100 Kg		IHP 0114.02
Thermometer (S001)	CIE 308	200 °C		IHP 1114.02
Temperature measuring eq. (SQ04)	Agilent 34970A	60 canal, T type termokapi		UNIS S5315
Multimetre (M01)	HP 3444001A	1000 V, 3 A		IHP 0914.01
Multimetre (M02)	Filko 87	10 A, 1000 V		IHP 0914.02
Caliper (KL03)	Mitutoyo	0.01 mm		IHP 0315.01
Torquemeter (TO 01)	Torquebaader	6-80 Nm		IHP 0215.01
Torquemeter (TO 03)	Treite AT 1502 LDIN	0-18 Nm		IHP 0215.02
Impulse test device (PT01)	HILLO PG1012C	0-10 kV, 1,250 ms		IHP 0312.03
Climatic chamber (IC01)	Angemal CH 600 C	-40+180 °C, 10-98 %RH		
Calibrator (K01)	Wavetek	1950 V, 20A		046690 FLUKE
Red-hot wire test device (KT01)	Federal	800 °C		
Temperature cabinet (SK01)	Federal	60 °C, 170x225x220 cm		
High Voltage Probe (Y001)	Tedronik P8018A	40 kV, x 1000 prob		IHP 0313.23

СЕРТИФИКАТ
ОПРАВИЛНИЦА




Handwritten signature

Handwritten mark


Handwritten mark

Page 47 of 47



Large handwritten signature

**ВЯРНО С
ОРИГИНАЛА**



304

Приложение 3 към Техническо предложение

За Обособена позиция 2

СРОКОВЕ ЗА ДОСТАВКА

№	Наименование	Мярка	Количество със срок на доставка до 7 кал. дни	Количество със срок на доставка до 30 кал. дни
1	2	3	4	5
1	КРШ НН-4, нисък, полиестерен	бр.	5	10
2	КРШ НН-5, нисък, полиестерен	бр.	5	10
3	КРШ НН-6, нисък, полиестерен	бр.	10	20
4	КРШ НН-7, нисък, полиестерен	бр.	2	5
5	КРШ НН-4PL, нисък, полиестерен	бр.	1	3
6	КРШ НН-5PL, нисък, полиестерен	бр.	1	3
7	КРШ НН-6PL, нисък, полиестерен	бр.	1	3
8	КРШ НН-7PL, нисък, полиестерен	бр.	1	3

Забелѝжки:

- 1/ Срокът на доставките започва да тече от датата на изпращане на поръчката.
- 2/ Количествата в колона 4, със срок на доставка до 7 /седем/ календарни дни, се доставят след SAP поръчка до посочените в обявлението складове на Възложителя за покриване на спешни нужди на Възложителя. Възложителят може да поръчва посоченото спешно количество веднъж месечно.
- 3/ В случай, че крайният срок на доставката съвпада с празничен или неработен ден, то доставката се извършва не по-късно от първия работен ден след изтичането на срока.
- 4/ При поръчки на Възложителя на количества в рамките на потвърдените от Изпълнителя и недоставени в посочените срокове, ще бъдат налагани неустойки, съгласно условията на договора.
- 5/ Възложителят може да поръчва количества по-малки от посочените в колони 4 и 5.
- 6/ Възложителят може да поръчва количества по-високи от посочените в колони 4 и 5, като това обстоятелство ще бъде посочено текстово в съответната поръчка изпратена към Изпълнителя. С потвърждението на поръчката, Изпълнителят вписва в същата очаквана дата за доставка на количествата надвишаващи посочените в колони 4 и 5.
- 7/ Количествата за доставка в колони 4 и 5 са отделни и независими едно от друго.
- 8/ Количествата за доставка в колона 5 не включват в себе си количествата за доставка в колона 4.
- 9/ Възложителят има право да направи едновременно поръчки за доставка на количества от колони 4 и 5.

Дата 13.03.2018 г.

ПОДПИС И ПЕЧАТ:

на основание чл. 2 от ЗЗЛД

Алексей Родин
Управител

(длъжност на представляващия участника)

ДЕКЛАРАЦИЯ

за приемане на условията в проекта на рамково споразумение и проекта на конкретен договор,
неразделна част от рамковото споразумение

Долуподписаният/-ната/ Алексей Николаевич Родин, в качеството ми на

представляващ „ЕМИ ЕЛЕКТРИК“ ЕООД, участник в процедура за възлагане на обществена поръчка с реф. № РPD 17-152 и предмет: " Доставка на кабелни разпределителни шкафове", обособена/и позиция/и №2

ДЕКЛАРИРАМ, ЧЕ:

1. Приемам условията в проекта на рамково споразумение, приложен в документацията за участие.
2. Приемам условията в проекта на конкретен договор, неразделна част от рамковото споразумение, приложен в документацията за участие.

Дата 13.03.2018 г.

ПОДПИС и ПЕЧАТ:

на основание чл. 2 от ЗЗЛД

(име и фамилия)
Алексей Родин

Забележка:

Декларацията се подписва от законния представител на участника или от надлежно упълномощено лице, което подава офертата.

Когато участник подава оферта за повече от една обособена позиция, може да бъде изготвена, подписана и подадена само една декларация (според настоящия образец), но на съответното място в декларацията задължително се отбелязват номерата на всички обособени позиции, за които участникът участва. Възможно е по преценка на участника, когато същият участва за повече от една обособена позиция, да изготви и подпише отделни декларации (съобразно настоящия образец) за всяка отделна обособена позиция, за която участва.

ДЕКЛАРАЦИЯ
за срока на валидност на офертата

Долуподписаният/ -ата Алексей Николаевич Родин,
(собствено, бащино, фамилно име)

на основание чл. 2 от ЗЗЛД

в качеството ми на Управител
(посочва се длъжността)

на „ЕМИ ЕЛЕКТРИК“ ЕООД,
(посочете наименованието на участника)

участник в процедура за възлагане на обществена поръчка с реф. № РРД 17-152 и предмет: „Доставка на кабелни разпределителни шкафове“, обособена/и позиция/и №2
(наименование на поръчката)

ДЕКЛАРИРАМ, ЧЕ:

С подаване на настоящата оферта, направените от нас предложения и поети ангажименти за обособена/и позиция/и №2, са валидни за срока, посочен в обявлението, считано от крайния срок за подаване на офертите.

Дата 13.03.2018 г.

ПОДПИС И ПЕЧАТ:

на основание чл. 2 от ЗЗЛД

(име и фамилно)
Алексей Родин

Забележка:

Декларацията се подписва от законния представител на участника или от надлежно упълномощено лице, което подава офертата.

Когато участник подава оферта за повече от една обособена позиция, може да бъде изготвена, подписана и подадена само една декларация (според настоящия образец), но на съответното място в декларацията задължително се отбелязват номерата на всички обособени позиции, за които участникът участва. Възможно е по преценка на участника, когато същият участва за повече от една обособена позиция, да изготви и подпише отделни декларации (съобразно настоящия образец) за всяка отделна обособена позиция, за която участва.